

WI DNR Public Record Provision of the Energy Policy Act of 2005

Summary Information for Releases

Number of Confirmed UST Releases: 97

Release Reporting Period Dates: 10/01/2023 to 09/30/2024

Summary Information for Release Sources and Causes

| Source | Totals | | Cause | | | | | | | | | | | | | |
|---------------------|-----------|-------------|-----------|------------|-----------|------------|-----------------|------------|-----------|------------|----------|-----------|-----------|------------|-----------|------------|
| | # | % | Spill | | Overfill | | Phy/Mech Damage | | Corrosion | | Install | | Other | | Unknown | |
| | | | # | % | # | % | # | % | # | % | # | % | # | % | # | % |
| Tank | 35 | 36% | 0 | 0% | 2 | 5.7% | 5 | 14.3% | 8 | 22.9% | 0 | 0.0% | 2 | 5.7% | 18 | 51.4% |
| Piping | 11 | 11% | 0 | 0% | 0 | 0.0% | 2 | 18.2% | 1 | 9.1% | 0 | 0.0% | 3 | 27.3% | 5 | 45.5% |
| Dispenser | 39 | 40% | 6 | 15% | 18 | 46.2% | 2 | 5.1% | 1 | 2.6% | 0 | 0.0% | 4 | 10.3% | 8 | 20.5% |
| Submersible Turbine | 0 | 0% | 0 | 0% | 0 | 0.0% | 0 | 0.0% | 0 | 0.0% | 0 | 0.0% | 0 | 0.0% | 0 | 0.0% |
| Delivery Problem | 5 | 5% | 2 | 40% | 2 | 40.0% | 1 | 20.0% | 0 | 0.0% | 0 | 0.0% | 0 | 0.0% | 0 | 0.0% |
| Other | 7 | 7% | 2 | 29% | 1 | 14.3% | 0 | 0.0% | 1 | 14.3% | 0 | 0.0% | 1 | 14.3% | 2 | 28.6% |
| Totals | 97 | 100% | 10 | 10% | 23 | 24% | 10 | 10% | 11 | 11% | 0 | 0% | 10 | 10% | 33 | 34% |

#=Count, %=Percent of Total Count

Determined Using the Activity Notification Date

Note: Release, source and cause information is based on information from the Bureau for Remediation and Redevelopment Tracking System (BRRTS) database. Source and cause data were collected using information reported to the Department of Natural Resources (DNR) from various sources, both internal and external to DNR. There may be omissions and errors in the data and delays in updating new information.

Site-specific information on compliance and releases may be obtained by searching BRRTS on the Web (BOTW) at <https://apps.dnr.wi.gov/botw>.