

2005 Energy Act Public Reporting

Reporting Period: October 1st to September 30th  
 Reported: September 30, 2012

Source	Number	Percent
Tanks	96	75.0
Piping	15	11.7
Dispensers	6	4.7
Submersible Pumps	0	0.0
Delivery Problems	2	1.6
Other	9	7.0
	128	100.0

Cause	Tanks	
	Number	Percent
Spill	0	0.0
Overfill	5	5.2
Physical / Mechanical Damage	5	5.2
Corrosion	32	33.3
Installation Problems	0	0.0
Other	4	4.2
Unknown	50	52.1
	96	100.0

Cause	Piping	
	Number	Percent
Spill	0	0.0
Overfill	0	0.0
Physical / Mechanical Damage	3	20.0
Corrosion	3	20.0
Installation Problems	1	6.7
Other	0	0.0
Unknown	8	53.3
	15	100.0

Cause	Dispensers	
	Number	Percent
Spill	0	0.0
Overfill	2	33.3
Physical / Mechanical Damage	1	16.7
Corrosion	0	0.0
Installation Problems	0	0.0
Other	0	0.0
Unknown	3	50.0
	6	100.0

Cause	Submersible Pumps	
	Number	Percent
Spill	0	0.0
Overfill	0	0.0
Physical / Mechanical Damage	0	0.0
Corrosion	0	0.0
Installation Problems	0	0.0
Other	0	0.0
Unknown	0	0.0
	0	0.0

Cause	Delivery Problems	
	Number	Percent
Spill	0	0.0
Overfill	1	50.0
Physical / Mechanical Damage	1	50.0
Corrosion	0	0.0
Installation Problems	0	0.0
Other	0	0.0
Unknown	0	0.0
	2	100.0

Cause	Other	
	Number	Percent
Spill	0	0.0
Overfill	4	44.4
Physical / Mechanical Damage	0	0.0
Corrosion	0	0.0
Installation Problems	0	0.0
Other	0	0.0
Unknown	5	55.6
	9	100.0