

# FEDERAL ENERGY ACT REPORT

September-2014

Reporting Period: October 1, 2013 to September 30, 2014

Sources and Causes of Environmental Discharges from Underground Petroleum Storage Tanks in Wisconsin

Source	Number	Percent
Tanks	58	48.3%
Piping	16	13.3%
Dispensers	27	22.5%
Submersible Pumps	1	0.8%
Delivery Problems	11	9.2%
Other	7	5.8%
	<b>120</b>	<b>100.0%</b>

	TANKS	
CAUSE	Number	Percent
Spill	0	0.0%
Overfill	1	1.7%
Physical /Mechanical Damage	3	5.2%
Corrosion	26	44.8%
Installation Problems	0	0.0%
Other	3	5.2%
Unknown	25	43.1%
	<b>58</b>	<b>100%</b>

	PIPING	
Number	Percent	
0	0.0%	
0	0.0%	
5	31.3%	
4	25.0%	
0	0.0%	
0	0.0%	
7	43.8%	
<b>16</b>	<b>100%</b>	

	DISPENSERS	
Number	Percent	
3	11.1%	
13	48.1%	
6	22.2%	
0	0.0%	
0	0.0%	
2	7.4%	
3	11.1%	
<b>27</b>	<b>100%</b>	

	SUBMERSIBLE PUMPS	
CAUSE	Number	Percent
Spill	0	0.0%
Overfill	0	0.0%
Physical /Mechanical Damage	1	100.0%
Corrosion	0	0.0%
Installation Problems	0	0.0%
Other	0	0.0%
Unknown	0	0.0%
	<b>1</b>	<b>100%</b>

	DELIVERY PROBLEMS	
Number	Percent	
0	0.0%	
6	54.5%	
4	36.4%	
0	0.0%	
0	0.0%	
1	9.1%	
0	0.0%	
<b>11</b>	<b>100%</b>	

	OTHER	
Number	Percent	
1	14.3%	
0	0.0%	
0	0.0%	
1	14.3%	
0	0.0%	
0	0.0%	
5	71.4%	
<b>7</b>	<b>100%</b>	