

Leachate Management Strategies: Marathon County, WI



Leading with Science®

Introduction



- 6+ Years Solid Waste Experience
- Landfill Permitting, and Construction, Env. Compliance, LFG Design/O&M, and Leachate Management
- Presenter at WIRMC 2025 (PFAS focus)



Jalen Thomas


jalen.thomas@tetrattech.com

(608) 630-4850

Presentation Outline

Part 1 – Regulatory Overview

Part 2 – Marathon County: Leachate and Regionalization



Federal Actions

- ✓ **Hazardous Substance Designation under CERCLA (April 2024)**
- ✓ **Drinking Water Standards (April 2024)**
- Effluent Limitations Guidelines (ELG) (Withdrawn January 2025; Ongoing)**
 - USEPA rulemaking intent: Effluent Limitations Guidelines (ELG a/k/a “Plan 15”)
 - Landfill Study - approx. 3-5 years
 - Rule Promulgation - approx. 1-2 years
 - Implementation Schedule - approx. 3 years
 - Systems operational - approx. 7-10 years (est. 2030-2033)

Biosolids

- ✓
 - Draft Risk Assessment (January 2025)
 - National Sewage Sludge Survey (ongoing)
- **Interim PFAS Destruction and Disposal Guidance**
 - Underground injection (UIC)
 - Landfill
 - Thermal treatment - including incineration

Current USEPA Guidance Policy

- Leverage NPDES permitting (USEPA, 2018)
 - Delegate responsibility to States and Territories
 - Facility monitoring
 - Source reduction
 - Require permittees to
 - Eliminate or use substitutes where “*reasonable alternatives exist*”
 - Require BMPs w/r/t firefighting foams
 - Enhanced public notification and engagement
 - **Protect WWTP discharges & Biosolid applications**
 - **Pre-treatment Programs**
 - Source Control
 - Best Management Practices
- Not an option for SW Industry

Wisconsin Approach

- Derive discharge requirements from Drinking Water standards
- Specify limits based on receiving water classification
 - Wisconsin - Chapters NR 102, 105, 106, 219, and other related regulations
 - Michigan - Rule #57
- Discharge reductions to WWTP
- Source Reduction



Where are we heading?

EPA National Primary Drinking Water Standards		
PFAS	Maximum Contaminant Level Goal	Maximum Contaminant Level
PFOA	0	4.0 ppt
PFOS	0	4.0 ppt
PFNA	10 ppt	10 ppt
PFHxS	10 ppt	10 ppt
GenX	10 ppt	10 ppt
Mixture of 2 or more	PFNA	1 (unitless) Hazard Index
	PFHxS	
	GenX	
	PFBS	

$$Hazard\ Index = \frac{[GenX]}{10} + \frac{[PFBS]}{2,000} + \frac{[PFNA]}{10} + \frac{[PFHxS]}{9}$$

Hazard Index for Typical Leachate >>> 1

How are MSW Landfills affected?

INDIRECT DISCHARGE (to WWTP)

- Industrial Pretreatment Program
- Local Limits Analysis
- Discharge criteria subject to WWTP headworks mass loading

DIRECT DISCHARGE (to SW or GW)

- NPDES permit
- Water Quality Values applicable to receiving waters
- State and local rulemaking

EFFLUENT LIMITATIONS

Regulated parameter	Maximum daily ¹	Maximum monthly avg. ¹
BOD	140	37
TSS	88	27
Ammonia (as N)	10	4.9
α -Terpineol	0.033	0.016
Benzoic acid	0.12	0.071
<i>p</i> -Cresol	0.025	0.014
Phenol	0.026	0.015
Zinc	0.20	0.11
pH	(²)	(²)

¹ Milligrams per liter (mg/L, ppm)

² Within the range 6 to 9.

Source: 40 CFR P445.20, RCRA Subtitle D Non-Hazardous Landfills

Presentation Outline

~~Part 1 – Regulatory Overview~~

Part 2 – Marathon County: Leachate and Regionalization



Background



- 120+ acres permitted, 85+ Constructed, 65+ acres closed, Multiple Landfills
- ~31,000 gpd total leachate generation (2024)
- Currently haul and discharge to POTW (under IPP)
- Need for on-site treatment
 - Impending PFAS requirements
 - No existing pre-treatment
 - Dwindling disposal options

Considerations

- Considered Technologies:
 - GAC with IX → POTW
 - GAC with FF → POTW
 - RO → Direct Discharge
- Advantages:
 - Re-use of existing infrastructure
 - Building with dual containment
 - Storage tanks
 - No off-site surface water discharge
- Disadvantages:
 - Separate leachate conveyance systems at each landfills
 - Remote location



Cost Considerations: Capital Costs



Site Improvements

Forcemain Systems,
Utilities, Basins,
Storage/EQ tank,
Buildings



Supporting Equipment

Pre- and Post-Treatment
Equipment, Tanks, Pumps,
Instrumentation, Controls



Engineering

Design, Permitting,
Construction
Management, Oversight
and Documentation



Treatment Equipment

GAC/IX
GAC/FF
RO



Construction & Operation

Delivery, installation,
testing, startup

Cost Considerations: Operations and Maintenance



Staffing

- Part time
- Full time



Compliance and Process Sampling and Analytics



Electrical Demand



Cleaning, Maintenance, Repairs, & Disposal

- Equipment
- Media



Processing Chemicals and Materials



Residuals Management

- Waste materials
- Sewer Service Fees

Case Study – Cost Comparison

Cost	GAC/IX (POTW)	GAC/FF (POTW)	RO (Direct Discharge & Recirculation)
Capital Cost (Annual Debt Service)	\$550,000	\$693,000	\$1,058,560
Operating Cost (Annual)	\$3,235,000	\$3,000,000	\$1,045,000 <small>JTO</small>
Total	\$3,785,000	\$3,693,000	\$2,103,560
Cost per Gallon	\$0.138	\$0.135	\$0.077

Assumptions:

Period = 20 years


Interest Rate = 5.5%

Average Utilization = 75% (i.e., 75,000 gallons per day)



JTO Percentages of cost instead of numbers
Thomas, Jalen, 2025-04-16T17:27:18.581

Conceptual Regional Leachate Management Solution



Parameter	Units	WPDES*	POTW
PFOS	ng/l	8	TBD
PFOA	ng/l	20 or 95	TBD

* WY-23-19

JTO Augment for other landfill leachate to marathon
Thomas, Jalen, 2025-04-16T17:16:21.653

Thank you!

