



# WPDES PERMIT

*STATE OF WISCONSIN*  
*DEPARTMENT OF NATURAL RESOURCES*  
**PERMIT TO DISCHARGE UNDER THE WISCONSIN POLLUTANT DISCHARGE  
ELIMINATION SYSTEM**

**Northern States Power, Wisconsin, d/b/a Xcel**

is permitted, under the authority of Chapter 283, Wisconsin Statutes, to discharge from a facility  
located at  
122 North 14TH Avenue West  
to

**CHEQUAMEGON BAY OF LAKE SUPERIOR WITHIN THE FISH CREEK WATERSHED IN THE LAKE  
SUPERIOR DRAINAGE BASIN IN ASHLAND COUNTY**

in accordance with the effluent limitations, monitoring requirements and other conditions set  
forth in this permit.

The permittee shall not discharge after the date of expiration. If the permittee wishes to continue to discharge after this expiration date an application shall be filed for reissuance of this permit, according to Chapter NR 200, Wis. Adm. Code, at least 180 days prior to the expiration date given below.

State of Wisconsin Department of Natural Resources  
For the Secretary

By

\_\_\_\_\_  
Jason Knutson  
Wastewater Section Chief

\_\_\_\_\_  
Date Permit Signed/Issued

**PERMIT TERM: EFFECTIVE DATE - April 01, 2025**

**EXPIRATION DATE - March 31, 2030**

## TABLE OF CONTENTS

<b>1 INFLUENT REQUIREMENTS - COOLING WATER INTAKE STRUCTURE (CWIS)</b>	<b>1</b>
1.1 SAMPLING POINT(S)	1
1.2 MONITORING REQUIREMENTS AND BTA DETERMINATIONS	1
1.2.1 <i>Sampling Point 702 – UNIT 5 INFLUENT; 703- UNIT 6 INFLUENT</i>	1
1.2.2 <i>Sampling Point 704 - INTAKE AT CHANNEL</i>	1
1.3 COOLING WATER INTAKE STRUCTURE STANDARD REQUIREMENTS	2
1.3.1 <i>Future BTA for Cooling Water Intake Structure</i>	2
1.3.2 <i>Impingement Mortality Monitoring</i>	2
1.3.3 <i>Visual or Remote Inspections</i>	2
1.3.4 <i>Reporting Requirements for Cooling Water Intake</i>	3
1.3.5 <i>Intake Screen Discharges and Removed Substances</i>	3
1.3.6 <i>Endangered Species Act</i>	3
<b>2 IN-PLANT REQUIREMENTS</b>	<b>4</b>
2.1 SAMPLING POINT(S)	4
2.2 MONITORING REQUIREMENTS AND LIMITATIONS	4
2.2.1 <i>Sampling Point 101 - BOILER DRAWDN PRIOR TO MIXING</i>	4
2.2.2 <i>Sampling Point 102 - PROCESS EFFLUENT FIELD BLANK</i>	5
2.2.3 <i>Sampling Point 103 - COLLECTION TANK BEFORE MIXING</i>	5
<b>3 SURFACE WATER REQUIREMENTS</b>	<b>6</b>
3.1 SAMPLING POINT(S)	6
3.2 MONITORING REQUIREMENTS AND EFFLUENT LIMITATIONS	6
3.2.1 <i>Sampling Point (Outfall) 001 - CONDENSER COOLING WATER</i>	6
3.2.2 <i>Sampling Point (Outfall) 002 - CONDENSER COOLING WATER</i>	10
3.2.3 <i>Sampling Point (Outfall) 004 - BYPASS PROCESS WATER</i>	11
3.2.4 <i>Sampling Point (Outfall) 007 - NONCONTACT SERVICE WATER; 013- NONCONTACT SERVICE WATER</i>	12
3.2.5 <i>Sampling Point (Outfall) 015 - COMBINED 103 &amp; 004</i>	13
3.2.6 <i>Sampling Point (Outfall) 016 - INTAKE SCREEN WASH WATER; 017- DE-ICING RECIRCULATION WATER; 018- DE-ICING RECIRCULATION WATER</i>	13
<b>4 SCHEDULES</b>	<b>14</b>
4.1 ANNUAL CERTIFICATION STATEMENT AND REPORT FOR INTAKE STRUCTURE	14
4.2 IMPINGEMENT MORTALITY BTA SCHEDULE	14
4.3 PFOS/PFOA MINIMIZATION PLAN DETERMINATION OF NEED	14
4.4 CONTINUOUS PH MONITORING	15
<b>5 STANDARD REQUIREMENTS</b>	<b>16</b>
5.1 REPORTING AND MONITORING REQUIREMENTS	16
5.1.1 <i>Monitoring Results</i>	16
5.1.2 <i>Sampling and Testing Procedures</i>	16
5.1.3 <i>Recording of Results</i>	16
5.1.4 <i>Reporting of Monitoring Results</i>	17
5.1.5 <i>Records Retention</i>	17
5.1.6 <i>Other Information</i>	17
5.1.7 <i>Reporting Requirements – Alterations or Additions</i>	17
5.2 SYSTEM OPERATING REQUIREMENTS	17
5.2.1 <i>Noncompliance Reporting</i>	18
5.2.2 <i>Bypass</i>	18
5.2.3 <i>Scheduled Bypass</i>	18
5.2.4 <i>Controlled Diversions</i>	19
5.2.5 <i>Proper Operation and Maintenance</i>	19
5.2.6 <i>Operator Certification</i>	19

<i>5.2.7 Spill Reporting</i>	19
<i>5.2.8 Planned Changes</i>	19
<i>5.2.9 Duty to Halt or Reduce Activity</i>	20
<b>5.3 SURFACE WATER REQUIREMENTS</b>	20
<i>5.3.1 Permittee-Determined Limit of Quantitation Incorporated into this Permit</i>	20
<i>5.3.2 Appropriate Formulas for Effluent Calculations</i>	20
<i>5.3.3 Effluent Temperature Requirements</i>	20
<i>5.3.4 Energy Emergency Events</i>	21
<i>5.3.5 Visible Foam or Floating Solids</i>	21
<i>5.3.6 Surface Water Uses and Criteria</i>	21
<i>5.3.7 Total Residual Chlorine Requirements</i>	21
<i>5.3.8 Additives</i>	22
<i>5.3.9 Whole Effluent Toxicity (WET) Monitoring Requirements</i>	22
<i>5.3.10 Whole Effluent Toxicity (WET) Identification and Reduction</i>	23
<i>5.3.11 PFOS and PFOA Requirements</i>	23
<b>6 SUMMARY OF REPORTS DUE</b>	<b>24</b>

# 1 Influent Requirements - Cooling Water Intake Structure (CWIS)

## 1.1 Sampling Point(s)

Sampling Point Designation	
Sampling Point Number	Sampling Point Location, Waste Type/Sample Contents and Treatment Description (as applicable)
702	Representative samples shall be collected from the intake service water from Unit 5 intakes for Outfall 001.
703	Representative samples shall be collected from the intake service water from Unit 6 intake for Outfall 002.
704	Trash racks and traveling screens located at end of the 605 foot long channel.

## 1.2 Monitoring Requirements and BTA Determinations

The permittee shall comply with the following monitoring requirements.

The intake(s) has been reviewed for compliance with BTA (Best Technology Available) standards and the BTA determination(s) is listed below.

### 1.2.1 Sampling Point 702 – UNIT 5 INFLUENT; 703- UNIT 6 INFLUENT

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Temperature Maximum		deg F	Daily	Continuous	
Phosphorus, Total		mg/L	Monthly	Grab	

#### 1.2.1.1 Intake Screen Discharges

Floating debris and accumulated trash shall be removed from the condenser water intake screen backwash discharge and shall be stored and disposed of in a manner to prevent any pollutant from the materials from entering the waters of the State pursuant to s. NR 205.07(03), Wis. Adm. Code.

### 1.2.2 Sampling Point 704 - INTAKE AT CHANNEL

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Daily	Calculated	
Intake Water Used Exclusively For Cooling		Percent	Daily	Calculated	

### 1.2.2.1 Intake Screen Discharges

Floating debris and accumulated trash shall be removed from the condenser water intake screen backwash discharge and shall be stored and disposed of in a manner to prevent any pollutant from the materials from entering the waters of the State pursuant to s. NR 205.07(03), Wis. Adm. Code.

### 1.2.2.2 CWIS - Authority to Operate and Description

The permittee shall at all times properly operate and maintain all water intake facilities. The permittee shall give advance notice to the Department of any planned changes in the location, design, operation, or capacity of the intake structure. The permittee is authorized to use the cooling water intake system which consists of the following:

- Location: 46°35'18"N, 90°54'10"W
- Major Components: Trash racks, three intake bays, two vertical traveling screens, a large common plenum, and three small pumphouses, each with two circulating water pumps.
- Maximum Design Intake Flow (DIF): 68.5 MGD
- Maximum Design Intake Velocity: 1.2 feet/second (calculated at the traveling screens)

### 1.2.2.3 Cooling Water Intake BTA (Best Technology Available) Determination

The Department has determined that the cooling water intake, as described above in subsection 1.2.1.1, does not represent BTA for minimizing impingement mortality, but represents BTA for minimizing entrainment in accordance with the requirements in section s. 283.31(6), Wis. Stats. and ch. NR 111, Wis. Adm. Code. The permittee shall complete the actions specified in the Schedules section of this permit to bring the intake into conformance with BTA requirements.

## 1.3 Cooling Water Intake Structure Standard Requirements

The following requirements and provisions apply to all water intake structures identified as sampling points in subsection 1.1.

### 1.3.1 Future BTA for Cooling Water Intake Structure

BTA determinations for entrainment and impingement mortality at cooling water intake structures will be made in each permit reissuance, in accordance with ch. NR 111, Wis. Adm. Code. **In subsequent permit reissuance applications, the permittee shall provide all the information required in s. NR 111.40, Wis. Adm. Code.**

**Note: Based on flow conditions at the time of this permit reissuance, this includes ss. NR 111.41(1) through (7) and (13), Wis. Adm. Code.**

Exemptions from some permit application requirements are possible in accordance with s. NR 111.42(1), Wis. Adm. Code, where information already submitted is sufficient. If an exemption is desired, a request for reduced application material requirements must be submitted at least 2 years and 6 months prior to permit expiration. Past submittals and previously conducted studies may satisfy some or all of the application material requirements.

### 1.3.2 Impingement Mortality Monitoring

Impingement mortality monitoring is required on a daily basis during April 2027 and April 2028. This entails quantification and identification of all life stages of fish and shellfish, to the lowest taxon possible, that are impinged against the traveling screen.

### 1.3.3 Visual or Remote Inspections

The permittee shall conduct a weekly visual inspection or employ a remote monitoring device during periods when the cooling water intake is in operation. The inspection frequency shall be weekly to ensure the intakes are maintained and operated to function as designed.

### **1.3.4 Reporting Requirements for Cooling Water Intake**

The permittee shall adhere to the reporting requirements listed below.

#### **1.3.4.1 Discharge Monitoring Reports (DMRs)**

Report the results of the compliance monitoring for impingement mortality on the monthly DMR in the General Remarks section.

#### **1.3.4.2 Annual Certification Statement and Report**

Submit an annual certification statement signed by the authorized representative with information on the following, no later than January 31<sup>st</sup> for the previous year:

- Certification that water intake structure technologies are being maintained and operated as set forth in this permit, or a justification to allow a modification of the practices. Include a summary of the required Visual or Remote Inspections.
- If there are substantial modifications to the operation of any unit that impacts the cooling water withdrawals or operation of the water intake structure, provide a summary of those changes.
- If the information contained in the previous year's annual certification is still applicable, the certification may simply state as such.
- Monitoring results for impingement mortality.

### **1.3.5 Intake Screen Discharges and Removed Substances**

Floating debris and accumulated trash collected on the cooling water intake trash rack shall be removed and disposed of in a manner to prevent any pollutant from the material from entering the waters of the State pursuant to s. NR 205.07 (3) (a), Wis. Adm. Code, except that backwashes may contain fine materials that originated from the intake water source such as sand, silt, small vegetation or aquatic life.

### **1.3.6 Endangered Species Act**

Nothing in this permit authorizes take for the purpose of a facility's compliance with the Endangered Species Act.

## 2 In-Plant Requirements

### 2.1 Sampling Point(s)

Sampling Point Designation	
Sampling Point Number	Sampling Point Location, Waste Type/Sample Contents and Treatment Description (as applicable)
101	Representative samples shall be collected at the boiler drawdown sample point for Boilers #1 and 2, prior to mixing with condenser cooling water and other wastestreams discharging at Outfall 001.
102	At least one field blank shall be collected for each day a sample of mercury is collected from Outfall 001. The purpose of the field blank is to determine whether the field or sample transporting procedures and environments have contaminated the sample.
103	Representative samples shall be collected immediately downstream of the collection tank, prior to mixing with the other wastestreams discharging at Outfall 001. Wastes collected in the collection tank include: process water from the package boiler condensate drain, reverse osmosis unit concentrate, all floor drains, engine and cooling water from the fire pump weekly operational tests, and various sump and cooling waters.

### 2.2 Monitoring Requirements and Limitations

The permittee shall comply with the following monitoring requirements and limitations.

#### 2.2.1 Sampling Point 101 - BOILER DRAWDN PRIOR TO MIXING

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Per Occurrence	Estimated	Monitoring is required at each boiler drawdown event.
Suspended Solids, Total	Daily Max	100 mg/L	Per Occurrence	Composite	Monitoring is required at each boiler drawdown event.
Suspended Solids, Total	Monthly Avg	30 mg/L	Per Occurrence	Composite	Monitoring is required at each boiler drawdown event.
Oil & Grease (Hexane)	Daily Max	20 mg/L	Per Occurrence	Grab	Monitoring is required at each boiler drawdown event.
Oil & Grease (Hexane)	Monthly Avg	15 mg/L	Per Occurrence	Grab	Monitoring is required at each boiler drawdown event.

### 2.2.2 Sampling Point 102 - PROCESS EFFLUENT FIELD BLANK

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Mercury, Total Recoverable		ng/L	Quarterly	Blank	Field blank for mercury sampling at Outfall 001

#### 2.2.2.1 Mercury Monitoring

The permittee shall collect and analyze all mercury samples according to the data quality requirements of ss. NR 106.145(9) and (10), Wisconsin Administrative Code. The limit of quantitation (LOQ) used for the effluent and field blank shall be less than 1.3 ng/L, unless the samples are quantified at levels above 1.3 ng/L. The permittee shall collect at least one mercury field blank for each set of mercury samples (a set of samples may include combinations of intake, influent, effluent or other samples all collected on the same day). The permittee shall report results of samples and field blanks to the Department on Discharge Monitoring Reports.

### 2.2.3 Sampling Point 103 - COLLECTION TANK BEFORE MIXING

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Weekly	Total Daily	
Suspended Solids, Total	Daily Max	100 mg/L	Weekly	Grab	
Suspended Solids, Total	Monthly Avg	30 mg/L	Weekly	Grab	
Suspended Solids, Total		lbs/day	Weekly	Calculated	Applicable mass limits for the combined flows from Sample Points 103 and 004 are found under Outfall 015.
Oil & Grease (Hexane)	Daily Max	20 mg/L	Weekly	Grab	
Oil & Grease (Hexane)	Monthly Avg	15 mg/L	Weekly	Grab	
Oil & Grease (Hexane)		lbs/day	Weekly	Calculated	Applicable mass limits for the combined flows from Sample Points 103 and 004 are found under Outfall 015.



### 3 Surface Water Requirements

#### 3.1 Sampling Point(s)

The discharge(s) shall be limited to the waste type(s) designated for the listed sampling point(s).

Sampling Point Designation	
Sampling Point Number	Sampling Point Location, Waste Type/Sample Contents and Treatment Description (as applicable)
001	Representative samples shall be collected prior to discharge to Chequamegon Bay of Lake Superior. This outfall is authorized to discharge condenser cooling water, boiler drawdown and blow off water, water used to fill the boiler and produce steam, reverse osmosis unit concentrate, all floor drains, engine and cooling water from the fire pump weekly operational tests, and various sump and cooling.
002	Representative samples shall be collected prior to discharge to Chequamegon Bay of Lake Superior. This outfall is authorized to discharge condenser cooling water.
004	Representative samples shall be collected prior to discharge to Chequamegon Bay of Lake Superior. This outfall is authorized to discharge overflow from collection tank overflow only during emergencies and scheduled maintenance.
007	Representative samples shall be collected prior to discharge to Chequamegon Bay of Lake Superior. This outfall is authorized to discharge noncontact service water.
013	Representative samples shall be collected prior to discharge to Chequamegon Bay of Lake Superior. This outfall is authorized to discharge noncontact service water.
015	When there is a discharge event, the mass limits for oil and grease and total suspended solids apply to the combined flows from sample points 103 and 004. Whenever possible sampling shall occur on the same day as the bypass event.
016	Flow volume shall be estimated prior to discharge to Chequamegon Bay of Lake Superior. This outfall is authorized to discharge lake water to clear the intake traveling screens located across the inlet slip.
017	Flow volume shall be estimated prior to discharge to Chequamegon Bay of Lake Superior. This outfall is authorized to discharge warm water from condenser #5 prior to the sump pit for Outfall 001 in order to de-ice the #5 crib house intake screen in the winter.
018	Flow volume shall be measured prior to discharge to Chequamegon Bay of Lake Superior. This outfall is authorized to discharge warm cooling water from condenser #6 in order to de-ice the # 6 crib house and traveling intake screens in the winter.

#### 3.2 Monitoring Requirements and Effluent Limitations

The permittee shall comply with the following monitoring requirements and limitations.

##### 3.2.1 Sampling Point (Outfall) 001 - CONDENSER COOLING WATER

Monitoring Requirements and Effluent Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Daily	Continuous	
pH Field	Daily Max	9.0 su	Weekly	Grab	Weekly monitoring required through 03/31/2027.

<b>Monitoring Requirements and Effluent Limitations</b>					
<b>Parameter</b>	<b>Limit Type</b>	<b>Limit and Units</b>	<b>Sample Frequency</b>	<b>Sample Type</b>	<b>Notes</b>
pH Field	Daily Min	6.0 su	Weekly	Grab	Weekly monitoring required through 03/31/2027.
Chlorine, Total Residual		µg/L	Monthly	Grab	
Phosphorus, Total	6-Month Avg	0.6 mg/L	Monthly	Grab	
Temperature Maximum		deg F	Daily	Continuous	
Mercury, Total Recoverable	Daily Max	5 ng/L	Quarterly	Grab	
Arsenic, Total Recoverable		µg/L	2/Year	Grab	
PFOS		ng/L	Monthly	Grab	Monitoring only. See PFOS/PFOA Minimization Plan Determination of Need schedule.
PFOA		ng/L	Monthly	Grab	Monitoring only. See PFOS/PFOA Minimization Plan Determination of Need schedule.
Additive – Tri-Act 1800	Daily Max	2.0 gpd	Daily	Calculated	Calculate from daily dosage records
Additive - Eliminox	Daily Max	64 gpd	Daily	Calculated	Calculate from daily dosage records
Acute WET		TU <sub>a</sub>	See Listed Qtr(s)	24-Hr Flow Prop Comp	
Chronic WET		TU <sub>c</sub>	See Listed Qtr(s)	24-Hr Flow Prop Comp	
pH (Continuous)			Daily	Continuous	Continuous monitoring required starting 04/01/2027. See "Continuous pH Monitoring" below for pH limits and allowed excursions

### 3.2.1.1 Chlorine Monitoring

Paired chlorine monitoring with either Lake Superior intake is recommended to support the conditions as described in s. NR 106.06(6), Wis. Adm. Code.

### 3.2.1.2 Mercury Monitoring

The permittee shall collect and analyze all mercury samples according to the data quality requirements of ss. NR 106.145(9) and (10), Wis. Adm. Code. The limit of quantitation (LOQ) used for the effluent and field blank shall be less than 1.3 ng/L, unless the samples are quantified at levels above 1.3 ng/L. The permittee shall collect at least one mercury field blank for each set of mercury samples (a set of samples may include combinations of intake, influent,

effluent or other samples all collected on the same day). The permittee shall report results of samples and field blanks to the Department on Discharge Monitoring Reports.

### **3.2.1.3 Effluent Temperature Monitoring**

For manually measuring effluent temperature, grab samples should be collected at 6 evenly spaced intervals during the 24-hour period. Alternative sampling intervals may be approved if the permittee can show that the maximum effluent temperature is captured during the sampling interval. For monitoring temperature continuously, collect measurements in accordance with s. NR 218.04(13). This means that discrete measurements shall be recorded at intervals of not more than 15 minutes during the 24-hour period. In either case, report the maximum temperature measured during the day on the DMR. For seasonal discharges collect measurements either manually or continuously during the period of operation and report the daily maximum effluent temperature on the DMR.

### **3.2.1.4 PFOS/PFOA Sampling and Reporting Requirements**

For grab samples, as defined per s. NR 218.04(10), Wis. Adm. Code, a single sample at a location as defined by the sample point description shall be taken during the time of the day most representative to capture all potential discharges. If extra equipment besides the sample bottle is used to collect the sample, it is recommended that a one-time equipment blank is collected with the first sample. An equipment blank would be collected by passing laboratory-verified PFAS-free water over or through field sampling equipment before the collection of a grab sample to evaluate potential contamination from the equipment used during sample.

If any equipment blanks are performed, these results shall be reported in the comments section of the eDMR and shall also be documented in the reports submitted as part of the PFOS/PFOA Minimization Plan Determination of Need schedule of the permit.

### **3.2.1.5 PFOS/PFOA Minimization Plan Determination of Need**

The permittee shall monitor PFOS and PFOA as specified in the table above and report on the effluent concentrations including trends in monthly and annual average PFOS and PFOA concentrations as specified in the PFOS/PFOA Minimization Plan Determination of Need Schedule.

If, after reviewing the data, the Department determines that a minimization plan for PFOS and PFOA is necessary based on the procedures in s. NR 106.98(4), Wis. Adm. Code, the Department will notify the permittee in writing that a PFOS and PFOA minimization plan that satisfies the requirements in s. NR 106.99, Wis. Adm. Code, is required. The permittee shall submit an initial plan for Department approval no later than 90 days after written notification was sent from the Department in accordance with s. NR 106.985(2)(a), Wis. Adm. Code. Pursuant to s. NR 106.985(2)(b), Wis. Adm. Code, as soon as possible after Department approval of the PFOS and PFOA minimization plan, the Department will modify or revoke and reissue the permit in accordance with public notice procedures under ch. 283, Wis. Stats., and ch. NR 203, Wis. Adm. Code, to include the PFOS and PFOA minimization plan and other related terms and condition.

If, however, the Department determines that a PFOS and PFOA minimization plan is unnecessary based on the procedures in s. NR 106.98(4), Wis. Adm. Code, the Department shall notify the permittee that no further action is required. Per s. NR 106.98(3)(a), Wis. Adm. Code, the Department may reduce monitoring frequency to once every 3 months (quarterly) on a case-by-case basis, but only after at least 12 representative results have been generated. If the permittee requests a reduction in monitoring and the Department agrees a reduction would be appropriate, the permit may be modified in accordance with public notice procedures under ch. 283, Wis. Stats., and ch. NR 203, Wis. Adm. Code, to incorporate this change.

### 3.2.1.6 Continuous pH Monitoring

The permittee shall maintain the pH of the discharge within the range of 6.0 to 9.0 standard units (s.u.) except excursions are permitted subject to the following conditions:

- The pH is monitored continuously;
- The total time during which the pH is outside the range of 6.0 to 9.0 s.u. shall not exceed 446 minutes in any calendar month;
- No individual pH excursion outside the range of 6.0 to 9.0 s.u. shall exceed 60 minutes in duration;
- No individual pH excursion shall be outside the range of 4.0 to 11.0 s.u.; and
- On a daily basis, the permittee shall report the minimum and maximum pH, the total time that the pH is outside the range of 6.0 to 9.0 s.u. and the number of pH excursions outside the range of 6.0 to 9.0 that exceed 60 minutes in duration.

### 3.2.1.7 Polychlorinated Biphenyls

There shall be no discharge of polychlorinated biphenyl compounds such as those commonly used for transformer fluid.

### 3.2.1.8 Additives

The permittee shall maintain a record of the dosage rate of all additives used on a monthly basis. The additives may be changed during the term of the permit following procedures in the 'Additives' subsection of the Standard Requirements.

### 3.2.1.9 Whole Effluent Toxicity (WET) Testing

**Primary Control Water:** Laboratory water

**Instream Waste Concentration (IWC):** 9%

**Acute Mixing Zone Concentration:** N/A

**Dilution series:** At least five effluent concentrations and dual controls must be included in each test.

- **Acute:** 100, 50, 25, 12.5, 6.25% and any additional selected by the permittee.
- **Chronic:** 100, 30, 10, 3, 1% and any additional selected by the permittee.

**WET Testing Frequency:**

**Acute** tests are required during the following quarters:

- **Acute:** October 1<sup>st</sup> – December 31<sup>st</sup> 2025, July 1<sup>st</sup> -September 30<sup>th</sup> 2026, April 1<sup>st</sup> – June 30<sup>th</sup> 2027, January 1<sup>st</sup> – March 31<sup>st</sup> 2028, and October 1<sup>st</sup> – December 31<sup>st</sup> 2029

Acute WET testing shall continue after the permit expiration date (until the permit is reissued) in accordance with the WET requirements specified for the last full calendar year of this permit. For example, the next test would be required in October 1<sup>st</sup> – December 31<sup>st</sup> 2030.

**Chronic** tests are required during the following quarters:

- **Chronic:** October 1<sup>st</sup> – December 31<sup>st</sup> 2025, July 1<sup>st</sup> -September 30<sup>th</sup> 2026, April 1<sup>st</sup> – June 30<sup>th</sup> 2027, January 1<sup>st</sup> – March 31<sup>st</sup> 2028, and October 1<sup>st</sup> – December 31<sup>st</sup> 2029

Chronic WET testing shall continue after the permit expiration date (until the permit is reissued) in accordance with the WET requirements specified for the last full calendar year of this permit. For example, the next test would be required in October 1<sup>st</sup> – December 31<sup>st</sup> 2030.

**Testing:** WET testing shall be performed during normal operating conditions. Permittees are not allowed to turn off or otherwise modify treatment systems, production processes, or change other operating or treatment conditions during WET tests.

**Reporting:** The permittee shall report test results on the Discharge Monitoring Report form, and also complete the "Whole Effluent Toxicity Test Report Form" (Section 6, "State of Wisconsin Aquatic Life Toxicity Testing Methods Manual, 2<sup>nd</sup> Edition"), for each test. The original, complete, signed version of the Whole Effluent Toxicity Test Report Form shall be sent to the Biomonitoring Coordinator, Bureau of Water Quality, 101 S. Webster St., P.O. Box 7921, Madison, WI 53707-7921, within 45 days of test completion. The Discharge Monitoring Report (DMR) form shall be submitted electronically by the required deadline.

**Determination of Positive Results:** An acute toxicity test shall be considered positive if the Toxic Unit - Acute (TU<sub>a</sub>) is greater than **1.0** for either species (fathead minnow (*Pimephales promelas*) and waterflea (*Ceriodaphnia dubia*)). The TU<sub>a</sub> shall be calculated as follows:  $TU_a = 100 \div LC_{50}$ . A chronic toxicity test shall be considered positive if the Toxic Unit - Chronic (TU<sub>c</sub>) is greater than **11** for either species. The TU<sub>c</sub> shall be calculated as follows:  $TU_c = 100 \div IC_{25}$ .

**Additional Testing Requirements:** Within 90 days of a test which showed positive results, the permittee shall submit the results of at least 2 retests to the Biomonitoring Coordinator on "Whole Effluent Toxicity Test Report Forms". The 90-day reporting period shall begin the day after the test which showed a positive result. The retests shall be completed using the same species and test methods specified for the original test (see the Standard Requirements section herein).

### 3.2.2 Sampling Point (Outfall) 002 - CONDENSER COOLING WATER

Monitoring Requirements and Effluent Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Daily	Continuous	
Temperature Maximum		deg F	Daily	Continuous	
pH Field	Daily Max	9.0 su	Weekly	Grab	Weekly monitoring required through 03/31/2027.
pH Field	Daily Min	6.0 su	Weekly	Grab	Weekly monitoring required through 03/31/2027.
Arsenic, Total Recoverable		µg/L	2/Year	Grab	
Chlorine, Total Residual		µg/L	Monthly	Grab	
pH (Continuous)			Daily	Continuous	Continuous monitoring required starting 04/01/2027. See "Continuous pH Monitoring" below for pH limits and allowed excursions

**3.2.2.1 Effluent Temperature Monitoring**

For manually measuring effluent temperature, grab samples should be collected at 6 evenly spaced intervals during the 24-hour period. Alternative sampling intervals may be approved if the permittee can show that the maximum effluent temperature is captured during the sampling interval. For monitoring temperature continuously, collect measurements in accordance with s. NR 218.04(13). This means that discrete measurements shall be recorded at intervals of not more than 15 minutes during the 24-hour period. In either case, report the maximum temperature measured during the day on the DMR. For seasonal discharges collect measurements either manually or continuously during the period of operation and report the daily maximum effluent temperature on the DMR.

**3.2.2.2 Continuous pH Monitoring**

The permittee shall maintain the pH of the discharge within the range of 6.0 to 9.0 standard units (s.u.) except excursions are permitted subject to the following conditions:

- The pH is monitored continuously;
- The total time during which the pH is outside the range of 6.0 to 9.0 s.u. shall not exceed 446 minutes in any calendar month;
- No individual pH excursion outside the range of 6.0 to 9.0 s.u. shall exceed 60 minutes in duration;
- No individual pH excursion shall be outside the range of 4.0 to 11.0 s.u.; and
- On a daily basis, the permittee shall report the minimum and maximum pH, the total time that the pH is outside the range of 6.0 to 9.0 s.u. and the number of pH excursions outside the range of 6.0 to 9.0 that exceed 60 minutes in duration.

**3.2.2.3 Polychlorinated Biphenyls**

There shall be no discharge of polychlorinated biphenyl compounds such as those commonly used for transformer fluid.

**3.2.2.4 Additives**

The permittee shall maintain a record of the dosage rate of all additives used on a monthly basis. The additives may be changed during the term of the permit following procedures in the ‘Additives’ subsection of the Standard Requirements.

**3.2.3 Sampling Point (Outfall) 004 - BYPASS PROCESS WATER**

<b>Monitoring Requirements and Effluent Limitations</b>					
<b>Parameter</b>	<b>Limit Type</b>	<b>Limit and Units</b>	<b>Sample Frequency</b>	<b>Sample Type</b>	<b>Notes</b>
Flow Rate		MGD	At Discharge	Estimated	
pH Field	Daily Max	9.0 su	At Discharge	Grab	
pH Field	Daily Min	6.0 su	At Discharge	Grab	
Suspended Solids, Total	Daily Max	100 mg/L	At Discharge	Composite	
Suspended Solids, Total	Monthly Avg	30 mg/L	At Discharge	Composite	

<b>Monitoring Requirements and Effluent Limitations</b>					
<b>Parameter</b>	<b>Limit Type</b>	<b>Limit and Units</b>	<b>Sample Frequency</b>	<b>Sample Type</b>	<b>Notes</b>
Suspended Solids, Total		lbs/day	At Discharge	Calculated	
Oil & Grease (Hexane)	Daily Max	20 mg/L	At Discharge	Grab	
Oil & Grease (Hexane)	Monthly Avg	15 mg/L	At Discharge	Grab	
Oil & Grease (Hexane)		lbs/day	At Discharge	Calculated	
Temperature Maximum		deg F	At Discharge	Grab	
Phosphorus, Total		mg/L	At Discharge	Grab	

**3.2.3.1 Bypasses**

Pursuant to s. NR 205.07(1)(u), Wis. Code, any bypass is prohibited. In certain situations a bypass may be approved by the department. See the Bypass Standard Requirement Section for more information on when a bypass may be approved.

**3.2.3.2 Effluent Temperature Monitoring**

For manually measuring effluent temperature, grab samples should be collected at 6 evenly spaced intervals during the 24-hour period. Alternative sampling intervals may be approved if the permittee can show that the maximum effluent temperature is captured during the sampling interval. For monitoring temperature continuously, collect measurements in accordance with s. NR 218.04(13). This means that discrete measurements shall be recorded at intervals of not more than 15 minutes during the 24-hour period. In either case, report the maximum temperature measured during the day on the DMR. For seasonal discharges collect measurements either manually or continuously during the period of operation and report the daily maximum effluent temperature on the DMR.

**3.2.3.3 Polychlorinated Biphenyls**

There shall be no discharge of polychlorinated biphenyl compounds such as those commonly used for transformer fluid.

**3.2.4 Sampling Point (Outfall) 007 - NONCONTACT SERVICE WATER; 013- NONCONTACT SERVICE WATER**

<b>Monitoring Requirements and Effluent Limitations</b>					
<b>Parameter</b>	<b>Limit Type</b>	<b>Limit and Units</b>	<b>Sample Frequency</b>	<b>Sample Type</b>	<b>Notes</b>
Flow Rate		MGD	Monthly	Estimated	
Chlorine, Total Residual		µg/L	Monthly	Grab	

### 3.2.5 Sampling Point (Outfall) 015 - COMBINED 103 & 004

Monitoring Requirements and Effluent Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Suspended Solids, Total	Daily Max	74 lbs/day	Weekly	Calculated	
Suspended Solids, Total	Monthly Avg	22 lbs/day	Weekly	Calculated	
Oil & Grease (Hexane)	Daily Max	15 lbs/day	Weekly	Calculated	
Oil & Grease (Hexane)	Monthly Avg	11 lbs/day	Weekly	Calculated	

### 3.2.6 Sampling Point (Outfall) 016 - INTAKE SCREEN WASH WATER; 017- DE-ICING RECIRCULATION WATER; 018- DE-ICING RECIRCULATION WATER

Monitoring Requirements and Effluent Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		gpd	Monthly	Measure	



## 4 Schedules

### 4.1 Annual Certification Statement and Report for Intake Structure

Submit Annual Reports by January 31st of each year in accordance with the Annual Reports subsection in Standard Requirements.

Required Action	Due Date
<b>Submit Annual Certification Statement and Report #1:</b>	01/31/2026
<b>Submit Annual Certification Statement and Report #2:</b>	01/31/2027
<b>Submit Annual Certification Statement and Report #3:</b>	01/31/2028
<b>Submit Annual Certification Statement and Report #4:</b>	01/31/2029
<b>Submit Annual Certification Statement and Report #5:</b>	01/31/2030
<b>Ongoing Annual Certification Statements and Reports:</b> Continue to submit Annual Certification Statements and Reports until permit reissuance has been completed	

### 4.2 Impingement Mortality BTA Schedule

Required Action	Due Date
<b>Plans and Specifications:</b> These intake structure upgrades are not a reviewable project under ch. NR 108, Wis. Adm. Code. However, the permittee must submit plans and specifications for the intake screen(s) by this date showing the proposed upgrades and get department concurrence to ensure that further upgrades are not necessary to fulfill the impingement mortality BTA standard.	04/01/2027
<b>Construction:</b> In order to comply with the selected impingement mortality BTA standard, complete construction. This is also the date when compliance with the BTA standards must start being met.	04/01/2028

### 4.3 PFOS/PFOA Minimization Plan Determination of Need

Required Action	Due Date
<b>Report on Effluent Discharge:</b> Submit a report on effluent PFOS and PFOA concentrations and include an analysis of trends in monthly and annual average PFOS and PFOA concentrations. This analysis should also include a comparison to the applicable narrative standard in s. NR 102.04(8)(d), Wis. Adm. Code.  This report shall include all additional PFOS and PFOA data that may be collected including any influent, intake, in-plant, collection system sampling, and blank sample results.	04/01/2026
<b>Report on Effluent Discharge and Evaluation of Need:</b> Submit a final report on effluent PFOS and PFOA concentrations and include an analysis of trends in monthly and annual average PFOS and PFOA concentrations of data collected over the last 24 months. The report shall also provide a comparison on the likelihood of the facility needing to develop a PFOS/PFOA minimization plan.  This report shall include all additional PFOS and PFOA data that may be collected including any influent, intake, in-plant, collection system sampling, and blank sample results.	04/01/2027

<p>The permittee shall also submit a request to the department to evaluate the need for a PFOS/PFOA minimization plan.</p> <p>If the Department determines a PFOS/PFOA minimization plan is needed based on a reasonable potential evaluation, the permittee will be required to develop a minimization plan for Department approval no later than 90 days after written notification was sent from the Department. The Department will modify or revoke and reissue the permit to include PFOS/PFOA minimization plan reporting requirements along with a schedule of compliance to meet WQBELs. Effluent monitoring of PFOS and PFOA shall continue as specified in the permit until the modified permit is issued.</p> <p>If, however, the Department determines there is no reasonable potential for the facility to discharge PFOS or PFOA above the narrative standard in s. NR 102.04(8)(d), Wis. Adm. Code, no further action is required and effluent monitoring of PFOS and PFOA shall continue as specified in the permit.</p>	
---	--

#### 4.4 Continuous pH Monitoring

Required Action	Due Date
<b>Plans and Specification:</b> The permittee must submit plans and specifications to the department for the continuous pH monitoring devices required for outfalls 001 and 002 in accordance with ch. NR 108, Wis. Adm. Code.	04/01/2026
<b>Installation:</b> The permittee must complete installation of the pH monitoring devices by this date	04/01/2027

## 5 Standard Requirements

**Chapter NR 205, Wisconsin Administrative Code (Conditions for Industrial Dischargers):** The conditions in ss. NR 205.07(1) and NR 205.07(3), Wis. Adm. Code, are included by reference in this permit. The permittee shall comply with all of these requirements. Some of these requirements are outlined in the Standard Requirements section of this permit. Requirements not specifically outlined in the Standard Requirement section of this permit can be found in ss. NR 205.07(1) and NR 205.07(3), Wis. Adm. Code.

### 5.1 Reporting and Monitoring Requirements

#### 5.1.1 Monitoring Results

Monitoring results obtained during the previous month shall be summarized and reported on a Department Wastewater Discharge Monitoring Report. The report may require reporting of any or all of the information specified below under 'Recording of Results'. This report is to be returned to the Department no later than the date indicated on the form. A copy of the Wastewater Discharge Monitoring Report Form or an electronic file of the report shall be retained by the permittee.

Monitoring results shall be reported on an electronic discharge monitoring report (eDMR). The eDMR shall be certified electronically by a responsible executive or officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The 'eReport Certify' page certifies that the electronic report form is true, accurate and complete.

If the permittee monitors any pollutant more frequently than required by this permit, the results of such monitoring shall be included on the Wastewater Discharge Monitoring Report.

The permittee shall comply with all limits for each parameter regardless of monitoring frequency. For example, monthly, weekly, and/or daily limits shall be met even with monthly monitoring. The permittee may monitor more frequently than required for any parameter.

#### 5.1.2 Sampling and Testing Procedures

Sampling and laboratory testing procedures shall be performed in accordance with Chapters NR 218 and NR 219, Wis. Adm. Code, and completed by a laboratory certified or registered in accordance with the requirements of ch. NR 149, Wis. Adm. Code. Groundwater sampling shall be performed in accordance with procedures contained in s. NR 140.16, Wis. Adm. Code, and the WDNR publications, Groundwater Sampling Desk Reference (PUBL-DG-037-96) and Groundwater Sampling Field Manual (PUBL-DG-038-96). The analytical methodologies used shall enable the laboratory to quantitate all substances for which monitoring is required at levels below the effluent limitation and/or groundwater standard. If the required level cannot be met by any of the methods available in ch. NR 219, Wis. Adm. Code, then the method with the lowest limit of detection shall be selected. Additional test procedures may be specified in this permit.

#### 5.1.3 Recording of Results

The permittee shall maintain records which provide the following information for each effluent measurement or sample taken:

- the date, exact place, method and time of sampling or measurements;
- the individual who performed the sampling or measurements;
- the date the analysis was performed;
- the individual who performed the analysis;
- the analytical techniques or methods used; and
- the results of the analysis.

#### **5.1.4 Reporting of Monitoring Results**

The permittee shall use the following conventions when reporting effluent monitoring results:

- Pollutant concentrations less than the limit of detection shall be reported as < (less than) the value of the limit of detection. For example, if a substance is not detected at a detection limit of 0.1 mg/L, report the pollutant concentration as < 0.1 mg/L.
- Pollutant concentrations equal to or greater than the limit of detection, but less than the limit of quantitation, shall be reported and the limit of quantitation shall be specified.
- For purposes of calculating fees under ch. NR 101, Wis. Adm. Code, a reporting limit of 2.0 mg/L for BOD<sub>5</sub> and 2.5 mg/L Total Suspended Solids shall be considered to be limits of quantitation.
- For the purposes of reporting a calculated result, average or a mass discharge value, the permittee may substitute a “0” (zero) for any pollutant concentration that is less than the limit of detection. However, if the effluent limitation is less than the limit of detection, the department may substitute a value other than zero for results less than the limit of detection, after considering the number of monitoring results that are greater than the limit of detection and if warranted when applying appropriate statistical techniques.
- If no discharge occurs through an outfall, flow related parameters (e.g. flow rate, hydraulic application rate, volume, etc.) should be reported as “0” (zero) at the required sample frequency specified for the outfall. For example: if the sample frequency is daily, “0” would be reported for any day during the month that no discharge occurred.

#### **5.1.5 Records Retention**

The permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings or electronic data records for continuous monitoring instrumentation, copies of all reports required by the permit, and records of all data used to complete the application for the permit for a period of at least 3 years from the date of the sample, measurement, report or application, except for sludge management forms and records, which shall be kept for a period of at least 5 years.

#### **5.1.6 Other Information**

Where the permittee becomes aware that it failed to submit any relevant facts in a permit application or submitted incorrect information in a permit application or in any report to the Department, it shall promptly submit such facts or correct information to the Department.

#### **5.1.7 Reporting Requirements – Alterations or Additions**

The permittee shall give notice to the Department as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is only required when:

- The alteration or addition to the permitted facility may meet one of the criteria for determining whether a facility is a new source.
- The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification requirement applies to pollutants which are not subject to effluent limitations in the existing permit.
- The alteration or addition results in a significant change in the permittee’s sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use of disposal sites not reported during the permit application process nor reported pursuant to an approved land application plan. Additional sites may not be used for the land application of sludge until department approval is received.

### **5.2 System Operating Requirements**

### 5.2.1 Noncompliance Reporting

The permittee shall report the following types of noncompliance by a telephone call to the Department's regional office within 24 hours after becoming aware of the noncompliance:

- any noncompliance which may endanger health or the environment;
- any violation of an effluent limitation resulting from a bypass;
- any violation of an effluent limitation resulting from an upset; and
- any violation of a maximum discharge limitation for any of the pollutants listed by the Department in the permit, either for effluent or sludge.

A written report describing the noncompliance shall also be submitted to the Department as directed at the end of this permit within 5 days after the permittee becomes aware of the noncompliance. On a case-by-case basis, the Department may waive the requirement for submittal of a written report within 5 days and instruct the permittee to submit the written report with the next regularly scheduled monitoring report. In either case, the written report shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times; the steps taken or planned to reduce, eliminate and prevent reoccurrence of the noncompliance; and if the noncompliance has not been corrected, the length of time it is expected to continue.

A scheduled bypass approved by the Department under the 'Scheduled Bypass' section of this permit shall not be subject to the reporting required under this section.

**NOTE:** Section 292.11(2)(a), Wisconsin Statutes, requires any person who possesses or controls a hazardous substance or who causes the discharge of a hazardous substance to notify the Department of Natural Resources **immediately** of any discharge not authorized by the permit. **The discharge of a hazardous substance that is not authorized by this permit or that violates this permit may be a hazardous substance spill. To report a hazardous substance spill, call DNR's 24-hour HOTLINE at 1-800-943-0003.**

### 5.2.2 Bypass

Except for a controlled diversion as provided in the 'Controlled Diversions' section of this permit, any bypass is prohibited and the Department may take enforcement action against a permittee for such occurrences under s. 283.89, Wis. Stats. The Department may approve a bypass if the permittee demonstrates all the following conditions apply:

- The bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
- There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities or adequate back-up equipment, retention of untreated wastes, reduction of inflow and infiltration, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance. When evaluating feasibility of alternatives, the department may consider factors such as technical achievability, costs and affordability of implementation and risks to public health, the environment and, where the permittee is a municipality, the welfare of the community served; and
- The bypass was reported in accordance with the 'Noncompliance Reporting' section of this permit.

### 5.2.3 Scheduled Bypass

Whenever the permittee anticipates the need to bypass for purposes of efficient operations and maintenance and the permittee may not meet the conditions for controlled diversions in the 'Controlled Diversions' section of this permit, the permittee shall obtain prior written approval from the Department for the scheduled bypass. A permittee's written request for Department approval of a scheduled bypass shall demonstrate that the conditions for unscheduled bypassing are met and include the proposed date and reason for the bypass, estimated volume and duration of the bypass, alternatives to bypassing and measures to mitigate environmental harm caused by the bypass. The department may require the permittee to provide public notification for a scheduled bypass if it is determined there is significant public interest in the proposed action and may recommend mitigation measures to minimize the impact of such bypass.

#### **5.2.4 Controlled Diversions**

Controlled diversions are allowed only when necessary for essential maintenance to assure efficient operation provided the following requirements are met:

- Effluent from the wastewater treatment facility shall meet the effluent limitations established in the permit. Wastewater that is diverted around a treatment unit or treatment process during a controlled diversion shall be recombined with wastewater that is not diverted prior to the effluent sampling location and prior to effluent discharge;
- A controlled diversion may not occur during periods of excessive flow or other abnormal wastewater characteristics;
- A controlled diversion may not result in a wastewater treatment facility overflow; and
- All instances of controlled diversions shall be documented in wastewater treatment facility records and such records shall be available to the department on request.

#### **5.2.5 Proper Operation and Maintenance**

The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance includes effective performance, adequate funding, adequate operator staffing and training as required in ch. NR 114, Wis. Adm. Code, and adequate laboratory and process controls, including appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems only when necessary to achieve compliance with the conditions of the permit.

#### **5.2.6 Operator Certification**

The wastewater treatment facility shall be under the direct supervision of a state certified operator. In accordance with s. NR 114.53, Wis. Adm. Code, every WPDES permitted treatment plant shall have a designated operator-in-charge holding a current and valid certificate. The designated operator-in-charge shall be certified at the level and in all subclasses of the treatment plant, except laboratory. Treatment plant owners shall notify the department of any changes in the operator-in-charge within 30 days. Note that s. NR 114.52(22), Wis. Adm. Code, lists types of facilities that are excluded from operator certification requirements (i.e. private sewage systems, pretreatment facilities discharging to public sewers, industrial wastewater treatment that consists solely of land disposal, agricultural digesters and concentrated aquatic production facilities with no biological treatment).

#### **5.2.7 Spill Reporting**

The permittee shall notify the Department in accordance with ch. NR 706 (formerly NR 158), Wis. Adm. Code, in the event that a spill or accidental release of any material or substance results in the discharge of pollutants to the waters of the state at a rate or concentration greater than the effluent limitations established in this permit, or the spill or accidental release of the material is unregulated in this permit, unless the spill or release of pollutants has been reported to the Department in accordance with s. NR 205.07 (1)(s), Wis. Adm. Code.

#### **5.2.8 Planned Changes**

In accordance with ss. 283.31(4)(b) and 283.59, Stats., the permittee shall report to the Department any facility expansion, production increase or process modifications which will result in new, different or increased discharges of pollutants. The report shall either be a new permit application, or if the new discharge will not violate the effluent limitations of this permit, a written notice of the new, different or increased discharge. The notice shall contain a description of the new activities, an estimate of the new, different or increased discharge of pollutants and a description of the effect of the new or increased discharge on existing waste treatment facilities. Following receipt of this report, the Department may modify this permit to specify and limit any pollutants not previously regulated in the permit.

### 5.2.9 Duty to Halt or Reduce Activity

Upon failure or impairment of treatment facility operation, the permittee shall, to the extent necessary to maintain compliance with its permit, curtail production or wastewater discharges or both until the treatment facility operations are restored or an alternative method of treatment is provided.

## 5.3 Surface Water Requirements

### 5.3.1 Permittee-Determined Limit of Quantitation Incorporated into this Permit

For pollutants with water quality-based effluent limits below the Limit of Quantitation (LOQ) in this permit, the LOQ calculated by the permittee and reported on the Discharge Monitoring Reports (DMRs) is incorporated by reference into this permit. The LOQ shall be reported on the DMRs, shall be the lowest quantifiable level practicable, and shall be no greater than the minimum level (ML) specified in or approved under 40 CFR Part 136 for the pollutant at the time this permit was issued, unless this permit specifies a higher LOQ.

### 5.3.2 Appropriate Formulas for Effluent Calculations

The permittee shall use the following formulas for calculating effluent results to determine compliance with average concentration limits and mass limits and total load limits:

**Weekly/Monthly/Six-Month/Annual Average Concentration** = the sum of all daily results for that week/month/six-month/year, divided by the number of results during that time period. [Note: When a six-month average effluent limit is specified for Total Phosphorus the applicable periods are May through October and November through April, except in cases of Water Quality Trading, wherein the applicable periods are January through June and July through December.]

**Weekly Average Mass Discharge (lbs/day):** Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the week.

**Monthly Average Mass Discharge (lbs/day):** Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the month.

**Six-Month Average Mass Discharge (lbs/day):** Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the six-month period. [Note: When a six-month average effluent limit is specified for Total Phosphorus the applicable periods are May through October and November through April.]

**Annual Average Mass Discharge (lbs/day):** Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the entire year.

**Total Monthly Discharge:** = monthly average concentration (mg/L) x total flow for the month (MG/month) x 8.34.

**Total Annual Discharge:** = sum of total monthly discharges for the calendar year.

**12-Month Rolling Sum of Total Monthly Discharge:** = the sum of the most recent 12 consecutive months of Total Monthly Discharges.

### 5.3.3 Effluent Temperature Requirements

**Weekly Average Temperature** – If temperature limits are included in this permit, Weekly Average Temperature shall be calculated as the sum of all daily maximum results for that week divided by the number of daily maximum results during that time period.

**Cold Shock Standard** – Water temperatures of the discharge shall be controlled in a manner as to protect fish and aquatic life uses from the deleterious effects of cold shock pursuant to Wis. Adm. Code, s. NR 102.28. ‘Cold Shock’ means exposure of aquatic organisms to a rapid decrease in temperature and a sustained exposure to low temperature that induces abnormal behavior or physiological performance and may lead to death.

**Rate of Temperature Change Standard** – Temperature of a water of the state or discharge to a water of the state may not be artificially raised or lowered at such a rate that it causes detrimental health or reproductive effects to fish or aquatic life of the water of the state pursuant to Wis. Adm. Code, s. NR 102.29.

### **5.3.4 Energy Emergency Events**

The Department will use enforcement discretion whenever there are exceedances of effluent temperature limitations for the electric generating facility during an energy emergency warning or when an energy emergency event has been declared under a Federal Energy Regulatory Commission order (Standard EOP-002, North American Electric Reliability Corporation).

### **5.3.5 Visible Foam or Floating Solids**

There shall be no discharge of floating solids or visible foam in other than trace amounts.

### **5.3.6 Surface Water Uses and Criteria**

In accordance with NR 102.04, Wis. Adm. Code, surface water uses and criteria are established to govern water management decisions. Practices attributable to municipal, industrial, commercial, domestic, agricultural, land development or other activities shall be controlled so that all surface waters including the mixing zone meet the following conditions at all times and under all flow and water level conditions:

- a) Substances that will cause objectionable deposits on the shore or in the bed of a body of water, shall not be present in such amounts as to interfere with public rights in waters of the state.
- b) Floating or submerged debris, oil, scum or other material shall not be present in such amounts as to interfere with public rights in waters of the state.
- c) Materials producing color, odor, taste or unsightliness shall not be present in such amounts as to interfere with public rights in waters of the state.
- d) Substances in concentrations or in combinations which are toxic or harmful to humans shall not be present in amounts found to be of public health significance, nor shall substances be present in amounts which are acutely harmful to animal, plant or aquatic life.

### **5.3.7 Total Residual Chlorine Requirements**

When total residual chlorine (TRC) limit(s) or monitoring are included in a permit, the permittee shall comply with the following conditions:

- a) The permittee shall perform TRC monitoring required in this permit using an approved method from ch. NR 219, Wis. Adm. Code, which produces a detection limit that is less than or equal to the permitted limit or produces the lowest economically feasible detection limit if the approved methods cannot meet the permit limit. If the facility cannot achieve a detection limit less than or equal to the permit limit using the approved methods, contact the laboratory accreditation program for guidance.
- b) The permittee shall determine the limit of detection (LOD) as specified in s. NR 149.48 (2)(b), Wis. Adm. Code, or the permittee shall contact the laboratory accreditation program for information on how to determine a verified detection limit allowed just for TRC. If the verified detection limit is determined using the special procedure, then the LOD and limit of quantitation (LOQ) shall be set to be equal to the verified detection limit determined from this special procedure.
- c) The permittee shall determine compliance with the TRC limit(s) as follows:



1. If the facility determines a statistical LOD as specified in s. NR 149.48 (2)(b), Wis. Adm. Code, and the measured TRC levels are less than the LOD, the permittee shall report the results as less than the LOD (<LOD). For this situation the LOQ shall be established at 3.33 times the LOD or at the concentration of the lowest standard in the calibration curve. TRC levels that are < LOD are in compliance with the TRC limit.
2. If the facility determines the verified detection limit using the laboratory accreditation program special procedure, this verified detection limit shall be reported as the LOD and LOQ. If the measured TRC levels are less than the LOD, the permittee shall report the results as < LOD. TRC levels that are < LOD are in compliance with the TRC limit.
3. If the facility determines the statistical LOD as specified in s. NR 149.48 (2)(b), Wis. Adm. Code, and the measured TRC levels are greater than the statistical LOD but less than the LOQ, TRC levels are in compliance with the TRC limit - except when the measured levels are consistently reported between the LOD and LOQ. When the measured TRC levels are consistently reported between the LOD and LOQ, the facility shall take action to determine the reliability of detected results (such as resampling and/or re-calculating dosages) and shall adjust the chemical feed system if necessary to reduce the chances of detecting levels between the statistical LOD and LOQ.
4. If the facility determines the statistical LOQ as specified in s. NR 149.48 (2)(b), Wis. Adm. Code, or determines the verified detection limit using the laboratory accreditation program special procedure, TRC measured levels that are greater than the statistical LOQ and the TRC limit, are not in compliance with the TRC limit. The permittee shall report the level as a limit exceedance.
5. If the facility determines the statistical LOD as specified in s. NR 149.48 (2)(b), Wis. Adm. Code, and the measured level is < LOD, then a "0" (zero) value may be substituted for any test result less than the statistical LOD when calculating the average or mass discharge values. Calculated values shall then be compared directly to the average or mass limits to determine compliance.
6. If the facility determines the verified detection limit using the laboratory accreditation program special procedure and the measured level is < LOD (set equal to the verified detection limit), then a "0" (zero) value may be substituted for any test result less than the LOD when calculating the average or mass discharge values. Calculated values shall then be compared directly to the average or mass limits to determine compliance.

### **5.3.8 Additives**

In the event that the permittee wishes to commence use of a water treatment additive, or increase the usage of the additives greater than indicated in the permit application, the permittee must get a written approval from the Department prior to initiating such changes. This written approval shall provide authority to utilize the additives at the specific rates until the permit can be either reissued or modified in accordance with s. 283.53, Stats. Restrictions on the use of the additives may be included in the authorization letter.

### **5.3.9 Whole Effluent Toxicity (WET) Monitoring Requirements**

In order to determine the potential impact of the discharge on aquatic organisms, static-renewal toxicity tests shall be performed on the effluent in accordance with the procedures specified in the *"State of Wisconsin Aquatic Life Toxicity Testing Methods Manual, 2<sup>nd</sup> Edition"* (PUB-WT-797, November 2004) as required by NR 219.04, Table A, Wis. Adm. Code). All of the WET tests required in this permit, including any required retests, shall be conducted on the *Ceriodaphnia dubia* and fathead minnow species. Receiving water samples shall not be collected from any point in contact with the permittee's mixing zone and every attempt shall be made to avoid contact with any other discharge's mixing zone.

### 5.3.10 Whole Effluent Toxicity (WET) Identification and Reduction

Within 60 days of a retest which showed positive results, the permittee shall submit a written report to the Biomonitoring Coordinator, Bureau of Water Quality, 101 S. Webster St., PO Box 7921, Madison, WI 53707-7921, which details the following:

- A description of actions the permittee has taken or will take to remove toxicity and to prevent the recurrence of toxicity;
- A description of toxicity reduction evaluation (TRE) investigations that have been or will be done to identify potential sources of toxicity, including the following actions:
  - a) Evaluate the performance of the treatment system to identify deficiencies contributing to effluent toxicity (e.g., operational problems, chemical additives, incomplete treatment)
  - b) Identify the compound(s) causing toxicity. Conduct toxicity screening tests on the effluent at a minimum of once per month for six months to determine if toxicity recurs. Screening tests are WET tests using fewer effluent concentrations conducted on the most sensitive species. If any of the screening tests contain toxicity, conduct a toxicity identification evaluation (TIE) to determine the cause. TIE methods are available from USEPA “Methods for Aquatic Toxicity Identification Evaluations: Phase I Toxicity Characterization Procedures (EPA/600/6-91/003) and “Toxicity Identification Evaluation: Characterization of Chronically Toxic Effluents, Phase I” (EPA/600/6-91/005F).
  - c) Trace the compound(s) causing toxicity to their sources (e.g., industrial, commercial, domestic)
  - d) Evaluate, select, and implement methods or technologies to control effluent toxicity (e.g., in-plant or pretreatment controls, source reduction or removal)
- Where corrective actions including a TRE have not been completed, an expeditious schedule under which corrective actions will be implemented;
- If no actions have been taken, the reason for not taking action.

The permittee may also request approval from the Department to postpone additional retests in order to investigate the source(s) of toxicity. Postponed retests must be completed after toxicity is believed to have been removed.

### 5.3.11 PFOS and PFOA Requirements

The laboratory performing the analysis on any samples shall be certified for the applicable PFAS compounds in the aqueous matrix by the Wisconsin Laboratory Certification Program established under s. 299.11, Wis. Stats., in accordance with s. NR 149.41, Wis. Adm. Code. If the EPA Office of Water publishes a 1600 series isotope dilution method for the analysis of PFAS in wastewater, the department recommends the use of the EPA method.

The Department may reject any sample results if results are produced by a laboratory that is not in compliance with certification requirements under ch. NR 149, Wis. Adm. Code.

## 6 Summary of Reports Due

FOR INFORMATIONAL PURPOSES ONLY

Description	Date	Page
Annual Certification Statement and Report for Intake Structure -Submit Annual Certification Statement and Report #1	January 31, 2026	14
Annual Certification Statement and Report for Intake Structure -Submit Annual Certification Statement and Report #2	January 31, 2027	14
Annual Certification Statement and Report for Intake Structure -Submit Annual Certification Statement and Report #3	January 31, 2028	14
Annual Certification Statement and Report for Intake Structure -Submit Annual Certification Statement and Report #4	January 31, 2029	14
Annual Certification Statement and Report for Intake Structure -Submit Annual Certification Statement and Report #5	January 31, 2030	14
Annual Certification Statement and Report for Intake Structure -Ongoing Annual Certification Statements and Reports	See Permit	14
Impingement Mortality BTA Schedule -Plans and Specifications	April 1, 2027	14
Impingement Mortality BTA Schedule -Construction	April 1, 2028	14
PFOS/PFOA Minimization Plan Determination of Need -Report on Effluent Discharge	April 1, 2026	14
PFOS/PFOA Minimization Plan Determination of Need -Report on Effluent Discharge and Evaluation of Need	April 1, 2027	14
Continuous pH Monitoring -Plans and Specification	April 1, 2026	15
Continuous pH Monitoring -Installation	April 1, 2027	15
Wastewater Discharge Monitoring Report	no later than the date indicated on the form	16

Report forms shall be submitted electronically in accordance with the reporting requirements herein. Any facility plans or plans and specifications for municipal, industrial, industrial pretreatment and non industrial wastewater systems shall be submitted to the Bureau of Water Quality, P.O. Box 7921, Madison, WI 53707-7921. All other submittals required by this permit shall be submitted to:

Central Office, 101 S Webster St, P.O. Box 7921, Madison, WI 53707-7921