STATE OF WISCONSIN DEPARTMENT OF NATURAL RESOURCES

PUBLIC NOTICE OF INFORMATIONAL HEARING AND INTENT TO REISSUE A WISCONSIN POLLUTANT DISCHARGE ELIMINATION SYSTEM (WPDES) PERMIT No.WI-0029025-10-0

Permittee: Village of Potter, PO Box 162, Potter, WI 54160

Facility Where Discharge Occurs: Potter Wastewater Treatment Facility, 320 Pheasant St, Potter, WI

Receiving Water And Location: Unnamed tributary to the North Branch of the Manitowoc River in Calumet County

Brief Facility Description: The Village of Potter owns and operates the Potter Wastewater Treatment Facility that treats residential and commercial domestic wastewater from the Village sanitary sewer collection system. All sludge generated from the treatment facility is currently stored and hauled to the Village of Hilbert Wastewater Treatment Facility (Outfall 002). Effluent exits by gravity discharge to the unnamed tributary to the North Branch of the Manitowoc River via Outfall 001.

Summary of Proposed Changes: 1) Addition of influent flow rate monitoring and reporting. 2) The influent sample type for BOD₅ and TSS is changed from 3-Hr Composite to 24-Hr Flow Proportional Composite. 3) The effluent sample type for BOD₅, TSS, chloride, phosphorus, ammonia nitrogen, and WET testing is changed from 3-Hr Composite to 24-Hr Flow Proportional Composite. 4) Addition of TMDL-based mass limits for total suspended solids (TSS). 5) Addition of Escherichia coli (E. coli) monitoring and limits, to become effective per the Effluent Limitations for E. coli Schedule. 6) Updated chloride variance interim limit to 450 mg/L as a weekly average and updated source reduction measures (SRMs) throughout the permit term. 7) Addition of TMDL-based mass limits for total phosphorus, to become effective per the TMDL-Based Effluent Mass Limits for Total Phosphorus Schedule. 8) Updated ammonia nitrogen daily maximum, weekly average and monthly average effluent limits. 9) Addition of maximum temperature monitoring for one year (Jan-Dec 2028). 10) Addition of annual total nitrogen effluent monitoring. 11) Addition of a Chronic Whole Effluent Toxicity (WET) testing effluent limit. 12) Removed PCB land application monitoring requirements. 13) Addition of annual PFAS land application monitoring. 14) Compliance Schedules for: chloride source reduction measures (target value), install continuous flow recording device and influent composite sampler, disinfection and effluent limitations for E. coli, TMDL-based effluent mass limits for total phosphorus, and sludge management plan.

Permit Drafter's Name, Address, Phone and Email: Sarah Donoughe, DNR, 2984 Shawano Ave, Green Bay, WI 54313-6727, (920) 366-6076, Sarah.Donoughe@wisconsin.gov

Basin Engineer's Name, Address, Phone and Email: Trevor Moen, DNR, 625 E Cty Rd Y, Ste 700, Oshkosh, WI 54901, (920) 410-5192, Trevor.Moen@wisconsin.gov

The Department has tentatively decided that the above-specified WPDES permit should be reissued.

Limitations and conditions which the Department believes adequately protect the receiving water are included in the proposed permit. Land application of waste shall be done in accordance with permit conditions and applicable codes. All land application sites shall be approved prior to their use. To receive a list of approved sites, or to be notified of potential approvals, contact the above-named basin engineer.

Proposed Chloride Variance: The Department has determined that a water quality-based effluent limitation (WQBEL) for chloride is needed in this permit to protect aquatic life. As allowed under s. NR 106.83(2), Wis. Adm. Code, the permittee has requested a variance to the chloride WQBEL. In support of this request, the permittee has submitted documentation intended to demonstrate that the cost of complying with the WQBEL through the use of end-of-pipe wastewater treatment may cause substantial and widespread adverse social and economic impacts in the area where the discharger is located. The Department concurs with that assessment; however, this concurrence is subject to USEPA approval before the variance limit may be included in the final reissued permit. In an effort to achieve chloride effluent reductions that are practically and economically achievable within the term of the proposed permit, the Department and the permittee have mutually agreed upon specific permit terms that include an interim limitation, a target limit (or value, as the case may be), and certain source reduction activities. As allowed under s. NR 106.83(3), Wis. Adm. Code, these requirements are contained in the proposed permit.

Hearing Date, Time, and Location: **Monday, December 9, 2024 at 1:00pm,** https://us02web.zoom.us/meeting/register/tZYkfu-qrTopHNdDlpNfvdXiguSICFUjpcyF

Hearing Officer, Name, Address, City/State/Zip , and Phone: Sarah Donoughe, DNR, 2984 Shawano Ave, Green Bay, WI 54313-6727, (920) 366-6076

The Department of Natural Resources, pursuant to s. 283.49, Wis. Stats, has scheduled for the time and place listed above, a public hearing for the purpose of giving all interested persons an opportunity to make a statement with respect to the above announced permit action for this existing discharge.

A hearing officer will conduct the hearing in an orderly and speedy way and will use procedures specified in Subchapter II of ch. NR 203, Wis. Adm. Code, necessary to insure broad public participation in the hearing.

The hearing officer will open the hearing and make a concise statement of the scope and purpose of the hearing and shall state what procedures will be used during the course of the hearing. The hearing officer shall explain the method of notification of the final decision to grant or deny the permit and the methods by which the decision may be reviewed in a public adjudicatory hearing.

The hearing officer may put limits on individual oral statements to ensure an opportunity for all persons present to make statements in a reasonable period of time and to prevent undue repetition. The hearing officer may also limit the number of representatives making oral statements on behalf of any person or group.

Informational and clarifying questions and oral statements shall be directed through the hearing officer. Cross-examination shall not be allowed.

Persons wishing to comment on or object to the proposed permit action are invited to do so by attending the public hearing or by submitting any comments or objections in writing to the Department of Natural Resources, at the above-named permit drafter's address. All comments or suggestions received from members of the public no later than 7 days following the date of this public hearing will be used, along with other information on file and testimony presented at the hearing, in making a final determination. Where designated as a reviewable surface water discharge permit, the U.S. Environmental Protection Agency is allowed up to 90 days to submit comments or objections regarding this permit determination.

Information on file for this permit action, including the draft permit, fact sheet and permit application, may be inspected and copied at either the above-named permit drafter's office or the above named basin engineer's office, Monday through Friday (except holidays), between 9:00 a.m. and 3:30 p.m. Please call the permit drafter or basin engineer for directions to their office location, if necessary. Information on this permit action may also be obtained by calling the permit drafter at (920) 662-5148 or by writing to the Department. Reasonable costs (15 cents per page for copies and 7 cents per page for scanning) will be charged for information in the file other than the public notice, permit and fact sheet. Permit information is also available on the internet at:

http://dnr.wi.gov/topic/wastewater/PublicNotices.html. Pursuant to the Americans with Disabilities Act, reasonable accommodation, including the provision of informational material in an alternative format, will be made to qualified individuals upon request.

NAME OF PUBLISHING NEWSPAPER: The Brillion News

ADDRESS OF PUBLISHING NEWSPAPER: 425 W Ryan St, Brillion, WI 54110

Date Notice Issued: Thursday, October 24, 2024