

STATE OF WISCONSIN DEPARTMENT OF NATURAL RESOURCES

PUBLIC NOTICE OF INFORMATIONAL HEARING AND INTENT TO REISSUE A WISCONSIN POLLUTANT DISCHARGE ELIMINATION SYSTEM (WPDES) PERMIT No. WI-0035581-08-0

Permittee: Rib Mountain Metropolitan Sewerage District WWTF, 151401 Aster Rd, Wausau, WI, 54401

Facility Where Discharge Occurs: Rib Mountain Metro Sewerage District WWTF, 151401 Aster Rd, Wausau, WI 54401

Receiving Water And Location: Wisconsin River in Mosinee Flowage Watershed of the Central Wisconsin River Watershed in Marathon county

Brief Facility Description and Summary of Proposed Changes: The Rib Mountain Metropolitan Sewerage District (RMMSD) Wastewater Treatment Facility is a publicly owned treatment works that receives and treats wastewater from the residents and businesses of the Villages of Rothschild, Kronenwetter and Weston, part of the Town of Weston, the Village of Rib Mountain and the City of Mosinee. The annual average design flow of the facility is 4.41 million gallons per day (MGD). Grit and bar screenings are disposed of in a sanitary landfill. The current liquid treatment facilities include influent pumping, raw wastewater screening and grit removal, primary sedimentation, activated sludge treatment with chemical phosphorus removal (polyaluminum chloride (PAC)), final clarification, ultraviolet disinfection, and cascade aeration. The solids processing facilities include waste activated sludge thickening by dissolved air floatation, primary and secondary stage anaerobic digestion, and liquid sludge storage.

Permit Drafter's Name, Address, Phone and Email: Victoria Ziegler, 141 NW Barstow St, Waukesha, WI, 53188, (414) 391-8946, Victoria.Ziegler@wisconsin.gov

Basin Engineer's Name, Address, Phone and Email: Nicholas Lindstrom, 1300 W Clairemont Avenue, Eau Claire, WI 54701, (715) 492-1787, Nicholas.Lindstrom@wisconsin.gov

The Department has tentatively decided that the above-specified WPDES permit should be reissued.

Limitations and conditions which the Department believes adequately protect the receiving water are included in the proposed permit. Land application of waste shall be done in accordance with permit conditions and applicable codes. All land application sites shall be approved prior to their use. To receive a list of approved sites, or to be notified of potential approvals, contact the above-named basin engineer.

Proposed Mercury Variance: The Department has determined that a water quality-based effluent limitation (WQBEL) of 1.3 ng/L for mercury is needed to protect wildlife and human health in the above-named receiving water. The permittee has applied for an alternative mercury effluent limitation (AMEL). The application included a pollutant minimization program (PMP) plan for mercury as required under s. NR 106.145(8), Wis. Adm. Code. The Department concludes that the permittee is eligible for a variance based on the information submitted, information on file and the findings provided in s. NR 106.145(1), Wis. Adm. Code. The Department and the permittee have mutually agreed upon an AMEL of 7.0 ng/L, expressed as a daily maximum, continued influent and effluent monitoring, and permit language requiring implementation of the PMP. The Department proposes to grant the AMEL, which represents a variance to the water quality standard used to derive the WQBEL, as provided for under s. NR 106.145(6), Wis. Adm. Code. The designated use of the receiving water will not change as a result of the variance. This mercury variance must be approved by USEPA prior to its inclusion in the final reissued permit.

Hearing Date, Time, and Location: April 16, 2025 at 1:00PM via Zoom:
<https://us02web.zoom.us/meeting/register/Gt5zgtbOTyqbXseGcnLDXg>

Hearing Officer, Name, Address, City/State/Zip , and Phone: Sarah Donoughe, 2984 Shawano Ave, Green Bay, WI 54313, 920-336-6076; Sarah.Donoughe@wisconsin.gov

The Department of Natural Resources, pursuant to s. 283.49, Wis. Stats, has scheduled for the time and place listed above, a public hearing for the purpose of giving all interested persons an opportunity to make a statement with respect to the above announced permit action for this existing discharge.

A hearing officer will conduct the hearing in an orderly and speedy way and will use procedures specified in Subchapter II of ch. NR 203, Wis. Adm. Code, necessary to insure broad public participation in the hearing.

The hearing officer will open the hearing and make a concise statement of the scope and purpose of the hearing and shall state what procedures will be used during the course of the hearing. The hearing officer shall explain the method of notification of the final decision to grant or deny the permit and the methods by which the decision may be reviewed in a public adjudicatory hearing.

The hearing officer may put limits on individual oral statements to ensure an opportunity for all persons present to make statements in a reasonable period of time and to prevent undue repetition. The hearing officer may also limit the number of representatives making oral statements on behalf of any person or group.

Informational and clarifying questions and oral statements shall be directed through the hearing officer. Cross-examination shall not be allowed.

Persons wishing to comment on or object to the proposed permit action are invited to do so by attending the public hearing or by submitting any comments or objections in writing to the Department of Natural Resources, at the above-named permit drafter's address. All comments or suggestions received from members of the public no later than 7 days following the date of this public hearing will be used, along with other information on file and testimony presented at the hearing, in making a final determination. Where designated as a reviewable surface water discharge permit, the U.S. Environmental Protection Agency is allowed up to 90 days to submit comments or objections regarding this permit determination.

Information on file for this permit action, including the draft permit, fact sheet and permit application, may be inspected and copied at either the above-named permit drafter's office or the above named basin engineer's office, Monday through Friday (except holidays), between 9:00 a.m. and 3:30 p.m. Please call the permit drafter or basin engineer for directions to their office location, if necessary. Information on this permit action may also be obtained by calling the permit drafter at (414) 391-8946 or by writing to the Department. Reasonable costs (15 cents per page for copies and 7 cents per page for scanning) will be charged for information in the file other than the public notice, permit and fact sheet. Permit information is also available on the internet at:

<http://dnr.wi.gov/topic/wastewater/PublicNotices.html>. Pursuant to the Americans with Disabilities Act, reasonable accommodation, including the provision of informational material in an alternative format, will be made to qualified individuals upon request.

NAME OF PUBLISHING NEWSPAPER: Wausau Daily Herald

ADDRESS OF PUBLISHING NEWSPAPER: 800 Scott Street, Wausau, WI 54402-1286

Date Notice Issued: Thursday, February 20, 2025