

2005 Energy Act Public Reporting

Source	Number	Percent
Tanks	80	69.6
Piping	8	7.0
Dispensers	18	15.7
Submersible Pumps	0	0.0
Delivery Problems	2	1.7
Other	7	6.1
	115	100.0

Reporting Period: October 1st to September 30th
 Reported: October 3, 2011

	Tanks	
Cause	Number	Percent
Spill	0	0.0
Overfill	4	5.0
Physical / Mechanical Damage	5	6.3
Corrosion	27	33.8
Installation Problems	0	0.0
Other	3	3.8
Unknown	41	51.3
	80	100.0

	Piping	
Cause	Number	Percent
Spill	0	0.0
Overfill	0	0.0
Physical / Mechanical Damage	2	25.0
Corrosion	1	12.5
Installation Problems	0	0.0
Other	2	25.0
Unknown	3	37.5
	8	100.0

	Dispensers	
Cause	Number	Percent
Spill	1	5.6
Overfill	3	16.7
Physical / Mechanical Damage	3	16.7
Corrosion	0	0.0
Installation Problems	0	0.0
Other	0	0.0
Unknown	11	61.1
	18	100.0

	Submersible Pumps	
Cause	Number	Percent
Spill	0	0.0
Overfill	0	0.0
Physical / Mechanical Damage	0	0.0
Corrosion	0	0.0
Installation Problems	0	0.0
Other	0	0.0
Unknown	0	0.0
	0	0.0

	Delivery Problems	
Cause	Number	Percent
Spill	0	0.0
Overfill	1	50.0
Physical / Mechanical Damage	0	0.0
Corrosion	0	0.0
Installation Problems	0	0.0
Other	1	50.0
Unknown	0	0.0
	2	100.0

	Other	
Cause	Number	Percent
Spill	1	14.3
Overfill	1	14.3
Physical / Mechanical Damage	0	0.0
Corrosion	0	0.0
Installation Problems	0	0.0
Other	1	14.3
Unknown	4	57.1
	7	100.0