

# FEDERAL ENERGY ACT REPORT

Reporting Period: October 1, 2014 to September 30, 2015

SOURCE	NUMBER	PERCENT
TANKS	60	64%
PIPING	7	7%
DISPENSERS	12	13%
SUBMERSIBLE PUMPS	1	1%
DELIVERY PROBLEMS	4	4%
OTHER	10	11%
	94	100%

	TANKS	
CAUSE	NUMBER	PERCENT
SPILL	0	0.0%
OVERFILL	1	1.7%
PHYSICAL/ MECHANICAL DAMAGE	1	1.7%
CORROSION	32	53.3%
INSTALLATION PROBLEMS	0	0.0%
OTHER	0	0.0%
UNKNOWN	26	43.3%
	60	100.0%

	PIPING	
NUMBER	PERCENT	
0	0.0%	
0	0.0%	
3	42.9%	
3	42.9%	
0	0.0%	
0	0.0%	
0	0.0%	
1	14.3%	
7	100.0%	

	DISPENSERS	
NUMBER	PERCENT	
0	0.0%	
4	33.3%	
2	16.7%	
	0.0%	
0	0.0%	
1	8.3%	
5	41.7%	
12	100.0%	

	SUBMERSIBLE PUMPS	
CAUSE	NUMBER	PERCENT
SPILL	0	0.0%
OVERFILL	0	0.0%
PHYSICAL/ MECHANICAL DAMAGE	1	100.0%
CORROSION	0	0.0%
INSTALLATION PROBLEMS	0	0.0%
OTHER	0	0.0%
UNKNOWN		0.0%
	1	100.0%

	DELIVERY PROBLEMS	
NUMBER	PERCENT	
0	0.0%	
3	75.0%	
1	25.0%	
0	0.0%	
0	0.0%	
0	0.0%	
0	0.0%	
4	100.0%	

	OTHER	
NUMBER	PERCENT	
1	10.0%	
	0.0%	
	0.0%	
0	0.0%	
0	0.0%	
0	0.0%	
9	90.0%	
10	100.0%	