

FEDERAL ENERGY ACT REPORT

Reporting Period: October 1, 2016 to September 30, 2017

Source	Number	Percent
Tanks	42	57.5
Piping	10	13.7
Dispensers	12	16.4
Submersible Pumps	1	1.4
Delivery Problems	1	1.4
Other	7	9.6
	73	100%

	Tanks	
Cause	Number	Percent
Spill	0	0
Overfill	3	7.1
Physical/Mechanical Damage	2	4.8
Corrosion	14	33.3
Installation Problems	0	0
Other	0	0
Unknown	23	54.8
	42	100%

	Piping	
Cause	Number	Percent
Spill	0	0
Overfill	0	0
Physical/Mechanical Damage	3	30
Corrosion	2	20
Installation Problems	0	0
Other	0	0
Unknown	5	50
	10	100%

	Dispensers	
Cause	Number	Percent
Spill	4	33.3
Overfill	0	0
Physical/Mechanical Damage	2	16.7
Corrosion	0	0
Installation Problems	0	0
Other	0	0
Unknown	6	50
	12	100%

	Submersible Pumps	
Cause	Number	Percent
Spill	0	0
Overfill	0	0
Physical/Mechanical Damage	1	100
Corrosion	0	0
Installation Problems	0	0
Other	0	0
Unknown	0	0
	1	100%

	Delivery Problems	
Cause	Number	Percent
Spill	1	100
Overfill	0	0
Physical/Mechanical Damage	0	0
Corrosion	0	0
Installation Problems	0	0
Other	0	0
Unknown	0	0
	1	100%

	Other	
Cause	Number	Percent
Spill	1	14.3
Overfill	0	0
Physical/Mechanical Damage	0	0
Corrosion	0	0
Installation Problems	0	0
Other	1	14.3
Unknown	5	71.4
	7	100%