

Industrial Facilities			Total Phosphorus (TP)					Total Suspended Solids (TSS)						
Facility Name	Permit No.	Baseline Flow (MGD)	TMDL TP WLA (lbs per year)	TP Month Limit (lbs/day)	TP 6-mo Limit (lbs/day)	TP Equivalent Monthly Concentration - Baseline flow (mg/L)	TP Equivalent 6-Month Concentration - Baseline flow (mg/L)	TMDL TSS WLA (lbs per year)	TSS Limit Mo avg (lbs/day)	TSS Limit weekly avg (lbs/day)	TSS Limit daily max (lbs/day)	TSS Equivalent Monthly Concentration (mg/L)	TSS Equivalent weekly Concentration (mg/L)	TSS Equivalent Daily Concentration (mg/L)
AGROPUR INC. - LUXEMBURG	0050237	0.6789	211	2.094	0.698	0.370	0.123	41387	180		352	32		62
BAKER CHEESE FACTORY INC.	0050521	0.2482	295	1.186		0.573		10932	44		93	21		45
BELGIOIOSO CHEESE, INC. - DENMARK	0051128	0.4755	209	2.005	0.668	0.506	0.169	23332	94		199	24		50
BEMIS MANUFACTURING COMPANY - PLANT D	0027456	0.4583	63	0.677	0.226	0.177	0.059	7603	40		65	10		17
BRIESS MALT & INGREDIENTS CO	0066257	0.9916	107	1.141	0.380	0.138	0.046	29122	151		248	18		30
CEDAR VALLEY CHEESE, INC	0051535	0.0864	9	0.096	0.032	0.133	0.044	1433	7		12	10		17
JOHNSONVILLE LLC	0001759	0.0030	0.419	0.00417	0.00139	0.169	0.056	32	0.14		0.27	6		11
JOHNSONVILLE LLC	0001759	0.5077	247	2.637	0.879	0.623	0.208	8424	44		72	10		17
KOHLER COMPANY POWER SYSTEMS AMERICAS	0000795	0.0293	50	0.260		1.061		487	3		4	10		17
LAKESIDE FOODS, INC. - BELGIUM PLANT	0000817	0.0825	99	0.513		0.746		1369	7		12	10		17
NEW ORGANIC DIGESTION LLC	0044938	0.0007	0.195	0.002	0.001	0.355	0.118	9	0		0	8		13
NEWTON MEATS AND SAUSAGE	0042650	0.0006	0.073	0.00077	0.00026	0.145	0.048	5	0		0	5		7
PLASTICS ENGINEERING COMPANY	0066681	0.0139	10	0.104	0.035	0.898	0.299	231	1		2	10		17
POLY VINYL COMPANY INC	0066699	0.0665	56	0.599	0.200	1.080	0.360	1104	6		9	10		17
SARTORI COMPANY-WEST MAIN BUILDING	0041904	0.1425	98	1.043	0.348	0.878	0.293	2364	12		20	10		17
TILLAMOOK WISCONSIN LLC	0027618	0.2240	123	1.179	0.393	0.631	0.210	4458	18		38	10		20
WISCONSIN POWER AND LIGHT EDGEWATER GEN. STATION*	0001589	0.0008	0.032					3						

\*Intermittent discharge--limit in permit anticipated to be expressed as an annual wasteload allocation

Municipal Facilities			Total Phosphorus (TP)					Total Suspended Solids (TSS)						
Facility Name	Permit No.	Baseline Flow (MGD)	TMDL TP WLA (lbs per year)	TP Month Limit (lbs/day)	TP 6-mo Limit (lbs/day)	TP Equivalent Monthly Concentration - Baseline flow (mg/L)	TP Equivalent 6-Month Concentration -Baseline flow (mg/L)	TMDL TSS WLA (lbs per year)	TSS Limit Mo avg (lbs/day)	TSS Limit weekly avg (lbs/day)	TSS Limit daily max (lbs/day)	TSS Equivalent Monthly Concentration (mg/L)	TSS Equivalent weekly Concentration (mg/L)	TSS Equivalent Daily Concentration (mg/L)
ALGOMA WASTEWATER TREATMENT FACILITY	0020745	1.0000	3,048	12.268		1.471		16591	67	94		8	11	
BELGIUM WASTEWATER TREATMENT FACILITY	0023353	0.6300	753	3.031		0.577		10453	42	59		8	11	
BRILLION WASTEWATER TREATMENT FACILITY	0020443	0.7080	1,081	5.624		0.952		11747	51	76		9	13	
CASCO WASTEWATER TREATMENT FACILITY	0023566	0.1790	546	2.196		1.471		2970	12	17		8	11	
CEDAR GROVE WASTEWATER TRTMNT FACIL	0020711	0.4000	157	1.678	0.559	0.503	0.168	6637	29	43		9	13	
CHILTON WASTEWATER TREATMENT FACILITY	0022799	1.1890	517	4.965	1.655	0.501	0.167	19727	79	112		8	11	
CLARKS MILLS SANITARY DISTRICT	0036030	0.0180	10	0.105	0.035	0.699	0.233	973	5	8		34	55	
DENMARK WASTEWATER TREATMENT FACILITY	0021741	0.7250	436	4.334	1.445	0.717	0.239	35573	143	202		24	33	
FORESTVILLE WASTEWATER TREATMENT FACILITY	0028894	0.1194	364	1.893		1.901		10916	57	93		57	93	
GIBBSVILLE SANITARY DISTRICT	0031577	0.0658	62	0.323		0.589		2562	13	22		24	40	
HILBERT WASTEWATER TREATMENT FACILITY	0021270	0.3260	218	2.171	0.724	0.798	0.266	5409	24	35		9	13	
HOLY FAMILY CONVENT WASTEWATER TREATMENT FAC	0028142	0.0420	52	0.272		0.777		697	4	6		10	17	
HOWARDS GROVE WASTEWATER TRTMT FAC	0021679	0.4467	308	2.957	0.986	0.794	0.265	7411	30	42		8	11	
KEWAUNEE WASTEWATER TREATMENT FACILITY	0020176	0.5395	1,273	5.125		1.139		49332	199	280		44	62	
KIEL WASTEWATER TREATMENT FACILITY	0020141	1.4300	4,359	22.674		1.901		23726	103	154		9	13	
KOSSUTH SANITARY DISTRICT NO. 2 WWTF	0035874	0.0406	56	0.290		0.858		1990	10	17		31	50	
LAKELAND UNIVERSITY	0029335	0.0830	40	0.431	0.144	0.623	0.208	7073	31	46		44	66	
MARIBEL WASTEWATER TREATMENT FACILITY	0061051	0.0480	71	0.371		0.927		2355	12	20		31	50	
MORRISON SANITARY DISTRICT NO 1	0036773	0.0522	74	0.323		0.743		866	4	6		9	13	
MOUNT CALVARY WASTEWATER TREATMENT FACILITY	0035963	0.1952	93	0.990	0.330	0.608	0.203	11089	48	72		30	44	
NEW HOLSTEIN WASTEWATER TREATMENT FACILITY	0020893	1.3300	1002	9.627	3.209	0.868	0.138	22067	89	125		8	11	
ONION RIVER WASTEWATER COMMISSION	0036811	0.1577	42	0.448	0.149	0.341	0.114	6137	25	35		19	26	
OOSTBURG WASTEWATER TREATMENT PLANT	0022233	0.4400	198	2.117	0.706	0.577	0.192	26824	108	152		29	41	
PLYMOUTH UTILITIES WWTF	0030031	1.9332	1,325	12.738	4.246	0.790	0.263	32074	119	156		7	10	
POTTER WASTEWATER TREATMENT FACILITY	0029025	0.0442	66	0.342		0.929		733	4	6		10	17	
REEDSVILLE WASTEWATER TREATMENT FACILITY	0021342	0.3073	180	1.927	0.642	0.752	0.251	5099	22	33		9	13	
ROCKLAND SD1 WASTEWATER TREATMENT FACILITY	0022802	0.0250	15	0.157	0.052	0.752	0.251	1351	7	12		34	55	
ST CLOUD VILLAGE UTILITY COMMISSION	0026867	0.1700	82	0.879	0.293	0.620	0.207	4604	24	39		17	28	
ST NAZIANZ WASTEWATER TREATMENT FACILITY	0022195	0.2000	258	1.341		0.804		3318	14	22		9	13	
VALDERS WASTEWATER TREATMENT FACILITY	0021831	0.2777	168	1.791	0.597	0.773	0.258	4608	20	30		9	13	
WALDO WASTEWATER UTILITY	0022471	0.1000	48	0.510	0.170	0.612	0.204	3892	17	25		20	30	
WHITELAW WASTEWATER TREATMENT FACILITY	0022047	0.1323	157	0.818		0.741		2196	10	14		9	13	