

**Well Construction Report
WISCONSIN UNIQUE WELL NUMBER**
AJ514
**Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707**

Form 3300-077A

Property Owner		Phone # (608)339-4222	
Mailing Address		PO BOX 187	
City		FRIENDSHIP	State WI Zip Code 53934
County	Co. Permit #	Notification #	Completed 12-02-1988
Well Constructor (Business Name) TERRY FARAGO		Lic. # 41	Facility ID # (Public Wells)
Address N6079 8TH AVE PLAINFIELD WI 54966-9757		Latitude / Longitude in Decimal Degree (DD) °N °W Well Plan Approval #	
Hicap Permanent Well #		Method Code GPS008 or Govt Lot # 13 18 N 5 E Approval Date (mm-dd-yyyy)	
Common Well #		Section Township Range	
3. Well serves # of SHOP Private, potable Heat Exchange ____ # of drillholes		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ?	
		Construction Type Drilled	

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method			8. Geology		
Dia. (in.)	From (ft.)	To (ft.)	Geology Codes	8. Geology Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)
6	Surface	124	Upper Enlarged Drillhole	Lower Open Bedrock	To (ft.)
			Rotary - Mud Circulation <u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ____ in. dia... Dual Rotary Temp. Outer Casing ____ in. dia. Removed? ____ depth ft. (If NO explain on back side)		
			S	SAND	Surface 18
			C	CLAY	18 48
			N S	FINE SAND	48 115
			N	SAND STONE	115 124

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM 589 USS STEEL 19.45#/PER FT TOT. WT. 2353.5#	Surface	121
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	#20 K/PACKER 56 INCH LG	121	124

9. Static Water Level

41 ft. below ground surface

11. Well Is

36 in. above grade

10. Pump Test

Pumping level 80 ft. below surface

Developed ? Yes

Pumping at 22 GP for 2 Hrs.

Disinfected ? Yes

Pumping Method ?

Capped ? Yes

7. Grout or Other Sealing Material

Method

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
TPF		12-29-1988
Drill Rig Operator	Lic or Reg #	Date Signed
TPF		12-29-1988

4a. Potential Contamination Sources			Is the well located in floodplain ? <u>No</u>			
Type	Qualifier	Distance	Type	Qualifier	Distance	
Building Overhang		8	Landfill		1200	

Comment:

Water Quality Text:

Water Quantity Text:

Difficulty Text:

Created On: 09-19-1989 Created by: HFRC LOAD Updated On: 09-19-1989 Updated by: MIGRATION