

WELL DETAIL INFORMATION SHEET

JOB NO. 542


BORING NO. MW-1

DATE 6/07/84

CHIEF R. Leyra

LOCATION Adams County, WI

All depth measurements of well detail assumed to be from ground surface unless otherwise indicated.



- 1 DEPTH TO BOTTOM OF WELL POINT OR SLOTTED PIPE 40.0 FEET.
- 2 DEPTH OF BOTTOM OF SEAL (if installed) 7.0 FEET.
- 3 DEPTH TO TOP OF SEAL (if installed) 2.0 FEET.
- 4 LENGTH OF WELL POINT, PVC WELL SCREEN, OR SLOTTED PIPE 15.0 FEET. (Circle One)
- 5 TOTAL LENGTH OF PIPE 27.0 FEET @ 2 IN. DIAMETER.
- 6 TYPE OF FILTER MATERIAL AROUND WELL POINT OR SLOTTED PIPE Mirafi.
- 7 CONCRETE CAP,  YES  NO (Circle One)
- 8 HEIGHT OF WELL CASING ABOVE GROUND 2.0 FEET.
- 9 PROTECTIVE CASING?  YES  NO (Circle One)  
HEIGHT ABOVE GROUND 2.1'  
LOCKING CAP?  YES  NO (Circle One)
- 10 TYPE OF BACKFILL: Sand

WATER LEVEL CHECKS

\*From top of casing, if protective casing higher, take measurement from top of protective casing.

BORING #	DATE	TIME	DEPTH TO WATER	REMARKS

WELL DETAIL INFORMATION SHEET

WI Unique Well No. DM436  
DNR Well ID No. 002

JOB NO. 1084


BORING NO. MW-1P

DATE 7-15-87

CHIEF L.E.

Adams County Landfill, WI

All depth measurements of well detail assumed to be from ground surface unless otherwise indicated.



WI Unique Well No. DM436

TO BOTTOM OF WELL POINT OR  
ED PIPE 70.0 FEET.

(2) DEPTH OF BOTTOM OF SEAL (if installed) 62.8 FEET.

(3) DEPTH TO TOP OF SEAL (if installed) Ground Surface FEET.

(4) LENGTH OF WELL POINT, PVC WELL SCREEN, OR SLOTTED PIPE 5.0 FEET. (Circle One)

(5) TOTAL LENGTH OF PIPE 66.9 FEET @ 2 IN. DIAMETER.

(6) TYPE OF FILTER MATERIAL AROUND WELL POINT OR SLOTTED PIPE Sand 30.

(7) CONCRETE CAP, YES NO (Circle One)

(8) HEIGHT OF WELL CASING ABOVE GROUND 1.9 FEET.

(9) PROTECTIVE CASING? YES NO (Circle One)  
HEIGHT ABOVE GROUND 2.0'.  
LOCKING CAP? YES NO (Circle One)

(10) TYPE OF BACKFILL: Bentonite Grout

WATER LEVEL CHECKS

\*From top of casing, if protective casing higher, take measurement from top of protective casing.

BORING #	DATE	TIME	DEPTH TO WATER	REMARKS

# MONITORING WELL DEVELOPMENT

WELL NUMBER MW-1P  
WELL DIAMETER 2"  
TOTAL DEPTH 70.0'  
DEPTH TO WATER 23.1'  
AFTER 30.0'

PROJECT Adams Co. Landfill  
PROJECT NO. 1084  
DATE 7-17-87  
DEVELOPED BY L.E.

## DESCRIPTION OF DEVELOPMENT METHOD

Surged and pumped

VOLUME OF WATER REMOVED FROM WELL 40 gallons  
CLARITY OF WATER IN WELL BEFORE DEVELOPMENT Cloudy  
CLARITY OF WATER IN WELL AFTER DEVELOPMENT Cloudy  
VOLUME OF WATER ADDED TO WELL --  
SOURCE OF WATER ADDED TO WELL --  
TIME SPENT FOR DEVELOPMENT 1.5 Hour

### COMMENTS:

WI Unique Well No. DM436  
DNR Well ID No. 002

**WISCONSIN TEST DRILLING INC.**  
SOIL AND FOUNDATION EXPLORATION

101 ALDERSON  
P. O. BOX 89  
SCHOFIELD, WISCONSIN 54476  
(715) 359-7090

WELL DETAIL INFORMATION SHEET

JOB NO. 542


BORING NO. MW-2

DATE 6/6/84

CHIEF R. Levra

Adams County, WI

All depth measurements of well detail assumed to be from ground surface unless otherwise indicated.



1 DEPTH TO BOTTOM OF WELL POINT OR SLOTTED PIPE 36.0 FEET.

2 DEPTH OF BOTTOM OF SEAL (if installed) 7.0 FEET.

3 DEPTH TO TOP OF SEAL (if installed) 2.0 FEET.

4 LENGTH OF WELL POINT, PVC WELL SCREEN, OR SLOTTED PIPE 15.0 FEET. (Circle One)

5 TOTAL LENGTH OF PIPE 23.0 FEET @ 2 IN. DIAMETER.

6 TYPE OF FILTER MATERIAL AROUND WELL POINT OR SLOTTED PIPE Mirafi.

7 CONCRETE CAP,  YES  NO (Circle One)

8 HEIGHT OF WELL CASING ABOVE GROUND 2.0 FEET.

9 PROTECTIVE CASING?  YES  NO (Circle One)  
HEIGHT ABOVE GROUND 2.1'  
LOCKING CAP?  YES  NO (Circle One)

10 TYPE OF BACKFILL: Sand

WATER LEVEL CHECKS

\*From top of casing, if protective casing higher, take measurement from top of protective casing.

BORING #	DATE	TIME	DEPTH TO WATER	REMARKS

WELL DETAIL INFORMATION SHEET

WI Unique Well No. DM438  
DNR Well ID No. 004

JOB NO. 1084


BORING NO. MW-2P

DATE 7-14-87

CHIEF L.E.

LOCATION Adams County Landfill, WI

All depth measurements of well detail assumed to be from ground surface unless otherwise indicated.



- 1 DEPTH TO BOTTOM OF WELL POINT OR SLOTTED PIPE 65.0 FEET.
- 2 DEPTH OF BOTTOM OF SEAL (if installed) 58.0 FEET.
- 3 DEPTH TO TOP OF SEAL (if installed)    FEET.
- 4 LENGTH OF WELL POINT, PVC WELL SCREEN, OR SLOTTED PIPE 5.0 FEET. (Circle One)
- 5 TOTAL LENGTH OF PIPE 61.9 FEET @ 2 IN. DIAMETER.
- 6 TYPE OF FILTER MATERIAL AROUND WELL POINT OR SLOTTED PIPE Sand 30.
- 7 CONCRETE CAP, YES NO (Circle One)
- 8 HEIGHT OF WELL CASING ABOVE GROUND 1.9 FEET.
- 9 PROTECTIVE CASING? YES NO (Circle One)  
HEIGHT ABOVE GROUND 2.0'  
LOCKING CAP?  YES NO (Circle One)
- 10 TYPE OF BACKFILL: Bentonite Grout

WATER LEVEL CHECKS

\*From top of casing, if protective casing higher, take measurement from top of protective casing.

BORING #	DATE	TIME	DEPTH TO WATER	REMARKS
				B-7

# MONITORING WELL DEVELOPMENT

WELL NUMBER MW-2P  
WELL DIAMETER 2"  
TOTAL DEPTH 65.0'  
DEPTH TO WATER 26.5'  
AFTER 26.6'

PROJECT Adams Co. Landfill  
PROJECT NO. 1084  
DATE 7-17-87  
DEVELOPED BY L.E.

## DESCRIPTION OF DEVELOPMENT METHOD

Surged and pumped

VOLUME OF WATER REMOVED FROM WELL 40 Gallons  
CLARITY OF WATER IN WELL BEFORE DEVELOPMENT Muddy  
CLARITY OF WATER IN WELL AFTER DEVELOPMENT Cloudy  
VOLUME OF WATER ADDED TO WELL --  
SOURCE OF WATER ADDED TO WELL --  
TIME SPENT FOR DEVELOPMENT 1 hour

### COMMENTS:

WI Unique Well No. DM438  
DNR Well ID No. 004

**WISCONSIN TEST DRILLING INC.**  
SOIL AND FOUNDATION EXPLORATION  
101 ALDERSON  
P. O. BOX 89  
SCHOFIELD, WISCONSIN 54476  
(715) 359-7090

WELL DETAIL INFORMATION SHEET

WI Unique Well No. DM439  
DNR Well ID No. 005

JOB NO. 542


BORING NO. MW-3

DATE 6/6/84

CHIEF R. Levra

LOCATION Adams County Wisconsin

All depth measurements of well detail assumed to be from ground surface unless otherwise indicated.



- 1 DEPTH TO BOTTOM OF WELL POINT OR SLOTTED PIPE 41.0 FEET.
- 2 DEPTH OF BOTTOM OF SEAL (if installed) 7.0 FEET.
- 3 DEPTH TO TOP OF SEAL (if installed) 5.0 FEET.
- 4 LENGTH OF WELL POINT, PVC WELL SCREEN OR SLOTTED PIPE 15.0 FEET. (Circle One)
- 5 TOTAL LENGTH OF PIPE 28.0 FEET @ 2 IN. DIAMETER.
- 6 TYPE OF FILTER MATERIAL AROUND WELL POINT OR SLOTTED PIPE Mirafi.
- 7 CONCRETE CAP,  YES  NO (Circle One)
- 8 HEIGHT OF WELL CASING ABOVE GROUND 2.0 FEET.
- 9 PROTECTIVE CASING?  YES  NO (Circle One)  
HEIGHT ABOVE GROUND 2.1'  
LOCKING CAP?  YES  NO (Circle One)
- 10 TYPE OF BACKFILL: Sand

WATER LEVEL CHECKS

\*From top of casing, if protective casing higher, take measurement from top of protective casing.

BORING #	DATE	TIME	DEPTH TO WATER	REMARKS

WELL DETAIL INFORMATION SHEET

WI Unique Well No. DM440  
DNR Well ID No. 006

JOB NO. 875

BORING NO. MW-3P

DATE 6-12-86

CHIEF J.W.

Adams County

All depth measurements of well detail assumed to be from ground surface unless otherwise indicated.

1 DEPTH TO BOTTOM OF WELL POINT OR SLOTTED PIPE 70.0 FEET.

2 DEPTH OF BOTTOM OF SEAL (if installed) 62.5 FEET.

3 DEPTH TO TOP OF SEAL (if installed) 58.1 FEET.

4 LENGTH OF WELL POINT, PVC WELL SCREEN, OR SLOTTED PIPE 5.0 FEET. (Circle One)

5 TOTAL LENGTH OF PIPE 65.0 FEET  
2 IN. DIAMETER.

6 TYPE OF FILTER MATERIAL AROUND WELL POINT OR SLOTTED PIPE Flint Sand.

7 CONCRETE CAP,  YES  NO (Circle One)

8 HEIGHT OF WELL CASING ABOVE GROUND 2.0 FEET.

9 PROTECTIVE CASING?  YES  NO (Circle One)  
HEIGHT ABOVE GROUND 2.3'


10 LOCKING CAP?  YES  NO (Circle One)

10 TYPE OF BACKFILL: Bentonite Slurry

WATER LEVEL CHECKS

\*From top of casing, if protective casing higher, take measurement from top of protective casing.

BORING #	DATE	TIME	DEPTH TO WATER	REMARKS



## MONITORING WELL DEVELOPMENT

WELL NUMBER MW-3P  
WELL DIAMETER 2"  
TOTAL DEPTH 76.0'  
DEPTH TO WATER 20.5'  
After Development 65.0'

PROJECT Adams Co. Landfill  
PROJECT NO. 875  
DATE 6-12-86  
DEVELOPED BY C.B.

### DESCRIPTION OF DEVELOPMENT METHOD

Surged 5 minutes, then bailed.

VOLUME OF WATER REMOVED FROM WELL 47 gallons

CLARITY OF WATER IN WELL BEFORE DEVELOPMENT Cloudy

CLARITY OF WATER IN WELL AFTER DEVELOPMENT Cloudy

VOLUME OF WATER ADDED TO WELL --

SOURCE OF WATER ADDED TO WELL --


TIME SPENT FOR DEVELOPMENT 2.5 hours

### COMMENTS:

WI Unique Well No. DM440  
DNR Well ID No. 006

**WISCONSIN TEST DRILLING INC.**  
SOIL AND FOUNDATION EXPLORATION

101 ALDERSON  
P. O. BOX 89  
SCHOFIELD, WISCONSIN 54476  
(715) 359-7090



WELL DETAIL INFORMATION SHEET

WI Unique Well No. DM441  
DNR Well ID No. 007

JOB NO. 875


BORING NO. MW-6

DATE 6-9-86

CHIEF J.W.

LOCATION Adams County

All depth measurements of well detail assumed to be from ground surface unless otherwise indicated.



1 DEPTH TO BOTTOM OF WELL POINT OR SLOTTED PIPE 42.0 FEET.

2 DEPTH OF BOTTOM OF SEAL (if installed) 25.0 FEET.

3 DEPTH TO TOP OF SEAL (if installed) 22.5 FEET.

4 LENGTH OF WELL POINT, PVC WELL SCREEN, OR SLOTTED PIPE 15.0 FEET. (Circle One)

5 TOTAL LENGTH OF PIPE 29.0 FEET  
Ø 2 IN. DIAMETER.

6 TYPE OF FILTER MATERIAL AROUND WELL POINT OR SLOTTED PIPE Flint Sand.

7 CONCRETE CAP,  YES  NO (Circle One)

8 HEIGHT OF WELL CASING ABOVE GROUND 2.0 FEET.

9 PROTECTIVE CASING?  YES  NO (Circle One)  
HEIGHT ABOVE GROUND 2.3'  
LOCKING CAP?  YES  NO (Circle One)

10 TYPE OF BACKFILL: Bentonite Slurry

WATER LEVEL CHECKS

\*From top of casing, if protective casing higher, take measurement from top of protective casing.

BORING #	DATE	TIME	DEPTH TO WATER	REMARKS

# MONITORING WELL DEVELOPMENT

WELL NUMBER MW-6  
WELL DIAMETER 2"  
TOTAL DEPTH 42.0'  
DEPTH TO WATER 30.1'  
After Development: 36.5'

PROJECT Adams Co. Land 11  
PROJECT NO. 875  
DATE 6-12-86  
DEVELOPED BY C.B.

## DESCRIPTION OF DEVELOPMENT METHOD

Surged 5 minutes, then bailed.

VOLUME OF WATER REMOVED FROM WELL 43 gallons  
CLARITY OF WATER IN WELL BEFORE DEVELOPMENT Dirty brown  
CLARITY OF WATER IN WELL AFTER DEVELOPMENT Cloudy  
VOLUME OF WATER ADDED TO WELL --  
SOURCE OF WATER ADDED TO WELL --  
TIME SPENT FOR DEVELOPMENT 1.5 hours

### COMMENTS:

WI Unique Well No. DM441  
DNR Well ID No. 007

**WISCONSIN TEST DRILLING INC.**  
SOIL AND FOUNDATION EXPLORATION

101 ALDERSON  
P. O. BOX 89  
SCHOFIELD, WISCONSIN 54476  
(715) 359-7090



## WELL DETAIL INFORMATION SHEET

WI Unique Well No. DM442  
DNR Well ID No. 008

JOB NO. 875


BORING NO. MW-6P

DATE 6-10-86

CHIEF J.W.

LOCATION Adams County

All depth measurements of well detail assumed to be from ground surface unless otherwise indicated.



- 1 DEPTH TO BOTTOM OF WELL POINT OR SLOTTED PIPE 72.2' FEET.
- 2 DEPTH OF BOTTOM OF SEAL (if installed) 64.0 FEET.
- 3 DEPTH TO TOP OF SEAL (if installed) 60.0 FEET.
- 4 LENGTH OF WELL POINT, PVC WELL SCREEN, OR SLOTTED PIPE 5.0 FEET. (Circle One)
- 5 TOTAL LENGTH OF PIPE 67.0 FEET  
Ø 2 IN. DIAMETER.
- 6 TYPE OF FILTER MATERIAL AROUND WELL POINT OR SLOTTED PIPE Flint Sand.
- 7 CONCRETE CAP.  YES  NO (Circle One)
- 8 HEIGHT OF WELL CASING ABOVE GROUND 2.0 FEET.
- 9 PROTECTIVE CASING?  YES  NO (Circle One)  
HEIGHT ABOVE GROUND 2.3'  
LOCKING CAP?  YES  NO (Circle One)
- 10 TYPE OF BACKFILL: Bentonite Slurry

WATER LEVEL CHECKS

\*From top of casing, if protective casing higher, take measurement from top of protective casing.

BORING #	DATE	TIME	DEPTH TO WATER	REMARKS

## MONITORING WELL DEVELOPMENT

WELL NUMBER MW-6P  
WELL DIAMETER 2"  
TOTAL DEPTH 72.2'  
DEPTH TO WATER 39.0'  
After Development: 46.5'

PROJECT Adams Co. Landfill  
PROJECT NO. 875  
DATE 6-12-86  
DEVELOPED BY C.B.

### DESCRIPTION OF DEVELOPMENT METHOD

Surged 5 minutes, then bailed.

VOLUME OF WATER REMOVED FROM WELL 49 gallons

CLARITY OF WATER IN WELL BEFORE DEVELOPMENT Clear

CLARITY OF WATER IN WELL AFTER DEVELOPMENT Clear

VOLUME OF WATER ADDED TO WELL --

SOURCE OF WATER ADDED TO WELL --

TIME SPENT FOR DEVELOPMENT 2.5 hours

### COMMENTS:

WI Unique Well No. DM442  
DNR Well ID No. 008

**WISCONSIN TEST DRILLING INC.**  
SOIL AND FOUNDATION EXPLORATION

101 ALDERSON  
P. O. BOX 89  
SCHOFIELD, WISCONSIN 54476  
(715) 359-7090



WELL DETAIL INFORMATION SHEET

WI Unique Well No. DM443  
DNR Well ID No. 009

JOB NO. 875

BORING NO. MW-7

DATE 6-10-86

CHIEF T. Kesy

LOCATION Adams County

All depth measurements of well detail assumed to be from ground surface unless otherwise indicated.

1 DEPTH TO BOTTOM OF WELL POINT OR SLOTTED PIPE 33.8 FEET.

2 DEPTH OF BOTTOM OF SEAL (if installed) 23.0 FEET.

3 DEPTH TO TOP OF SEAL (if installed) 19.0 FEET.

4 LENGTH OF WELL POINT, PVC WELL SCREEN, OR SLOTTED PIPE 10.0 FEET. (Circle One)

5 TOTAL LENGTH OF PIPE 25.8 FEET  
Ø 2 IN. DIAMETER.

6 TYPE OF FILTER MATERIAL AROUND WELL POINT OR SLOTTED PIPE Filter Sand.

7 CONCRETE CAP. YES NO (Circle One)

8 HEIGHT OF WELL CASING ABOVE GROUND 2.0 FEET.


9 PROTECTIVE CASING? YES NO (Circle One)  
HEIGHT ABOVE GROUND 2.0  
LOCKING CAP? YES NO (Circle One)

10 TYPE OF BACKFILL: Cuttings & Granular Bentonite

WATER LEVEL CHECKS

\*From top of casing, if protective casing higher, take measurement from top of protective casing.

<u>BORING #</u>	<u>DATE</u>	<u>TIME</u>	<u>DEPTH TO WATER</u>	<u>REMARKS</u>



# MONITORING WELL DEVELOPMENT

WELL NUMBER MW-7  
WELL DIAMETER 2"  
TOTAL DEPTH 33.8'  
DEPTH TO WATER 25.1'  
After Development: 28.2'

PROJECT Adams Co. Landfill  
PROJECT NO. 875  
DATE 6-12-86  
DEVELOPED BY C.B.

## DESCRIPTION OF DEVELOPMENT METHOD

Surged 5 minutes, then bailed

VOLUME OF WATER REMOVED FROM WELL 25 gallons

CLARITY OF WATER IN WELL BEFORE DEVELOPMENT Brown, Dirty

CLARITY OF WATER IN WELL AFTER DEVELOPMENT Cloudy

VOLUME OF WATER ADDED TO WELL --

SOURCE OF WATER ADDED TO WELL --

TIME SPENT FOR DEVELOPMENT 1 hour

## COMMENTS:

WI Unique Well No. DM443  
DNR Well ID No. 009

## WISCONSIN TEST DRILLING INC.

SOIL AND FOUNDATION EXPLORATION

101 ALDERSON  
P. O. BOX 89  
SCHOFIELD, WISCONSIN 54476  
(715) 359-7090



WELL DETAIL INFORMATION SHEET

WI Unique Well No. DM444  
DNR Well ID No. 010

JOB NO. 875

BORING NO. MW-7P

DATE 6-11-86

CHIEF J. Weeks

LOCATION Adams County

All depth measurements of well detail assumed to be from ground surface unless otherwise indicated.

1 DEPTH TO BOTTOM OF WELL POINT OR SLOTTED PIPE 62.7 FEET.

2 DEPTH OF BOTTOM OF SEAL (if installed) 55.2 FEET.

3 DEPTH TO TOP OF SEAL (if installed) 52.7 FEET.

4 LENGTH OF WELL POINT, (PVC WELL SCREEN) OR SLOTTED PIPE 5.0 FEET. (Circle One)

5 TOTAL LENGTH OF PIPE 57.7 FEET  
Ø 2 IN. DIAMETER.

6 TYPE OF FILTER MATERIAL AROUND WELL POINT OR SLOTTED PIPE Flint Sand.

7 CONCRETE CAP,  YES  NO (Circle One)

8 HEIGHT OF WELL CASING ABOVE GROUND 2.0 FEET.


9 PROTECTIVE CASING?  YES  NO (Circle One)  
HEIGHT ABOVE GROUND 2.3  
LOCKING CAP?  YES  NO (Circle One)

10 TYPE OF BACKFILL: Bentonite Slurry

WATER LEVEL CHECKS

\*From top of casing, if protective casing higher, take measurement from top of protective casing.

BORING #	DATE	TIME	DEPTH TO WATER	REMARKS



# MONITORING WELL DEVELOPMENT

WELL NUMBER MW-7P

PROJECT Adams Co. Landfill

WELL DIAMETER 2"

PROJECT NO. 875

TOTAL DEPTH 62.7'

DATE 6-12-86

DEPTH TO WATER 25.2'

DEVELOPED BY C.B.

After Development: 33.1'

## DESCRIPTION OF DEVELOPMENT METHOD

Surged 5 minutes, then bailed

VOLUME OF WATER REMOVED FROM WELL 45 gallons

CLARITY OF WATER IN WELL BEFORE DEVELOPMENT Milky

CLARITY OF WATER IN WELL AFTER DEVELOPMENT Almost Clear

VOLUME OF WATER ADDED TO WELL --

SOURCE OF WATER ADDED TO WELL --

TIME SPENT FOR DEVELOPMENT 2 hours

## COMMENTS:

WI Unique Well No. DM444  
DNR Well ID No. 010

**WISCONSIN TEST DRILLING INC.**  
SOIL AND FOUNDATION EXPLORATION

101 ALDERSON  
P. O. BOX 89  
SCHOFIELD, WISCONSIN 54476  
(715) 359-7090



WELL DETAIL INFORMATION SHEET

WI Unique Well No. DM445  
DNR Well ID No. 011

JOB NO. 875

BORING NO. MW-8

DATE 6-12-86

CHIEF T. Kesy

Adams County

All depth measurements of well detail assumed to be from ground surface unless otherwise indicated.

1 DEPTH TO BOTTOM OF WELL POINT OR SLOTTED PIPE 48.2 FEET.

2 DEPTH OF BOTTOM OF SEAL (if installed) 35.0 FEET.

3 DEPTH TO TOP OF SEAL (if installed) 31.0 FEET.

4 LENGTH OF WELL POINT, PVC WELL SCREEN, OR SLOTTED PIPE 10.0 FEET. (Circle One)

5 TOTAL LENGTH OF PIPE 40.0 FEET  
Ø 2 IN. DIAMETER.

6 TYPE OF FILTER MATERIAL AROUND WELL POINT OR SLOTTED PIPE Filter Sand.

7 CONCRETE CAP, YES NO (Circle One)

8 HEIGHT OF WELL CASING ABOVE GROUND 2.0 FEET.


9 PROTECTIVE CASING?  
HEIGHT ABOVE GROUND 2.0  
LOCKING CAP? YES NO (Circle One)

10 TYPE OF BACKFILL: Cuttings & Granular Bentonite

WATER LEVEL CHECKS

\*From top of casing, if protective casing higher, take measurement from top of protective casing.

BORING #	DATE	TIME	DEPTH TO WATER	REMARKS



## MONITORING WELL DEVELOPMENT

WELL NUMBER MW-8

WELL DIAMETER 2"

TOTAL DEPTH 48.2'

DEPTH TO WATER 39.3'

After Development: 43.0'

PROJECT Adams Co. Landfill

PROJECT NO. 875

DATE 6-12-86

DEVELOPED BY C.B.

### DESCRIPTION OF DEVELOPMENT METHOD

Surged 5 minutes, then bailed.

VOLUME OF WATER REMOVED FROM WELL 25 gallons

CLARITY OF WATER IN WELL BEFORE DEVELOPMENT Dirty

CLARITY OF WATER IN WELL AFTER DEVELOPMENT Cloudy

VOLUME OF WATER ADDED TO WELL --

SOURCE OF WATER ADDED TO WELL --

TIME SPENT FOR DEVELOPMENT 1 hour

### COMMENTS:

WI Unique Well No. DM445  
DNR Well ID No. 011

### WISCONSIN TEST DRILLING INC.

SOIL AND FOUNDATION EXPLORATION

101 ALDERSON  
P. O. BOX 89  
SCHOFIELD, WISCONSIN 54476  
(715) 359-7090



WELL DETAIL INFORMATION SHEET

WI Unique Well No. DM446  
DNR Well ID No. 012

JOB NO. 875


BORING NO. MW-9

DATE 6-10-86

CHIEF T. Kesy

LOCATION Adams County

All depth measurements of well detail assumed to be from ground surface unless otherwise indicated.



1 DEPTH TO BOTTOM OF WELL POINT OR SLOTTED PIPE 28.2 FEET.

2 DEPTH OF BOTTOM OF SEAL (if installed) 6.0 FEET.

3 DEPTH TO TOP OF SEAL (if installed) 2.0 FEET.

4 LENGTH OF WELL POINT, PVC WELL SCREEN, OR SLOTTED PIPE 10.0 FEET. (Circle One)

5 TOTAL LENGTH OF PIPE 2.0 FEET  
Ø 2 IN. DIAMETER.

6 TYPE OF FILTER MATERIAL AROUND WELL POINT OR SLOTTED PIPE Filter Sand.

7 CONCRETE CAP, YES NO (Circle One)

8 HEIGHT OF WELL CASING ABOVE GROUND 2.0 FEET.

9 PROTECTIVE CASING? YES NO (Circle One)  
HEIGHT ABOVE GROUND 2.0 FEET  
LOCKING CAP? YES NO (Circle One)

10 TYPE OF BACKFILL: Cuttings & Granular Bentonite

WATER LEVEL CHECKS

\*From top of casing, if protective casing higher, take measurement from top of protective casing.

BORING #	DATE	TIME	DEPTH TO WATER	REMARKS

## MONITORING WELL DEVELOPMENT

WELL NUMBER MW-9  
WELL DIAMETER 2"  
TOTAL DEPTH 28.2'  
DEPTH TO WATER 20.6'  
After Development: 28.0'

PROJECT Adams Co. Landfill  
PROJECT NO. 875  
DATE 6-12-86  
DEVELOPED BY C.B.

### DESCRIPTION OF DEVELOPMENT METHOD

Surged 5 minutes, then bailed.

VOLUME OF WATER REMOVED FROM WELL 23 gallons

CLARITY OF WATER IN WELL BEFORE DEVELOPMENT Dirty

CLARITY OF WATER IN WELL AFTER DEVELOPMENT Cloudy

VOLUME OF WATER ADDED TO WELL ---

SOURCE OF WATER ADDED TO WELL ---

TIME SPENT FOR DEVELOPMENT 1 hour

#### COMMENTS:

WI Unique Well No. DM446  
DNR Well ID No. 012

#### WISCONSIN TEST DRILLING INC.

SOIL AND FOUNDATION EXPLORATION

101 ALDERSON  
P. O. BOX 89  
SCHOFIELD, WISCONSIN 54476  
(715) 359-7090



WELL DETAIL INFORMATION SHEET

WI Unique Well No. DM447  
DNR Well ID No. 013

JOB NO. 907


BORING NO. MW-16

DATE 8-12-86

CHIEF \_\_\_\_\_ T.K.

Adams County - Jensen Property

All depth measurements of well detail assumed to be from ground surface unless otherwise indicated.



### WATER LEVEL CHECKS

\*From top of casing, if protective casing higher, take measurement from top of protective casing.

BORING #	DATE	TIME	DEPTH TO WATER	REMARKS

MONITORINGDEVELOPMENT

WELL NUMBER MW-16  
WELL DIAMETER 2"  
TOTAL DEPTH 30.20  
DEPTH TO WATER 21.04

PROJECT Adams County  
PROJECT NO. 86A22  
DATE 8/15/86  
DEVELOPED BY M.J.H.

DESCRIPTION OF DEVELOPMENT METHOD

Surged bailer up and down repeatedly 10-15 times for every 5 bails removed.  
5 volumes removed

VOLUME OF WATER REMOVED FROM WELL 10 gallons

CLARITY OF WATER IN WELL BEFORE DEVELOPMENT clear

CLARITY OF WATER IN WELL AFTER DEVELOPMENT Lt. Br. Mod. Turbidity

VOLUME OF WATER ADDED TO WELL -

SOURCE OF WATER ADDED TO WELL -

TIME SPENT FOR DEVELOPMENT 45 minutes

COMMENTS: Well recovers at approximately 1'/min.

If bailed fast will go dry temporarily

WI Unique Well No. DM447  
DNR Well ID No. 013

**Foth & Van Dyke**  
Waste/Energy Division

WELL DETAIL INFORMATION SHEET

WI Unique Well No. DM448  
DNR Well ID No. 014

JOB NO. 907

BORING NO. MW-17

DATE 8-11-86

CHIEF T.K.

Adams County - Jensen Property

All depth measurements of well detail assumed to be from ground surface unless otherwise indicated.

1 DEPTH TO BOTTOM OF WELL POINT OR SLOTTED PIPE 49.0' FEET.

2 DEPTH OF BOTTOM OF SEAL (if installed) 32.0 FEET.

3 DEPTH TO TOP OF SEAL (if installed) 28.5' FEET.

4 LENGTH OF WELL POINT, PVC WELL SCREEN, OR SLOTTED PIPE 10.0 FEET. (Circle One)

5 TOTAL LENGTH OF PIPE 41.0 FEET  
Ø 2 IN. DIAMETER.

6 TYPE OF FILTER MATERIAL AROUND WELL POINT OR SLOTTED PIPE Flint Sand (45-55)

7 CONCRETE CAP,  YES  NO (Circle One)

8 HEIGHT OF WELL CASING ABOVE GROUND 2.0 FEET.


9 PROTECTIVE CASING?  YES  NO (Circle One)  
HEIGHT ABOVE GROUND 2.1  
LOCKING CAP?  YES  NO (Circle One)

10 TYPE OF BACKFILL: Sand - Bentonite

WATER LEVEL CHECKS

\*From top of casing, if protective casing higher, take measurement from top of protective casing.

BORING #	DATE	TIME	DEPTH TO WATER	REMARKS
	8-12-86	7:30 a.m.	37'8"	



# MONITORING WELL DEVELOPMENT

WELL NUMBER MW-17

PROJECT Adams county

WELL DIAMETER 2"

PROJECT NO. 86A22

TOTAL DEPTH 52.05

DATE 8/15/86

DEPTH TO WATER 38.9

DEVELOPED BY M.J.H.

## DESCRIPTION OF DEVELOPMENT METHOD

Surged bailer up and down repeatedly 10-15 times for every 5 bails removed.

5 volumes removed

VOLUME OF WATER REMOVED FROM WELL 12 gallons

CLARITY OF WATER IN WELL BEFORE DEVELOPMENT clear

CLARITY OF WATER IN WELL AFTER DEVELOPMENT Lt. Br. Mod. Turbidity

VOLUME OF WATER ADDED TO WELL -

SOURCE OF WATER ADDED TO WELL -

TIME SPENT FOR DEVELOPMENT 1 hour

## COMMENTS:

Well recovers at approximately 1'/30 seconds

WI Unique Well No. DM448  
DNR Well ID No. 014

**Foth & Van Dyke**

Waste/Energy Division

WELL DETAIL INFORMATION SHEET

WI Unique Well No. DM449  
DNR Well ID No. 015

JOB NO. 1084


BORING NO. MW-17P

DATE 7-14-87

CHIEF L.E.

Adams County Landfill, WI

All depth measurements of well detail assumed to be from ground surface unless otherwise indicated.



1 DEPTH TO BOTTOM OF WELL POINT OR SLOTTED PIPE 80.5 FEET.

2 DEPTH OF BOTTOM OF SEAL (if installed) 73.0 FEET.

3 DEPTH TO TOP OF SEAL (if installed) FEET.

4 LENGTH OF WELL POINT, PVC WELL SCREEN OR SLOTTED PIPE 5.0 FEET. (Circle One)

5 TOTAL LENGTH OF PIPE 77.4 FEET  
@ 2 IN. DIAMETER.

6 TYPE OF FILTER MATERIAL AROUND WELL POINT OR SLOTTED PIPE Sand 30

7 CONCRETE CAP, YES NO (Circle One)

8 HEIGHT OF WELL CASING ABOVE GROUND 1.9 FEET.

9 PROTECTIVE CASING? YES NO (Circle One)  
HEIGHT ABOVE GROUND 2.0'  
LOCKING CAP? YES NO (Circle One)

10 TYPE OF BACKFILL: Bentonite Grout

WATER LEVEL CHECKS

\*From top of casing, if protective casing higher, take measurement from top of protective casing.

BORING #	DATE	TIME	DEPTH TO WATER	REMARKS

# MONITORING WELL DEVELOPMENT

WELL NUMBER MW-17P  
WELL DIAMETER 2"  
TOTAL DEPTH 80.5'  
DEPTH TO WATER 44.8'  
AFTER 45.0'

PROJECT Adams Co. Landfill  
PROJECT NO. 1084  
DATE 7-16-87  
DEVELOPED BY L.E.

## DESCRIPTION OF DEVELOPMENT METHOD

Surged and pumped with black pipe

VOLUME OF WATER REMOVED FROM WELL 40 gallons  
CLARITY OF WATER IN WELL BEFORE DEVELOPMENT Muddy  
CLARITY OF WATER IN WELL AFTER DEVELOPMENT Cloudy  
VOLUME OF WATER ADDED TO WELL --  
SOURCE OF WATER ADDED TO WELL --  
TIME SPENT FOR DEVELOPMENT 1.5 Hour

### COMMENTS:

WI Unique Well No. DM449  
DNR Well ID No. 015

**WISCONSIN TEST DRILLING INC.**  
SOIL AND FOUNDATION EXPLORATION  
101 ALDERSON  
P. O. BOX 89  
SCHOFIELD, WISCONSIN 54476  
(715) 359-7090

## WELL DETAIL INFORMATION SHEET

WI Unique Well No. DM450  
DNR Well ID No. 016

JOB NO. 907


BORING NO. MW-18

DATE 8-12-86

CHIEF T.K.

LOCATION Adams County - Jensen Property

All depth measurements of well detail assumed to be from ground surface unless otherwise indicated.



(1) DEPTH TO BOTTOM OF WELL POINT OR SLOTTED PIPE 31.5' FEET.

(2) DEPTH OF BOTTOM OF SEAL (if installed) 16.0' FEET.

(3) DEPTH TO TOP OF SEAL (if installed) 12.5' FEET.

(4) LENGTH OF WELL POINT, PVC WELL SCREEN, OR SLOTTED PIPE 10.0' FEET. (Circle One)

(5) TOTAL LENGTH OF PIPE 23.5' FEET  
Ø 2 IN. DIAMETER.

(6) TYPE OF FILTER MATERIAL AROUND WELL POINT OR SLOTTED PIPE Flint Sand (45-50)

(7) CONCRETE CAP,  YES  NO (Circle One)

(8) HEIGHT OF WELL CASING ABOVE GROUND 2.0 FEET.

(9) PROTECTIVE CASING?  YES  NO (Circle One)  
HEIGHT ABOVE GROUND 2.1  
LOCKING CAP?  YES  NO (Circle One)

(10) TYPE OF BACKFILL: Bentonite Powder &amp; Sand

## WATER LEVEL CHECKS

\*From top of casing, if protective casing higher, take measurement from top of protective casing.

BORING #	DATE	TIME	DEPTH TO WATER	REMARKS
	8-12-86		23'8"	

## MONITORING WELL DEVELOPMENT

WELL NUMBER MW-18  
WELL DIAMETER 2"  
TOTAL DEPTH 32.25  
DEPTH TO WATER 24.50

PROJECT Adams county  
PROJECT NO. 86A22  
DATE 8/15/86  
DEVELOPED BY M.J.H.

### DESCRIPTION OF DEVELOPMENT METHOD

Surged bailer up and down repeatedly 10-15 times for every 5 bails removed  
5 volumes removed

VOLUME OF WATER REMOVED FROM WELL 10 gallons

CLARITY OF WATER IN WELL BEFORE DEVELOPMENT clear

CLARITY OF WATER IN WELL AFTER DEVELOPMENT Lt. Br. Mod Turbidity

VOLUME OF WATER ADDED TO WELL -

SOURCE OF WATER ADDED TO WELL -

TIME SPENT FOR DEVELOPMENT 45 minutes

### COMMENTS:

Well recovers at approximately 1'/min. If bailed fast will go dry temporarily.

WI Unique Well No. DM450  
DNR Well ID No. 016

**Foth & Van Dyke**  
Waste/Energy Division

WELL DETAIL INFORMATION SHEET

WI Unique Well No. DM451  
DNR Well ID No. 017

JOB NO. 907


BORING NO. MW-18P

DATE 8-13-86

CHIEF T.K.

Adams County - Jensen Property

All depth measurements of well detail assumed to be from ground surface unless otherwise indicated.



- 1 DEPTH TO BOTTOM OF WELL POINT OR SLOTTED PIPE 62.0' FEET.
- 2 DEPTH OF BOTTOM OF SEAL (if installed) 55.5 FEET.
- 3 DEPTH TO TOP OF SEAL (if installed) 45.0' FEET.
- 4 LENGTH OF WELL POINT, PVC WELL SCREEN, OR SLOTTED PIPE 5.0 FEET. (Circle One)
- 5 TOTAL LENGTH OF PIPE 59.0 FEET  
0 2 IN. DIAMETER.
- 6 TYPE OF FILTER MATERIAL AROUND WELL POINT OR SLOTTED PIPE Flintsand (45-50)
- 7 CONCRETE CAP,  YES  NO (Circle One)
- 8 HEIGHT OF WELL CASING ABOVE GROUND 2 FEET.
- 9 PROTECTIVE CASING?  YES  NO (Circle One)  
HEIGHT ABOVE GROUND 2.2  
LOCKING CAP?  YES  NO (Circle One)
- 10 TYPE OF BACKFILL: Bentonite Slurry

WATER LEVEL CHECKS

\*From top of casing, if protective casing higher, take measurement from top of protective casing.

<u>BORING #</u>	<u>DATE</u>	<u>TIME</u>	<u>DEPTH TO WATER</u>	<u>REMARKS</u>

## MONITORING & WELL DEVELOPMENT

WELL NUMBER MW-18P  
WELL DIAMETER 2"  
TOTAL DEPTH 64.50  
DEPTH TO WATER 30.65

PROJECT Adams County  
PROJECT NO. 86A22  
DATE 8/15/86  
DEVELOPED BY M.J.H.

### DESCRIPTION OF DEVELOPMENT METHOD

Surged bailer up and down repeatedly 10-15 times for every 5 bails removed.

5 volumes removed

VOLUME OF WATER REMOVED FROM WELL 25 gallons

CLARITY OF WATER IN WELL BEFORE DEVELOPMENT clear

CLARITY OF WATER IN WELL AFTER DEVELOPMENT Lt. Br. High Turbidity

VOLUME OF WATER ADDED TO WELL -

SOURCE OF WATER ADDED TO WELL -

TIME SPENT FOR DEVELOPMENT 2 hours 15 minutes

### COMMENTS:

Well recovers fast - approximately 1'/min.

WI Unique Well No. DM451  
DNR Well ID No. 017

**Foth & Van Dyke**  
Waste/Energy Division

## WELL DETAIL INFORMATION SHEET

WI Unique Well No. DM452  
DNR Well ID No. 018

JOB NO. 1084


BORING NO. MW-19

DATE 7-15-87

CHIEF L.E.

LOCATION Adams County Landfill, WI

All depth measurements of well detail assumed to be from ground surface unless otherwise indicated.



1 DEPTH TO BOTTOM OF WELL POINT OR  
 SLOTTED PIPE 30.0 FEET.  
 2 DEPTH OF BOTTOM OF SEAL (if installed)  
 11.5 FEET.  
 3 DEPTH TO TOP OF SEAL (if installed)  
 10.0 FEET.  
 4 LENGTH OF WELL POINT, PVC WELL SCREEN  
 OR SLOTTED PIPE 10.0 FEET. (Circle One)  
 5 TOTAL LENGTH OF PIPE 21.9 FEET  
 @ 2 IN. DIAMETER.  
 6 TYPE OF FILTER MATERIAL AROUND WELL  
 POINT OR SLOTTED PIPE Sand 30.  
 7 CONCRETE CAP, YES NO (Circle One)  
 8 HEIGHT OF WELL CASING ABOVE GROUND  
 1.9 FEET.  
 9 PROTECTIVE CASING?  
 HEIGHT ABOVE GROUND YES NO (Circle One)  
 LOCKING CAP? YES NO (Circle One)  
 10 TYPE OF BACKFILL: Bentonite & Cuttings

## WATER LEVEL CHECKS

\*From top of casing, if protective casing higher, take measurement from top of protective casing.

BORING #	DATE	TIME	DEPTH TO WATER	REMARKS

## MONITORING WELL DEVELOPMENT

WELL NUMBER MW-19  
WELL DIAMETER 2"  
TOTAL DEPTH 30.0'  
DEPTH TO WATER 22.5'  
AFTER Dry

PROJECT Adams Co. Landfill  
PROJECT NO. 1084  
DATE 7-17-87  
DEVELOPED BY L.E.

### DESCRIPTION OF DEVELOPMENT METHOD

Surged and pumped

Only 2 gallons of water in well.

VOLUME OF WATER REMOVED FROM WELL 2 gallons  
CLARITY OF WATER IN WELL BEFORE DEVELOPMENT Muddy  
CLARITY OF WATER IN WELL AFTER DEVELOPMENT --  
VOLUME OF WATER ADDED TO WELL --  
SOURCE OF WATER ADDED TO WELL --  
TIME SPENT FOR DEVELOPMENT 1/2 Hour

### COMMENTS:

WI Unique Well No. DM452  
DNR Well ID No. 018

WISCONSIN TEST DRILLING INC.  
SOIL AND FOUNDATION EXPLORATION  
101 ALDERSON  
P. O. BOX 89  
SCHOFIELD, WISCONSIN 54476  
(715) 369-7090

WELL DETAIL INFORMATION SHEET

WI Unique Well No. DM453  
DNR Well ID No. 019

JOB NO. 1084


BORING NO. MW-19P

DATE 7-15-87

CHIEF L.E.

Adams County Landfill, WI

All depth measurements of well detail assumed to be from ground surface unless otherwise indicated.



1 DEPTH TO BOTTOM OF WELL POINT OR SLOTTED PIPE 60.2 FEET.

2 DEPTH OF BOTTOM OF SEAL (if installed) 51.9 FEET.

3 DEPTH TO TOP OF SEAL (if installed) Ground Surface FEET.

4 LENGTH OF WELL POINT, PVC WELL SCREEN OR SLOTTED PIPE 5.0 FEET. (Circle One)

5 TOTAL LENGTH OF PIPE 57.1 FEET  
Ø 2 IN. DIAMETER.

6 TYPE OF FILTER MATERIAL AROUND WELL POINT OR SLOTTED PIPE Sand 30.

7 CONCRETE CAP, YES NO (Circle One)

8 HEIGHT OF WELL CASING ABOVE GROUND 1.9 FEET.

9 PROTECTIVE CASING? YES NO (Circle One)  
HEIGHT ABOVE GROUND 2.0'.  
LOCKING CAP? YES NO (Circle One)

10 TYPE OF BACKFILL: Bentonite Grout

WATER LEVEL CHECKS

\*From top of casing, if protective casing higher, take measurement from top of protective casing.

BORING #	DATE	TIME	DEPTH TO WATER	REMARKS

# MONITORING WELL DEVELOPMENT

WELL NUMBER MW-19P  
WELL DIAMETER 2"  
TOTAL DEPTH 60.2'  
DEPTH TO WATER 28.8'  
AFTER 28.7'

PROJECT Adams Co. Landfill  
PROJECT NO. 1084  
DATE 7-17-87  
DEVELOPED BY L.E.

## DESCRIPTION OF DEVELOPMENT METHOD

Surged and pumped

VOLUME OF WATER REMOVED FROM WELL 40 Gallons  
CLARITY OF WATER IN WELL BEFORE DEVELOPMENT Muddy  
CLARITY OF WATER IN WELL AFTER DEVELOPMENT Cloudy  
VOLUME OF WATER ADDED TO WELL --  
SOURCE OF WATER ADDED TO WELL --  
TIME SPENT FOR DEVELOPMENT 1 hour

### COMMENTS:

WI Unique Well No. DM453  
DNR Well ID No. 019

WISCONSIN TEST DRILLING INC.  
SOIL AND FOUNDATION EXPLORATION

101 ALDERSON  
P. O. BOX 89  
SCHOFIELD, WISCONSIN 54476  
(715) 359-7090

## MONITORING WELL CONSTRUCTION DIAGRAM

Driller: Wisconsin Test Drilling


Well No.: MW-20

Drilling Method: 4 1/4" I.D. H.S.A.

Date Installed: 2/23/89

Coordinates: 114+55N 105+80E

WI Unique Well No.: EI302  
WDNR Well ID. No.: 040



**Protector Pipe:**

Size: 4" I.D.  
Material: Steel  
Lock No.: 2121

**Riser:**

Diameter: 2" I.D.  
Material: PVC  
Sch.: 40  
Type of Joints: Flush Threaded  
Stenciled? --

**Screen:**

Diameter: 2" I.D.  
Material: PVC  
Slot Size: 0.010"  
Length: 10'

**Sump:**

Length:

Type of Cap: PVC Point

Centralizer: Used   
Not Used

Depth to Water From Top of Riser at Completion: 34.95'

NOTE: Not to Scale



## MONITORING WELL CONSTRUCTION DIAGRAM

Driller: Wisconsin Test Drilling

Well No: MW-21

Drilling Method: 4 1/4" I.D. H.S.A.

Date Installed: 2/23/89

Coordinates: 116+00N 105+70E


WDNR Well ID. No.: 041; WI Unique Well No.: EI303

**Protector Pipe:**

Size: 4" I.D.

Material: Steel


Lock No.: 2121





# MONITORING WELL CONSTRUCTION DIAGRAM


Driller: Wisconsin Test Drilling Well No: MW-22  
Drilling Method: 4 1/4" I.D. H.S.A. Date Installed: 2/24/89  
Coordinates: 116+50N 104+15E WDNR Well ID. No.: 042; WI Unique Well No.: E1304





Facility/Project Name <b>ADAMS Co. COMPOST</b>	Local Grid Location of Well ft. <input type="checkbox"/> N. <input type="checkbox"/> S. ft. <input type="checkbox"/> E. <input type="checkbox"/> W.	Well Name <b>ME-25</b>
Facility License, Permit or Monitoring Number	Grid Origin Location Lat. _____ Long. _____ or St. Plane 790, 369.6 ft. N, 2,041,566.6 ft. E.	Wis. Unique Well Number <b>GN076</b> DNR Well Number <b>045</b>
Type of Well Water Table Observation Well <input checked="" type="checkbox"/> 11 Piezometer <input type="checkbox"/> 12	Section Location of Waste/Source NE 1/4 of SE 1/4 of Sec. 13, T. 1 S. N. R. 5 E.	Date Well Installed <b>09/14/90</b>
Distance Well Is From Waste/Source Boundary ft.	Location of Well Relative to Waste/Source u <input type="checkbox"/> Upgradient s <input type="checkbox"/> Sidegradient d <input type="checkbox"/> Downgradient n <input type="checkbox"/> Not Known	Well Installed By: (Person's Name and Firm) <b>CRAIG DICKINSON</b>
Is Well A Point of Enforcement Std. Application? <input type="checkbox"/> Yes <input type="checkbox"/> No		WTD

A. Protective pipe, top elevation <b>965.32</b> ft. MSL	1. Cap and lock? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
B. Well casing, top elevation <b>965.34</b> ft. MSL	a. Inside diameter: <b>04.0 in.</b>
C. Land surface elevation <b>962.2</b> ft. MSL	b. Length: <b>27.0 ft.</b>
D. Surface seal, bottom <b>03.0</b> ft. MSL or <b>03.0</b> ft.	c. Material: Steel <input type="checkbox"/> 0.4 Other <input type="checkbox"/>
12. USCS classification of soil near screen: GP <input type="checkbox"/> GM <input type="checkbox"/> GC <input type="checkbox"/> GW <input type="checkbox"/> SW <input type="checkbox"/> SP <input checked="" type="checkbox"/> SM <input checked="" type="checkbox"/> SC <input type="checkbox"/> ML <input checked="" type="checkbox"/> MH <input checked="" type="checkbox"/> CL <input checked="" type="checkbox"/> CH <input type="checkbox"/> Bedrock <input type="checkbox"/>	d. Additional protection? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If yes, describe: _____
13. Sieve analysis attached? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	3. Surface seal: Bentonite <input type="checkbox"/> 3.0 Concrete <input checked="" type="checkbox"/> 0.1 Other <input type="checkbox"/>
14. Drilling method used: Rotary <input type="checkbox"/> 50 Hollow Stem Auger <input checked="" type="checkbox"/> 41 Other <input type="checkbox"/>	4. Material between well casing and protective pipe: Bentonite <input type="checkbox"/> 3.0 Annular space seal <input checked="" type="checkbox"/> Other <input type="checkbox"/>
15. Drilling fluid used: Water <input type="checkbox"/> 02 Air <input type="checkbox"/> 01 Drilling Mud <input type="checkbox"/> 03 None <input checked="" type="checkbox"/> 99	5. Annular space seal: a. <input checked="" type="checkbox"/> Granular Bentonite <input type="checkbox"/> 3.3 b. _____ Lbs/gal mud weight ... Bentonite-sand slurry <input type="checkbox"/> 3.5 c. _____ Lbs/gal mud weight ..... Bentonite slurry <input type="checkbox"/> 3.1 d. _____ % Bentonite ..... Bentonite-cement grout <input type="checkbox"/> 5.0 e. _____ Ft <sup>3</sup> volume added for any of the above f. How installed: Tremie <input type="checkbox"/> 0.1 Tremie pumped <input type="checkbox"/> 0.2 Gravity <input checked="" type="checkbox"/> 0.8
16. Drilling additives used? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	6. Bentonite seal: a. Bentonite granules <input type="checkbox"/> 3.3 b. <input type="checkbox"/> 1/4 in. <input type="checkbox"/> 3/8 in. <input checked="" type="checkbox"/> 1/2 in. Bentonite pellets <input checked="" type="checkbox"/> 3.2 c. _____ Other <input type="checkbox"/>
Describe _____	7. Fine sand material: Manufacturer, product name & mesh size a. <u>UNININ. GRANULIC INDUSTRIAL SAND</u> b. Volume added <u>0.0050 ft<sup>3</sup></u>
17. Source of water (attach analysis): _____	8. Filter pack material: Manufacturer, product name and mesh size a. <u>AMERICAN MATERIALS #30 FLINT</u> b. Volume added <u>4.12 ft<sup>3</sup></u>
E. Bentonite seal, top <b>018.5</b> ft. MSL or <b>018.5</b> ft.	9. Well casing: Flush threaded PVC schedule 40 <input checked="" type="checkbox"/> 23 Flush threaded PVC schedule 80 <input type="checkbox"/> 24 Other <input type="checkbox"/>
F. Fine sand, top <b>020.5</b> ft. MSL or <b>020.5</b> ft.	10. Screen material: <b>.010 PVC</b> a. Screen type: Factory cut <input checked="" type="checkbox"/> 1.1 Continuous slot <input type="checkbox"/> 0.1 Other <input type="checkbox"/>
G. Filter pack, top <b>022.5</b> ft. MSL or <b>022.5</b> ft.	b. Manufacturer <u>Northeast Pipe</u> c. Slot size: <b>0.010 in.</b> d. Slotted length: <b>10.0 ft.</b>
H. Screen joint, top <b>024.5</b> ft. MSL or <b>024.5</b> ft.	
I. Well bottom <b>034.5</b> ft. MSL or <b>034.5</b> ft.	
J. Filter pack, bottom <b>036.5</b> ft. MSL or <b>036.5</b> ft.	
K. Borehole, bottom <b>036.5</b> ft. MSL or <b>036.5</b> ft.	
L. Borehole, diameter <b>06.7</b> in.	
M. O.D. well casing <b>02.10</b> in.	
N. I.D. well casing <b>01.90</b> in.	



1. Cap and lock?  Yes  No
2. Protective cover pipe:  
a. Inside diameter: **04.0 in.**  
b. Length: **27.0 ft.**  
c. Material: Steel  0.4  
Other
3. Surface seal: Bentonite  3.0  
Concrete  0.1  
Other
4. Material between well casing and protective pipe:  
Bentonite  3.0  
Annular space seal   
Other
5. Annular space seal:  
a.  Granular Bentonite  3.3  
b. \_\_\_\_\_ Lbs/gal mud weight ... Bentonite-sand slurry  3.5  
c. \_\_\_\_\_ Lbs/gal mud weight ..... Bentonite slurry  3.1  
d. \_\_\_\_\_ % Bentonite ..... Bentonite-cement grout  5.0  
e. \_\_\_\_\_ Ft<sup>3</sup> volume added for any of the above  
f. How installed: Tremie  0.1  
Tremie pumped  0.2  
Gravity  0.8
6. Bentonite seal:  
a. Bentonite granules  3.3  
b.  1/4 in.  3/8 in.  1/2 in. Bentonite pellets  3.2  
c. \_\_\_\_\_ Other
7. Fine sand material: Manufacturer, product name & mesh size  
a. UNININ. GRANULIC INDUSTRIAL SAND  
b. Volume added 0.0050 ft<sup>3</sup>
8. Filter pack material: Manufacturer, product name and mesh size  
a. AMERICAN MATERIALS #30 FLINT  
b. Volume added 4.12 ft<sup>3</sup>
9. Well casing:  
Flush threaded PVC schedule 40  23  
Flush threaded PVC schedule 80  24  
Other
10. Screen material: **.010 PVC**  
a. Screen type: Factory cut  1.1  
Continuous slot  0.1  
Other
11. Backfill material (below filter pack):  
None  14  
Other

I hereby certify that the information on this form is true and correct to the best of my knowledge.

Signature Philip R. Brinkley

Firm Fonk & Van Dike

Please complete both sides of this form and return to the appropriate DNR office listed at the top of this form as required by chs. 144, 147 and 160, Wis. Stats., and ch. NR 141, Wis. Ad. Code. In accordance with ch. 144, Wis. Stats., failure to file this form may result in a forfeiture of not less than \$10, nor more than \$5000 for each day of violation. In accordance with ch. 147, Wis. Stats., failure to file this form may result in a forfeiture of not more than \$10,000 for each day of violation. NOTE: Shaded areas are for DNR use only. See instructions for more information including where the completed form should be sent.

Route to: Solid Waste  Haz. Waste  Wastewater   
Env. Response & Repair  Underground Tanks  Other

Facility/Project Name <b>ADMUS Co. Compost</b>	County Name <b>ADMUS</b>	Well Name <b>MW-25</b>
Facility License, Permit or Monitoring Number	County Code <b>01</b>	Wis. Unique Well Number <b>GN076</b>
		DNR Well Number <b>045</b>

1. Can this well be purged dry?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	11. Depth to Water (from top of well casing)	Before Development a. <u>028.01</u> ft.	After Development <u>032.60</u> ft.
2. Well development method		Date	b. <u>10/02/90</u> m m d d y y	<u>10/02/90</u> m m d d y y
surged with bailer and bailed	<input checked="" type="checkbox"/> 41	Time	c. <u>10:15</u> <input checked="" type="checkbox"/> a.m. <u>10:45</u> <input type="checkbox"/> p.m.	<u>10:45</u> <input checked="" type="checkbox"/> a.m. <u>10:45</u> <input type="checkbox"/> p.m.
surged with bailer and pumped	<input type="checkbox"/> 61	12. Sediment in well bottom	_____ inches	_____ inches
surged with block and bailed	<input type="checkbox"/> 42	13. Water clarity	Clear <input type="checkbox"/> 10 Turbid <input checked="" type="checkbox"/> 15 (Describe) <u>LT. Brown</u>	Clear <input type="checkbox"/> 20 Turbid <input checked="" type="checkbox"/> 25 (Describe) <u>LT. Brown</u>
surged with block and pumped	<input type="checkbox"/> 62			
surged with block, bailed and pumped	<input type="checkbox"/> 70			
compressed air	<input type="checkbox"/> 20			
bailed only	<input type="checkbox"/> 10			
pumped only	<input type="checkbox"/> 51			
pumped slowly	<input type="checkbox"/> 50			
Other _____				
3. Time spent developing well	<u>0030</u> min.			
4. Depth of well (from top of well casisng)	<u>037.6</u> ft.			
5. Inside diameter of well	<u>02.00</u> in.			
6. Volume of water in filter pack and well casing	_____ gal.			
7. Volume of water removed from well	<u>008.0</u> gal.			
8. Volume of water added (if any)	_____ gal.			
9. Source of water added	_____			
10. Analysis performed on water added?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No (If yes, attach results)			
16. Additional comments on development:	<i>The information presented here was obtained from Foth &amp; Van Dyke Giles. Development was done by Mike Hasterfer who is no longer with firm.</i>			

Well developed by: Person's Name and Firm

Name: Mike Hasterfer

Firm: Foth & Van Dyke

I hereby certify that the above information is true and correct to the best of my knowledge.

Signature: Philip D. Bochert


Print Initials: PRB

Firm: Foth & Van Dyke

NOTE: Shaded areas are for DNR use only. See instructions for more information including a list of county codes.

Facility/Project Name <b>ADAMS Co. COMPOST</b>	Local Grid Location of Well ft. <input type="checkbox"/> N. <input type="checkbox"/> S. ft. <input type="checkbox"/> E. <input type="checkbox"/> W.	Well Name <b>MW-26</b>
Facility License, Permit or Monitoring Number	Grid Origin Location	Wis. Unique Well Number <b>GN077</b>
Type of Well Water Table Observation Well <input checked="" type="checkbox"/> 11 Piezometer <input type="checkbox"/> 12	Lat. _____ Long. _____ or St. Plane <b>740,629.0</b> ft. N. <b>3,091,413.5</b> ft. E.	DNR Well Number <b>046</b>
Distance Well Is From Waste/Source Boundary ft.	Section Location of Waste/Source <b>NE 1/4 of SE 1/4 of Sec. 13, T. 18 N, R. 5 E.</b>	Date Well Installed <b>09/17/90</b>
Is Well A Point of Enforcement Std. Application? <input type="checkbox"/> Yes <input type="checkbox"/> No	Location of Well Relative to Waste/Source u <input type="checkbox"/> Upgradient s <input type="checkbox"/> Sidegradient d <input type="checkbox"/> Downgradient n <input type="checkbox"/> Not Known	Well Installed By: (Person's Name and Firm) <b>CRAIG DICKINSON</b> <b>WTD</b>
A. Protective pipe, top elevation <b>963.04</b> ft. MSL	1. Cap and lock?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
B. Well casing, top elevation <b>963.02</b> ft. MSL	2. Protective cover pipe: a. Inside diameter: <b>04.0 in.</b> b. Length: <b>07.0 ft.</b> c. Material: <input checked="" type="checkbox"/> Steel <b>04</b> <input type="checkbox"/> Other	
C. Land surface elevation <b>960.0</b> ft. MSL	d. Additional protection? If yes, describe: <b>Bentonite</b> <input type="checkbox"/> 30 <b>Concrete</b> <input checked="" type="checkbox"/> 01 <b>Other</b> <input type="checkbox"/>	
D. Surface seal, bottom _____ ft. MSL or <b>04.2</b> ft.	3. Surface seal: <b>Bentonite</b> <input type="checkbox"/> 30 <b>Concrete</b> <input checked="" type="checkbox"/> 01 <b>Other</b> <input type="checkbox"/>	
12. USCS classification of soil near screen: GP <input type="checkbox"/> GM <input type="checkbox"/> GC <input type="checkbox"/> GW <input type="checkbox"/> SW <input type="checkbox"/> SP <input checked="" type="checkbox"/> SM <input type="checkbox"/> SC <input type="checkbox"/> ML <input checked="" type="checkbox"/> MH <input checked="" type="checkbox"/> CL <input checked="" type="checkbox"/> CH <input type="checkbox"/> Bedrock <input type="checkbox"/>	4. Material between well casing and protective pipe: Bentonite <input type="checkbox"/> 30 Annular space seal <input checked="" type="checkbox"/> Other <input type="checkbox"/> 33	
13. Sieve analysis attached? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	5. Annular space seal: a. <b>Shipped</b> <input checked="" type="checkbox"/> 33 b. _____ Lbs/gal mud weight ... Bentonite-sand slurry <input type="checkbox"/> 35 c. _____ Lbs/gal mud weight ..... Bentonite slurry <input type="checkbox"/> 31 d. _____ % Bentonite ..... Bentonite-cement grout <input type="checkbox"/> 50 e. <b>43.9</b> <sup>3</sup> Ft <sup>3</sup> volume added for any of the above <input type="checkbox"/> 01 f. How installed: Tremie <input type="checkbox"/> 01 Tremie pumped <input type="checkbox"/> 02 Gravity <input type="checkbox"/> 08	
14. Drilling method used: Rotary <input type="checkbox"/> 50 Hollow Stem Auger <input checked="" type="checkbox"/> 41 Other <input type="checkbox"/>	6. Bentonite seal: a. Bentonite granules <input type="checkbox"/> 33 b. <input type="checkbox"/> 1/4 in. <input type="checkbox"/> 3/8 in. <input checked="" type="checkbox"/> 1/2 in. Bentonite pellets <input checked="" type="checkbox"/> 32 c. <input type="checkbox"/> Other	
15. Drilling fluid used: Water <input type="checkbox"/> 02 Air <input type="checkbox"/> 01 Drilling Mud <input type="checkbox"/> 03 None <input checked="" type="checkbox"/> 99	7. Fine sand material: Manufacturer, product name & mesh size a. <b>Orbaining Geomusil Industrial Sand</b> b. Volume added <b>0.6</b> <sup>3</sup> <b>30/50</b>	
16. Drilling additives used? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	8. Filter pack material: Manufacturer, product name and mesh size a. <b>American Filter Media #30</b> b. Volume added <b>4.4</b> <sup>3</sup>	
Describe _____	9. Well casing: Flush threaded PVC schedule 40 <input checked="" type="checkbox"/> 23 Flush threaded PVC schedule 80 <input type="checkbox"/> 24 Other <input type="checkbox"/>	
17. Source of water (attach analysis): _____	10. Screen material: <b>0.010 PVC</b> a. Screen type: <input checked="" type="checkbox"/> Factory cut <b>11</b> <input type="checkbox"/> Continuous slot <b>01</b> <input type="checkbox"/> Other	
E. Bentonite seal, top _____ ft. MSL or <b>017.5</b> ft.	b. Manufacturer <b>Northern</b> c. Slot size: d. Slotted length: <b>0.010 in.</b> <b>10.0 ft.</b>	
F. Fine sand, top _____ ft. MSL or <b>019.5</b> ft.		
G. Filter pack, top _____ ft. MSL or <b>021.5</b> ft.		
H. Screen joint, top _____ ft. MSL or <b>023.5</b> ft.		
I. Well bottom _____ ft. MSL or <b>033.5</b> ft.		
J. Filter pack, bottom _____ ft. MSL or <b>026.5</b> ft.		
K. Borehole, bottom _____ ft. MSL or <b>026.5</b> ft.		
L. Borehole, diameter <b>06.7</b> in.		
M. O.D. well casing <b>02.10</b> in.		
N. I.D. well casing <b>01.90</b> in.		
11. Backfill material (below filter pack): None <input checked="" type="checkbox"/> 14 Other <input type="checkbox"/>		

I hereby certify that the information on this form is true and correct to the best of my knowledge.

Signature  Firm 

Please complete both sides of this form and return to the appropriate DNR office listed at the top of this form as required by chs. 144, 147 and 160, Wis. Stats., and ch. NR 141, Wis. Ad. Code. In accordance with ch. 144, Wis. Stats., failure to file this form may result in a forfeiture of not less than \$10, nor more than \$5000 for each day of violation. In accordance with ch. 147, Wis. Stats., failure to file this form may result in a forfeiture of not more than \$10,000 for each day of violation. NOTE: Shaded areas are for DNR use only. See instructions for more information including where the completed form should be sent.

Route to: Solid Waste  Haz. Waste  Wastewater   
Env. Response & Repair  Underground Tanks  Other

Facility/Project Name <i>Adams Co. Compost</i>	County Name <i>Adams</i>	Well Name <i>AW-26</i>
Facility License, Permit or Monitoring Number -----	County Code <i>01</i>	Wis. Unique Well Number <i>GN077</i>
		DNR Well Number <i>046</i>

1. Can this well be purged dry? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	11. Depth to Water (from top of well casing) a. <u>026.31</u> ft.	Before Development	After Development
2. Well development method surged with bailer and bailed surged with bailer and pumped surged with block and bailed surged with block and pumped surged with block, bailed and pumped compressed air bailed only pumped only pumped slowly Other _____  <input checked="" type="checkbox"/> 41 <input type="checkbox"/> 61 <input type="checkbox"/> 42 <input type="checkbox"/> 62 <input type="checkbox"/> 70 <input type="checkbox"/> 20 <input type="checkbox"/> 10 <input type="checkbox"/> 51 <input type="checkbox"/> 50 <input type="checkbox"/>	Date b. <u>10/02/90</u> m m d d y y	<u>10/02/90</u>	<u>10/02/90</u>
3. Time spent developing well <u>2015</u> min.	Time c. <u>13:35</u> a.m. <u>13:49</u> p.m.	<u>13:35</u> a.m. <u>13:49</u> p.m.	
4. Depth of well (from top of well casisng) <u>026.3</u> ft.	12. Sediment in well bottom _____ inches	_____ inches	_____ inches
5. Inside diameter of well <u>01.90</u> in.	13. Water clarity Clear <input type="checkbox"/> 10 Turbid <input checked="" type="checkbox"/> 15 (Describe)	Clear <input type="checkbox"/> 20 Turbid <input checked="" type="checkbox"/> 25 (Describe)	_____
6. Volume of water in filter pack and well casing _____ gal.	LT Brown	LT Brown	LT Brown
7. Volume of water removed from well <u>005.</u> gal.			
8. Volume of water added (if any) _____ gal.			
9. Source of water added _____			
10. Analysis performed on water added? (If yes, attach results) <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	14. Total suspended solids _____ mg/l	_____ mg/l	_____ mg/l
16. Additional comments on development: <i>The information presented here was obtained from Foth &amp; Van Dyke files. Development was done by Mike Masteelee who is no longer with the firm.</i>	15. COD _____ mg/l	_____ mg/l	_____ mg/l

Well developed by: Person's Name and Firm

Name: Mike Masteelee

Firm: Foth & Van Dyke

I hereby certify that the above information is true and correct to the best of my knowledge.

Signature: Philip R. Becker


Print Initials: P R B

Firm: Foth & Van Dyke

NOTE: Shaded areas are for DNR use only. See instructions for more information including a list of county codes.

Facility/Project Name <b>Adams Co. Compost</b>		Local Grid Location of Well ft. <input type="checkbox"/> N. <input type="checkbox"/> S. ft. <input type="checkbox"/> E. <input type="checkbox"/> W.	Well Name <b>MW-27</b>
Facility License, Permit or Monitoring Number		Grid Origin Location Lat. _____ Long. _____ or St. Plane <b>740,564.1</b> ft. N. <b>2,041,858.0</b> ft. E.	Wis. Unique Well Number <b>GN078</b> DNR Well Number <b>047</b>
Type of Well	Water Table Observation Well <input checked="" type="checkbox"/> 11 Piezometer <input type="checkbox"/> 12	Section Location of Waste/Source <b>NE 1/4 of SE 1/4 of Sec. 13, T. 18 N. R. 5 E. W.</b>	Date Well Installed <b>09/13/90</b> m m d y
Distance Well Is From Waste/Source Boundary ft.		Well Installed By: (Person's Name and Firm) <b>CRAIG DICKINSON</b>	
Is Well A Point of Enforcement Std. Application? <input type="checkbox"/> Yes <input type="checkbox"/> No		Location of Well Relative to Waste/Source u <input type="checkbox"/> Upgradient s <input type="checkbox"/> Sidegradient d <input type="checkbox"/> Downgradient n <input type="checkbox"/> Not Known	
A. Protective pipe, top elevation <b>-280.84</b> ft. MSL		1. Cap and lock? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
B. Well casing, top elevation <b>-280.81</b> ft. MSL		2. Protective cover pipe: a. Inside diameter: <b>04.0</b> in. b. Length: <b>07.0</b> ft. c. Material: Steel <input checked="" type="checkbox"/> 04 Other <input type="checkbox"/> 	
C. Land surface elevation <b>-272.0</b> ft. MSL		d. Additional protection? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If yes, describe: _____	
D. Surface seal, bottom _____ ft. MSL or <b>03.8</b> ft.		3. Surface seal: Bentonite <input type="checkbox"/> 3.0 Concrete <input checked="" type="checkbox"/> 0.1 Other <input type="checkbox"/> 	
12. USCS classification of soil near screen: GP <input type="checkbox"/> GM <input type="checkbox"/> GC <input type="checkbox"/> GW <input type="checkbox"/> SW <input type="checkbox"/> SP <input checked="" type="checkbox"/> SM <input type="checkbox"/> SC <input type="checkbox"/> ML <input type="checkbox"/> MH <input type="checkbox"/> CL <input checked="" type="checkbox"/> CH <input type="checkbox"/> Bedrock <input type="checkbox"/>		4. Material between well casing and protective pipe: Bentonite <input type="checkbox"/> 3.0 Annular space seal <input checked="" type="checkbox"/> Other <input type="checkbox"/> 	
13. Sieve analysis attached? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		5. Annular space seal: a. Granular Bentonite <input checked="" type="checkbox"/> 3.3 b. _____ Lbs/gal mud weight ... Bentonite-sand slurry <input type="checkbox"/> 3.5 c. _____ Lbs/gal mud weight ..... Bentonite slurry <input type="checkbox"/> 3.1 d. _____ % Bentonite ..... Bentonite-cement grout <input type="checkbox"/> 5.0 e. <b>13.9</b> Ft <sup>3</sup> volume added for any of the above f. How installed: Tremie <input type="checkbox"/> 0.1 Tremie pumped <input type="checkbox"/> 0.2 Gravity <input checked="" type="checkbox"/> 0.8	
14. Drilling method used: Rotary <input type="checkbox"/> 50 Hollow Stem Auger <input checked="" type="checkbox"/> 4.1 Other <input type="checkbox"/> 		6. Bentonite seal: a. Bentonite granules <input type="checkbox"/> 3.3 b. <input type="checkbox"/> 1/4 in. <input type="checkbox"/> 3/8 in. <input checked="" type="checkbox"/> 1/2 in. Bentonite pellets <input checked="" type="checkbox"/> 3.2 c. _____ Other <input type="checkbox"/> 	
15. Drilling fluid used: Water <input type="checkbox"/> 0.2 Air <input type="checkbox"/> 0.1 Drilling Mud <input type="checkbox"/> 0.3 None <input checked="" type="checkbox"/> 9.9		7. Fine sand material: Manufacturer, product name & mesh size a. <u>WILM. GEORGE INDUSTRIAL SUP.</u>  b. Volume added <b>0.9</b> ft <sup>3</sup> <b>3950</b>	
16. Drilling additives used? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		8. Filter pack material: Manufacturer, product name and mesh size a. <u>AMERICAN MATERIALS #30 STAIN</u>  b. Volume added <b>5.8</b> ft <sup>3</sup>	
Describe _____		9. Well casing: Flush threaded PVC schedule 40 <input checked="" type="checkbox"/> 2.3 Flush threaded PVC schedule 80 <input type="checkbox"/> 2.4 Other: <input type="checkbox"/> 	
17. Source of water (attach analysis): _____		10. Screen material: <b>010 PVC</b> a. Screen type: Factory cut <input checked="" type="checkbox"/> 1.1 Continuous slot <input type="checkbox"/> 0.1 Other <input type="checkbox"/> 	
E. Bentonite seal, top _____ ft. MSL or <b>034.0</b> ft.		b. Manufacturer <u>Northland Pipe</u> c. Slot size: <b>0.010</b> in. d. Slotted length: <b>10.0</b> ft.	
F. Fine sand, top _____ ft. MSL or <b>036.0</b> ft.		11. Backfill material (below filter pack): None <input checked="" type="checkbox"/> 1.4 Other <input type="checkbox"/> 	
G. Filter pack, top _____ ft. MSL or <b>038.0</b> ft.			
H. Screen joint, top _____ ft. MSL or <b>040.0</b> ft.			
I. Well bottom _____ ft. MSL or <b>050.0</b> ft.			
J. Filter pack, bottom _____ ft. MSL or <b>050.5</b> ft.			
K. Borehole, bottom _____ ft. MSL or <b>050.5</b> ft.			
L. Borehole, diameter <b>08.3</b> in.			
M. O.D. well casing <b>02.38</b> in.			
N. I.D. well casing <b>02.00</b> in.			

I hereby certify that the information on this form is true and correct to the best of my knowledge.

Signature  Firm **Philip D. Beale**

Please complete both sides of this form and return to the appropriate DNR office listed at the top of this form as required by chs. 144, 147 and 160, Wis. Stats., and ch. NR 141, Wis. Ad. Code. In accordance with ch. 144, Wis. Stats., failure to file this form may result in a forfeiture of not less than \$10, nor more than \$5000 for each day of violation. In accordance with ch. 147, Wis. Stats., failure to file this form may result in a forfeiture of not more than \$10,000 for each day of violation. NOTE: Shaded areas are for DNR use only. See instructions for more information including where the completed form should be sent.

Route to: Solid Waste  Haz. Waste  Wastewater   
Env. Response & Repair  Underground Tanks  Other

Facility/Project Name <b>ADAMS Co. Compost</b>	County Name <b>ADAMS</b>	Well Name <b>MW-27</b>
Facility License, Permit or Monitoring Number	County Code <b>01</b>	Wis. Unique Well Number <b>GN078</b>
		DNR Well Number <b>047</b>

1. Can this well be purged dry? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	11. Depth to Water (from top of well casing) a. <u>042.31</u> ft.	Before Development	After Development
2. Well development method surged with bailer and bailed surged with bailer and pumped surged with block and bailed surged with block and pumped surged with block, bailed and pumped compressed air bailed only pumped only pumped slowly Other _____	<input checked="" type="checkbox"/> 41 <input type="checkbox"/> 61 <input type="checkbox"/> 42 <input type="checkbox"/> 62 <input type="checkbox"/> 70 <input type="checkbox"/> 20 <input type="checkbox"/> 10 <input type="checkbox"/> 51 <input type="checkbox"/> 50 <input checked="" type="checkbox"/>	Date b. <u>10/02/90</u> m m d d y y	<u>045.40</u> ft. m m d d y y
3. Time spent developing well <u>0020</u> min.	Time c. <u>11:10</u> <input checked="" type="checkbox"/> a.m. <input type="checkbox"/> p.m.	<u>11:28</u> <input type="checkbox"/> a.m. <input type="checkbox"/> p.m.	
4. Depth of well (from top of well casing) <u>553.3</u> ft.	12. Sediment in well bottom _____ inches	_____ inches	
5. Inside diameter of well <u>02.00</u> in.	13. Water clarity Clear <input type="checkbox"/> 10 Turbid <input checked="" type="checkbox"/> 15 (Describe) <u>cf Brown</u>	Clear <input type="checkbox"/> 20 Turbid <input checked="" type="checkbox"/> 25 (Describe) <u>cf Brown</u>	
6. Volume of water in filter pack and well casing _____ gal.	14. Total suspended solids _____ mg/l	_____ mg/l	
7. Volume of water removed from well <u>008.0</u> gal.	15. COD _____ mg/l	_____ mg/l	
8. Volume of water added (if any) _____ gal.			
9. Source of water added _____			
10. Analysis performed on water added? (If yes, attach results)	Fill in if drilling fluids were used and well is at solid waste facility:		

16. Additional comments on development:

*The information presented here was obtained from Foth & Van Dike. Development was done by Mike Masteer who is no longer with F&V.*

Well developed by: Person's Name and Firm

Name: MIKE MASTEER

Firm: Foth & Van Dike

I hereby certify that the above information is true and correct to the best of my knowledge.

Signature: Dilip R. Borkar, Jr.

Print Initials: P R B

Firm: Foth and Van Dike

NOTE: Shaded areas are for DNR use only. See instructions for more information including a list of county codes.

Facility/Project Name <i>Adams Co. Compost</i>	Local Grid Location of Well ft. <input type="checkbox"/> N. <input type="checkbox"/> S. ft. <input type="checkbox"/> E. <input type="checkbox"/> W.	Well Name <i>MW-28</i>
Facility License, Permit or Monitoring Number	Grid Origin Location Lat. _____ Long. _____ or St. Plane <i>740,262,2</i> ft. N. <i>2,041,656.8</i> ft. E.	Wis. Unique Well Number <i>GN079</i> DNR Well Number <i>048</i>
Type of Well Water Table Observation Well <input checked="" type="checkbox"/> 11 Piezometer <input type="checkbox"/> 12	Section Location of Waste/Source <i>NE 1/4 of SE 1/4 of Sec. 13, T. 18 N, R. 5 E.</i>	Date Well Installed <i>09/15/91</i>
Distance Well Is From Waste/Source Boundary ft.	Location of Well Relative to Waste/Source u <input type="checkbox"/> Upgradient s <input type="checkbox"/> Sidegradient d <input type="checkbox"/> Downgradient n <input type="checkbox"/> Not Known	Well Installed By: (Person's Name and Firm) <i>Craig Dickinson</i>
Is Well A Point of Enforcement Std. Application? <input type="checkbox"/> Yes <input type="checkbox"/> No		WTI, INC.

A. Protective pipe, top elevation <i>924.20</i> ft. MSL	1. Cap and lock? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
B. Well casing, top elevation <i>924.15</i> ft. MSL	2. Protective cover pipe: a. Inside diameter: <i>24.0</i> in. b. Length: <i>21.0</i> ft. c. Material: Steel <input checked="" type="checkbox"/> 04 Other <input type="checkbox"/>
C. Land surface elevation <i>921.2</i> ft. MSL	d. Additional protection? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If yes, describe: _____
D. Surface seal, bottom ft. MSL or <i>04.3</i> ft.	3. Surface seal: Bentonite <input type="checkbox"/> 30 Concrete <input checked="" type="checkbox"/> 01 Other <input type="checkbox"/>
12. USCS classification of soil near screen: GP <input type="checkbox"/> GM <input type="checkbox"/> GC <input type="checkbox"/> GW <input type="checkbox"/> SW <input type="checkbox"/> SP <input checked="" type="checkbox"/> SM <input checked="" type="checkbox"/> SC <input type="checkbox"/> ML <input checked="" type="checkbox"/> MH <input type="checkbox"/> CL <input checked="" type="checkbox"/> CH <input type="checkbox"/> Bedrock <input type="checkbox"/>	4. Material between well casing and protective pipe: Bentonite <input type="checkbox"/> 30 Annular space seal <input checked="" type="checkbox"/> Other <input type="checkbox"/>
13. Sieve analysis attached? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	5. Annular space seal: a. <i>Chipped</i> Granular Bentonite <input checked="" type="checkbox"/> 33 b. _____ Lbs/gal mud weight . . . Bentonite-sand slurry <input type="checkbox"/> 35 c. _____ Lbs/gal mud weight . . . Bentonite slurry <input type="checkbox"/> 31 d. _____ % Bentonite . . . Bentonite-cement grout <input type="checkbox"/> 50 e. <i>9.2</i> Ft <sup>3</sup> volume added for any of the above f. How installed: Tremie <input type="checkbox"/> 01 Tremie pumped <input type="checkbox"/> 02 Gravity <input checked="" type="checkbox"/> 08
14. Drilling method used: Rotary <input type="checkbox"/> 50 Hollow Stem Auger <input checked="" type="checkbox"/> 41 Other <input type="checkbox"/>	6. Bentonite seal: a. Bentonite granules <input type="checkbox"/> 33 b. <input type="checkbox"/> 1/4 in. <input type="checkbox"/> 3/8 in. <input checked="" type="checkbox"/> 1/2 in. Bentonite pellets <input checked="" type="checkbox"/> 32 c. _____ Other <input type="checkbox"/>
15. Drilling fluid used: Water <input type="checkbox"/> 02 Air <input type="checkbox"/> 01 Drilling Mud <input type="checkbox"/> 03 None <input checked="" type="checkbox"/> 99	7. Fine sand material: Manufacturer, product name & mesh size a. <i>Union Gravimatic Industrial Sand</i> b. Volume added <i>0.86</i> ft <sup>3</sup>
16. Drilling additives used? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	8. Filter pack material: Manufacturer, product name and mesh size a. <i>American Mesh 15 #30 Flint Sand</i> b. Volume added <i>5.3</i> ft <sup>3</sup>
Describe _____	9. Well casing: Flush threaded PVC schedule 40 <input checked="" type="checkbox"/> 23 Flush threaded PVC schedule 80 <input type="checkbox"/> 24 Other <input type="checkbox"/>
17. Source of water (attach analysis): _____	10. Screen material: <i>.010 PVC</i> a. Screen type: Factory cut <input checked="" type="checkbox"/> 11 Continuous slot <input type="checkbox"/> 01 Other <input type="checkbox"/>
E. Bentonite seal, top ft. MSL or <i>026.0</i> ft.	b. Manufacturer <i>NORTHERN FIRE</i> c. Slot size: d. Slotted length: <i>0.010</i> in. <i>10.0</i> ft.
F. Fine sand, top ft. MSL or <i>028.0</i> ft.	11. Backfill material (below filter pack): None <input checked="" type="checkbox"/> 14 Other <input type="checkbox"/>
G. Filter pack, top ft. MSL or <i>030.0</i> ft.	
H. Screen joint, top ft. MSL or <i>032.0</i> ft.	
I. Well bottom ft. MSL or <i>042.0</i> ft.	
J. Filter pack, bottom ft. MSL or <i>042.5</i> ft.	
K. Borehole, bottom ft. MSL or <i>042.5</i> ft.	
L. Borehole, diameter <i>08.0</i> in.	
M. O.D. well casing <i>02.38</i> in.	
N. I.D. well casing <i>02.00</i> in.	

I hereby certify that the information on this form is true and correct to the best of my knowledge.

Signature *Philip D. Borchers*

Firm *Foothills Van Dyke*

Please complete both sides of this form and return to the appropriate DNR office listed at the top of this form as required by chs. 144, 147 and 160, Wis. Stats., and ch. NR 141, Wis. Ad. Code. In accordance with ch. 144, Wis. Stats., failure to file this form may result in a forfeiture of not less than \$10, nor more than \$5000 for each day of violation. In accordance with ch. 147, Wis. Stats., failure to file this form may result in a forfeiture of not more than \$10,000 for each day of violation. NOTE: Shaded areas are for DNR use only. See instructions for more information including where the completed form should be sent.

Route to: Solid Waste  Haz. Waste  Wastewater   
Env. Response & Repair  Underground Tanks  Other

Facility/Project Name <i>Adams Co. Compost</i>	County Name <i>Adams</i>	Well Name <i>MW-28</i>	
Facility License, Permit or Monitoring Number _____	County Code <i>01</i>	Wis. Unique Well Number <i>GN079</i>	DNR Well Number <i>048</i>

1. Can this well be purged dry? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	11. Depth to Water (from top of well casing) a. <u>039.68</u> ft.	Before Development	After Development
2. Well development method surged with bailer and bailed surged with bailer and pumped surged with block and bailed surged with block and pumped surged with block, bailed and pumped compressed air bailed only pumped only pumped slowly Other _____	<input checked="" type="checkbox"/> 41 <input type="checkbox"/> 61 <input type="checkbox"/> 42 <input type="checkbox"/> 62 <input type="checkbox"/> 70 <input type="checkbox"/> 20 <input type="checkbox"/> 10 <input type="checkbox"/> 51 <input type="checkbox"/> 50 <input type="checkbox"/> _____	Date <u>10/02/90</u> m m d d y y	<u>10/02/90</u> m m d d y y
3. Time spent developing well <u>0020</u> min.	Time <u>12:09</u> <input type="checkbox"/> a.m. <u>12:25</u> <input type="checkbox"/> p.m.		
4. Depth of well (from top of well casing) <u>045.5</u> ft.	12. Sediment in well bottom _____ inches		
5. Inside diameter of well <u>02.00</u> in.	13. Water clarity Clear <input type="checkbox"/> 10 Turbid <input checked="" type="checkbox"/> 15 (Describe) <i>lt. Brown</i>	Clear <input type="checkbox"/> 20 Turbid <input checked="" type="checkbox"/> 25 (Describe) <i>lt. Brown</i>	
6. Volume of water in filter pack and well casing _____ gal.			
7. Volume of water removed from well <u>006.0</u> gal.			
8. Volume of water added (if any) _____ gal.			
9. Source of water added _____			
10. Analysis performed on water added? (If yes, attach results) _____			
11. Additional comments on development: <i>The information presented here was obtained from Foth &amp; Van Dyke files. Development was done by MIKE HASTREITER who is no longer with them.</i>			

Well developed by: Person's Name and Firm

Name: MIKE HASTREITER

Firm: Foth & Van Dyke

I hereby certify that the above information is true and correct to the best of my knowledge.

Signature: Philip R. Brookfield

Print Initials: PRB

Firm: Foth & Van Dyke

NOTE: Shaded areas are for DNR use only. See instructions for more information including a list of county codes.

Facility /Project Name Adams County Solid Waste Feasibility		Local Grid Location of Well N. ft. <u>          </u> S. <u>          </u> ft. <u>          </u> E. W. <u>          </u>	Well Name <b>MW-29</b>
Facility License, Permit or Monitoring Number <b>3150</b>		Grid Origin Location Lat. <u>          </u> Long. <u>          </u> St. Plane <u>742169.151</u> ft. N. <u>2010739.562</u> ft.E.	Wis. Unique Well Number <b>VP-147</b> DNR Well Number <b>049</b>
Type of Well Water Table Observation Well <input checked="" type="checkbox"/> 11 Piezometer <u>          </u> 12	Section Location of Waste/Source <u>          </u> 236 ft.		Date Well Installed <u>11/20/15</u>
Distance Well Is From Waste/Source Boundary <u>          </u> 236 ft.		Well Installed By: (Person's Name and Firm) <u>Joe Black - PSI</u>	
Is Well A Point of Enforcement Std. Application? <u>          </u> Yes <input type="checkbox"/> No		Location of Well Relative to Waste/Source u <input checked="" type="checkbox"/> Upgradeant <u>          </u> s <input checked="" type="checkbox"/> Sidegradient d <input type="checkbox"/> Downgradient <u>          </u> n <input type="checkbox"/> Not Known	
A. Protective Pipe, top elevation <u>963.69</u> ft. MSL B. Well casing, top elevation <u>963.47</u> ft. MSL C. Land surface elevaton <u>961.73</u> ft. MSL D. Surface seal, bottom <u>          </u> ft. MSL or <u>1</u> ft.		1. Cap and Lock? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No 2. Protective cover pipe: a. Inside diameter: <u>4</u> in. b. Length: <u>5</u> ft. c. Material: Steel <input checked="" type="checkbox"/> 04 Other <u>          </u> d. Additional protection? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> If yes, describe <u>          </u> 3. Surface seal: Bentonite <u>30</u> Concrete <u>01</u> Native Cuttings <u>          </u> 4. Material between well casing and protective pipe: Bentonite <u>30</u> Annular Space Seal <u>          </u> Native cuttings <u>          </u> Other <input checked="" type="checkbox"/> 5. Annular space seal: a. Granular Bentonite <input checked="" type="checkbox"/> 33 b. <u>          </u> Lbs/gal mud weight..... Bentonite-sand slurry <u>35</u> c. <u>          </u> Lbs/gal mud weight..... Bentonite slurry <u>31</u> d. <u>          </u> % Bentonite..... Bentonite-cement grout <u>50</u> e. <u>4.5</u> cubic ft volume added for any of the above f. How installed: Tremie <u>01</u> Tremie pumped <u>02</u> Gravity <input checked="" type="checkbox"/> 08	
12. USCS classification of soil near screen: GP <u>          </u> GM <u>          </u> GC <u>          </u> GW <u>          </u> SW <u>          </u> SP <u>          </u> SM <u>          </u> SC <u>          </u> ML <u>          </u> MH <u>          </u> CL <input checked="" type="checkbox"/> CH <u>          </u> Bedrock <u>          </u>		6. Bentonite seal: a. Bentonite granules <u>33</u> b. 1/4in. <u>          </u> 3/8in. <input checked="" type="checkbox"/> 1/2in. <u>          </u> Bentonite Pellets <input checked="" type="checkbox"/> 32 c. <u>          </u> Other <u>          </u> 7. Fine sand material: Manufacturer, product name and mesh size a. Red Flint Sand <u>0.45-0.55</u> b. Volume Added <u>0.70ft3</u> 8. Filter pack material: Manufacturer, product name and mesh size a. Red Flint Sand <u>6.63ft3</u> b. Volume Added <u>40</u> 9. Well casing: Flush threaded PVC schedule 40 <input checked="" type="checkbox"/> 23 Flush threaded PVC schedule 80 <u>24</u> Other <u>          </u> 10. Screen material: a. Screen type: PVC Factory cut <input checked="" type="checkbox"/> 11 Continuous slot <u>01</u> Other <u>          </u> b. Manufacturer <u>          </u> EMI c. Slot size: <u>0.010</u> in. d. Slotted length: <u>15</u> ft. 11. Backfill Material (below filter pack): None <u>14</u> Native cuttings <u>          </u> Other <u>          </u>	
13. Sieve analysis attached? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No 14. Drilling method used: Rotary <u>50</u> Hollow Stem Auger <input checked="" type="checkbox"/> 41 Other <u>          </u> 15. Drilling fluid used: Air <u>01</u> Water <u>02</u> Drilling Mud <u>03</u> None <input checked="" type="checkbox"/> 99		16. Drilling additives used? <u>          </u> Yes <input checked="" type="checkbox"/> No Describe <u>          </u> 17. Source of water (attach analysis):	
E. Bentonite seal, top <u>          </u> ft. MSL or <u>1.0</u> ft. F. Fine sand, top <u>          </u> ft. MSL or <u>14.0</u> ft. G. Filter pack, top <u>          </u> ft. MSL or <u>16.0</u> ft. H. Screen joint, top <u>          </u> ft. MSL or <u>18.0</u> ft. I. Well bottom <u>          </u> ft. MSL or <u>33.0</u> ft. J. Filter pack, bottom <u>          </u> ft. MSL or <u>33.0</u> ft. K. Borehole, bottom <u>          </u> ft. MSL or <u>35.0</u> ft. L. Borehole, diameter <u>8</u> in M. O.D. well casing <u>2.375</u> in N. I.D. well casing <u>2.047</u> in			

I hereby certify that the information on this form is true and correct to the best of my knowledge.

Signature

**William Honea, Nicole Bader**

Firm

**AYRES ASSOCIATES**

and ch. NR 141, Wis. Ad. Code. In accordance with ch. 144, Wis. Stats., failure to file this form may result in a forfeiture of not less than \$10, nor more than \$5000 for each day of violation. In accordance with ch. 147, Wis. Stats., failure to file this form may result in a forfeiture of not more than \$10,000 for each day of violation. NOTE: Shaded areas are for DNR use only. See instruction for more information including where the completed form should be sent.

## MONITORING WELL DEVELOPMENT

Form 4400-13B

Facility/Project Name <b>Adams County Landfill &amp; Recycling Center</b>		County Name <b>Adams</b>	Well Name <b>MW-29</b>
License/Permit/Monitoring Number <b>3150</b>		County Code <b>1</b>	Wisconsin Unique Well Number <b>VP-147</b>
1. Can this well be purged dry?		Yes <input checked="" type="checkbox"/> No	Before Development <b>30.72</b>
2. Well Development method			After Development <b>34.22</b>
surged with bailer and bailed		41	
surged with bailer and pumped		61	
surged with block and bailed		42	
surged with block and pumped		62	
surged with block, bailed and pumped		70	
compressed air		20	
bailed only		10	
pumped only	<input checked="" type="checkbox"/>	51	
pumped slowly		50	
Other			
3. Time spent developing well	180	min.	Time 10:25 a.m. p.m.
4. Depth of well (from top of well casing)	34.62	ft.	11/23/2015 mm dd yy
5. Inside diameter of well	2.067	in.	11/24/2015 mm dd yy
6. Volume of water in filter pack and well	9.4	gal.	
7. Volume of water removed from well	200	gal.	
8. Volume of water added (if any)	N/A	gal.	
9. Source of water added	N/A		
10. Analysis performed on water added? (If yes, attach results)	Yes <input checked="" type="checkbox"/> No		
11. Depth to Water (from top of well casing) Date			
12. Sediment in well bottom			
13. Water clarity			
Clear		Clear	
Turbid	<input checked="" type="checkbox"/>	Turbid	<input checked="" type="checkbox"/>
Describe		Describe	
See Additional Comments Below			
Fill in if drilling fluids were used and well is at solid waste facility			
14. Total suspended solids		mg/l	<b>20</b> mg/l
15. COD		mg/l	mg/l

#### Additional comments on development:

Well developed by: Person's Name and Firm

Name: Eric J Madsen

Firm: Professional Service Industries Inc.

I hereby certify that the above information is true and correct  
to the best of my knowledge.

Signature:

Print Initials: EJM

Firm: Professional Service Industries, Inc.

Firm: Professional Service Industries Inc.

I hereby certify that the information on this form is true and correct to the best of my knowledge.

Signature

---

### Firm

## AYRES ASSOCIATES

1

and ch. NR 141, Wis. Ad. Code. In accordance with ch. 144, Wis. Stats., failure to file this form may result in a forfeiture of not less than \$10, nor more than \$5000 for each day of violation. In accordance with ch. 147, Wis. Stats., failure to file this form may result in a forfeiture of not more than \$10,000 for each day of violation. NOTE: Shaded areas are for DNR use only. See instruction for more information including where the completed form should be sent.

## MONITORING WELL DEVELOPMENT

Form 4400-13B

Facility/Project Name <b>Adams County Landfill &amp; Recycling Center</b>		County Name <b>Adams</b>	Well Name <b>MW-30</b>
License/Permit/Monitoring Number <b>3150</b>		County Code <b>1</b>	Wisconsin Unique Well Number <b>VP-144</b>
1. Can this well be purged dry?		<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Before Development <b>38.54</b>
2. Well Development method			After Development <b>41.13</b>
surged with bailer and bailed		41	
surged with bailer and pumped		61	
surged with block and bailed		42	
surged with block and pumped		62	
surged with block, bailed and pumped		70	
compressed air		20	
bailed only		10	
pumped only	<input checked="" type="checkbox"/>	51	
pumped slowly		50	
Other			
3. Time spent developing well	<b>55</b>	min.	
4. Depth of well (from top of well casing)	<b>47.16</b>	ft.	
5. Inside diameter of well	<b>2.067</b>	in.	
6. Volume of water in filter pack and well	<b>7.8</b>	gal.	
7. Volume of water removed from well	<b>100</b>	gal.	
8. Volume of water added (if any)	<b>N/A</b>	gal.	
9. Source of water added	<b>N/A</b>		
10. Analysis performed on water added? (If yes, attach results)	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
11. Depth to Water (from top of well casing)			
Date <b>11/23/2015</b>			
Time <b>1:00</b> a.m. <b>1:55</b> p.m.			
12. Sediment in well bottom <b>27.84</b> inches			
13. Water clarity Clear <input type="checkbox"/> Turbid <input checked="" type="checkbox"/> Describe			
See Additional Comments Below			
Fill in if drilling fluids were used and well is at solid waste facility			
14. Total suspended solids		<b>mg/l</b>	<b>17</b> mg/l
15. COD		<b>mg/l</b>	<b>mg/l</b>

#### Additional comments on development:

Well developed by: Person's Name and Firm

I hereby certify that the above information is true and correct  
to the best of my knowledge. *[Signature]*

Name: Eric J Madsen

Signature: Eric J. Mack  
Print Initials: EJM

Firm: Professional Service Industries Inc.

Firm: Professional Service Industries Inc.

Facility /Project Name Adams County Solid Waste Feasibility		Local Grid Location of Well ft. N. ft. S. ft. E. ft. W.	Well Name <b>MW-30P</b>
Facility License, Permit or Monitoring Number <b>3150</b>		Grid Origin Location Lat. _____ Long. _____ or St. Plane <b>741645.608</b> ft. N. <b>2010659.79</b> ft. E.	Wis. Unique Well Number <b>VP-145</b> DNR Well Number <b>051</b>
Type of Well Water Table Observation Well	11	Section Location of Waste/Source	Date Well Installed <b>11/18/15</b>
Piezometer	<b>X</b> 12		Well Installed By: (Person's Name and Firm) <b>Joe Black - PSI</b>
Distance Well Is From Waste/Source Boundary 120 ft.		Location of Well Relative to Waste/Source u <b>X</b> Upgradient d <b> </b> Downgradient n <b> </b> Sidegradient s <b> </b> Not Known	
<p>A. Protective Pipe, top elevation <b>979.94</b> ft. MSL      B. Well casing, top elevation <b>979.69</b> ft. MSL      C. Land surface elevation <b>977.94</b> ft. MSL      D. Surface seal, bottom ft. MSL or <b>1</b> ft.</p> <p>12. USCS classification of soil near screen:      GP <b> </b> GM <b> </b> GC <b> </b> GW <b> </b> SW <b> </b> SP <b> </b>      SM <b>x</b> SC <b> </b> ML <b> </b> MH <b> </b> CL <b> </b> CH <b> </b>      Bedrock <b> </b></p> <p>13. Sieve analysis attached? <b>x</b> Yes <b> </b> No</p> <p>14. Drilling method used:      Rotary <b> </b> 50      Hollow Stem Auger <b>x</b> 41      Other <b> </b></p> <p>15. Drilling fluid used:      Air <b> </b> 01 Water <b> </b> 02      Drilling Mud <b> </b> 03 None <b>x</b> 99</p> <p>16. Drilling additives used? <b> </b> Yes <b>x</b> No      Describe _____</p> <p>17. Source of water (attach analysis):      Drinking water well at Adams County solid waste office</p>			
<p>1. Cap and Lock? <b>x</b> Yes <b> </b> No</p> <p>2. Protective cover pipe:      a. Inside diameter: <b>4</b> in.      b. Length: <b>5</b> ft.</p> <p>3. Surface seal:      Bentonite <b> </b> 30      Concrete <b> </b> 01      Native Cuttings <b> </b></p> <p>4. Material between well casing and protective pipe:      Bentonite <b> </b> 30      Annular Space Seal <b> </b>      Native cuttings <b> </b>      Other <b>x</b></p> <p>5. Annular space seal:      a. Granular Bentonite <b> </b> 33      b. Lbs/gal mud weight..... Bentonite-sand slurry <b> </b> 35      c. Lbs/gal mud weight..... Bentonite slurry <b> </b> 31      d. % Bentonite..... Bentonite-cement grout <b>x</b> 50      e. 12.22 cubic ft volume added for any of the above      f. How installed:      Tremie <b>x</b> 01      Tremie pumped <b> </b> 02      Gravity <b> </b> 08</p> <p>6. Bentonite seal:      a. Bentonite granules <b> </b> 33      b. 1/4in. <b> </b> 3/8in. <b>x</b> 1/2in. <b> </b> Bentonite Pellets <b>x</b> 32      c. <b> </b> Other <b> </b></p> <p>7. Fine sand material:      a. <b> </b> Manufacturer, product name and mesh size      Red Flint Sand <b> </b> 0.45-0.55      b. Volume Added <b> </b> 0.70ft<sup>3</sup></p> <p>8. Filter pack material:      a. <b> </b> Manufacturer, product name and mesh size      Red Flint Sand <b> </b> 40      b. Volume Added <b> </b> 2.44ft<sup>3</sup></p> <p>9. Well casing:      Flush threaded PVC schedule 40 <b>x</b> 23      Flush threaded PVC schedule 80 <b> </b> 24      Other <b> </b></p> <p>10. Screen material:      a. Screen type: <b> </b> PVC      Factory cut <b>x</b> 11      Continuous slot <b> </b> 01      Other <b> </b>      b. Manufacturer <b> </b> EMI      c. Slot size: <b> </b> 0.010 in.      d. Slotted length: <b> </b> 5 ft.</p> <p>11. Backfill Material (below filter pack):      None <b>x</b> 14      Other <b> </b></p>			

I hereby certify that the information on this form is true and correct to the best of my knowledge.

Signature

**William Honea, Nicole Bader**

Firm

**AYRES ASSOCIATES**

1. and ch. NR 141, Wis. Ad. Code. In accordance with ch. 144, Wis. Stats., failure to file this form may result in a forfeiture of not less than \$10, nor more than \$5000 for each day of violation. In accordance with ch. 147, Wis. Stats., failure to file this form may result in a forfeiture of not more than \$10,000 for each day of violation. NOTE: Shaded areas are for DNR use only. See instruction for more information including where the completed form should be sent.

State of Wisconsin  
Department of Natural Resources

**MONITORING WELL DEVELOPMENT**  
Form 4400-13B

Facility/Project Name <b>Adams County Landfill &amp; Recycling Center</b>		County Name <b>Adams</b>	Well Name <b>MW-30P</b>
License/Permit/Monitoring Number <b>3150</b>		County Code <b>1</b>	Wisconsin Unique Well Number <b>VP-145</b>
		DNR Well Number <b>051</b>	
1. Can this well be purged dry?		Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	Before Development
2. Well Development method			After Development
surged with bailer and bailed		41	45.3
surged with bailer and pumped		61	45.32
surged with block and bailed		42	
surged with block and pumped		62	11/23/2015
surged with block, bailed and pumped		70	11/23/2015
compressed air		20	mm dd yy
bailed only		10	mm dd yy
pumped only	<input checked="" type="checkbox"/>	51	a.m.
pumped slowly		50	p.m.
Other			2:00 3:00
3. Time spent developing well	90	inches	a.m. p.m.
4. Depth of well (from top of well casing)	76.05	0	5.3 inches
5. Inside diameter of well	2.067	inches	inches
6. Volume of water in filter pack and well	10.4	Clear	Turbid
7. Volume of water removed from well	150	Turbid	Describe
8. Volume of water added (if any)	N/A	Describe	Clear
9. Source of water added	N/A		
10. Analysis performed on water added? (If yes, attach results)	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	See Additional Comments Below	
Fill in if drilling fluids were used and well is at solid waste facility			
14. Total suspended solids		mg/l	99 mg/l
15. COD		mg/l	mg/l

#### Additional comments on development:

Well developed by: Person's Name and Firm

Name: Eric J Madsen

Firm: Professional Service Industries Inc.

I hereby certify that the above information is true and correct  
to the best of my knowledge.

Signature:

Print Initials: E.JM

Firm: Professional Service Industries Inc.

NOTE: Shaded areas are for DNR use only. See instructions for more information.

Facility /Project Name Adams County Solid Waste Feasibility		Local Grid Location of Well N. ft. S. ft. E. W.	Well Name MW-31
Facility License, Permit or Monitoring Number 3150		Grid Origin Location Lat. _____ St. Plane _____ ft. N. Long. _____ ft. E. 2010709.457	Wis. Unique Well Number VP-146 DNR Well Number 052
Type of Well Water Table Observation Well Piezometer	11 12	Section Location of Waste/Source	Date Well Installed 11/17/15
Distance Well Is From Waste/Source Boundary 118 ft.		Well Installed By: (Person's Name and Firm) Joe Black - PSI	
Is Well A Point of Enforcement Std. Application? Yes _____ No _____		Location of Well Relative to Waste/Source u X Upgradient d Downdgradient n Sidegradient n Not Known	
A. Protective Pipe, top elevation 969.92 ft. MSL		1. Cap and Lock? X Yes _____ No _____	
B. Well casing, top elevation 969.70 ft. MSL		2. Protective cover pipe: a. Inside diameter: 4 in. b. Length: 5 ft.	
C. Land surface elevation 967.89 ft. MSL		c. Material: Steel X 04 Other _____	
D. Surface seal, bottom ft. MSL or 1 ft.		d. Additional protection? Yes _____ No X If yes, describe _____	
12. USCS classification of soil near screen: GP _____ GM _____ GC _____ GW _____ SW _____ SP _____ SM x SC _____ ML _____ MH _____ CL _____ CH _____ Bedrock _____		3. Surface seal: Bentonite 30 Concrete 01 Native Cuttings _____ Other x _____	
13. Sieve analysis attached? X Yes _____ No _____		4. Material between well casing and protective pipe: Bentonite 30 Annular Space Seal _____ Native cuttings _____ Other x _____	
14. Drilling method used: Rotary 50 Hollow Stem Auger x 41 Other _____		5. Annular space seal: a. Granular Bentonite X 33 b. Lbs/gal mud weight..... Bentonite-sand slurry 35 c. Lbs/gal mud weight..... Bentonite slurry 31 d. % Bentonite..... Bentonite-cement grout 50 e. 6.98 cubic ft volume added for any of the above	
15. Drilling fluid used: Air 01 Water 02 Drilling Mud 03 None x 99		f. How installed: Tremie 01 Tremie pumped 02 Gravity X 08	
16. Drilling additives used? Yes _____ No _____ Describe _____		6. Bentonite seal: a. Bentonite granules 33 b. 1/4in. 3/8in. x 1/2in. Bentonite Pellets X 32 c. Other _____	
17. Source of water (attach analysis):		7. Fine sand material: a. Manufacturer, product name and mesh size Red Flint Sand 0.45-0.55 b. Volume Added 0.70ft <sup>3</sup>	
E. Bentonite seal, top ft. MSL or 1.0 ft.		8. Filter pack material: a. Manufacturer, product name and mesh size Red Flint Sand 40 b. Volume Added 5.93ft <sup>3</sup>	
F. Fine sand, top ft. MSL or 21.0 ft.		9. Well casing: Flush threaded PVC schedule 40 X 23 Flush threaded PVC schedule 80 24 Other _____	
G. Filter pack, top ft. MSL or 23.0 ft.		10. Screen material: a. Screen type: PVC Factory cut X 11 Continuous slot 01 Other _____	
H. Screen joint, top ft. MSL or 25.0 ft.		b. Manufacturer EMI c. Slot size: 0.010 in. d. Slotted length: 15 ft.	
I. Well bottom ft. MSL or 40.0 ft.		11. Backfill Material (below filter pack): None X 14 Other _____	
J. Filter pack, bottom ft. MSL or 40.0 ft.			
K. Borehole, bottom ft. MSL or 40.0 ft.			
L. Borehole, diameter 8 in			
M. O.D. well casing 2.38 in			
N. I.D. well casing 2.06 in			

I hereby certify that the information on this form is true and correct to the best of my knowledge.

Signature

William Honea, Nicole Bader

Firm

AYRES ASSOCIATES

F.  
and ch. NR 141, Wis. Ad. Code. In accordance with ch. 144, Wis. Stats., failure to file this form may result in a forfeiture of not less than \$10, nor more than \$5000 for each day of violation. In accordance with ch. 147, Wis. Stats., failure to file this form may result in a forfeiture of not more than \$10,000 for each day of violation. NOTE: Shaded areas are for DNR use only. See instruction for more information including where the completed form should be sent.

## MONITORING WELL DEVELOPMENT

Form 4400-13B

Facility/Project Name <b>Adams County Landfill &amp; Recycling Center</b>		County Name <b>Adams</b>	Well Name <b>MW-31</b>
License/Permit/Monitoring Number <b>3150</b>		County Code <b>1</b>	Wisconsin Unique Well Number <b>VP-146</b>
		DNR Well Number <b>052</b>	
1. Can this well be purged dry?		Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	Before Development
2. Well Development method			After Development
surged with bailer and bailed		41	
surged with bailer and pumped		61	
surged with block and bailed		42	
surged with block and pumped		62	
surged with block, bailed and pumped		70	
compressed air		20	
bailed only		10	
pumped only	<input checked="" type="checkbox"/>	51	
pumped slowly		50	
Other			
3. Time spent developing well	180	min.	30.72
4. Depth of well (from top of well casing)	42.22	ft.	34.22
5. Inside diameter of well	2.067	in.	
6. Volume of water in filter pack and well	10.4	gal.	
7. Volume of water removed from well	280	gal.	
8. Volume of water added (if any)	N/A	gal.	
9. Source of water added	N/A		
10. Analysis performed on water added? (If yes, attach results)	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>		
		Date 11/23/2015	11/24/2015
		Time 10:25 a.m. p.m.	2:40 p.m.
		12. Sediment in well bottom 27.84 inches	0 inches
		13. Water clarity Clear Turbid <input checked="" type="checkbox"/> Describe	Clear Turbid <input checked="" type="checkbox"/> Describe
See Additional Comments Below			
Fill in if drilling fluids were used and well is at solid waste facility			
14. Total suspended solids		mg/l	12 mg/l
15. COD		mg/l	mg/l

#### Additional comments on development:

Well developed by: Person's Name and Firm

Name: Eric J Madsen

Firm: Professional Service Industries Inc.

I hereby certify that the above information is true and correct  
to the best of my knowledge.

Signature: Eric J. Molson  
Print Initials: EJM  
Firm: Professional Service Industries Inc.

Facility Name Adams Cnty Landfill & Recycling Center				Facility ID Number 701040560	License, Permit or Monitoring No. 03150			Date 3/4/2016			Completed By (Name and Firm) William Honea, Ayres Associates									
W1 Unique Well No	Well Name	DNR Well ID Number	Well Location	Dir. N S E W	Well Casing	Elevations			Reference		Depths			Screen Length	Well Type	Well Status	Enf. Std.	Grad- ient	Distance to Waste	
						Diam.	Type	Top of Well Casing	Ground Surface	MSL ( $\gamma$ )	Site Datum ( $\gamma$ )	Screen Top	Initial Groundwater	Well Depth						
DM435	MW-1	001	742163.63	N	6/7/1984	2	P	960.53	959.12	X		26.41	20.0	39.45	15	11/mw	A	U	117	
			2009288.72	E																
DM436	MW-1P	002	742159.41	N	7/15/1987	2	P	960.64	959.70	X		65.94	NA	71.65	5	12/pz	A	U	117	
			2009288.59	E																
DM437	MW-2	003	742159.34	N	6/6/1984	2	P	964.96	963.24	X		22.72	20.0	36.35	15	11/mw	A	S	115	
			2010389.72	E																
DM438	MW-2P	004	742158.76	N	7/14/1987	2	P	964.62	963.03	X		61.59	NA	66.43	5	12/pz	A	S	115	
			2010387.37	E																
DM439	MW-3	005	741290.78	N	6/6/1984	2	P	964.88	962.22	X		28.66	25.0	41.05	15	11/mw	A	X	D	283
			2010400.54	E																
DM440	MW-3P	006	741291.05	N	6/12/1986	2	P	964.04	962.07	X		66.97	NA	70.00	5	12/pz	A	X	D	283
			2010400.64	E																
DM441	MW-6	007	741239.75	N	6/9/1986	2	P	975.27	973.83	X		28.44	36.0	44.52	15	11/mw	A	X	U	235
			2009082.11	E																
DM442	MW-6P	008	741236.73	N	6/10/1986	2	P	976.08	974.22	X		69.06	NA	73.38	5	12/pz	A	X	U	235
			2009084.47	E																
DM443	MW-7	009	741656.35	N	6/10/1986	2	P	968.09	966.44	X		25.45	26.0	34.62	10	71/dw	A	U	233	
			2009093.52	E																
DM444	MW-7P	010	741660.34	N	6/11/1986	2	P	968.58	966.65	X		59.63	NA	64.46	5	72/dp	A	U	233	
			2009096.36	E																
DM445	MW-8	011	NS		6/12/1986	2	P	982.90	981.06	X		40.34	39.6	50.34	10	NA	I	N	0	
			NS																	
DM446	MW-9	012	740960.50	N	6/10/1986	2	P	965.54	963.03	X		20.71	21.0	32.53	10	11/dw	A	X	S	300
			2009652.58	E																

Location Coordinates Are:

State Plane Coordinate     Local Grid System  
 Northern     Central     Southern

Grid Origin Location: (Check if estimated:  )  
Lat. \_\_\_\_\_ ° \_\_\_\_\_ ' \_\_\_\_\_ "   Long. \_\_\_\_\_ ° \_\_\_\_\_ ' \_\_\_\_\_ " or  
St. Plane \_\_\_\_\_ ft. N. \_\_\_\_\_ ft. E. S/C/N Zone

Remarks: Updated State Plane Coordinates and top of casing elevations  
surface elevations, screen top depths, initial groundwater depth, and well depths  
NA- not available, NS- not surveyed

Facility Name Adams Cnty Landfill & Recycling Center				Facility ID Number 701040560		License, Permit or Monitoring No. 03150			Date 3/4/2016			Completed By (Name and Firm) William Honea, Ayres Associates								
W1 Unique Well No	Well Name	DNR Well ID Number	Well Location	Dir. N S E W	Well Casing	Elevations			Reference		Depths			Screen Length	Well Type	Well Status	Enf. Std.	Grad- ient	Distance to Waste	
						Date Established	Diam.	Type	Top of Well Casing	Ground Surface	MSL ( $\gamma$ )	Site Datum ( $\gamma$ )	Screen Top							Initial Groundwater
DM447	MW-16	013	2010072.45	N	8/12/1986	2	P	963.42	961.63	X		20.09	22.0	30.23	10	71/dw	A	S	150	
			741084.01	E																
DM448	MW-17	014	741663.28	N	8/11/1986	2	P	982.64	981.35	X		40.29	42.0	47.76	10	71/dw	A	D	167	
			2010307.73	E																
DM449	MW-17P	015	741667.30	N	7/14/1987	2	P	982.99	981.64	X		76.85	NA	80.87	5	72/dp	A	D	167	
			2010308.75	E																
DM450	MW-18	016	742146.71	N	8/12/1986	2	P	965.34	963.98	X		22.86	25.0	32.90	10	71/dw	A	S	100	
			2009729.00	E																
DM451	MW-18P	017	742145.63	N	8/13/1986	2	P	965.69	964.21	X		58.48	NA	64.00	5	72/dp	A	S	100	
			2009725.74	E																
DM452	MW-19	018	742113.11	N	7/15/1987	2	P	966.09	965.13	X		20.96	22.5	32.20	10	11/mw	A	S	100	
			2010223.30	E																
DM453	MW-19P	019	742116.00	N	7/15/1986	2	P	966.06	964.72	X		56.54	NA	60.88	5	12/pz	A	S	100	
			2010004.39	E																
EI302	MW-20	040	741448.48	N	2/23/1989	2	P	971.36	969.57	X		31.09	40.5	41.20	NA	11/dw	A	X	U	267
			2009048.28	E																
EI303	MW-21	041	741627.29	N	2/23/1989	2	P	967.16	964.97	X		25.69	25.5	36.64	NA	11/dw	A	X	U	283
			2009035.53	E																
EI304	MW-22	042	741640.54	N	2/24/1989	2	P	966.06	964.50	X		28.06	28.41	36.86	NA	11/dw	A	X	U	433
			2008885.05	E																
GN076	MW-25	045	740863.50	N	9/14/1990	2	P	965.14	961.99	X		27.65	28.0	37.23	10	11/dw	A	X	S	400
			2010034.57	E																
GN077	MW-26	046	740622.30	N	9/17/1990	2	P	962.87	959.97	X		26.40	26.0	33.80	10	11/dw	A	X	S	633
			2009881.13	E																

Location Coordinates Are:

State Plane Coordinate     Local Grid System  
 Northern     Central  
 Southern

Grid Origin Location: (Check if estimated:  )

Lat. \_\_\_\_ ° \_\_\_\_ ' \_\_\_\_ "   Long. \_\_\_\_ ° \_\_\_\_ ' \_\_\_\_ " or

St. Plane \_\_\_\_\_ ft. N. \_\_\_\_\_ ft. E. S/C/N Zone

Remarks: Updated State Plane Coordinates, top of casing elevations, ground

surface elevations, screen top depths, initial groundwater depth, and well depths

NA- not available, NS- not surveyed

Completion of this form is mandatory under s. NR 507.14 and NR 110.25 Wis. Adm. Code. Failure to file this form may result in forfeiture of not less than \$10 nor more than \$5,000 for each day of violation. Personally identifiable information provided is intended to be used by the Department for the purposes related to the waste management program.

Facility Name Adams Cnty Landfill & Recycling Center				Facility ID Number 701040560		License, Permit or Monitoring No. 03150			Date 3/4/2016			Completed By (Name and Firm) William Honea, Ayres Associates								
WI Unique Well No	Well Name	DNR Well ID Number	Well Location	Dir. N S E W	Date Established	Well Casing		Elevations		Reference		Depths			Screen Length	Well Type	Well Status	Enf. Stds.	Grad-ient	Distance to Waste
						Diam.	Type	Top of Well Casing	Ground Surface	MSL ( $\backslash$ )	Site Datum ( $\backslash$ )	Screen Top	Initial Groundwater	Well Depth						
VP147	MW-29	049	742169.15	N	11/20/2015	2	P	963.47	961.73	X		18.27	24.26	33.27	15	11/mw	A	X	U-S	236
			2010739.56	E																
VP144	MW-30	050	741638.77	N	11/17/2015	2	P	979.49	977.84	X		32.42	38.55	47.42	15	71/dw	A		U	118
			2010658.58	E																
VP145	MW-30P	051	741645.61	N	11/18/2015	2	P	979.69	977.94	X		70.30	45.46	75.30	5	72/dp	A		U	119
			2010659.79	E																
VP146	MW-31	052	741100.75	N	11/19/2015	2	P	969.70	967.90	X		24.89	30.90	39.89	15	11/mw	A	X	D-S	235
			2010709.46	E																
Location Coordinates Are:				Grid Origin Location: (Check if estimated: <input type="checkbox"/> )								Remarks:								
<input checked="" type="checkbox"/> State Plane Coordinate <input type="checkbox"/> Local Grid System <input type="checkbox"/> Northern <input type="checkbox"/> Central <input checked="" type="checkbox"/> Southern				Lat. ____ <sup>°</sup> ____' ____" Long. ____ <sup>°</sup> ____' ____" or St. Plane _____ ft. N. _____ ft. E. S/C/N Zone _____																

Completion of this form is mandatory under s. NR 507.14 and NR 110.25 Wis. Adm. Code. Failure to file this form may result in forfeiture of not less than \$10 nor more than \$5,000 for each day of violation. Personally identifiable information provided is intended to be used by the Department for the purposes related to the waste management program.