



USED OIL GENERATOR - NONHAZARDOUS WASTE HANDLER

Revision: 04/29/2022
WASTE & MATERIALS
MANAGEMENT PROGRAM

This Inspection Form, used for the inspection of facilities that generate used oil, evaluates facility compliance with Wisconsin's Used Oil Rules in ch. NR 679, subch. C, Wis. Adm. Code. A used oil generator is a person, by site, whose act or process produces used oil or whose act first causes used oil to become regulated.

Section 1: General Requirements

A. Used oil containing $\geq 1,000$ ppm halogens is managed as listed hazardous waste or the rebuttable presumption requirements have been met.		679.10(2)(a)2
B. Used oil containers and tanks are in good condition and not leaking.		679.22(2)
C. Used oil containers and tanks are marked "used oil".		679.22(3)(a)
D. Transporter has an EPA ID number, except when generator self-transport or has a tolling arrangement.		679.24
E. If oil containing materials are disposed of as a solid waste, the used oil has been properly drained so there is no visible sign of free-flowing oil and a waste determination has been properly made.		679.10(3)(a)
F. If used oil is burned in an on-site used oil-fired space heater, all of the following are met: 1. Only used oil from the generator or household do-it-yourselfers is burned. 2. The heater is designed with a maximum capacity of 0.5 million BTU per hour or less. 3. The combustion gases are vented to the ambient air.		679.23
G. If used oil is accepted from others or sent off-site to be burned in a space heater, the used oil meets fuel specifications and the marketer requirements in NR 679 subch. H are met.		679.11