

State of Wisconsin
DEPARTMENT OF NATURAL RESOURCES
101 S. Webster Street
Box 7921
Madison WI 53707-7921

Tony Evers, Governor
Karen Hyun, Ph.D., Secretary
Telephone 608-266-2621
Toll Free 1-888-936-7463
TTY Access via relay - 711



Ms. Tera Fong, Director, Water Division
U.S. EPA Region 5
77 West Jackson Blvd., W-15J
Chicago, IL 60604

Subject: Request for Approval of a Variance from Water Quality Standards for Chloride
Receiving Stream: Kummel Creek in Dodge County
Permittee: Village of Brownsville - WPDES Permit No. WI-0021601-09-0

Dear Ms. Fong:

In accordance with s. 283.15, Wis. Stats., and 40 CFR 131, the Wisconsin Department of Natural Resources (hereafter Department) requests U.S. EPA, Region 5 to approve a water quality standards variance for the above-referenced discharge. The water quality criterion for which the permittee is seeking a variance is contained in ch. NR 105, Wis. Adm. Code.

To assist your staff during their review, relevant background information pertaining to this variance is attached to this letter. The draft permit and variance were publicly noticed on April 30, 2026, and a hearing for the variance was held on June 23, 2026. The comment period has now ended. No public comments were received relating to the proposed variance.

The Department is committed to working with the permittee during the term of this variance to find a solution that will lead toward full compliance with the applicable water quality standard. Conditions on the variance, which are included in the WPDES permit, specify actions to be taken by the permittee and timetables for those actions. If the variance is approved by EPA, the Department will include the variance limitation and related conditions in the final WPDES permit.

The Department appreciates your consideration of this request. Should you have further questions regarding this matter, please contact Sarah Donoughe at 920-366-6076.

Sincerely,

Signed by:

30AA5DE79C8A40D
Joe Van Rossum, Deputy Division Administrator
Division of Environmental Management

DATED: 7/9/2026 | 8:31 AM CDT

Attachment

e-cc Jordan Main – DNR/SCR
Tim Elkins – EPA Region 5

BACKGROUND INFORMATION REGARDING WATER QUALITY STANDARDS VARIANCE

Receiving Stream and Classification: **Kummel Creek; Limited Forage Fish (LFF) community, non-public water supply and recreational use**

Criterion: **395 mg/L chronic toxicity criterion in ch. NR 105, Wis. Adm. Code**

Water Quality Based Effluent Limit: **420 mg/L as a weekly average; 420 mg/L as a monthly average**

Existing Permit Limit: **530 mg/L as a weekly average**

Permit Limit Based on Proposed Variance: **530 mg/L as a weekly average**

Duration of Variance: **Five years - from the effective date of permit reissuance through the proposed permit expiration date of September 30, 2031.**

Department Rationale for Approving Variance:

Section NR 106.83(2), Wis. Adm. Code, outlines findings that justify expediting chloride variances. More specifically:

- a) The Department considers treating these large volumes to produce effluent that reliably meets the water quality-based effluent limit to be prohibitively expensive. See Section VIII of the Facility Specific Standard Variance Data Sheet for clarification.
- b) End-of-pipe wastewater treatment technology for chloride produces concentrated brine that can be as much or more of a liability than the untreated effluent. Since the concentrated brine cannot be further treated, the only recourse for the disposal of the brine is transfer to another community, which is often not feasible.
- c) Appropriate chloride source reduction activities are preferable environmentally to effluent end-of-pipe treatment in most cases, since the end product of treatment (production of concentrated brine) does not remove the load of chloride from the environment.
- d) For some dischargers, attaining the water quality-based effluent limit for chloride may cause substantial and widespread adverse social and economic impacts in the area where the discharge is located.

The Department concludes that the applicant has met the requirements of Subchapter VII of ch. NR 106, Wis. Adm. Code, and s. 283.15, Wis. Stats. The Department further concludes that requiring the applicant to meet the water quality standard for chloride at this time would result in substantial and widespread adverse social and economic impacts. The Department therefore proposes to grant the variance for chloride.

Conditions to be Included in WPDES Permit: **See Draft Permit being sent to EPA in Electronic Format.**

Attachments:

Facility Specific Standard Variance Data Sheet

Certification from DNR Attorney – Bureau of Legal Services