


State of Wisconsin  
DEPARTMENT OF NATURAL RESOURCES  
Waukesha Service Center  
141 NW Barstow St, Room 180  
Waukesha WI 53188

Scott Walker, Governor  
Cathy Stepp, Secretary  
Telephone 608-266-2621  
Toll Free 1-888-936-7463  
TTY Access via relay - 711



June 22, 2017

Ben Heidemann  
Town & Country Engineering, Inc.  
2912 Marketplace Drive Suite 103  
Madison WI 53719

Subject: Dane Iowa WWTF Adaptive Management Plan: APPROVAL

Dear Mr. Heidemann:

Thank you for submitting an updated draft of an Adaptive Management Plan on behalf of the Dane Iowa Wastewater Commission. The initial plan was received in December 2016 and the updated plan was received on May 8, 2017. The Department has reviewed the updated report and has no additional comments at this time.

Sufficient evidence has been provided that the Dane Iowa WWTP will be able to comply with the minimum TP reduction requirement of 81 lbs/yr within Dane County. Subject to public comments, the Department sees no further impediments at this time for approval of your Adaptive Management Plan. The final Adaptive Management Plan will be included as part of the public noticed package for permit reissuance. You should expect to see adaptive management requirements in the draft permit WI-00449816 for public notice including in-stream monitoring and the minimum TP reduction of 81 lbs/yr.

If you have any questions or comments, please contact me at 262-574-2135 or at [amy.garbe@wisconsin.gov](mailto:amy.garbe@wisconsin.gov).

Thank you again,

Amy Garbe, P.E.  
Wastewater Engineer  
Wisconsin Department of Natural Resources

CC. Brian Sroda – Dane Iowa Wastewater Commission  
Jake Zimmerman – WDNR (email)