

Public Noticed Baldwin WWTF Draft Permit Fact Sheet

General Information

Permit Number	WI-0026891-11-0
Permittee Name and Address	Village of Baldwin Baldwin Community Center, 400 Cedar Street Baldwin WI 54002
Permitted Facility Name and Address	Baldwin Wastewater Treatment Facility 2021 Highway J, Baldwin, WI
Permit Term	February 01, 2025 to December 31, 2029
Discharge Location	NW1/4 NW1/4, Section 36, T29N R17W, Town of Hammond, St. Croix County, WI The north bank of Baldwin Creek, ¼ mile east of 200 th St., 500 feet south of County Rd J
Receiving Water	Baldwin Creek in Rush River of Chippewa River (lower) in St. Croix county
Stream Flow (Q _{7,10})	0 cfs
Stream Classification	Limited Forage Fish
Discharge Type	Existing, Continuous
Annual Average Design Flow (MGD)	0.540 MGD
Industrial or Commercial Contributors	Donaldson Company Inc (metal finishing)
Plant Classification	A1 - Suspended Growth Processes; B - Solids Separation; C - Biological Solids/Sludges; D - Disinfection; L - Laboratory; SS - Sanitary Sewage Collection System
Approved Pretreatment Program?	N/A

Facility Description

The Baldwin Wastewater Treatment Facility treats domestic wastewater from the Village of Baldwin and industrial categorical wastewater from Donaldson Company Inc (metal finishing). The annual average design flow of the current facility is 0.540 million gallons per day (MGD) and the actual annual average influent flow in 2023 was 0.373 MGD. The new treatment facility as of 2023 consists of an influent fine screen (HUBER Rotary Drum Fine Screen), grit removal, two oxidation ditches, two covered final clarifiers, ETS - compact, medium pressure in-line ultraviolet system for disinfection, and post aeration. Sludge is treated via a Membrane Thickener (MBT), transferred to a storage tank and then shipped to the West Central Wisconsin Biosolids Facility (WCWBF). Baldwin also receives centrate from WCWBF, and this is fed into the headworks of the facility. The permittee resubmitted a dissipative cooling (DC) request to the department. After review, the department determined that a free zone of passage exists in the receiving stream and thereby reapproved the DC request. Therefore, no effluent temperature limits are included this permit term, however one year of effluent temperature monitoring will be required. Both Baldwin Creek and the downstream Rush River are considered

"disappearing streams" at the point of proposed discharge. Under normal base-flow conditions it is anticipated that all of the effluent will seep into the ground prior to reaching the permanently flowing portion of the Rush River. Therefore, in addition to the surface water limits and monitoring based on surface water criteria, disinfection is year round and an annual waterway inspection is required to monitor and take action for any sinkholes that may develop. Significant monitoring and limitation changes for the upcoming permit term are as follows: 1) influent flow has been changed from "continuous" to "daily" for eDMR reporting purposes, and ammonia nitrogen, and phosphorus sample frequencies have increased to minimum monitoring frequencies (weekly to 3/week) for this size/type of facility, 2) the addition of effluent flow monitoring, 3) addition of annual effluent monitoring for total nitrogen, nitrite + nitrate nitrogen and TKN and effluent flow, 4) fecal coliform limits have been replaced with E. coli limits, 5) addition of acute Whole Effluent Toxicity (WET) testing, 6) addition of monitoring for effluent PFOS and PFOA once every two months and an associated determination of need schedule in accordance with s. NR 106.98(2)(b), Wis. Adm. Code., and 7) PFAS sludge sampling has been included in the proposed WPDES permit pursuant to ss. NR 214.18(5)(b) and NR 204.06(2)(b)9., Wis. Adm. Code to quantitate risk.

Substantial Compliance Determination

Enforcement During Last Permit: A Notice of Noncompliance (NON) letter was sent on April 12, 2024. Baldwin WWTF (Baldwin) recently upgraded their facility and have been working on optimizing the process. In addition, Baldwin also had some missing data, exceedances, and report issues that have been addressed. After a desktop review of all discharge monitoring reports, land app reports, compliance schedule, and a compliance inspection on October 10, 2023, this facility has been found to be in substantial compliance with their current permit.

Compliance determination made by Adebowale Adesanwo on 11/20/2024.

Sample Point Descriptions

Sample Point Designation		
Sample Point Number	Discharge Flow, Units, and Averaging Period	Sample Point Location, Waste Type/Sample Contents and Treatment Description (as applicable)
701	0.373 MGD (2023)	Representative influent samples shall be collected after the fine screen.
001	Treated effluent discharged to Baldwin Creek continuously throughout the year (Baldwin does not have an effluent flow meter)	Representative effluent samples shall be collected downstream from the final clarifier prior to discharge to Baldwin Creek. Dissolved oxygen, pH, and E. coli grab samples shall be collected after disinfection.
005	93.70 US. Dry Tons (2023)	As long as sludge is shipped to the West Central Wisconsin Biosolids Facility (WCWBF) for disposal, representative sludge samples shall be collected once per year and monitored for List 1 and PFAS. Sludge samples shall be collected prior to hauling and test results shall be reported on Form 3400-49 "Waste Characteristics Report". Hauled sludge reports shall be submitted on Form 3400-52 "Other Methods of Disposal or Distribution Report" following each year that sludge is hauled.

Permit Requirements

1 Influent – Monitoring Requirements

1.1 Sample Point Number: 701- INFLUENT TO PLANT

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Daily	Continuous	
BOD5, Total		mg/L	5/Week	24-Hr Flow Prop Comp	
Suspended Solids, Total		mg/L	5/Week	24-Hr Flow Prop Comp	

1.1.1 Changes from Previous Permit:

Influent limitations and monitoring requirements were evaluated for this permit term and the only change required in this permit section is the sample frequency for flow has been changed from “continuous” to “daily” for eDMR reporting purposes.

1.1.2 Explanation of Limits and Monitoring Requirements

Monitoring of influent flow, BOD5 and total suspended solids is required by s. NR 210.04(2), Wis. Adm. Code, to assess wastewater strengths and volumes and to demonstrate the percent removal requirements in s. NR 210.05, Wis. Adm. Code, and in the Standard Requirements section of the permit.

2 Surface Water - Monitoring and Limitations

2.1 Sample Point Number: 001- EFFLUENT to BALDWIN CREEK

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Daily	Continuous	
BOD5, Total	Daily Max	30 mg/L	3/Week	24-Hr Flow Prop Comp	
BOD5, Total	Monthly Avg	15 mg/L	3/Week	24-Hr Flow Prop Comp	
Suspended Solids, Total	Daily Max	30 mg/L	3/Week	24-Hr Flow Prop Comp	
Suspended Solids, Total	Monthly Avg	20 mg/L	3/Week	24-Hr Flow Prop Comp	
pH Field	Daily Max	9.0 su	Daily	Grab	
pH Field	Daily Min	6.0 su	Daily	Grab	
Dissolved Oxygen	Daily Min	4.0 mg/L	Daily	Grab	

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Daily	Continuous	
Nitrogen, Ammonia (NH3-N) Total	Monthly Avg	7.5 mg/L	3/Week	24-Hr Flow Prop Comp	Limit applies Oct - April.
Nitrogen, Ammonia (NH3-N) Total	Monthly Avg	2.2 mg/L	3/Week	24-Hr Flow Prop Comp	Limit applies May - Sept.
Nitrogen, Ammonia (NH3-N) Total	Weekly Avg	16 mg/L	3/Week	24-Hr Flow Prop Comp	Limit applies Oct - April.
Nitrogen, Ammonia (NH3-N) Total	Weekly Avg	5.6 mg/L	3/Week	24-Hr Flow Prop Comp	Limit applies May - Sept.
Nitrogen, Ammonia (NH3-N) Total	Daily Max - Variable	mg/L	3/Week	24-Hr Flow Prop Comp	Report the daily maximum Ammonia result in the Nitrogen, Ammonia (NH3-N) Total column of the eDMR. See Ammonia Limitation section below.
Nitrogen, Ammonia Variable Limit		mg/L	3/Week	See Table	Look up the variable ammonia limit from the 'Variable Ammonia Limitation' table and report the variable limit in the Ammonia Variable Limit column on the eDMR.
E. coli	Geometric Mean - Monthly	126 #/100 ml	2/Week	Grab	Limit effective upon permit issuance and effective year round.
E. coli	% Exceedance	10 Percent	Monthly	Calculated	Limit effective upon permit issuance and effective year round. See the E. coli Percent Limit section below. Enter the result in the DMR on the last day of the month.
Temperature Maximum		deg F	Weekly	Multiple Grab	Sample in 2028 only. See Temperature section below.
Chloride		mg/L	Quarterly	24-Hr Flow Prop Comp	Sample concurrently with WET tests when possible.
Phosphorus, Total	6-Month Avg	0.075 mg/L	3/Week	24-Hr Flow Prop Comp	
Phosphorus, Total	Monthly Avg	0.225 mg/L	3/Week	24-Hr Flow Prop Comp	

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Daily	Continuous	
Nitrogen, Total Kjeldahl		mg/L	See Listed Qtr(s)	24-Hr Flow Prop Comp	Annual in rotating quarters. See Nitrogen Series Monitoring section below.
Nitrogen, Nitrite + Nitrate Total		mg/L	See Listed Qtr(s)	24-Hr Flow Prop Comp	Annual in rotating quarters. See Nitrogen Series Monitoring section below.
Nitrogen, Total		mg/L	See Listed Qtr(s)	Calculated	Annual in rotating quarters. See Nitrogen Series Monitoring section below. Total Nitrogen shall be calculated as the sum of reported values for Total Kjeldahl Nitrogen and Total Nitrite + Nitrate Nitrogen.
PFOS		ng/L	1/ 2 Months	Grab	Monitoring only. See PFOS/PFOA Minimization Plan Determination of Need schedule.
PFOA		ng/L	1/ 2 Months	Grab	Monitoring only. See PFOS/PFOA Minimization Plan Determination of Need schedule.
Acute WET		rTUa	See Listed Qtr(s)	24-Hr Flow Prop Comp	See WET section below.

2.1.1 Changes from Previous Permit

Effluent limitations and monitoring requirements were evaluated for this permit term and the following changes were made from the previous permit: 1) effluent nitrogen and phosphorus sample frequencies have increased to minimum frequencies (weekly to 3/week) for this size/type of facility, 2) the addition of annual effluent monitoring for total nitrogen, nitrite + nitrate nitrogen and TKN, 2) fecal coliform limits have been replaced with E. coli limits, 3) addition of acute Whole Effluent Toxicity (WET) testing, 4) addition of monitoring for effluent PFOS and PFOA once every two months and an associated determination of need schedule in accordance with s. NR 106.98(2)(b), Wis. Adm. Code., and 4) PFAS sludge sampling has been included in the proposed WPDES permit pursuant to ss. NR 214.18(5)(b) and NR 204.06(2)(b)9., Wis. Adm. Code to quantitate risk.

See additional explanation of limits under “Explanation of Limits and Monitoring Requirements” below.

2.1.2 Explanation of Limits and Monitoring Requirements

Detailed discussions of limits and monitoring requirements can be found in the attached water quality-based effluent limits (WQBEL) memo dated October 14, 2024.

Monitoring Frequencies- The Monitoring Frequencies for Individual Wastewater Permits guidance (April 12, 2021) recommends that standard monitoring frequencies be included in individual wastewater permits based on the size and type of the facility, in order to characterize effluent quality and variability, to detect events of noncompliance, and to ensure consistency in permits issued across the state. Guidance and requirements in administrative code were considered when determining the appropriate monitoring frequencies for pollutants that have final effluent limits in effect during this permit term. Effluent sample frequencies for BOD and TSS, increased from 3/week to 5/week, and phosphorus and ammonia nitrogen from weekly to 3/week. These frequencies have increased to standard minimum frequencies for this size/type of facility.

Expression of Limits- In accordance with the federal regulation 40 CFR 122.45(d) and s. NR 205.065, Wis. Adm. Code, limits in this permit are to be expressed as **municipal weekly and monthly averages** whenever practicable. Minor changes have been made to **ammonia nitrogen**.

BOD, TSS and pH: Monitoring for BOD, TSS have increased to 5/week to correspond to the higher design flow, and the limits stay that same. However pH corresponds to the requirements in the current permit since the facility already has daily sampling due to daily maximum ammonia limitations requirements.

Ammonia- Current acute and chronic ammonia toxicity criteria for the protection of aquatic life are included in Tables 2C and 4B of ch. NR 105, Wis. Adm. Code. Subchapter IV of ch. NR 106 establishes the procedure for calculating water quality based effluent limitations (WQBELs) for ammonia. The permit requires seasonal weekly and monthly averages, in addition to variable daily maximum limits based on pH. Daily maximum ammonia limits that vary with effluent pH apply year-round. See table below titled “Variable Daily Maximum Ammonia Limits” for more information. Samples for ammonia shall be collected on the same day as the pH samples.

Effluent pH s.u.	Limit mg/L	Effluent pH s.u.	Limit mg/L	Effluent pH s.u.	Limit mg/L
6.0 ≤ pH ≤ 6.1	54	7.0 < pH ≤ 7.1	33	8.0 < pH ≤ 8.1	6.9
6.1 < pH ≤ 6.2	53	7.1 < pH ≤ 7.2	30	8.1 < pH ≤ 8.2	5.7
6.2 < pH ≤ 6.3	52	7.2 < pH ≤ 7.3	26	8.2 < pH ≤ 8.3	4.7
6.3 < pH ≤ 6.4	51	7.3 < pH ≤ 7.4	23	8.3 < pH ≤ 8.4	3.9
6.4 < pH ≤ 6.5	49	7.4 < pH ≤ 7.5	20	8.4 < pH ≤ 8.5	3.2
6.5 < pH ≤ 6.6	47	7.5 < pH ≤ 7.6	17	8.5 < pH ≤ 8.6	2.7
6.6 < pH ≤ 6.7	45	7.6 < pH ≤ 7.7	14	8.6 < pH ≤ 8.7	2.2
6.7 < pH ≤ 6.8	42	7.7 < pH ≤ 7.8	12	8.7 < pH ≤ 8.8	1.8
6.8 < pH ≤ 6.9	39	7.8 < pH ≤ 7.9	10	8.8 < pH ≤ 8.9	1.6
6.9 < pH ≤ 7.0	36	7.9 < pH ≤ 8.0	8.4	8.9 < pH ≤ 9.0	1.3

Chloride- Acute and chronic chloride toxicity criteria for the protection of aquatic life are included in Tables 1 and 5 of ch. NR 105, Wis. Adm. Code. Subchapter VII of ch. NR 106 establishes the procedure for calculating water quality based effluent limitations (WQBELs) for chloride. To ensure that representative sample results are available at the next permit issuance, quarterly monitoring is required.

Disinfection/E. Coli/Fecal Coliform: Year-round fecal coliform monitoring and limits have been replaced with *Escherichia coli* (*E. coli*) monitoring and limits. Year-round requirements are due to the receiving water being a disappearing stream which has the potential of the discharge going to groundwater if future sinkholes develop. Revisions to bacteria surface water quality criteria to protect recreational uses and accompanying *E. coli* WPDES permit implementation procedures became effective May 1, 2020. The new rule requires that WPDES permits for facilities with required disinfection include monitoring for *E. coli* while facilities are disinfecting during the recreation period and establish effluent limitations for *E. coli* established in s. NR 210.06 (2), Wis. Adm Code. The administrative code rule changes included the following actions: revised the bacteria water quality criteria from fecal coliform to *E. coli* to protect recreation in ch. NR 102, Wis. Adm. Code.; removed fecal coliform criteria for certain individual waters from ch. NR 104, Wis. Adm. Code.; revised permit requirements for publicly and privately owned sewage treatment works in ch. NR 210, Wis. Adm. Code.; and, updated approved analytical methods for bacteria in ch. NR 219, Wis. Adm. Code.

Thermal- Requirements for Temperature are included in NR 102 Subchapter II Water Quality Standards for Temperature and NR 106 Subchapter V Effluent Limitations for Temperature. Thermal discharges must meet the Public Health criterion of 120 degrees F and the Fish & Aquatic Life criteria which are established to protect aquatic communities from lethal and sub-lethal thermal effects. The permittee re-submitted a dissipative cooling (DC) request to the department. After review, the department re- approved the DC request as part of the Water Quality Based Effluent Limitations Memo for Baldwin dated October 14, 2024. Therefore, no effluent temperature limits are included this permit term, however one year of effluent temperature monitoring will be required.

Phosphorus - Phosphorus rules became effective December 1, 2010 per NR 217, Wis. Adm. Code, that required the permittee to comply with water quality based effluent limits (WQBELs) for total phosphorous. Phosphorus limits continue from the previous issuance.

Total Nitrogen Monitoring (NO₂+NO₃, TKN and Total N): The Department has included effluent monitoring for Total Nitrogen in the permit through the authority under §§ 283.55(1)(e), Wis. Stats., which allows the department to require the permittee to submit information necessary to identify the type and quantity of any pollutants discharged from the point source, and through s. NR 200.065(1)(h), Wis. Adm. Code, which allows for this monitoring to be collected during the permit term. More information on the justification to include total nitrogen monitoring in wastewater permits can be found in the “Guidance for Total Nitrogen Monitoring in Wastewater Permits” dated October 1, 2019. Monitoring for total nitrogen, nitrite + nitrate nitrogen and TKN is required annually in specific quarters to obtain seasonal variation as listed in the permit.

PFOS and PFOA- NR 106 Subchapter VIII – Permit Requirements for PFOS and PFOA Dischargers became effective on August 1, 2022. At the first reissuance of a WPDES permit after August 1, 2022, the new rule requires WPDES permits for industrial dischargers to be evaluated on a case-by-case basis to determine if monitoring is required pursuant to s. NR 106.98(2)(d), Wis. Adm. Code. The department evaluated the need for PFOS and PFOA monitoring taking into consideration industry type and other potential sources of PFOS or PFOA. Based on information available at the time the proposed permit was drafted, it was identified that the industrial discharger category may be a potential source of PFOS/PFOA.

Therefore, bimonthly monitoring is included. The initial determination of need sampling shall be conducted for up to two years in order to determine if the permitted discharge has the reasonable potential to cause or contribute to an exceedance of the PFOS or PFOA standards under s. NR 102.04(8)(d)1, Wis. Adm. Code.

Whole Effluent Toxicity (WET): Whole effluent toxicity (WET) testing requirements and limits (if applicable) are determined in accordance with ss. NR 106.08 and NR 106.09 Wis. Adm. Code, as revised August 2016. (See the current version of the Whole Effluent Toxicity Program Guidance Document and checklist and WET information, guidance and test methods at <http://dnr.wi.gov/topic/wastewater/wet.html>). Using this guidance, 2 Acute tests are required.

3 Land Application - Monitoring and Limitations

Municipal Sludge Description						
Sample Point	Sludge Class (A or B)	Sludge Type (Liquid or Cake)	Pathogen Reduction Method	Vector Attraction Method	Reuse Option	Amount Reused/Disposed (Dry Tons/Year)
005	B	Liquid	N/A	N/A	Hauled	93
Does sludge management demonstrate compliance? yes						
Is additional sludge storage required? no						
Is Radium-226 present in the water supply at a level greater than 2 pCi/liter? no						
Is a priority pollutant scan required? no						

3.1 Sample Point Number: 005- SLUDGE HAULED TO WCWBF

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Solids, Total		Percent	Annual	Composite	
Arsenic Dry Wt	Ceiling	75 mg/kg	Annual	Composite	
Arsenic Dry Wt	High Quality	41 mg/kg	Annual	Composite	
Cadmium Dry Wt	Ceiling	85 mg/kg	Annual	Composite	
Cadmium Dry Wt	High Quality	39 mg/kg	Annual	Composite	
Copper Dry Wt	Ceiling	4,300 mg/kg	Annual	Composite	
Copper Dry Wt	High Quality	1,500 mg/kg	Annual	Composite	
Lead Dry Wt	Ceiling	840 mg/kg	Annual	Composite	
Lead Dry Wt	High Quality	300 mg/kg	Annual	Composite	
Mercury Dry Wt	Ceiling	57 mg/kg	Annual	Composite	
Mercury Dry Wt	High Quality	17 mg/kg	Annual	Composite	
Molybdenum Dry Wt	Ceiling	75 mg/kg	Annual	Composite	
Nickel Dry Wt	Ceiling	420 mg/kg	Annual	Composite	
Nickel Dry Wt	High Quality	420 mg/kg	Annual	Composite	
Selenium Dry Wt	Ceiling	100 mg/kg	Annual	Composite	
Selenium Dry Wt	High Quality	100 mg/kg	Annual	Composite	
Zinc Dry Wt	Ceiling	7,500 mg/kg	Annual	Composite	
Zinc Dry Wt	High Quality	2,800 mg/kg	Annual	Composite	
PFOA + PFOS		ug/kg	Annual	Calculated	Report the sum of PFOA and PFOS. See PFAS

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
					Permit Sections for more information.
PFAS Dry Wt			Annual	Grab	Perfluoroalkyl and Polyfluoroalkyl Substances based on updated DNR PFAS List. See PFAS Permit Sections for more information.

3.1.1 Changes from Previous Permit:

Sludge limitations and monitoring requirements were evaluated for this permit term and the following changes were made from the previous permit. See additional explanation of limits under “Explanation of Limits and Monitoring Requirements” below.

PFAS –Monitoring is required annually pursuant to s. NR 204.06(2)(b)9., Wis. Adm. Code.

3.1.2 Explanation of Limits and Monitoring Requirements

Requirements for disposal, including land application of municipal sludge, are determined in accordance with ch. NR 204, Wis. Adm. Code. Ceiling and high-quality limits for metals in sludge are specified in s. NR 204.07(5). Requirements for pathogens are specified in s. NR 204.07(6) and in s. NR 204.07 (7) for vector attraction requirements. Limitations for PCBs are addressed in s. NR 204.07(3)(k). Radium requirements are addressed in s. NR 204.07(3)(n).

PFAS- The presence and fate of PFAS in municipal and industrial sludges is an emerging public health concern. EPA is currently developing a risk assessment to determine future land application rates and expects to release this risk assessment by the end of 2024. In the interim, the department has developed the “Interim Strategy for Land Application of Biosolids and Industrial Sludges Containing PFAS.”

Collecting sludge data on PFAS concentrations from a wide range of wastewater treatment facilities will help protect public health from exposure to elevated levels of PFAS and determine the department’s implementation of EPA’s recommendations. To quantitate this risk, PFAS sampling has been included in this WPDES permit pursuant to ss. NR 214.18(5)(b) and NR 204.06(2)(b)9., Wis. Adm. Code.

4 Schedules

4.1 Annual Waterway Inspection

Required Action	Due Date
Maintenance: If swallets, sinkholes or fractured bedrock are observed during the waterway inspection or at other times, the permittee shall report presence of swallets or sinkholes to the Department within 24 hours. Implement a temporary remedy as soon as possible but not later than 7 days from discovery of the problem. Implement a permanent remedy within 60 days of discovery.	

<p>Annual Inspection: Inspect waterway once per year from point of discharge to point effluent seeps into the ground. The inspection should be done at a time of year when snow or excessive vegetation does not interfere with the inspection. Document on an 8 1/2 x 11 inch map the location where effluent seeps into the bed of the waterway. Mark locations of any swallets, sinkholes, fractured bedrock or similar features on the map. Submit a report that summarizes the results of the inspection to the Department.</p> <p>Due Date: Within 30 days of the date of the inspection but not later than October 31 of each year.</p>	
--	--

4.1.1 Explanation of Schedule

Annual Waterway Inspection: The waterway inspection is included in the permit to make sure that any swallets or sinkholes are found and repaired as soon as possible.

4.2 PFOS/PFOA Minimization Plan Determination of Need

Required Action	Due Date
<p>Report on Effluent Discharge: Submit a report on effluent PFOS and PFOA concentrations and include an analysis of trends in monthly and annual average PFOS and PFOA concentrations. This analysis should also include a comparison to the applicable narrative standard in s. NR 102.04(8)(d), Wis. Adm. Code.</p> <p>This report shall include all additional PFOS and PFOA data that may be collected including any influent, intake, in-plant, collection system sampling, and blank sample results.</p>	03/31/2026
<p>Report on Effluent Discharge and Evaluation of Need: Submit a final report on effluent PFOS and PFOA concentrations and include an analysis of trends in monthly and annual average PFOS and PFOA concentrations of data collected over the last 24 months. The report shall also provide a comparison on the likelihood of the facility needing to develop a PFOS/PFOA minimization plan.</p> <p>This report shall include all additional PFOS and PFOA data that may be collected including any influent, intake, in-plant, collection system sampling, and blank sample results.</p> <p>The permittee shall also submit a request to the department to evaluate the need for a PFOS/PFOA minimization plan.</p> <p>If the Department determines a PFOS/PFOA minimization plan is needed based on a reasonable potential evaluation, the permittee will be required to develop a minimization plan for Department approval no later than 90 days after written notification was sent from the Department. The Department will modify or revoke and reissue the permit to include PFOS/PFOA minimization plan reporting requirements along with a schedule of compliance to meet WQBELs. Effluent monitoring of PFOS and PFOA shall continue as specified in the permit until the modified permit is issued.</p> <p>If, however, the Department determines there is no reasonable potential for the facility to discharge PFOS or PFOA above the narrative standard in s. NR 102.04(8)(d), Wis. Adm. Code, no further action is required and effluent monitoring of PFOS and PFOA shall continue as specified in the permit.</p>	03/31/2027

4.1.2 Explanation of Schedule

PFOS/PFOA Minimization Plan Determination of Need- As stated above, ch. NR 106 Subchapter VIII – Permit Requirements for PFOS and PFOA Dischargers became effective on August 1, 2022. Section NR 106.98, Wis. Adm. Code, specifies steps to generate data in order to determine the need for reducing PFOS and PFOA in the discharge. Data generated per the effluent monitoring requirements will be used to determine the need for developing a PFOS/PFOA minimization plan. As part of the schedule, the permittee is required to submit two annual Reports on Effluent Discharge.

If the Department determines that a minimization plan is needed, the permit will be modified or revoked/reissued to include additional requirements.

Other Comments

Fact check included comments to clarify monitoring frequencies. After review, effluent ammonia and phosphorus monitoring will increase to minimum frequency for this type of facility/size to 3/week.

Attachments

Water Quality Based Effluent Limits Memo

Justification Of Any Waivers From Permit Application Requirements

None

Public Notice Paper: The Baldwin Bulletin, 805 Main St., PO Box 76, Baldwin, WI 54002-0076

Prepared By: Angela Parkhurst Wastewater Specialist Date: 01/08/2025

CORRESPONDENCE/MEMORANDUM

DATE: October 14, 2024

TO: Angela Parkhurst– WCR/Eau Claire

FROM: Benjamin Hartenbower – WCR/Eau Claire

SUBJECT: Water Quality-Based Effluent Limitations for the Baldwin Wastewater Treatment Facility
WPDES Permit No. WI-0026891

This is in response to your request for an evaluation of the need for water quality-based effluent limitations (WQBELs) using chapters NR 102, 104, 105, 106, 207, 210, 212, and 217 of the Wisconsin Administrative Code (where applicable), for the discharge from the Baldwin Wastewater Treatment Facility in St. Croix County. This municipal wastewater treatment facility (WWTF) discharges to Baldwin Creek, located in the Rush River Watershed in the Lower Chippewa River Basin. The evaluation of the permit recommendations is discussed in more detail in the attached report.

Based on our review, the following recommendations are made on a chemical-specific basis at Outfall 001:

Parameter	Daily Maximum	Daily Minimum	Weekly Average	Monthly Average	Six-Month Average	Footnotes
BOD ₅	30 mg/L			15 mg/L		1
TSS	30 mg/L			20 mg/L		1
pH	9.0 s.u.	6.0 s.u.				1
Dissolved Oxygen		4.0 mg/L				1
Ammonia Nitrogen May - September October - April	Variable Variable		5.6 mg/L 16 mg/L	2.2 mg/L 7.5 mg/L		2,3
<i>E. Coli</i>				126 #/100 mL geometric mean		4
Chloride						1,5
Total Dissolved Solids						1,5
Temperature						1,5
PFOS and PFOA						6
Phosphorus				0.225 mg/L	0.075 mg/L	
TKN, Nitrate+Nitrite, and Total Nitrogen						1,7
Acute WET						8

Footnotes:

1. No changes from the current permit.
2. Additional limits to comply with the expression of limits requirements in ss. NR 106.07 and NR 205.065(7), Wis. Adm. Codes, are included in bold.


3. The variable daily maximum ammonia nitrogen limit table corresponding to effluent pH values. These limits apply year-round.

Effluent pH s.u.	Limit mg/L	Effluent pH s.u.	Limit mg/L	Effluent pH s.u.	Limit mg/L
6.0 ≤ pH ≤ 6.1	54	7.0 < pH ≤ 7.1	33	8.0 < pH ≤ 8.1	6.9
6.1 < pH ≤ 6.2	53	7.1 < pH ≤ 7.2	30	8.1 < pH ≤ 8.2	5.7
6.2 < pH ≤ 6.3	52	7.2 < pH ≤ 7.3	26	8.2 < pH ≤ 8.3	4.7
6.3 < pH ≤ 6.4	51	7.3 < pH ≤ 7.4	23	8.3 < pH ≤ 8.4	3.9
6.4 < pH ≤ 6.5	49	7.4 < pH ≤ 7.5	20	8.4 < pH ≤ 8.5	3.2
6.5 < pH ≤ 6.6	47	7.5 < pH ≤ 7.6	17	8.5 < pH ≤ 8.6	2.7
6.6 < pH ≤ 6.7	45	7.6 < pH ≤ 7.7	14	8.6 < pH ≤ 8.7	2.2
6.7 < pH ≤ 6.8	42	7.7 < pH ≤ 7.8	12	8.7 < pH ≤ 8.8	1.8
6.8 < pH ≤ 6.9	39	7.8 < pH ≤ 7.9	10	8.8 < pH ≤ 8.9	1.6
6.9 < pH ≤ 7.0	36	7.9 < pH ≤ 8.0	8.4	8.9 < pH ≤ 9.0	1.3

4. Bacteria limits apply year-round. Additional limit: No more than 10 percent of *E. coli* bacteria samples collected in any calendar month may exceed 410 count/100 mL.
5. Monitoring only.
6. Monitoring once every two months is required in accordance with s. NR 106.98(2), Wis. Adm. Code.
7. As recommended in the Department's October 1, 2019 Guidance for Total Nitrogen Monitoring in Wastewater Permits, annual total nitrogen monitoring is recommended for all minor municipal permittees. Total Nitrogen is the sum of nitrate (NO₃), nitrite (NO₂), and total kjeldahl nitrogen (TKN) (all expressed as N).
8. Two acute WET tests are recommended in the reissued permit. Sampling WET concurrently with any chemical-specific toxic substances is recommended. Tests should be done in rotating quarters, to collect seasonal information about this discharge and should continue after the permit expiration date (until the permit is reissued).

Please consult the attached report for details regarding the above recommendations. If there are any questions or comments, please contact Benjamin Hartenbower at (715) 225-4705 or Benjamin.Hartenbower@wisconsin.gov or Diane Figiel at Diane.Figiel@wisconsin.gov.

Attachments (3) – Narrative, Thermal Table, & Map

PREPARED BY:  Date: 10/14/2024
Benjamin Hartenbower, PE,
Water Resources Engineer

E-cc:

Adebowale Adesanwo, Wastewater Engineer – WCR/Eau Claire
Geisa Thielen, Regional Wastewater Supervisor – WCR/Eau Claire
Diane Figiel, Water Resources Engineer – WY/3
Chris Willger, Water Quality Biologist – WCR/Eau Claire
Nate Willis, Wastewater Engineer – WY/3

**Water Quality-Based Effluent Limitations for
the Baldwin Wastewater Treatment Facility
WPDES Permit No. WI-0026891**

Prepared by: Benjamin P. Hartenbower

PART 1 – BACKGROUND INFORMATION

Facility Description:

The Baldwin Wastewater Treatment Facility treats domestic wastewater from the Village of Baldwin and industrial categorical wastewater from Donaldson Company Inc (metal finishing). The treatment facility consists of parallel vertical fine screens, stacked tray vortex grit removal, influent pumping, splitter structure, oxidation ditch with biological phosphorus removal, splitter structure, final clarifiers, closed vessel UV disinfection, reactive sand filtration for low level phosphorus removal, cascade aeration and discharge to Baldwin Creek via gravity. Solids removed from clarifiers are thickened via membrane, stored and transported to the WCWBF.

Attachment #3 is a map of the area showing the approximate location of Outfall 001.

Existing Permit Limitations

The current permit, expiring on September 30, 2024, includes the following effluent limitations and monitoring requirements.

Parameter	Daily Maximum	Daily Minimum	Weekly Average	Monthly Average	Six-Month Average	Footnotes
BOD ₅	30 mg/L			15 mg/L		1
TSS	30 mg/L			20 mg/L		1
pH	9.0 s.u.	6.0 s.u.				1
Dissolved Oxygen		4.0 mg/L				1
Ammonia Nitrogen May - September October - April	Variable Variable		5.6 mg/L 16 mg/L	2.2 mg/L 10 mg/L		2,3
Fecal Coliform year-round			780 #/100 mL geometric mean	400 #/100 mL geometric mean		2
Chloride						4
Total Dissolved Solids						4
Temperature						4
Phosphorus Interim Final WQBEL				4.70 mg/L 0.225 mg/L	0.075 mg/L	5
TKN, Nitrate+Nitrite, and Total Nitrogen						4

Footnotes:

Attachment #1

1. These limitations are not being evaluated as part of this review. Because the water quality criteria (WQC), reference effluent flow rates, and receiving water characteristics have not changed, limitations for these water quality characteristics do not need to be re-evaluated at this time.
2. Additional limits to comply with the expression of limits requirements in ss. NR 106.07 and NR 205.065(7), Wis. Adm. Codes, are included in bold.
3. The variable daily maximum ammonia nitrogen limit table corresponding to effluent pH values. These limits apply year-round.

Effluent pH s.u.	Limit mg/L	Effluent pH s.u.	Limit mg/L	Effluent pH s.u.	Limit mg/L
$6.0 \leq \text{pH} \leq 6.1$	54	$7.0 < \text{pH} \leq 7.1$	33	$8.0 < \text{pH} \leq 8.1$	6.9
$6.1 < \text{pH} \leq 6.2$	53	$7.1 < \text{pH} \leq 7.2$	30	$8.1 < \text{pH} \leq 8.2$	5.7
$6.2 < \text{pH} \leq 6.3$	52	$7.2 < \text{pH} \leq 7.3$	26	$8.2 < \text{pH} \leq 8.3$	4.7
$6.3 < \text{pH} \leq 6.4$	51	$7.3 < \text{pH} \leq 7.4$	23	$8.3 < \text{pH} \leq 8.4$	3.9
$6.4 < \text{pH} \leq 6.5$	49	$7.4 < \text{pH} \leq 7.5$	20	$8.4 < \text{pH} \leq 8.5$	3.2
$6.5 < \text{pH} \leq 6.6$	47	$7.5 < \text{pH} \leq 7.6$	17	$8.5 < \text{pH} \leq 8.6$	2.7
$6.6 < \text{pH} \leq 6.7$	45	$7.6 < \text{pH} \leq 7.7$	14	$8.6 < \text{pH} \leq 8.7$	2.2
$6.7 < \text{pH} \leq 6.8$	42	$7.7 < \text{pH} \leq 7.8$	12	$8.7 < \text{pH} \leq 8.8$	1.8
$6.8 < \text{pH} \leq 6.9$	39	$7.8 < \text{pH} \leq 7.9$	10	$8.8 < \text{pH} \leq 8.9$	1.6
$6.9 < \text{pH} \leq 7.0$	36	$7.9 < \text{pH} \leq 8.0$	8.4	$8.9 < \text{pH} \leq 9.0$	1.3

4. Monitoring only.
5. A compliance schedule is in the current permit to meet the final WQBEL by December 1, 2023.

Receiving Water Information

- Name: Baldwin Creek
- Waterbody Identification Code (WBIC): 2444600
- Classification used in accordance with chs. NR 102 and 104, Wis. Adm. Code: Limited Forage Fish (LFF), non-public water supply.
- Low flows used in accordance with chs. NR 106 and 217, Wis. Adm. Code:
 - 7-Q₁₀ = 0 cfs
 - 7-Q₂ = 0 cfs
 - Harmonic Mean Flow = 0 cfs
- Hardness = 270 mg/L as CaCO₃. This value represents the geometric mean effluent data. Effluent hardness is used in place of receiving water because there is no receiving water flow upstream of the discharge.
- % of low flow used to calculate limits in accordance with s. NR 106.06(4)(c)5., Wis. Adm. Code: Not applicable where the receiving water low flows are zero.
- Source of background concentration data: Background concentrations are not included because they do not impact the calculated WQBEL when the receiving water low flows are equal to zero.
- Multiple dischargers: None
- Impaired water status: None

Effluent Information:

- Design Flow Rates(s):
Annual Average = 0.540 MGD (Million Gallons per Day)
For reference, the actual average flow from December 2019 to August 2024 was 0.379 MGD.
- Hardness = 270 mg/L as CaCO₃. This value represents the geometric mean of 4 effluent samples collected from 01/18/2024 to 02/17/2024.
- Acute dilution factor used in accordance with s. NR 106.06 (3) (c), Wis. Adm. Code: Not applicable – this facility does not have an approved Zone of Initial Dilution (ZID).
- Water Source: Domestic wastewater with water supply from wells and nondomestic contributions from Donaldson Company, Northern Metals, Vital Plastics, Nolato Contour, Skycoat LLC, and K-tech.
- Additives: Ferric Chloride
- Effluent characterization: This facility is categorized as a minor municipality, so the permit application required effluent sample analyses for a limited number of common pollutants, as specified in s. NR 200.065, Table 1, Wis. Adm. Code, primarily metal substances plus Hardness. The permit-required monitoring for Ammonia Nitrogen, Chloride, Temperature, and Phosphorus from December 2019 to August 2024 is used in this evaluation.

Chemical Specific Effluent Data at Outfall 001

	Chloride mg/L
1-day P ₉₉	399
4-day P ₉₉	318
30-day P ₉₉	273
Mean	250
Std	53
Sample size	19
Range	184 - 357

Chemical Specific Effluent Data at Outfall 001

Sample Date	Copper µg/L
01/18/2024	9.2
01/21/2024	8.5
01/24/2024	7.4
01/27/2024	10
01/30/2024	6.9
02/02/2024	8.6
02/05/2024	10
02/08/2024	15
02/11/2024	9.9
02/14/2024	11
02/17/2024	14
1-day P ₉₉	17.29
4-day P ₉₉	13.32

Effluent data for substances for which a single sample was analyzed is shown in the tables in Part 2 below, in the column titled “MEAN EFFL. CONC.”.

The following table presents the average concentrations and loadings at Outfall 001 from December 2019 to August 2024 for all parameters with limits in the current permit to meet the requirements of s. NR 201.03(6):

	Average Measurement
BOD ₅	3.9 mg/L*
TSS	3.7 mg/L*
pH	7.34 s.u.
Dissolved Oxygen	7.31 mg/L
Ammonia Nitrogen	0.94 mg/L*
Fecal Coliform	278#/100 mL
Phosphorus	2.41 mg/L*

*Results below the level of detection (LOD) were included as zeroes in calculation of average.

PART 2 – WATER QUALITY-BASED EFFLUENT LIMITATIONS FOR TOXIC SUBSTANCES – EXCEPT AMMONIA NITROGEN

Permit limits for toxic substances are required whenever any of the following occur:

1. The maximum effluent concentration exceeds the calculated limit (s. NR 106.05(3), Wis. Adm. Code)
2. If 11 or more detected results are available in the effluent, the upper 99th percentile (or P₉₉) value exceeds the comparable calculated limit (s. NR 106.05(4), Wis. Adm. Code)
3. If fewer than 11 detected results are available, the mean effluent concentration exceeds 1/5 of the calculated limit (s. NR 106.05(6), Wis. Adm. Code)

Acute Limits based on 1-Q₁₀

Daily maximum effluent limitations for toxic substances are based on the acute toxicity criteria (ATC), listed in ch. NR 105, Wis. Adm. Code. Previously daily maximum limits for toxic substances were calculated as two times the ATC. However, changes to ch. NR 106, Wis. Code, (September 1, 2016) require the Department to calculate acute limitations using the same mass balance equation as used for other limits along with the 1-Q₁₀ receiving water low flow to determine if more restrictive effluent limitations are needed to protect the receiving stream from discharges which may cause or contribute to an exceedance of the acute water quality standards. The mass balance equation is provided below.

$$\text{Limitation} = \frac{(\text{WOC}) (Q_s + (1-f) Q_e) - (Q_s - f Q_e) (C_s)}{Q_e}$$

Where:

WQC = Acute toxicity criterion or secondary acute value according to ch. NR 105, Wis. Adm. Code.

Qs = average minimum 1-day flow which occurs once in 10 years (1-day Q₁₀)
 if the 1-day Q₁₀ flow data is not available = 80% of the average minimum 7-day flow which occurs once in 10 years (7-day Q₁₀).

Qe = Effluent flow (in units of volume per unit time) as specified in s. NR 106.06(4)(d), Wis. Adm. Code.

f = Fraction of the effluent flow that is withdrawn from the receiving water, and

Cs = Background concentration of the substance (in units of mass per unit volume) as specified in s. NR 106.06(4)(e), Wis. Adm. Code.

If the receiving water is effluent dominated under low stream flow conditions, the 1-Q₁₀ method of limit calculation produces the most stringent daily maximum limitations and should be used while making reasonable potential determinations. This is the case for the Baldwin Wastewater Treatment Facility.

The following tables list the calculated WQBELs for this discharge along with the results of effluent sampling. All concentrations are expressed in terms of micrograms per Liter (µg/L), except for hardness and chloride (mg/L).

Daily Maximum Limits based on Acute Toxicity Criteria (ATC)

RECEIVING WATER FLOW = 0.00 cfs, (1-Q₁₀ (estimated as 80% of 7-Q₁₀)), as specified in s. NR 106.06(3)(bm), Wis. Adm. Code.

SUBSTANCE	REF. HARD.* mg/L	ATC	MEAN BACK-GRD.	MAX. EFFL. LIMIT**	1/5 OF EFFL. LIMIT	MEAN EFFL. CONC.	1-day P ₉₉	1-day MAX. CONC.
Arsenic		340		340	68	<1.1		
Cadmium	270	32.2		32.2	6.4	<0.19		
Chromium (+3)	270	4066		4066	813	1.2		
Copper	270	39.6		39.6			17.3	15.0
Lead	270	279		279	56	<4.3		
Nickel	268	1080		1080	216	4.4		
Zinc	270	287		287	57	54.00		
Chloride		757		757			399	357

* The indicated hardness may differ from the effluent hardness because the effluent hardness exceeded the maximum range in ch. NR 105, Wis. Adm. Code, over which the acute criteria are applicable. In that case, the maximum of the range is used to calculate the criterion.

** Per the changes to s. NR 106.07(3), Wis. Adm. Code, effective 09/01/2016 consideration of ambient concentrations and 1-Q₁₀ flow rates yields a more restrictive limit than the 2 × ATC method of limit calculation.

Attachment #1

Weekly Average Limits based on Chronic Toxicity Criteria (CTC)

RECEIVING WATER FLOW = 0.00 cfs (¼ of the 7-Q₁₀), as specified in s. NR 106.06(4)(c), Wis. Adm. Code.

SUBSTANCE	REF. HARD.* mg/L	CTC	MEAN BACK-GRD.	MAX. EFFL. LIMIT	1/5 OF EFFL. LIMIT	MEAN EFFL. CONC.	4-day P ₉₉
Arsenic		152		152	30	<1.1	
Cadmium	175	3.8		3.8	0.8	<0.19	
Chromium (+3)	270	298		298	60	1.2	
Copper	270	24.2		24.2			13.3
Lead	270	73		73	15	<4.3	
Nickel	268	120		120	24	4.4	
Zinc	270	287		287	57	54.00	
Chloride		395		395			318

* The indicated hardness may differ from the receiving water hardness because the receiving water hardness exceeded the maximum range in ch. NR 105, Wis. Adm. Code, over which the chronic criteria are applicable. In that case, the maximum of the range is used to calculate the criterion.

Monthly Average Limits based on Wildlife Criteria (WC)

The effluent characterization did not include any effluent sampling results for substances for which Wildlife Criteria exist.

Monthly Average Limits based on Human Threshold Criteria (HTC)

RECEIVING WATER FLOW = 0.00 cfs (¼ of the Harmonic Mean), as specified in s. NR 106.06(4), Wis. Adm. Code.

SUBSTANCE	HTC	MEAN BACK-GRD.	MAX. EFFL. LIMIT	1/5 OF EFFL. LIMIT	MEAN EFFL. CONC.	30-day P ₉₉
Cadmium	370.0		370.0	74.0	<0.19	
Chromium (+3)	3818000		3818000	763600	1.2	
Lead	140		140	28	<4.3	
Nickel	43000		43000	8600	4.4	

Monthly Average Limits based on Human Cancer Criteria (HCC)

RECEIVING WATER FLOW = 0.00 cfs (¼ of the Harmonic Mean), as specified in s. NR 106.06(4), Wis. Adm. Code.

SUBSTANCE	HCC	MEAN BACK-GRD.	MAX. EFFL. LIMIT**	1/5 OF EFFL. LIMIT	MEAN EFFL. CONC.	30-day P ₉₉
Arsenic	13.3		13.3	2.7	<1.1	

In addition to evaluating the need for limits for each individual substance for which HCC exist, s. NR 106.06(8), Wis. Adm. Code, requires the evaluation of the cumulative cancer risk. Because no effluent limits are needed based on HCC, determination of the cumulative cancer risk is not needed per s. NR 106.06(8), Wis. Adm. Code.

Conclusions and Recommendations: Based on a comparison of the effluent data and calculated effluent limitations, limits are not required for toxic substances.

Chloride – Considering available effluent data from the current permit term (January 2020 to July 2024), the 1-day P₉₉ chloride concentration is 399 mg/L, and the 4-day P₉₉ of effluent data is 318 mg/L.

These effluent concentrations are below the calculated WQBELs for chloride, therefore no effluent limits are needed. **Chloride monitoring is recommended to continue.**

PFOS and PFOA

The need for PFOS and PFOA monitoring is evaluated in accordance with s. NR 106.98, Wis. Adm. Code. PFOS and PFOA were not detected in the water supply. Based on the nondomestic contributions, **PFOS and PFOA monitoring is recommended once every two months.**

Mercury – The permit application did not require monitoring for mercury because the Baldwin Wastewater Treatment Facility is categorized as a minor facility as defined in s. NR 200.02(8), Wis. Adm. Code. In accordance with s. NR 106.145(3)(a)3., Wis. Adm. Code, a minor municipal discharger shall monitor, and report results of influent and effluent mercury monitoring once every three months if, there are two or more exceedances in the last five years of the high-quality sludge mercury concentration of 17 mg/kg specified in s. NR 204.07(5). A review of the past five years of sludge characteristics data reveals that all the sample results are within expected analytical ranges and well below the 17 mg/kg level. The average concentration in the sludge from 2020 to 2023 was 0.20 mg/kg, with a maximum reported concentration of 0.50 mg/kg. Therefore, **no mercury monitoring is recommended at Outfall 001.**

PART 3 – WATER QUALITY-BASED EFFLUENT LIMITATIONS FOR AMMONIA NITROGEN

The State of Wisconsin promulgated revised water quality standards for ammonia nitrogen in ch. NR 105, Wis. Adm. Code, effective March 1, 2004 which includes criteria based on both acute and chronic toxicity to aquatic life. The current permit has daily maximum, weekly average, and monthly average limits. These limits are re-evaluated at this time due to the following changes:

- Subchapter IV of ch. NR 106, Wis. Adm. Code allows limits based on available dilution instead of limits set to twice the acute criteria.
- Section NR 106.07(3), Wis. Adm. Code requires weekly and monthly average limits for municipal treatment plants.
- The maximum expected effluent pH has changed

Daily Maximum Limits based on Acute Toxicity Criteria (ATC):

Daily maximum limitations are based on acute toxicity criteria in ch. NR 105, Wis. Adm. Code, which are a function of the effluent pH and the receiving water classification. The acute toxicity criterion (ATC) for ammonia is calculated using the following equation.

$$\text{ATC in mg/L} = [A \div (1 + 10^{(7.204 - \text{pH})})] + [B \div (1 + 10^{(\text{pH} - 7.204)})]$$

Where:

A = 0.411 and B = 58.4 for a Warm Water Sport fishery, and pH (s.u.) = that characteristic of the effluent.

The effluent pH data was examined as part of this evaluation. A total of 1736 sample results were reported from December 2019 to August 2024. The maximum reported value was 8.00 s.u. (Standard pH Units). The effluent pH was 7.90 s.u. or less 99% of the time. The 1-day P₉₉, calculated in accordance with s. NR 106.05(5), Wis. Adm. Code, is 7.84 s.u. The mean plus the standard deviation multiplied by a factor of 2.33, an estimate of the upper ninety ninth percentile for a normally distributed dataset, is 7.83 s.u. Therefore, a value of 7.90 s.u. is believed to represent the maximum reasonably expected pH, and therefore most appropriate for determining daily maximum limitations for ammonia nitrogen. Substituting a value of 7.9 s.u. into the equation above yields an ATC = 10.13 mg/L.

Daily Maximum Ammonia Nitrogen Effluent Limitations Calculation Method

In accordance with s. NR 106.32(2), Wis. Adm. Code daily maximum ammonia limitations are calculated using the 1-Q₁₀ receiving water low flow if it is determined that the previous method of acute ammonia limit calculation (2×ATC) is not sufficiently protective of the fish and aquatic life. The more restrictive calculated limits shall apply.

The calculated daily maximum ammonia nitrogen effluent limits using the mass balance approach with the 1-Q₁₀ (estimated as 80 % of 7-Q₁₀) and the 2×ATC approach are shown below.

Daily Maximum Ammonia Nitrogen Determination

	Ammonia Nitrogen Limit mg/L
2×ATC	20.26
1-Q ₁₀	10.13

The 1-Q₁₀ method yields the most stringent limits for the Baldwin Wastewater Treatment Facility.

Attachment #1

The current permit has variable daily maximum effluent limits based on effluent pH. Presented below is a table of daily maximum limitations corresponding to various effluent pH values.

Daily Maximum Ammonia Nitrogen Limits – LFF

Effluent pH s.u.	Limit mg/L	Effluent pH s.u.	Limit mg/L	Effluent pH s.u.	Limit mg/L
6.0 ≤ pH ≤ 6.1	54	7.0 < pH ≤ 7.1	33	8.0 < pH ≤ 8.1	6.9
6.1 < pH ≤ 6.2	53	7.1 < pH ≤ 7.2	30	8.1 < pH ≤ 8.2	5.7
6.2 < pH ≤ 6.3	52	7.2 < pH ≤ 7.3	26	8.2 < pH ≤ 8.3	4.7
6.3 < pH ≤ 6.4	51	7.3 < pH ≤ 7.4	23	8.3 < pH ≤ 8.4	3.9
6.4 < pH ≤ 6.5	49	7.4 < pH ≤ 7.5	20	8.4 < pH ≤ 8.5	3.2
6.5 < pH ≤ 6.6	47	7.5 < pH ≤ 7.6	17	8.5 < pH ≤ 8.6	2.7
6.6 < pH ≤ 6.7	45	7.6 < pH ≤ 7.7	14	8.6 < pH ≤ 8.7	2.2
6.7 < pH ≤ 6.8	42	7.7 < pH ≤ 7.8	12	8.7 < pH ≤ 8.8	1.8
6.8 < pH ≤ 6.9	39	7.8 < pH ≤ 7.9	10	8.8 < pH ≤ 8.9	1.6
6.9 < pH ≤ 7.0	36	7.9 < pH ≤ 8.0	8.4	8.9 < pH ≤ 9.0	1.3

Weekly and Monthly Average Limits based on Chronic Toxicity Criteria (CTC)

The ammonia limit calculation also warrants evaluation of weekly and monthly average limits based on chronic toxicity criteria for ammonia, since those limits relate to the assimilative capacity of the receiving water.

Weekly average and monthly average limits for ammonia nitrogen are based on chronic toxicity criteria in ch. NR 105, Wis. Adm. Code.

The 30-day chronic toxicity criterion (CTC) for ammonia in waters classified as Limited Forage Fish Community is calculated by the following equation, according to subchapter IV of NR 106, Wis. Adm. Code.

$$CTC = E \times \{ [0.0676 \div (1 + 10^{(7.688 - pH)})] + [2.912 \div (1 + 10^{(pH - 7.688)})] \} \times C$$

Where:

pH = the pH (s.u.) of the receiving water,

E = 1.0,

C = the minimum of 3.09 or $3.73 \times 10^{(0.028 \times (25 - T))}$ – (Early Life Stages Present), or

C = $3.73 \times 10^{(0.028 \times (25 - T))}$ – (Early Life Stages Absent), and

T = the temperature (°C) of the receiving water – (Early Life Stages Present), or

T = the maximum of the actual temperature (°C) and 7 - (Early Life Stages Absent)

The 4-day criterion is equal to the 30-day criterion multiplied by 2.5. The 4-day criteria are used in a mass-balance equation with the 7-Q₁₀ (4-Q₃, if available) to derive weekly average limitations. And the 30-day criteria are used with the 30-Q₅ (estimated as 85% of the 7-Q₂ if the 30-Q₅ is not available) to derive monthly average limitations. The stream flow value is further adjusted to temperature; 100% of the flow is used if the Temperature ≥ 16 °C, 25% of the flow is used if the Temperature < 11 °C, and 50% of the flow is used if the Temperature ≥ 11 °C but < 16 °C.

Attachment #1

Section NR 106.32 (3), Wis. Adm. Code, provides a mechanism for less stringent weekly average and monthly average effluent limitations when early life stages (ELS) of critical organisms are absent from the receiving water. This applies only when the water temperature is less than 14.5 °C, during the winter and spring months. Based on a review of the DNR Fisheries database, burbot, an early spawning species, are not believed to be present in Baldwin Creek. So “ELS Absent” criteria apply from October through March, and “ELS Present” criteria will apply from April through September for a LFF classification.

The “default” basin assumed values are used for temperature and background ammonia concentrations, because minimum ambient data is available. The values for pH are based on data collected within the Rush River Watershed. These values are shown in the table below, with the resulting criteria and effluent limitations.

Weekly and Monthly Ammonia Nitrogen Limits – LFF

		May-September	October-April
Effluent Flow	Qe (MGD)	0.540	0.540
Background Information	7-Q ₁₀ (cfs)	0.00	0.00
	7-Q ₂ (cfs)	0.00	0.00
	Ammonia (mg/L)	0.07	0.13
	Temperature (°C)	20.6	12.8
	pH (s.u.)	8.18	8.06
	% of Flow used	100	25
	Reference Weekly Flow (cfs)	0.00	0.00
	Reference Monthly Flow (cfs)	0.00	0.00
	Criteria mg/L	4-day Chronic	
Early Life Stages Present		5.86	7.11
Early Life Stages Absent		9.42	18.87
30-day Chronic			
Early Life Stages Present		2.34	2.84
Early Life Stages Absent		3.77	7.55
Effluent Limitations mg/L	Weekly Average		
	Early Life Stages Present	5.9	
	Early Life Stages Absent		19
	Monthly Average		
	Early Life Stages Present	2.3	
	Early Life Stages Absent		7.5

Effluent Data

The following table evaluates the statistics based upon ammonia data reported from December 2019 to August 2024, with those results being compared to the calculated limits to determine the need to include ammonia limits in the Baldwin Wastewater Treatment Facility permit for the respective month ranges.

Ammonia Nitrogen Effluent Data

Ammonia Nitrogen mg/L	May-September	October-April
1-day P ₉₉	8.56	9.03
4-day P ₉₉	4.90	5.55
30-day P ₉₉	2.14	2.32
Mean*	1.01	0.89
Std	1.99	2.36
Sample size	104	133
Range	0.0107 - 13	<0.05 - 15.4

*Values lower than the level of detection were substituted with a zero.

Based on this comparison, there is no reasonable potential for the discharge to exceed any of the calculated ammonia nitrogen limits.

The permit currently has daily maximum, weekly average, and monthly average limits. Where there are existing ammonia nitrogen limits in the permit, the limits must be retained regardless of reasonable potential, consistent with s. NR 106.33(1)(b), Wis. Adm. Code:

- (b) If a permittee is subject to an ammonia limitation in an existing permit, the limitation shall be included in any reissued permit. Ammonia limitations shall be included in the permit if the permitted facility will be providing treatment for ammonia discharges.

Antidegradation

The calculated monthly average limit of 2.2 mg/L for May – September as well as the weekly average limits of 5.9 mg/L for May – September and 19 mg/L for October – April are less restrictive than the limits in the current permit. Without a demonstration of need for a higher limit in accordance with s. NR 207.04, Wis. Adm. Code, these limits must be continued in the reissued permit. The monthly average limit for October – April is should be updated to the more restrictive calculated value of 7.5 mg/L.

Conclusions and Recommendations

In summary, after rounding to two significant figures, the following ammonia nitrogen limitations are recommended. No mass limitations are recommended in accordance with s. NR 106.32(5), Wis. Adm Code.

Final Ammonia Nitrogen Limits

	Daily Maximum mg/L	Weekly Average mg/L	Monthly Average mg/L
May-September	Variable	5.6	2.2
October-April	Variable	16	7.5

**PART 4 – WATER QUALITY-BASED EFFLUENT LIMITATIONS
FOR BACTERIA**

Section NR 102.04(5), Wis. Adm. Code, states that all surface waters shall be suitable for supporting recreational use and shall meet *E. coli* criteria during the recreation season. Section NR 102.04(5)(b), Wis. Adm. Code, allows the Department to make exceptions when it determines, in accordance with s. NR 210.06(3), Wis. Adm. Code, that wastewater disinfection is not required to meet *E. coli* limits and protect the recreational use. Section NR 210.06(3), Wis. Adm. Code, tasks the Department with determining the need for disinfection using a site-specific analysis based on potential risk to human or animal health. It sets out the factors that must be considered in determining the necessity to disinfect municipal wastewater or to change the length of the disinfection season.

1. The geometric mean of *E. coli* bacteria in effluent samples collected in any calendar month may not exceed 126 counts/100 mL.
2. No more than 10 percent of *E. coli* bacteria samples collected in any calendar month may exceed 410 counts/100 mL.

E. coli monitoring is recommended at the same frequency that fecal coliform monitoring is required in the current permit. Because the Baldwin Wastewater Treatment Facility permit requires 2/week monitoring, the 410 counts/100 mL limit will effectively function as a daily maximum limit unless the facility performs additional monitoring. Any additional monitoring beyond what is required by the permit must also be reported on the DMR as required in the standard requirements section of the permit.

The current permit requires the Baldwin Wastewater Treatment Facility to disinfect year-round. Because the *E. coli* limits listed in NR 210.06(2)(a)1, Wis. Adm. Code, are set for protection of recreational uses, these *E. coli* limits do not necessarily need to be applied year-round. However, either *E. coli* or fecal coliform bacteria limits are needed year-round in order to ensure that there is no reduction from the current level of disinfection.

In accordance with s. NR 210.06(2)(a)2, Wis. Adm. Code, outside of the recreational season, bacteria limits may either be set equal to the previous fecal coliform limits or the listed *E. coli* limits. Therefore, the facility can select one of the two possible sets of permit limits:

- *E. coli* limits as listed above during the recreation period of May through September and a fecal coliform limit of 400 counts/100 mL as a monthly geometric mean in November through April. Any fecal coliform weekly geometric mean limit which was included in the previous permit for expression of limits purposes does not need to be included in the reissued permit.
- *E. coli* limits as listed above apply year-round.

Effluent Data

The Baldwin Wastewater Treatment Facility has monitored effluent *E. coli* from July 2023 to September 2023 and a total of 24 results are available. A geometric mean of 126 counts/100 mL was never exceeded, with a maximum monthly geometric mean of 83 counts/100 mL. Effluent data exceeded 410 counts/100 mL 3 times (which is 13% of the total sample results). The maximum reported value was 2000 counts/100 mL. Based on this effluent data it appears that the facility can meet new *E. coli* limits and a compliance schedule is not needed in the reissued permit.

Attachment #1
PART 5 – PHOSPHORUS

Technology-Based Effluent Limit

Subchapter II of Chapter NR 217, Wis. Adm. Code, requires municipal wastewater treatment facilities that discharge greater than 150 pounds of Total Phosphorus per month to comply with a monthly average limit of 1.0 mg/L, or an approved alternative concentration limit.

Because the Baldwin Wastewater Treatment Facility has a WQBEL that is more restrictive than 1.0 mg/L, this limit should be included in the reissued permit. This limit remains applicable unless a more stringent WQBEL is given.

Water Quality-Based Effluent Limits (WQBEL)

Revisions to administrative rules regulating phosphorus took effect on December 1, 2010. These rule revisions include additions to s. NR 102.06, Wis. Adm. Code, which establish phosphorus standards for surface waters. Subchapter III of NR 217, Wis. Adm. Code, establishes procedures for determining WQBELs for phosphorus, based on the applicable standards in ch. NR 102, Wis. Adm. Code.

Section NR 102.06(3)(a), Wis. Adm. Code, specifically names river segments for which a phosphorus criterion of 0.100 mg/L applies. For other stream segments that are not specified in s. NR 102.06(3)(a), Wis. Adm. Code, s. NR 102.06(3)(b), Wis. Adm. Code, specifies a phosphorus criterion of 0.075 mg/L. The phosphorus criterion of 0.075 mg/L applies for Baldwin Creek.

The conservation of mass equation is described in s. NR 217.13(2)(a), Wis. Adm. Code, for phosphorus WQBELs and includes variables of water quality criterion (WQC), receiving water flow rate (Qs), effluent flow rate (Qe), and upstream phosphorus concentrations (Cs) provided below.

$$\text{Limitation} = [(WQC)(Q_s + (1-f) Q_e) - (Q_s - f Q_e) (C_s)] / Q_e$$

Where:

WQC = 0.075 mg/L for Baldwin Creek.

Qs = 100% of the 7-Q₂ of 0 cfs

Cs = background concentration of phosphorus in the receiving water pursuant to s. NR 217.13(2)(d), Wis. Adm. Code

Qe = effluent flow rate = 0.540 MGD = 0.836 cfs

f = the fraction of effluent withdrawn from the receiving water = 0

Since the receiving water flow is equal to zero, the effluent limit is set equal to criteria.

Effluent Data

Attachment #1

The following table summarizes effluent total phosphorus monitoring data from December 2019 to August 2024.

	Phosphorus mg/L
1-day P ₉₉	8.97
4-day P ₉₉	5.23
30-day P ₉₉	3.27
Mean	2.41
Std	1.78
Sample size	232
Range	<0.06 - 12.7

Reasonable Potential Determination

Since the 30-day P₉₉ of reported effluent total phosphorus data is greater than the calculated WQBEL, the discharge has reasonable potential to cause or contribute to an exceedance of the water quality criterion. Therefore, a WQBEL is required.

Limit Expression

According to s. NR 217.14 (2), Wis. Adm. Code, because the calculated WQBEL is less than or equal to 0.3 mg/L, the effluent limit of 0.075 mg/L may be expressed as a six-month average. If a concentration limitation expressed as a six-month average is included in the permit, a monthly average concentration limitation of 0.225 mg/L, equal to three times the WQBEL calculated under s. NR 217.13, Wis. Adm. Code shall also be included in the permit. The six-month average should be averaged during the months of May – October and November – April.

PART 6 – WATER QUALITY-BASED EFFLUENT LIMITATIONS FOR THERMAL

Surface water quality standards for temperature took effect on October 1, 2010. These regulations are detailed in chs. NR 102 (Subchapter II – Water Quality Standards for Temperature) and NR 106 (Subchapter V – Effluent Limitations for Temperature) of the Wisconsin Administrative Code. Daily maximum and weekly average temperature criteria are available for the 12 different months of the year depending on the receiving water classification.

In accordance with s. NR 106.53(2)(b), Wis. Adm. Code, the highest daily maximum flow rate for a calendar month is used to determine the acute (daily maximum) effluent limitation. In accordance with s. NR 106.53(2)(c), Wis. Adm. Code, the highest 7-day rolling average flow rate for a calendar month is used to determine the sub-lethal (weekly average) effluent limitation. These values were based off actual flow reported from December 2019 to August 2024.

The table below summarizes the maximum temperatures reported during monitoring from January 2017 to December 2023.

Monthly Temperature Effluent Data & Limits

Month	Representative Highest Monthly Effluent Temperature		Calculated Effluent Limit	
	Weekly Maximum	Daily Maximum	Weekly Average Effluent Limitation	Daily Maximum Effluent Limitation
	(°F)	(°F)	(°F)	(°F)
JAN	48	50	54	78
FEB	50	50	54	79
MAR	50	50	57	80
APR	58	58	63	81
MAY	61	62	70	84
JUN	68	68	77	85
JUL	68	69	81	86
AUG	78	78	79	86
SEP	76	76	73	85
OCT	74	74	63	83
NOV	66	66	54	80
DEC	64	64	54	79

Reasonable Potential

Permit limits for temperature are recommended based on the procedures in s. NR 106.56, Wis. Adm. Code.

- An acute limit for temperature is recommended for each month in which the representative daily maximum effluent temperature for that month exceeds the acute WQBEL. The representative daily maximum effluent temperature is the greater of the following:
 - (a) The highest recorded representative daily maximum effluent temperature
 - (b) The projected 99th percentile of all representative daily maximum effluent temperatures
- A sub-lethal limitation for temperature is recommended for each month in which the representative weekly average effluent temperature for that month exceeds the weekly average WQBEL. The representative weekly average effluent temperature is the greater of the following:
 - (a) The highest weekly average effluent temperature for the month.
 - (b) The projected 99th percentile of all representative weekly average effluent temperatures for the month

Comparing the representative highest effluent temperature to the calculated effluent limits determines the reasonable potential of exceeding the effluent limits. The months in which limitations are recommended are shown in bold. Based on this analysis, weekly average temperature limits are necessary for September, October, November, and December. The complete thermal table used for the limit calculation is attached.

The Village of Baldwin has submitted a request for consideration of dissipative cooling. This request states that there have been no substantial changes in the operation of, or thermal loadings to, the treatment facility since the 2014 dissipative cooling determination. The department has reviewed that request and associated data and believes that the effluent does not have a reasonable potential to cause or contribute to an exceedance of the sub-lethal criterion outside of a small area of mixing and cooling. Therefore, a temperature limit is not recommended at this time. **Effluent monitoring is recommended for the 4th year of the permit term.**

Future WPDES Permit Reissuance

Dissipative cooling requests must be re-evaluated every permit reissuance. The permittee is responsible to submit an updated DC request prior to permit reissuance. Such a request must either include:

- a) A statement by the permittee that there have been no substantial changes in operation of, or thermal loadings to, the treatment facility and the receiving water; or
- b) New information demonstrating DC to supplement the information used in the previous DC determination. If significant changes in operation or thermal loads have occurred, additional DC data must be submitted to the Department.

PART 7 – WHOLE EFFLUENT TOXICITY (WET)

WET testing is used to measure, predict, and control the discharge of toxic materials that may be harmful to aquatic life. In WET tests, organisms are exposed to a series of effluent concentrations for a given time and effects are recorded. Decisions below related to the selection of representative data and the need for WET limits were made according to ss. NR 106.08 and 106.09, Wis. Adm. Code. WET monitoring frequency and toxicity reduction evaluation (TRE) recommendations were made using the best professional judgment of staff familiar with the discharge after consideration of the guidance in the *Whole Effluent Toxicity (WET) Program Guidance Document (2022)*.

- Acute tests predict the concentration that causes lethality of aquatic organisms during a 48 to 96-hour exposure. To assure that a discharge is not acutely toxic to organisms in the receiving water, WET tests must produce a statistically valid LC50 (Lethal Concentration to 50% of the test organisms) greater than 100% effluent, according to s. NR 106.09(2)(b), Wis. Adm Code.
- Chronic testing is usually not recommended where the distance between the outfall and the point where the receiving water becomes a non-variance waterbody (i.e., one that supports a cold water, warm water sport fish, or warm water forage fish community) is greater than four miles. For the Baldwin Wastewater Treatment Facility, that distance is approximately 10 miles. Given this distance, there is believed to be little potential for chronic toxicity effects in the Rush River associated with the discharge from the Baldwin WWTF, so the need for chronic WET testing was not considered further.
- According to the *State of Wisconsin Aquatic Life Toxicity Testing Methods Manual*, a synthetic (standard) laboratory water may be used as the dilution water and primary control in acute WET tests, unless the use of different dilution water is approved by the Department prior to use. The primary control water must be specified in the WPDES permit.
- Shown below is a tabulation of all available WET data for Outfall 001. Efforts are made to ensure that

Attachment #1

decisions about WET monitoring and limits are made based on representative data, as specified in s. NR 106.08(3), Wis. Adm Code. Data which is not believed to be representative of the discharge was not included in reasonable potential calculations. The table below differentiates between tests used and not used when making WET determinations.

WET Data History

Date Test Initiated	Acute Results LC ₅₀ %				Chronic Results IC ₂₅ %					Footnotes or Comments
	<i>C. dubia</i>	Fathead minnow	Pass or Fail?	Used in RP?	<i>C. dubia</i>	Fathead Minnow	Algae (IC ₅₀)	Pass or Fail?	Use in RP?	
07/26/1994					>100	>100		Pass	No	1
07/15/1998	>100	>100	Fail	No						1
09/23/1998	>100	>100	Pass	No						1
07/10/2002	>100	>100	Pass	No						1
07/30/2003	>100	>100	Pass	No						1
01/31/2007	>100	>100	Pass	Yes						

Footnotes:

1. *Data Not Representative.* Significant changes were made to WET test methods in 2004 and these changes were assumed to be fully implemented by certified labs by no later than June 2005.
- According to s. NR 106.08, Wis. Adm. Code, WET reasonable potential is determined by multiplying the highest toxicity value that has been measured in the effluent by a safety factor, to predict the likelihood (95% probability) of toxicity occurring in the effluent above the applicable WET limit. The safety factor used in the equation changes based on the number of toxicity detects in the dataset. The fewer detects present, the higher the safety factor, because there is more uncertainty surrounding the predicted value. WET limits must be given, according to s. NR 106.08(6), Wis. Adm. Code, whenever the applicable Reasonable Potential equation results in a value greater than 1.0.

$$\text{Acute Reasonable Potential} = [(TUa \text{ effluent})(B)]$$

According to s. NR 106.08(6)(d), Wis. Adm. Code, TUa effluent values are equal to zero whenever toxicity is not detected (i.e. when the LC₅₀ ≥ 100%).

Acute Reasonable Potential = 0 < 1.0, reasonable potential is not shown, and a limit is not required.

The WET checklist was developed to help DNR staff make recommendations regarding WET limits, monitoring, and other related permit conditions. The checklist indicates whether acute and chronic WET limits are needed, based on requirements specified in s. NR 106.08, Wis. Adm. Code. The checklist steps the user through a series of questions, assesses points based on the potential for effluent toxicity, and suggests monitoring frequencies based on points accumulated during the checklist analysis. As toxicity potential increases, more points accumulate, and more monitoring is recommended to ensure that toxicity is not occurring. A summary of the WET checklist analysis completed for this permittee is shown in the table below. Staff recommendations based on best professional judgment are provided below the summary table. For guidance related to reasonable potential and the WET checklist, see Chapter 1.3 of the WET Guidance Document: <https://dnr.wisconsin.gov/topic/Wastewater/WET.html>.

WET Checklist Summary

Attachment #1

	Acute	Chronic
AMZ/IWC	Not Applicable. 0 Points	Chronic WET not evaluated.
Historical Data	One tests used to calculate RP. No tests failed. Data not available in past 5 years. 5 Points	
Effluent Variability	Fecal Coliform, Ammonia Nitrogen, and Phosphorus exceedances. NONs sent in 2024. 5 Points	
Receiving Water Classification	Variance water > 4 miles to WWSF 0 Points	
Chemical-Specific Data	No reasonable potential for limits based on ATC. Ammonia nitrogen limit carried over from the current permit. Chromium, Copper, Nickel, Zinc, and Chloride detected. (3 pts) Additional Compounds of Concern: none 3 Points	
Additives	No biocides and one water quality conditioner (1 pt) added. Permittee has proper P chemical SOPs in place. 1 Point	
Discharge Category	Six Industrial Contributors 10 Points	
Wastewater Treatment	Secondary or Better 0 Points	
Downstream Impacts	No impacts known. 0 Points	
Total Checklist Points:	24 Points	
Recommended Monitoring Frequency (from Checklist):	2 tests during permit term	
Limit Required?	No	
TRE Recommended? (from Checklist)	No	

- After consideration of the guidance provided in the Department's WET Program Guidance Document (2022) and other information described above, two acute WET tests are recommended in the reissued permit. Tests should be done in rotating quarters to collect seasonal information about this discharge. WET testing should continue after the permit expiration date (until the permit is reissued).

Temperature limits for receiving waters with unidirectional flow

(calculation using default ambient temperature data)

Facility:	Baldwin WWTF	7-Q₁₀:	0.00	cfs	Temp Dates		Flow Dates	
Outfall(s):	001	Dilution:	25%		Start:	01/03/23	12/01/19	
Date Prepared:	09/20/2024	f:	0		End:	12/27/23	08/31/24	
Design Flow (Q_e):	0.540 MGD	Stream type:	Limited forage fish community					
Storm Sewer Dist.	0 ft	Q_s:Q_e ratio:	0.0	:1				
		Calculation Needed?	YES					

Month	Water Quality Criteria			Receiving Water Flow Rate (Q _s) (cfs)	Representative Highest Effluent Flow Rate (Q _e)		f	Representative Highest Monthly Effluent Temperature		Calculated Effluent Limit	
	T _a (default) (°F)	Sub-Lethal WQC (°F)	Acute WQC (°F)		7-day Rolling Average (Q _{esl}) (MGD)	Daily Maximum Flow Rate (Q _{ea}) (MGD)		Weekly Average (°F)	Daily Maximum (°F)	Weekly Average Effluent Limitation (°F)	Daily Maximum Effluent Limitation (°F)
JAN	37	54	78	0.00	0.442	0.490	0	48	50	54	78
FEB	39	54	79	0.00	0.446	0.839	0	50	50	54	79
MAR	43	57	80	0.00	0.734	1.357	0	50	50	57	80
APR	50	63	81	0.00	0.843	1.625	0	58	58	63	81
MAY	59	70	84	0.00	0.774	1.469	0	61	62	70	84
JUN	64	77	85	0.00	1.022	3.052	0	68	68	77	85
JUL	69	81	86	0.00	0.636	1.436	0	68	69	81	86
AUG	68	79	86	0.00	0.471	0.920	0	78	78	79	86
SEP	63	73	85	0.00	0.421	0.972	0	76	76	73	85
OCT	55	63	83	0.00	0.460	0.996	0	74	74	63	83
NOV	46	54	80	0.00	0.431	0.740	0	66	66	54	80
DEC	40	54	79	0.00	0.452	1.098	0	64	64	54	79



Baldwin WWTF



Legend

Permits

Surface Water Outfalls



Basemaps

Imagery

Latest Leaf Off Imagery

Red: Band_1

Green: Band_2

Blue: Band_3

Notes



1:2,071



Service layer credits:
WI Dept. of Natural Resources, Division of Water

This map is a product generated by a DNR mapping application

This map is for informational purposes only and may not have been prepared for or be suitable for legal, engineering or surveying purposes. The user is solely responsible for verifying the accuracy of information before using for any purpose. By using this product for any purpose user agrees to be bound by all disclaimers found here: <https://dnr.wisconsin.gov/legal>

Date Printed: 09/19/2024

