



WPDES PERMIT

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
**PERMIT TO DISCHARGE UNDER THE WISCONSIN POLLUTANT DISCHARGE
ELIMINATION SYSTEM**

BELOIT CITY

is permitted, under the authority of Chapter 283, Wisconsin Statutes, to discharge from a facility
located at
555 Willowbrook Road, City of Beloit
to
Rock River (Turtle Creek Watershed, LR01 – Lower Rock River basin) in Rock County

in accordance with the effluent limitations, monitoring requirements and other conditions set
forth in this permit.

The permittee shall not discharge after the date of expiration. If the permittee wishes to continue to discharge after this expiration date an application shall be filed for reissuance of this permit, according to Chapter NR 200, Wis. Adm. Code, at least 180 days prior to the expiration date given below.

State of Wisconsin Department of Natural Resources
For the Secretary

By _____
Thomas Bauman
Wastewater Field Supervisor

Date Permit Signed/Issued

PERMIT TERM: EFFECTIVE DATE - October 01, 2020
Permit Modification Effective Date: January 1, 2022
Permit Modification 2 Effective Date: July 1, 2022
Permit Modificaiton 3 Effective Date: January 1, 2025

EXPIRATION DATE - September 30, 2025

TABLE OF CONTENTS

1 INFLUENT REQUIREMENTS	1
1.1 SAMPLING POINT(S)	1
1.2 MONITORING REQUIREMENTS	1
1.2.1 <i>Sampling Point 701 - INFLUENT TO PLANT</i>	1
2 IN-PLANT REQUIREMENTS	3
2.1 SAMPLING POINT(S)	3
2.2 MONITORING REQUIREMENTS AND LIMITATIONS	3
2.2.1 <i>Sampling Point 107 - Mercury Field Blank</i>	3
3 SURFACE WATER REQUIREMENTS	4
3.1 SAMPLING POINT(S)	4
3.2 MONITORING REQUIREMENTS AND EFFLUENT LIMITATIONS	4
3.2.1 <i>Sampling Point (Outfall) 001 - EFFLUENT</i>	4
4 LAND APPLICATION REQUIREMENTS	14
4.1 SAMPLING POINT(S)	14
4.2 MONITORING REQUIREMENTS AND LIMITATIONS	14
4.2.1 <i>Sampling Point (Outfall) 002 - Anaerobic Liquid Sludge and 005- Anaerobic Cake Sludge</i>	14
5 SCHEDULES	19
5.1 EFFLUENT LIMITATIONS FOR E. COLI	19
5.2 MERCURY POLLUTANT MINIMIZATION PLAN	19
5.3 WATER QUALITY TRADING (WQT) MANAGEMENT PLAN	20
5.4 ANNUAL WATER QUALITY TRADING (WQT) REPORT	20
6 STANDARD REQUIREMENTS	22
6.1 REPORTING AND MONITORING REQUIREMENTS	22
6.1.1 <i>Monitoring Results</i>	22
6.1.2 <i>Sampling and Testing Procedures</i>	22
6.1.3 <i>Pretreatment Sampling Requirements</i>	22
6.1.4 <i>Recording of Results</i>	22
6.1.5 <i>Reporting of Monitoring Results</i>	23
6.1.6 <i>Compliance Maintenance Annual Reports</i>	23
6.1.7 <i>Records Retention</i>	23
6.1.8 <i>Other Information</i>	24
6.1.9 <i>Reporting Requirements – Alterations or Additions</i>	24
6.2 SYSTEM OPERATING REQUIREMENTS	24
6.2.1 <i>Noncompliance Reporting</i>	24
6.2.2 <i>Flow Meters</i>	25
6.2.3 <i>Raw Grit and Screenings</i>	25
6.2.4 <i>Sludge Management</i>	25
6.2.5 <i>Prohibited Wastes</i>	25
6.2.6 <i>Bypass</i>	25
6.2.7 <i>Scheduled Bypass</i>	26
6.2.8 <i>Controlled Diversions</i>	26
6.2.9 <i>Proper Operation and Maintenance</i>	26
6.2.10 <i>Operator Certification</i>	26
6.3 SEWAGE COLLECTION SYSTEMS	26
6.3.1 <i>Sanitary Sewage Overflows and Sewage Treatment Facility Overflows</i>	26
6.3.2 <i>Capacity, Management, Operation and Maintenance (CMOM) Program</i>	28
6.3.3 <i>Sewer Cleaning Debris and Materials</i>	28
6.4 SURFACE WATER REQUIREMENTS	29

6.4.1	<i>Permittee-Determined Limit of Quantitation Incorporated into this Permit</i>	29
6.4.2	<i>Appropriate Formulas for Effluent Calculations</i>	29
6.4.3	<i>Effluent Temperature Requirements</i>	29
6.4.4	<i>Visible Foam or Floating Solids</i>	30
6.4.5	<i>Surface Water Uses and Criteria</i>	30
6.4.6	<i>Percent Removal</i>	30
6.4.7	<i>Fecal Coliform</i>	30
6.4.8	<i>E. coli</i>	30
6.4.9	<i>Seasonal Disinfection</i>	30
6.4.10	<i>Total Residual Chlorine Requirements (When De-Chlorinating Effluent)</i>	30
6.4.11	<i>Whole Effluent Toxicity (WET) Monitoring Requirements</i>	31
6.4.12	<i>Whole Effluent Toxicity (WET) Identification and Reduction</i>	31
6.5	PRETREATMENT PROGRAM REQUIREMENTS	32
6.5.1	<i>Inventories</i>	32
6.5.2	<i>Regulation of Industrial Users</i>	32
6.5.3	<i>Annual Pretreatment Program Report</i>	33
6.5.4	<i>Pretreatment Program Modifications</i>	33
6.5.5	<i>Program Resources</i>	34
6.6	LAND APPLICATION REQUIREMENTS	34
6.6.1	<i>Sludge Management Program Standards And Requirements Based Upon Federally Promulgated Regulations</i>	34
6.6.2	<i>General Sludge Management Information</i>	34
6.6.3	<i>Sludge Samples</i>	34
6.6.4	<i>Land Application Characteristic Report</i>	34
6.6.5	<i>Calculation of Water Extractable Phosphorus</i>	35
6.6.6	<i>Monitoring and Calculating PCB Concentrations in Sludge</i>	35
6.6.7	<i>Annual Land Application Report</i>	35
6.6.8	<i>Other Methods of Disposal or Distribution Report</i>	36
6.6.9	<i>Approval to Land Apply</i>	36
6.6.10	<i>Soil Analysis Requirements</i>	36
6.6.11	<i>Land Application Site Evaluation</i>	36
6.6.12	<i>Class B Sludge: Fecal Coliform Limitation</i>	36
6.6.13	<i>Class B Sludge: Anaerobic Digestion</i>	37
6.6.14	<i>Vector Control: Drying Without Primary Solids</i>	37
6.6.15	<i>Class B Sludge - Vector Control: Injection</i>	37
6.6.16	<i>Class B Sludge - Vector Control: Incorporation</i>	37
6.6.17	<i>Landfilling of Sludge</i>	37
6.6.18	<i>Sludge Landfilling Reports</i>	37
7	SUMMARY OF REPORTS DUE	39

1 Influent Requirements

1.1 Sampling Point(s)

Sampling Point Designation	
Sampling Point Number	Sampling Point Location, WasteType/Sample Contents and Treatment Description (as applicable)
701	Influent: 24-Hr flow proportional sampler and flow meter located after preliminary screening but before grit removal in the basement of the process building.

1.2 Monitoring Requirements

The permittee shall comply with the following monitoring requirements.

1.2.1 Sampling Point 701 - INFLUENT TO PLANT

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Daily	Continuous	
BOD ₅ , Total		mg/L	Monthly	24-Hr Flow Prop Comp	
CBOD ₅		mg/L	5/Week	24-Hr Flow Prop Comp	
Suspended Solids, Total		mg/L	Daily	24-Hr Flow Prop Comp	
Cadmium, Total Recoverable		µg/L	Quarterly	24-Hr Flow Prop Comp	
Chromium, Total Recoverable		µg/L	Quarterly	24-Hr Flow Prop Comp	
Copper, Total Recoverable		µg/L	Quarterly	24-Hr Flow Prop Comp	
Lead, Total Recoverable		µg/L	Quarterly	24-Hr Flow Prop Comp	
Nickel, Total Recoverable		µg/L	Quarterly	24-Hr Flow Prop Comp	
Zinc, Total Recoverable		µg/L	Quarterly	24-Hr Flow Prop Comp	
Mercury, Total Recoverable		ng/L	Quarterly	24-Hr Flow Prop Comp	See Mercury section

1.2.1.1 Total Metals Analyses

Measurements of total metals and total recoverable metals shall be considered as equivalent.

1.2.1.2 Mercury Monitoring

The permittee shall collect and analyze all mercury samples according to the data quality requirements of ss. NR 106.145(9) and (10), Wisconsin Administrative Code. The limit of quantitation (LOQ) used for the effluent and field blank shall be less than 1.3 ng/L, unless the samples are quantified at levels above 1.3 ng/L. The permittee shall collect at least one mercury field blank for each set of mercury samples (a set of samples may include combinations of intake, influent, effluent or other samples all collected on the same day). The permittee shall report results of samples and field blanks to the Department on Discharge Monitoring Reports.

2 In-Plant Requirements

2.1 Sampling Point(s)

Sampling Point Designation	
Sampling Point Number	Sampling Point Location, WasteType/Sample Contents and Treatment Description (as applicable)
107	Collect the mercury field blank using sample handling procedures specified in NR 106.145(9), Wisconsin Administrative Code.

2.2 Monitoring Requirements and Limitations

The permittee shall comply with the following monitoring requirements and limitations.

2.2.1 Sampling Point 107 - Mercury Field Blank

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Mercury, Total Recoverable		ng/L	Quarterly	Blank	See Mercury section.

2.2.1.1 Mercury Monitoring

The permittee shall collect and analyze all mercury samples according to the data quality requirements of ss. NR 106.145(9) and (10), Wisconsin Administrative Code. The limit of quantitation (LOQ) used for the effluent and field blank shall be less than 1.3 ng/L, unless the samples are quantified at levels above 1.3 ng/L. The permittee shall collect at least one mercury field blank for each set of mercury samples (a set of samples may include combinations of intake, influent, effluent or other samples all collected on the same day). The permittee shall report results of samples and field blanks to the Department on Discharge Monitoring Reports.

3 Surface Water Requirements

3.1 Sampling Point(s)

Sampling Point Designation	
Sampling Point Number	Sampling Point Location, Waste Type/Sample Contents and Treatment Description (as applicable)
001	Effluent: 24-Hr flow proportional composite sampler and flow meter located in the disinfection building basement. Grab sample taken after the chlorinate/dechlorinate disinfection in the chlorine contact tank, prior to discharge to the Rock River.

3.2 Monitoring Requirements and Effluent Limitations

The permittee shall comply with the following monitoring requirements and limitations.

3.2.1 Sampling Point (Outfall) 001 - EFFLUENT

Monitoring Requirements and Effluent Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Daily	Continuous	
CBOD ₅	Monthly Avg	25 mg/L	5/Week	24-Hr Flow Prop Comp	
CBOD ₅	Weekly Avg	40 mg/L	5/Week	24-Hr Flow Prop Comp	
Suspended Solids, Total	Weekly Avg	45 mg/L	Daily	24-Hr Flow Prop Comp	
Suspended Solids, Total	Monthly Avg	30 mg/L	Daily	24-Hr Flow Prop Comp	
Suspended Solids, Total	Weekly Avg	2,276 lbs/day	Daily	Calculated	
Suspended Solids, Total	Weekly Avg	2,811 lbs/day	Daily	Calculated	
Suspended Solids, Total	Weekly Avg	3,155 lbs/day	Daily	Calculated	
Suspended Solids, Total	Weekly Avg	2,973 lbs/day	Daily	Calculated	
Suspended Solids, Total	Weekly Avg	2,740 lbs/day	Daily	Calculated	
Suspended Solids, Total	Weekly Avg	2,579 lbs/day	Daily	Calculated	
Suspended Solids, Total	Weekly Avg	2,043 lbs/day	Daily	Calculated	
Suspended Solids, Total	Weekly Avg	1,597 lbs/day	Daily	Calculated	

Monitoring Requirements and Effluent Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Suspended Solids, Total	Weekly Avg	1,082 lbs/day	Daily	Calculated	
Suspended Solids, Total	Weekly Avg	1,750 lbs/day	Daily	Calculated	
Suspended Solids, Total	Weekly Avg	2,680 lbs/day	Daily	Calculated	
Suspended Solids, Total	Weekly Avg	2,235 lbs/day	Daily	Calculated	
Suspended Solids, Total	Monthly Avg	1,778 lbs/day	Daily	Calculated	
Suspended Solids, Total	Monthly Avg	2,196 lbs/day	Daily	Calculated	
Suspended Solids, Total	Monthly Avg	2,465 lbs/day	Daily	Calculated	
Suspended Solids, Total	Monthly Avg	2,323 lbs/day	Daily	Calculated	
Suspended Solids, Total	Monthly Avg	2,141 lbs/day	Daily	Calculated	
Suspended Solids, Total	Monthly Avg	2,015 lbs/day	Daily	Calculated	
Suspended Solids, Total	Monthly Avg	1,596 lbs/day	Daily	Calculated	
Suspended Solids, Total	Monthly Avg	1,248 lbs/day	Daily	Calculated	
Suspended Solids, Total	Monthly Avg	845 lbs/day	Daily	Calculated	
Suspended Solids, Total	Monthly Avg	1,367 lbs/day	Daily	Calculated	
Suspended Solids, Total	Monthly Avg	2,094 lbs/day	Daily	Calculated	
Suspended Solids, Total	Monthly Avg	1,746 lbs/day	Daily	Calculated	
Nitrogen, Ammonia (NH ₃ -N) Total	Daily Max	17 mg/L	3/Week	24-Hr Flow Prop Comp	
Nitrogen, Ammonia (NH ₃ -N) Total	Weekly Avg	17 mg/L	3/Week	24-Hr Flow Prop Comp	
Nitrogen, Ammonia (NH ₃ -N) Total	Monthly Avg	17 mg/L	3/Week	24-Hr Flow Prop Comp	
Fecal Coliform	Geometric Mean - Monthly	400 #/100 ml	2/Week	Grab	Interim limit effective May through September annually until the final E. coli limit goes into effect per the Effluent Limitations for E. coli Schedule.

Monitoring Requirements and Effluent Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
E. coli		#/100 ml	2/Week	Grab	Monitoring only May through September annually until the final limit goes into effect per the Effluent Limitations for E. coli Schedule.
E. coli	Geometric Mean - Monthly	126 #/100 ml	2/Week	Grab	Limit Effective May through September annually per the Effluent Limitations for E. coli Schedule.
E. coli	% Exceedance	10 Percent	Monthly	Calculated	Limit Effective May through September annually per the Effluent Limitations for E. coli Schedule. See the E. coli Percent Limit section. Enter the result in the DMR on the last day of the month.
Phosphorus, Total	Monthly Avg	1.0 mg/L	Daily	24-Hr Flow Prop Comp	Limit effective throughout the permit term, as it represents a minimum control level. See Water Quality Trading (WQT) sections for more information.
Phosphorus, Total		lbs/day	Daily	Calculated	Report daily mass discharged using Equation 1a. in the Water Quality Trading (WQT) section.
WQT Credits Used (TP)		lbs/month	Monthly	Calculated	Report WQT TP Credits used per month using Equation 2b. in the Water Quality Trading (WQT) section. Available TP Credits are specified in Table 2 and in the approved Water Quality Trading Plan.
WQT Computed Compliance (TP)	Monthly Avg	33 lbs/day	Monthly	Calculated	Limit is effective January & April annually. Report the WQT TP Computed Compliance value using Equation 4a. in the Water Quality Trading (WQT) section. Value entered on the last day of the month.

Monitoring Requirements and Effluent Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
WQT Computed Compliance (TP)	Monthly Avg	35.1 lbs/day	Monthly	Calculated	Limit is effective February annually.
WQT Computed Compliance (TP)	Monthly Avg	30.8 lbs/day	Monthly	Calculated	Limit is effective March annually.
WQT Computed Compliance (TP)	Monthly Avg	31.3 lbs/day	Monthly	Calculated	Limit is effective May annually.
WQT Computed Compliance (TP)	Monthly Avg	23.5 lbs/day	Monthly	Calculated	Limit is effective July annually.
WQT Computed Compliance (TP)	Monthly Avg	30.4 lbs/day	Monthly	Calculated	Limit is effective June annually.
WQT Computed Compliance (TP)	Monthly Avg	20.3 lbs/day	Monthly	Calculated	Limit is effective August annually.
WQT Computed Compliance (TP)	Monthly Avg	18.5 lbs/day	Monthly	Calculated	Limit is effective starting September 2022.
WQT Computed Compliance (TP)	Monthly Avg	20.2 lbs/day	Monthly	Calculated	Limit is effective starting October 2022.
WQT Computed Compliance (TP)	Monthly Avg	24.4 lbs/day	Monthly	Calculated	Limit is effective November annually.
WQT Computed Compliance (TP)	Monthly Avg	29.5 lbs/day	Monthly	Calculated	Limit is effective December annually.
WQT Credits Used (TP)	Annual Total	1,074.5 lbs/yr	Annual	Calculated	Limit effective in 2022. The sum of total monthly credits used may not exceed Table 2 values listed below.
WQT Credits Used (TP)	Annual Total	2,149 lbs/yr	Annual	Calculated	Limit effective in 2023, 2024 and 2025. The sum of total monthly credits used may not exceed Table 2 values listed below.
pH Field	Daily Max	9.0 su	Daily	Grab	
pH Field	Daily Min	6.0 su	Daily	Grab	
Nitrogen, Total Kjeldahl		mg/L	Quarterly	24-Hr Flow Prop Comp	
Nitrogen, Nitrite + Nitrate Total		mg/L	Quarterly	24-Hr Flow Prop Comp	
Nitrogen, Total		mg/L	Quarterly	Calculated	
Acute WET		TU _a	See Listed Qtr(s)	24-Hr Flow Prop Comp	See WET Section
Chronic WET		TU _c	See Listed Qtr(s)	24-Hr Flow Prop Comp	See WET Section
Cadmium, Total Recoverable		µg/L	Quarterly	24-Hr Flow Prop Comp	
Chromium, Total Recoverable		µg/L	Quarterly	24-Hr Flow Prop Comp	
Copper, Total Recoverable		µg/L	Quarterly	24-Hr Flow Prop Comp	

Monitoring Requirements and Effluent Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Lead, Total Recoverable		µg/L	Quarterly	24-Hr Flow Prop Comp	
Nickel, Total Recoverable		µg/L	Quarterly	24-Hr Flow Prop Comp	
Zinc, Total Recoverable		µg/L	Quarterly	24-Hr Flow Prop Comp	
Mercury, Total Recoverable		ng/L	Quarterly	Grab	
Chloride		mg/L	4/Month	24-Hr Flow Prop Comp	Monitoring only in 2024
Temperature Maximum		deg F	3/Week	Continuous	Monitoring only in 2024

3.2.1.1 Annual Average Design Flow

The annual average design flow of the permittee’s wastewater treatment facility is 13.2 MGD.

3.2.1.2 Total Metals Analyses

Measurements of total metals and total recoverable metals shall be considered as equivalent.

3.2.1.3 Sample Analysis

Samples shall be analyzed using a method which provides adequate sensitivity so that results can be quantified, unless not possible using the most sensitive approved method.

3.2.1.4 Mercury Monitoring

The permittee shall collect and analyze all mercury samples according to the data quality requirements of ss. NR 106.145(9) and (10), Wisconsin Administrative Code. The limit of quantitation (LOQ) used for the effluent and field blank shall be less than 1.3 ng/L, unless the samples are quantified at levels above 1.3 ng/L. The permittee shall collect at least one mercury field blank for each set of mercury samples (a set of samples may include combinations of intake, influent, effluent or other samples all collected on the same day). The permittee shall report results of samples and field blanks to the Department on Discharge Monitoring Reports.

3.2.1.5 Mercury – Pollutant Minimization Plan

The permittee shall continue to (a) maintain effluent quality at or below the current effluent concentrations, (b) continue to implement the mercury pollutant minimization plan and (c) perform the actions listed in the schedule.

3.2.1.6 E. coli Percent Limit

No more than 10 percent of *E. coli* bacteria samples collected in any calendar month may exceed 410 #/100 ml. Bacteria samples may be collected more frequently than required. All samples shall be reported on the monthly discharge monitoring reports (DMRs). The following calculation should be used to calculate percent exceedances.

$$\frac{\text{\# of Samples greater than 410 \#/100}}{\text{Total \# of samples}} \times 100 = \% \text{ Exceedance}$$

3.2.1.7 Effluent Temperature Monitoring

For monitoring temperature continuously, collect measurements in accordance with s. NR 218.04(13). This means that discrete measurements shall be recorded at intervals of not more than 15 minutes during the 24-hour period. Report the maximum temperature measured during the day on the DMR.

3.2.1.8 4/Monthly Chloride Sampling Frequency

A sample frequency of 4/Month requires that samples be collected on four consecutive days one week each month. Any four consecutive days of sampling shall be exclusive to one week of a month; where Week 1 is days 1-7, Week 2 is days 8-14, Week 3 is days 15-21, and Week 4 is days 22-28. Any monitoring performed on days 29, 30, or 31 (the stub week) will not be included in any weekly average. Note that only the daily concentration result and calculated daily mass discharge needs to be reported on the electronic discharge monitoring report (eDMR); the eDMR will automatically calculate the weekly average and compare to the weekly average limit to determine compliance.

3.2.1.9 Phosphorus Water Quality Trading (WQT)

The permittee may use water quality trading to demonstrate compliance with WQBELS for total phosphorus (TP) in the chart below. Pollutant reduction credits for total phosphorus are available as specified in Water Quality Trading Plan WQT-2021-0008 or approved amendments thereof.

Total Phosphorus TMDL WQBELS

Month	Monthly Average Total P Effluent Limit (lbs/day)
Jan	33.0
Feb	35.1
March	30.8
April	33.0
May	31.3
June	30.4
July	23.5
Aug	20.3
Sept	18.5
Oct	20.2
Nov	24.4
Dec	29.5

Table 2. Available Phosphorus Credits per WQT-2021-0008

Year	Available TP Credits (lbs/yr) – Long Term	Available TP Credits (lbs/yr) – Interim	Available TP Credits (lbs/yr) – Total

2022	376.97	697.83	1074.5
2023	753.94	1395.65	2149
2024	753.94	1395.65	2149
2025*	753.94	1395.65	2149

*In the event that this permit is not reissued prior to the expiration date, 2149 lbs/yr of credit will be available in subsequent year(s).

Only those pollutant reduction credits established by a water quality trading plan approved by the Department may be used by the permittee to demonstrate compliance with the WQBELs identified in this subsection. If the permittee wishes to use pollutant reduction credits not identified in an approved water quality trading plan, the permittee must amend the plan or develop a new plan and obtain Department approval of the amended or new plan prior to use of the new pollutant reduction credits. Prior to Department approval, the amended or new water quality trading plan will be subject to notice and opportunity for public comment. Any change in the number of available credits requires a permit modification.

In the event pollutant reduction credits as defined in the approved water quality trading plan are no longer generated, the permittee shall comply with the WQBELs for TP contained in this subsection. The sum of available interim and long-term credits shown in Table 2 may be used to demonstrate compliance for a given year. Interim credits are subject to duration limits and may not be used past the duration defined in Water Quality Trading Plan WQT-2021-0008.

3.2.1.10 Demonstrating Compliance with TP WQBELs Using Water Quality Trading

Use the following methods to demonstrate compliance with the TP WQBELs contained in the Water Quality Trading subsection above.

TOTAL POLLUTANT DISCHARGED (TP)

Use the following equations to calculate the amount of pollutant discharged for Monthly Avg TP [lbs/day].

$\text{TP Discharged [lbs/day]} = \text{TP Discharged [mg/L]} \times \text{Daily Flow [MGD]} \times 8.34$	<i>(Eq. 1a.)</i>
---	------------------

Monthly or Weekly Avg = Σ daily results \div # of results *(Eq. 1b.)*

WQT CREDITS USED (TOTAL PHOSPHORUS)

Use the following method to calculate the credits to be used expressed as a mass in lbs/month:

WQT TP Credits Needed [lbs/day] = Monthly Avg TP [lbs/day] – {the Monthly Ave limit} [lbs/day]
(Eq. 2a.)

Note: When the TP discharge is less than {the monthly average limit} lbs/day as a monthly avg, report 0 (zero) as the “WQT Credits Used (TP)”. The monthly limit for each month ({Monthly Ave limit} [lbs/day]) is located in the Total Phosphorus TMDL WQBELs Table above at 2.1.2.8.

WQT TP Credits Used [lbs/month] = WQT TP Credits Needed [lbs/day] × # of days of discharge/month (Eq. 2b.)

WQT COMPUTED COMPLIANCE (TOTAL PHOSPHORUS)

Use the following method to demonstrate compliance with TP WQBELs expressed as a mass in lbs/day:

WQT TP Computed Compliance [lbs/day] = Monthly Avg TP [lbs/day] – [WQT TP Credits Needed [lbs/day] (Eq. 4a.)

Negative computed compliance values should be entered as zero - “0”.

3.2.1.11 Additional Water Quality Trading Requirements

When using water quality trading to demonstrate compliance with WQBELs for TP, the permittee shall comply with the following:

- Failure to implement any of the terms or conditions of the approved water quality trading plan is a violation of this permit.
- Each month the permittee shall certify that the nonpoint source management practices installed to generate pollutant reduction credits are operated and maintained in a manner consistent with that specified in the approved water quality trading plan. Such a certification may be made by including the following statement as a comment on the monthly discharge monitoring report:

I certify that management practices identified in the approved water quality trading plan as the source of pollutant reduction credits are installed, established and properly maintained.

- At least once a year the permittee or the permittee’s agent shall inspect each nonpoint source management practice that generates pollutant reduction credits to confirm the implementation of the management practice and their appropriate operation and adequate maintenance.
- The permittee shall notify WDNR by telephone within 24 hours or next business day of becoming aware that pollutant reduction credits used or intended for use by the permittee are not being implemented or generated as defined in the approved trading plan. A written notification shall be submitted to the Department within 5 days regarding the status of the permittee’s pollutant reduction credits.
- The permittee shall provide WDNR written notice within 7 days of the trade agreement upon which the approved water quality trading plan is based being amended, modified, or revoked. This notification shall include the details of any amendment or modification in addition to the justification for the changes.
- The permittee shall not use pollutant reduction credits for the demonstration of compliance when pollutant reduction credits are not being generated.

3.2.1.12 Water Quality Trading Reopener Clause

Under any of the following conditions as provided by s. 283.53(2), Wis. Stats. and Wis. Adm. Code NR 203.135 and 203.136, the Department may modify or revoke and reissue this permit to modify or eliminate permit terms and conditions related to water quality trading:

- The permittee fails to implement the water quality trading plan as approved;
- The permittee fails to comply with permit terms and conditions related to water quality trading;
- New information becomes available that would change the number of credits available for the water quality trade or would change the Department's determinations that water quality trading is an acceptable option.

3.2.1.13 Submittal of Permit Application for Next Reissuance and Pollutant Trading Plan

The permittee shall submit the permit application for the next reissuance at least 6 months prior to expiration of this permit.

The permittee has submitted a Water Quality Trading Plan that was approved by WDNR on July 7, 2021. If the permittee intends to pursue pollutant trading to achieve compliance in a future permit term, an updated water quality trading plan is due with the application for the next reissuance. If system upgrades will be used in combination with pollutant trading the permittee shall submit plans for any system upgrade.

3.2.1.14 Whole Effluent Toxicity (WET) Testing

Primary Control Water: Rock River upstream of influence of mixing zone

Instream Waste Concentration (IWC): 27%

Dilution series: At least five effluent concentrations and dual controls must be included in each test.

- **Acute:** 100, 50, 25, 12.5, 6.25% and any additional selected by the permittee.
- **Chronic:** 100, 75, 50, 25, 12.5% (if the IWC >30%) and any additional selected by the permittee.

WET Testing Frequency:

Acute tests shall be conducted once each year in rotating quarters in order to collect seasonal information about the discharge. Tests are required during the following quarters.

July-September 2021; April-June 2022; January-March 2023; July-September 2024; January-March 2025

Acute WET testing shall continue after the permit expiration date (until the permit is reissued) in accordance with the WET requirements specified for the last full calendar year of this permit. For example, the next test would be required in **July-September 2026**.

Chronic tests shall be conducted once each year in rotating quarters in order to collect seasonal information about the discharge. Tests are required during the following quarters.

July-September 2021; April-June 2022; January-March 2023; July-September 2024; January-March 2025

Chronic WET testing shall continue after the permit expiration date (until the permit is reissued) in accordance with the WET requirements specified for the last full calendar year of this permit. For example, the next test would be required in **July-September 2026**.

Testing: WET testing shall be performed during normal operating conditions. Permittees are not allowed to turn off or otherwise modify treatment systems, production processes, or change other operating or treatment conditions during WET tests.

Reporting: The permittee shall report test results on the Discharge Monitoring Report form, and also complete the "Whole Effluent Toxicity Test Report Form" (Section 6, "*State of Wisconsin Aquatic Life Toxicity Testing Methods Manual, 2nd Edition*"), for each test. The original, complete, signed version of the Whole Effluent Toxicity Test Report Form shall be sent to the Biomonitoring Coordinator, Bureau of Water Quality, 101 S. Webster St., P.O. Box 7921, Madison, WI 53707-7921, within 45 days of test completion. The Discharge Monitoring Report (DMR) form shall be submitted electronically by the required deadline.

Determination of Positive Results: An acute toxicity test shall be considered positive if the Toxic Unit - Acute (TU_a) is greater than 1.0 for either species. The TU_a shall be calculated as follows: $TU_a = 100 \div LC_{50}$. A chronic toxicity test shall be considered positive if the Toxic Unit - Chronic (TU_c) is greater than 3.7 for either species. The TU_c shall be calculated as follows: $TU_c = 100 \div IC_{25}$.

Additional Testing Requirements: Within 90 days of a test which showed positive results, the permittee shall submit the results of at least 2 retests to the Biomonitoring Coordinator on "Whole Effluent Toxicity Test Report Forms". The 90 day reporting period shall begin the day after the test which showed a positive result. The retests shall be completed using the same species and test methods specified for the original test (see the Standard Requirements section herein).

4 Land Application Requirements

4.1 Sampling Point(s)

The discharge(s) shall be limited to land application of the waste type(s) designated for the listed sampling point(s) on Department approved land spreading sites or by hauling to another facility.

Sampling Point Designation	
Sampling Point Number	Sampling Point Location, WasteType/Sample Contents and Treatment Description (as applicable)
002	Anaerobically digested, thickened, Liquid, Class B. Representative sludge samples shall be collected from the on-site storage tank recirculation line.
005	Anaerobically digested, thickened, Cake, Class B. Representative sludge samples shall be collected from the cake pump after the belt press.

4.2 Monitoring Requirements and Limitations

The permittee shall comply with the following monitoring requirements and limitations.

4.2.1 Sampling Point (Outfall) 002 - Anaerobic Liquid Sludge and 005- Anaerobic Cake Sludge

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Solids, Total		Percent	1/ 2 Months	Composite	
Arsenic Dry Wt	Ceiling	75 mg/kg	1/ 2 Months	Composite	
Arsenic Dry Wt	High Quality	41 mg/kg	1/ 2 Months	Composite	
Cadmium Dry Wt	Ceiling	85 mg/kg	1/ 2 Months	Composite	
Cadmium Dry Wt	High Quality	39 mg/kg	1/ 2 Months	Composite	
Copper Dry Wt	Ceiling	4,300 mg/kg	1/ 2 Months	Composite	
Copper Dry Wt	High Quality	1,500 mg/kg	1/ 2 Months	Composite	
Lead Dry Wt	Ceiling	840 mg/kg	1/ 2 Months	Composite	
Lead Dry Wt	High Quality	300 mg/kg	1/ 2 Months	Composite	
Mercury Dry Wt	Ceiling	57 mg/kg	1/ 2 Months	Composite	
Mercury Dry Wt	High Quality	17 mg/kg	1/ 2 Months	Composite	
Molybdenum Dry Wt	Ceiling	75 mg/kg	1/ 2 Months	Composite	
Nickel Dry Wt	Ceiling	420 mg/kg	1/ 2 Months	Composite	
Nickel Dry Wt	High Quality	420 mg/kg	1/ 2 Months	Composite	
Selenium Dry Wt	Ceiling	100 mg/kg	1/ 2 Months	Composite	
Selenium Dry Wt	High Quality	100 mg/kg	1/ 2 Months	Composite	
Zinc Dry Wt	Ceiling	7,500 mg/kg	1/ 2 Months	Composite	
Zinc Dry Wt	High Quality	2,800 mg/kg	1/ 2 Months	Composite	
Nitrogen, Total Kjeldahl		Percent	1/ 2 Months	Composite	
Nitrogen, Ammonium (NH ₄ -N) Total		Percent	1/ 2 Months	Composite	

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Phosphorus, Total		Percent	1/ 2 Months	Composite	
Phosphorus, Water Extractable		% of Tot P	1/ 2 Months	Composite	
Potassium, Total Recoverable		Percent	1/ 2 Months	Composite	
PCB Total Dry Wt	Ceiling	50 mg/kg	Once	Composite	Once in 2021
PCB Total Dry Wt	High Quality	10 mg/kg	Once	Composite	Once in 2021

Other Sludge Requirements	
Sludge Requirements	Sample Frequency
List 3 Requirements – Pathogen Control: The requirements in List 3 shall be met prior to land application of sludge.	BiMonthly
List 4 Requirements – Vector Attraction Reduction: The vector attraction reduction shall be satisfied prior to, or at the time of land application as specified in List 4.	BiMonthly

4.2.1.1 List 2 Analysis

If the monitoring frequency for List 2 parameters is more frequent than "Annual" then the sludge may be analyzed for the List 2 parameters just prior to each land application season rather than at the more frequent interval specified.

4.2.1.2 Changes in Feed Sludge Characteristics

If a change in feed sludge characteristics, treatment process, or operational procedures occurs which may result in a significant shift in sludge characteristics, the permittee shall reanalyze the sludge for List 1, 2, 3 and 4 parameters each time such change occurs.

4.2.1.3 Multiple Sludge Sample Points (Outfalls)

If there are multiple sludge sample points (outfalls), but the sludges are not subject to different sludge treatment processes, then a separate List 2 analysis shall be conducted for each sludge type which is land applied, just prior to land application, and the application rate shall be calculated for each sludge type. In this case, List 1, 3, and 4 and PCBs need only be analyzed on a single sludge type, at the specified frequency. If there are multiple sludge sample points (outfalls), due to multiple treatment processes, List 1, 2, 3 and 4 and PCBs shall be analyzed for each sludge type at the specified frequency.

4.2.1.4 Sludge Which Exceeds the High Quality Limit

Cumulative pollutant loading records shall be kept for all bulk land application of sludge which does not meet the high quality limit for any parameter. This requirement applies for the entire calendar year in which any exceedance of Table 3 of s. NR 204.07(5)(c), is experienced. Such loading records shall be kept for all List 1 parameters for each site land applied in that calendar year. The formula to be used for calculating cumulative loading is as follows:

$$[(\text{Pollutant concentration (mg/kg)} \times \text{dry tons applied/ac}) \div 500] + \text{previous loading (lbs/acre)} = \text{cumulative lbs pollutant per acre}$$

When a site reaches 90% of the allowable cumulative loading for any metal established in Table 2 of s. NR 204.07(5)(b), the Department shall be so notified through letter or in the comment section of the annual land application report (3400-55).

4.2.1.5 Sludge Analysis for PCBs

The permittee shall analyze the sludge for Total PCBs one time during 2021. The results shall be reported as "PCB Total Dry Wt". Either congener-specific analysis or Aroclor analysis shall be used to determine the PCB concentration. The permittee may determine whether Aroclor or congener specific analysis is performed. Analyses shall be performed in accordance with Table EM in s. NR 219.04, Wis. Adm. Code and the conditions specified in Standard Requirements of this permit. PCB results shall be submitted by January 31, following the specified year of analysis.

4.2.1.6 Lists 1, 2, 3, and 4

<p>List 1 TOTAL SOLIDS AND METALS</p> <p>See the Monitoring Requirements and Limitations table above for monitoring frequency and limitations for the List 1 parameters</p>
Solids, Total (percent)
Arsenic, mg/kg (dry weight)
Cadmium, mg/kg (dry weight)
Copper, mg/kg (dry weight)
Lead, mg/kg (dry weight)
Mercury, mg/kg (dry weight)
Molybdenum, mg/kg (dry weight)
Nickel, mg/kg (dry weight)
Selenium, mg/kg (dry weight)
Zinc, mg/kg (dry weight)

<p>List 2 NUTRIENTS</p> <p>See the Monitoring Requirements and Limitations table above for monitoring frequency for the List 2 parameters</p>
Solids, Total (percent)
Nitrogen Total Kjeldahl (percent)
Nitrogen Ammonium (NH ₄ -N) Total (percent)
Phosphorus Total as P (percent)
Phosphorus, Water Extractable (as percent of Total P)
Potassium Total Recoverable (percent)

List 3

PATHOGEN CONTROL FOR CLASS B SLUDGE

The permittee shall implement pathogen control as listed in List 3. The Department shall be notified of the pathogen control utilized and shall be notified when the permittee decides to utilize alternative pathogen control.

The following requirements shall be met prior to land application of sludge.

Parameter	Unit	Limit
Fecal Coliform *	MPN/gTS or CFU/gTS	2,000,000
OR, ONE OF THE FOLLOWING PROCESS OPTIONS		
Aerobic Digestion		Air Drying
Anaerobic Digestion		Composting
Alkaline Stabilization		PSRP Equivalent Process
* The Fecal Coliform limit shall be reported as the geometric mean of 7 discrete samples on a dry weight basis.		

List 4

VECTOR ATTRACTION REDUCTION

The permittee shall implement any one of the vector attraction reduction options specified in List 4. The Department shall be notified of the option utilized and shall be notified when the permittee decides to utilize an alternative option.

One of the following shall be satisfied prior to, or at the time of land application as specified in List 4.

Option	Limit	Where/When it Shall be Met
Volatile Solids Reduction	≥38%	Across the process
Specific Oxygen Uptake Rate	≤1.5 mg O ₂ /hr/g TS	On aerobic stabilized sludge
Anaerobic bench-scale test	<17 % VS reduction	On anaerobic digested sludge
Aerobic bench-scale test	<15 % VS reduction	On aerobic digested sludge
Aerobic Process	>14 days, Temp >40°C and Avg. Temp > 45°C	On composted sludge
pH adjustment	>12 S.U. (for 2 hours) and >11.5 (for an additional 22 hours)	During the process
Drying without primary solids	>75 % TS	When applied or bagged
Drying with primary solids	>90 % TS	When applied or bagged
Equivalent Process	Approved by the Department	Varies with process
Injection	-	When applied
Incorporation	-	Within 6 hours of application

4.2.1.7 Daily Land Application Log

Daily Land Application Log		
Discharge Monitoring Requirements and Limitations		
<p>The permittee shall maintain a daily land application log for biosolids land applied each day when land application occurs. The following minimum records must be kept, in addition to all analytical results for the biosolids land applied. The log book records shall form the basis for the annual land application report requirements.</p>		
Parameters	Units	Sample Frequency
DNR Site Number(s)	Number	Daily as used
Outfall number applied	Number	Daily as used
Acres applied	Acres	Daily as used
Amount applied	As appropriate * /day	Daily as used
Application rate per acre	unit */acre	Daily as used
Nitrogen applied per acre	lb/acre	Daily as used
Method of Application	Injection, Incorporation, or surface applied	Daily as used

*gallons, cubic yards, dry US Tons or dry Metric Tons

5 Schedules

5.1 Effluent Limitations for E. coli

Required Action	Due Date
<p>Status Update: The permittee shall submit information within the discharge monitoring report (DMR) comment section documenting the steps taken in preparation for properly monitoring and testing for E. coli including, but not limited to, selected test method and location of sampling.</p>	11/21/2020
<p>Operational Evaluation Report: The permittee shall prepare and submit an Operational Evaluation Report to the Department for review and approval. The report shall include an evaluation of collected effluent data and proposed operational improvements that will optimize efficacy of disinfection at the treatment plant during the period prior to complying with final E. coli limitations and, to the extent possible, enable compliance with the final E. coli limitations. The report shall include a plan and schedule for implementation of the operational improvements. These improvements shall occur as soon as possible, but not later than April 30, 2022. The report shall state whether the operational improvements are expected to result in compliance with the final E. coli limitations.</p> <p>The permittee shall implement the operational improvements in accordance with the approved plan and schedule specified in the Operational Evaluation Report and in no case later than April 30, 2022.</p> <p>If the Operational Evaluation Report concludes that the operational improvements are expected to result in compliance with the final E. coli limitations, the permittee shall comply with the final E. coli limitations by April 30, 2022 and the permittee is not required to comply with subsequent milestones identified below in this compliance schedule ('Submit Facility Plan', 'Final Plans and Specifications', 'Treatment Plant Upgrade to Meet Limitations', 'Construction Upgrade Progress Report', 'Complete Construction', 'Achieve Compliance').</p> <p>FACILITY PLAN - If the Operational Evaluation Report concludes that operational improvements alone are not expected to result in compliance with the final E. coli limitations, the permittee shall initiate development of a facility plan for meeting final E. coli limitations and comply with the remaining required actions in this schedule of compliance.</p> <p>If the Department disagrees with the conclusion of the report, and determines that the permittee can achieve final E. coli limitations using the existing treatment system with only operational improvements, the Department may reopen and modify the permit to include an implementation schedule for achieving the final E. coli limitations sooner than April 30, 2025.</p>	10/31/2021
<p>Construction Upgrade Progress Report: The permittee shall submit a progress report on construction upgrades.</p>	09/30/2022
<p>Complete Construction: The permittee shall complete construction of wastewater treatment system upgrades.</p>	03/31/2023
<p>Achieve Compliance: The permittee shall achieve compliance with final E. coli limitations.</p>	04/30/2023

5.2 Mercury Pollutant Minimization Plan

Required Action	Due Date
<p>Final Mercury Report: Submit a report summarizing the mercury pollutant minimization measures</p>	03/31/2025

<p>implemented during the current permit term and the success in maintaining effluent quality at or below the current concentrations. The report shall include an analysis of trends in quarterly and annual average mercury concentrations and total mass discharge of mercury based on mercury sampling and flow data covering the current permit term. The report shall also include an analysis of how influent and effluent mercury varies with time and with significant loadings of mercury such as loads from industries or collection system maintenance.</p>	
--	--

5.3 Water Quality Trading (WQT) Management Plan

Required Action	Due Date
<p>Submit Progress Report on Management Practices Installation: Submit a progress report on the installation of management practices as identified in the Water Quality Management Plan WQT-2021-0008 as approved by the Department.</p>	03/31/2022
<p>Complete Installation of Management Practices: Complete the installation of management practices as identified in the Water Quality Management Plan WQT-2021-0008 as approved by the Department.</p>	06/30/2022
<p>Management Practices: The Management Practices as identified in the Water Quality Trading Plan shall become effective and the permittee shall submit a completed Management Practice Registration Form 3400-207 for each site.</p>	06/30/2022
<p>Comply with Total Phosphorus Limits: Comply with the TP limits as specified in Table 2.2.1.</p>	07/01/2022

5.4 Annual Water Quality Trading (WQT) Report

Required Action	Due Date
<p>Annual WQT Report: Submit an annual WQT report that shall cover the first year of the permit term. The WQT Report shall include:</p> <p>The number of pollutant reduction credits (lbs/month) used each month of the previous year to demonstrate compliance;</p> <p>The source of each month’s pollutant reduction credits by identifying the approved water quality trading plan that details the source;</p> <p>A summary of the annual inspection of each nonpoint source management practice that generated any of the pollutant reduction credits used during the previous year; and</p> <p>Identification of noncompliance or failure to implement any terms or conditions of this permit with respect to water quality trading that have not been reported in discharge monitoring reports.</p>	01/31/2023
<p>Annual WQT Report #2: Submit an annual WQT report that shall cover the previous year.</p>	01/31/2024
<p>Annual WQT Report #3: Submit an annual WQT report that shall cover the previous year.</p>	01/31/2025
<p>Annual WQT Report #4: Submit the 4th annual WQT report. If the permittee wishes to continue to comply with phosphorus limits through WQT in subsequent permit terms, the permittee shall submit a revised WQT plan including a demonstration of credit need, compliance record of the existing WQT, and any additional practices needed to maintain compliance over time.</p>	01/31/2026

<p>Annual WQT Report Required After Permit Expiration: In the event that this permit is not reissued by the expiration date, the permittee shall continue to submit annual WQT reports by January 31 each year covering the total number of pollutant credits used, the source of the pollution reduction credits, a summary of annual inspection reports performed, and identification of noncompliance or failure to implement any terms or conditions of the approved water quality trading plan for the previous calendar year.</p>	
--	--

6 Standard Requirements

NR 205, Wisconsin Administrative Code: The conditions in ss. NR 205.07(1) and NR 205.07(2), Wis. Adm. Code, are included by reference in this permit. The permittee shall comply with all of these requirements. Some of these requirements are outlined in the Standard Requirements section of this permit. Requirements not specifically outlined in the Standard Requirement section of this permit can be found in ss. NR 205.07(1) and NR 205.07(2).

6.1 Reporting and Monitoring Requirements

6.1.1 Monitoring Results

Monitoring results obtained during the previous month shall be summarized and reported on a Department Wastewater Discharge Monitoring Report. The report may require reporting of any or all of the information specified below under 'Recording of Results'. This report is to be returned to the Department no later than the date indicated on the form. A copy of the Wastewater Discharge Monitoring Report Form or an electronic file of the report shall be retained by the permittee.

Monitoring results shall be reported on an electronic discharge monitoring report (eDMR). The eDMR shall be certified electronically by a responsible executive or municipal officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The 'eReport Certify' page certifies that the electronic report form is true, accurate and complete.

If the permittee monitors any pollutant more frequently than required by this permit, the results of such monitoring shall be included on the Wastewater Discharge Monitoring Report.

The permittee shall comply with all limits for each parameter regardless of monitoring frequency. For example, monthly, weekly, and/or daily limits shall be met even with monthly monitoring. The permittee may monitor more frequently than required for any parameter.

6.1.2 Sampling and Testing Procedures

Sampling and laboratory testing procedures shall be performed in accordance with Chapters NR 218 and NR 219, Wis. Adm. Code and shall be performed by a laboratory certified or registered in accordance with the requirements of ch. NR 149, Wis. Adm. Code. Groundwater sample collection and analysis shall be performed in accordance with ch. NR 140, Wis. Adm. Code. The analytical methodologies used shall enable the laboratory to quantitate all substances for which monitoring is required at levels below the effluent limitation. If the required level cannot be met by any of the methods available in NR 219, Wis. Adm. Code, then the method with the lowest limit of detection shall be selected. Additional test procedures may be specified in this permit.

6.1.3 Pretreatment Sampling Requirements

Sampling for pretreatment parameters (cadmium, chromium, copper, lead, nickel, zinc, and mercury) shall be done during a day each month when industrial discharges are occurring at normal to maximum levels. The sampling of the influent and effluent for these parameters shall be coordinated. All 24 hour composite samples shall be flow proportional.

6.1.4 Recording of Results

The permittee shall maintain records which provide the following information for each effluent measurement or sample taken:

- the date, exact place, method and time of sampling or measurements;
- the individual who performed the sampling or measurements;

- the date the analysis was performed;
- the individual who performed the analysis;
- the analytical techniques or methods used; and
- the results of the analysis.

6.1.5 Reporting of Monitoring Results

The permittee shall use the following conventions when reporting effluent monitoring results:

- Pollutant concentrations less than the limit of detection shall be reported as < (less than) the value of the limit of detection. For example, if a substance is not detected at a detection limit of 0.1 mg/L, report the pollutant concentration as < 0.1 mg/L.
- Pollutant concentrations equal to or greater than the limit of detection, but less than the limit of quantitation, shall be reported and the limit of quantitation shall be specified.
- For purposes of calculating NR 101 fees, the 2 mg/l lower reporting limits for BOD₅ and Total Suspended Solids shall be considered to be limits of quantitation
- For the purposes of reporting a calculated result, average or a mass discharge value, the permittee may substitute a “0” (zero) for any pollutant concentration that is less than the limit of detection. However, if the effluent limitation is less than the limit of detection, the department may substitute a value other than zero for results less than the limit of detection, after considering the number of monitoring results that are greater than the limit of detection and if warranted when applying appropriate statistical techniques.
- If no discharge occurs through an outfall, flow related parameters (e.g. flow rate, hydraulic application rate, volume, etc.) should be reported as “0” (zero) at the required sample frequency specified for the outfall. For example: if the sample frequency is daily, “0” would be reported for any day during the month that no discharge occurred.

6.1.6 Compliance Maintenance Annual Reports

Compliance Maintenance Annual Reports (CMAR) shall be completed using information obtained over each calendar year regarding the wastewater conveyance and treatment system. The CMAR shall be submitted and certified by the permittee in accordance with ch. NR 208, Wis. Adm. Code, by June 30, each year on an electronic report form provided by the Department.

In the case of a publicly owned treatment works, a resolution shall be passed by the governing body and submitted as part of the CMAR, verifying its review of the report and providing responses as required. Private owners of wastewater treatment works are not required to pass a resolution; but they must provide an Owner Statement and responses as required, as part of the CMAR submittal.

The CMAR shall be certified electronically by a responsible executive or municipal officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The certification verifies that the electronic report is true, accurate and complete.

6.1.7 Records Retention

The permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings or electronic data records for continuous monitoring instrumentation, copies of all reports required by the permit, and records of all data used to complete the application for the permit for a period of at least 3 years from the date of the sample, measurement, report or application. All pertinent sludge information,

including permit application information and other documents specified in this permit or s. NR 204.06(9), Wis. Adm. Code shall be retained for a minimum of 5 years.

6.1.8 Other Information

Where the permittee becomes aware that it failed to submit any relevant facts in a permit application or submitted incorrect information in a permit application or in any report to the Department, it shall promptly submit such facts or correct information to the Department.

6.1.9 Reporting Requirements – Alterations or Additions

The permittee shall give notice to the Department as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is only required when:

- The alteration or addition to the permitted facility may meet one of the criteria for determining whether a facility is a new source.
- The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification requirement applies to pollutants which are not subject to effluent limitations in the existing permit.
- The alteration or addition results in a significant change in the permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use of disposal sites not reported during the permit application process nor reported pursuant to an approved land application plan. Additional sites may not be used for the land application of sludge until department approval is received.

6.2 System Operating Requirements

6.2.1 Noncompliance Reporting

Sanitary sewer overflows and sewage treatment facility overflows shall be reported according to the 'Sanitary Sewer Overflows and Sewage Treatment Facility Overflows' section of this permit.

The permittee shall report the following types of noncompliance by a telephone call to the Department's regional office within 24 hours after becoming aware of the noncompliance:

- any noncompliance which may endanger health or the environment;
- any violation of an effluent limitation resulting from a bypass;
- any violation of an effluent limitation resulting from an upset; and
- any violation of a maximum discharge limitation for any of the pollutants listed by the Department in the permit, either for effluent or sludge.

A written report describing the noncompliance shall also be submitted to the Department's regional office within 5 days after the permittee becomes aware of the noncompliance. On a case-by-case basis, the Department may waive the requirement for submittal of a written report within 5 days and instruct the permittee to submit the written report with the next regularly scheduled monitoring report. In either case, the written report shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times; the steps taken or planned to reduce, eliminate and prevent reoccurrence of the noncompliance; and if the noncompliance has not been corrected, the length of time it is expected to continue.

A scheduled bypass approved by the Department under the 'Scheduled Bypass' section of this permit shall not be subject to the reporting required under this section.

NOTE: Section 292.11(2)(a), Wisconsin Statutes, requires any person who possesses or controls a hazardous substance or who causes the discharge of a hazardous substance to notify the Department of Natural Resources

immediately of any discharge not authorized by the permit. **The discharge of a hazardous substance that is not authorized by this permit or that violates this permit may be a hazardous substance spill. To report a hazardous substance spill, call DNR's 24-hour HOTLINE at 1-800-943-0003.**

6.2.2 Flow Meters

Flow meters shall be calibrated annually, as per s. NR 218.06, Wis. Adm. Code.

6.2.3 Raw Grit and Screenings

All raw grit and screenings shall be disposed of at a properly licensed solid waste facility or picked up by a licensed waste hauler. If the facility or hauler are located in Wisconsin, then they shall be licensed under chs. NR 500-555, Wis. Adm. Code.

6.2.4 Sludge Management

All sludge management activities shall be conducted in compliance with ch. NR 204 "Domestic Sewage Sludge Management", Wis. Adm. Code.

6.2.5 Prohibited Wastes

Under no circumstances may the introduction of wastes prohibited by s. NR 211.10, Wis. Adm. Code, be allowed into the waste treatment system. Prohibited wastes include those:

- which create a fire or explosion hazard in the treatment work;
- which will cause corrosive structural damage to the treatment work;
- solid or viscous substances in amounts which cause obstructions to the flow in sewers or interference with the proper operation of the treatment work;
- wastewaters at a flow rate or pollutant loading which are excessive over relatively short time periods so as to cause a loss of treatment efficiency; and
- changes in discharge volume or composition from contributing industries which overload the treatment works or cause a loss of treatment efficiency.

6.2.6 Bypass

This condition applies only to bypassing at a sewage treatment facility that is not a scheduled bypass, approved blending as a specific condition of this permit, a sewage treatment facility overflow or a controlled diversion as provided in the sections titled 'Scheduled Bypass', 'Blending' (if approved), 'SSO's and Sewage Treatment Facility Overflows' and 'Controlled Diversions' of this permit. Any other bypass at the sewage treatment facility is prohibited and the Department may take enforcement action against a permittee for such occurrences under s. 283.89, Wis. Stats. The Department may approve a bypass if the permittee demonstrates all the following conditions apply:

- The bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
- There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities or adequate back-up equipment, retention of untreated wastes, reduction of inflow and infiltration, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventative maintenance. When evaluating feasibility of alternatives, the department may consider factors such as technical achievability, costs and affordability of implementation and risks to public health, the environment and, where the permittee is a municipality, the welfare of the community served; and
- The bypass was reported in accordance with the Noncompliance Reporting section of this permit.

6.2.7 Scheduled Bypass

Whenever the permittee anticipates the need to bypass for purposes of efficient operations and maintenance and the permittee may not meet the conditions for controlled diversions in the 'Controlled Diversions' section of this permit, the permittee shall obtain prior written approval from the Department for the scheduled bypass. A permittee's written request for Department approval of a scheduled bypass shall demonstrate that the conditions for bypassing specified in the above section titled 'Bypass' are met and include the proposed date and reason for the bypass, estimated volume and duration of the bypass, alternatives to bypassing and measures to mitigate environmental harm caused by the bypass. The department may require the permittee to provide public notification for a scheduled bypass if it is determined there is significant public interest in the proposed action and may recommend mitigation measures to minimize the impact of such bypass.

6.2.8 Controlled Diversions

Controlled diversions are allowed only when necessary for essential maintenance to assure efficient operation. Sewage treatment facilities that have multiple treatment units to treat variable or seasonal loading conditions may shut down redundant treatment units when necessary for efficient operation. The following requirements shall be met during controlled diversions:

- Effluent from the sewage treatment facility shall meet the effluent limitations established in the permit. Wastewater that is diverted around a treatment unit or treatment process during a controlled diversion shall be recombined with wastewater that is not diverted prior to the effluent sampling location and prior to effluent discharge;
- A controlled diversion does not include blending as defined in s. NR 210.03(2e), Wis. Adm. Code, and as may only be approved under s. NR 210.12. A controlled diversion may not occur during periods of excessive flow or other abnormal wastewater characteristics;
- A controlled diversion may not result in a wastewater treatment facility overflow; and
- All instances of controlled diversions shall be documented in sewage treatment facility records and such records shall be available to the department on request.

6.2.9 Proper Operation and Maintenance

The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance includes effective performance, adequate funding, adequate operator staffing and training as required in ch. NR 114, Wis. Adm. Code, and adequate laboratory and process controls, including appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems only when necessary to achieve compliance with the conditions of the permit.

6.2.10 Operator Certification

The wastewater treatment facility shall be under the direct supervision of a state certified operator. In accordance with s. NR 114.53, Wis. Adm. Code, every WPDES permitted treatment plant shall have a designated operator-in-charge holding a current and valid certificate. The designated operator-in-charge shall be certified at the level and in all subclasses of the treatment plant, except laboratory. Treatment plant owners shall notify the department of any changes in the operator-in-charge within 30 days. Note that s. NR 114.52(22), Wis. Adm. Code, lists types of facilities that are excluded from operator certification requirements (i.e. private sewage systems, pretreatment facilities discharging to public sewers, industrial wastewater treatment that consists solely of land disposal, agricultural digesters and concentrated aquatic production facilities with no biological treatment).

6.3 Sewage Collection Systems

6.3.1 Sanitary Sewage Overflows and Sewage Treatment Facility Overflows

6.3.1.1 Overflows Prohibited

Any overflow or discharge of wastewater from the sewage collection system or at the sewage treatment facility, other than from permitted outfalls, is prohibited. The permittee shall provide information on whether any of the following conditions existed when an overflow occurred:

- The sanitary sewer overflow or sewage treatment facility overflow was unavoidable to prevent loss of life, personal injury or severe property damage;
- There were no feasible alternatives to the sanitary sewer overflow or sewage treatment facility overflow such as the use of auxiliary treatment facilities or adequate back-up equipment, retention of untreated wastes, reduction of inflow and infiltration, or preventative maintenance activities;
- The sanitary sewer overflow or the sewage treatment facility overflow was caused by unusual or severe weather related conditions such as large or successive precipitation events, snowmelt, saturated soil conditions, or severe weather occurring in the area served by the sewage collection system or sewage treatment facility; and
- The sanitary sewer overflow or the sewage treatment facility overflow was unintentional, temporary, and caused by an accident or other factors beyond the reasonable control of the permittee.

6.3.1.2 Permittee Response to Overflows

Whenever a sanitary sewer overflow or sewage treatment facility overflow occurs, the permittee shall take all feasible steps to control or limit the volume of untreated or partially treated wastewater discharged, and terminate the discharge as soon as practicable. Remedial actions, including those in NR 210.21 (3), Wis. Adm. Code, shall be implemented consistent with an emergency response plan developed under the CMOM program.

6.3.1.3 Permittee Reporting

Permittees shall report all sanitary sewer overflows and sewage treatment overflows as follows:

- The permittee shall notify the department by telephone, fax or email as soon as practicable, but no later than 24 hours from the time the permittee becomes aware of the overflow;
- The permittee shall, no later than five days from the time the permittee becomes aware of the overflow, provide to the department the information identified in this paragraph using department form number 3400-184. If an overflow lasts for more than five days, an initial report shall be submitted within 5 days as required in this paragraph and an updated report submitted following cessation of the overflow. At a minimum, the following information shall be included in the report:
 - The date and location of the overflow;
 - The surface water to which the discharge occurred, if any;
 - The duration of the overflow and an estimate of the volume of the overflow;
 - A description of the sewer system or treatment facility component from which the discharge occurred such as manhole, lift station, constructed overflow pipe, or crack or other opening in a pipe;
 - The estimated date and time when the overflow began and stopped or will be stopped;
 - The cause or suspected cause of the overflow including, if appropriate, precipitation, runoff conditions, areas of flooding, soil moisture and other relevant information;
 - Steps taken or planned to reduce, eliminate and prevent reoccurrence of the overflow and a schedule of major milestones for those steps;
 - A description of the actual or potential for human exposure and contact with the wastewater from the overflow;
 - Steps taken or planned to mitigate the impacts of the overflow and a schedule of major milestones for those steps;
 - To the extent known at the time of reporting, the number and location of building backups caused by excessive flow or other hydraulic constraints in the sewage collection system that occurred

concurrently with the sanitary sewer overflow and that were within the same area of the sewage collection system as the sanitary sewer overflow; and

◦The reason the overflow occurred or explanation of other contributing circumstances that resulted in the overflow event. This includes any information available including whether the overflow was unavoidable to prevent loss of life, personal injury, or severe property damage and whether there were feasible alternatives to the overflow.

NOTE: A copy of form 3400-184 for reporting sanitary sewer overflows and sewage treatment facility overflows may be obtained from the department or accessed on the department's web site at <http://dnr.wi.gov/topic/wastewater/SSOreport.html>. As indicated on the form, additional information may be submitted to supplement the information required by the form.

- The permittee shall identify each specific location and each day on which a sanitary sewer overflow or sewage treatment facility overflow occurs as a discrete sanitary sewer overflow or sewage treatment facility overflow occurrence. An occurrence may be more than one day if the circumstances causing the sanitary sewer overflow or sewage treatment facility overflow results in a discharge duration of greater than 24 hours. If there is a stop and restart of the overflow at the same location within 24 hours and the overflow is caused by the same circumstance, it may be reported as one occurrence. Sanitary sewer overflow occurrences at a specific location that are separated by more than 24 hours shall be reported as separate occurrences; and
- A permittee that is required to submit wastewater discharge monitoring reports under NR 205.07 (1) (r) shall also report all sanitary sewer overflows and sewage treatment facility overflows on that report.

6.3.1.4 Public Notification

The permittee shall notify the public of any sanitary sewer and sewage treatment facility overflows consistent with its emergency response plan required under the CMOM (Capacity, Management, Operation and Maintenance) section of this permit and s. NR 210.23 (4) (f), Wis. Adm. Code. Such public notification shall occur promptly following any overflow event using the most effective and efficient communications available in the community. At minimum, a daily newspaper of general circulation in the county(s) and municipality whose waters may be affected by the overflow shall be notified by written or electronic communication.

6.3.2 Capacity, Management, Operation and Maintenance (CMOM) Program

- The permittee shall have written documentation of the Capacity, Management, Operation and Maintenance (CMOM) program components in accordance with s. NR 210.23(4), Wis. Adm. Code. Such documentation shall be available for Department review upon request. The Department may request that the permittee provide this documentation or prepare a summary of the permittee's CMOM program at the time of application for reissuance of the WPDES permit.
- The permittee shall implement a CMOM program in accordance with s. NR 210.23, Wis. Adm. Code.
- The permittee shall at least annually conduct a self-audit of activities conducted under the permittee's CMOM program to ensure CMOM components are being implemented as necessary to meet the general standards of s. NR 210.23(3), Wis. Adm. Code.

6.3.3 Sewer Cleaning Debris and Materials

All debris and material removed from cleaning sanitary sewers shall be managed to prevent nuisances, run-off, ground infiltration or prohibited discharges.

- Debris and solid waste shall be dewatered, dried and then disposed of at a licensed solid waste facility.
- Liquid waste from the cleaning and dewatering operations shall be collected and disposed of at a permitted wastewater treatment facility.

- Combination waste including liquid waste along with debris and solid waste may be disposed of at a licensed solid waste facility or wastewater treatment facility willing to accept the waste.

6.4 Surface Water Requirements

6.4.1 Permittee-Determined Limit of Quantitation Incorporated into this Permit

For pollutants with water quality-based effluent limits below the Limit of Quantitation (LOQ) in this permit, the LOQ calculated by the permittee and reported on the Discharge Monitoring Reports (DMRs) is incorporated by reference into this permit. The LOQ shall be reported on the DMRs, shall be the lowest quantifiable level practicable, and shall be no greater than the minimum level (ML) specified in or approved under 40 CFR Part 136 for the pollutant at the time this permit was issued, unless this permit specifies a higher LOQ.

6.4.2 Appropriate Formulas for Effluent Calculations

The permittee shall use the following formulas for calculating effluent results to determine compliance with average concentration limits and mass limits and total load limits:

Weekly/Monthly/Six-Month/Annual Average Concentration = the sum of all daily results for that week/month/six-month/year, divided by the number of results during that time period. [Note: When a six-month average effluent limit is specified for Total Phosphorus the applicable periods are May through October and November through April.]

Weekly Average Mass Discharge (lbs/day): Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the week.

Monthly Average Mass Discharge (lbs/day): Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the month.

Six-Month Average Mass Discharge (lbs/day): Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the six-month period. [Note: When a six-month average effluent limit is specified for Total Phosphorus the applicable periods are May through October and November through April.]

Annual Average Mass Discharge (lbs/day): Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the entire year.

Total Monthly Discharge: = monthly average concentration (mg/L) x total flow for the month (MG/month) x 8.34.

Total Annual Discharge: = sum of total monthly discharges for the calendar year.

12-Month Rolling Sum of Total Monthly Discharge: = the sum of the most recent 12 consecutive months of Total Monthly Discharges.

6.4.3 Effluent Temperature Requirements

Weekly Average Temperature – The permittee shall use the following formula for calculating effluent results to determine compliance with the weekly average temperature limit (as applicable): Weekly Average Temperature = the sum of all daily maximum results for that week divided by the number of daily maximum results during that time period.

Cold Shock Standard – Water temperatures of the discharge shall be controlled in a manner as to protect fish and aquatic life uses from the deleterious effects of cold shock. ‘Cold Shock’ means exposure of aquatic organisms to a rapid decrease in temperature and a sustained exposure to low temperature that induces abnormal behavior or physiological performance and may lead to death.

Rate of Temperature Change Standard – Temperature of a water of the state or discharge to a water of the state may not be artificially raised or lowered at such a rate that it causes detrimental health or reproductive effects to fish or aquatic life of the water of the state.

6.4.4 Visible Foam or Floating Solids

There shall be no discharge of floating solids or visible foam in other than trace amounts.

6.4.5 Surface Water Uses and Criteria

In accordance with NR 102.04, Wis. Adm. Code, surface water uses and criteria are established to govern water management decisions. Practices attributable to municipal, industrial, commercial, domestic, agricultural, land development or other activities shall be controlled so that all surface waters including the mixing zone meet the following conditions at all times and under all flow and water level conditions:

- a) Substances that will cause objectionable deposits on the shore or in the bed of a body of water, shall not be present in such amounts as to interfere with public rights in waters of the state.
- b) Floating or submerged debris, oil, scum or other material shall not be present in such amounts as to interfere with public rights in waters of the state.
- c) Materials producing color, odor, taste or unsightliness shall not be present in such amounts as to interfere with public rights in waters of the state.
- d) Substances in concentrations or in combinations which are toxic or harmful to humans shall not be present in amounts found to be of public health significance, nor shall substances be present in amounts which are acutely harmful to animal, plant or aquatic life.

6.4.6 Percent Removal

During any 30 consecutive days, the average effluent concentrations of BOD₅ and of total suspended solids shall not exceed 15% of the average influent concentrations, respectively. This requirement does not apply to removal of total suspended solids if the permittee operates a lagoon system and has received a variance for suspended solids granted under NR 210.07(2), Wis. Adm. Code.

6.4.7 Fecal Coliform

The monthly limit for fecal coliform shall be expressed as a geometric mean. In calculating the geometric mean, a value of 1 is used for any result of 0.

6.4.8 *E. coli*

The monthly limit for *E. coli* shall be expressed as a geometric mean. In calculating the geometric mean, a value of 1 is used for any result of 0.

6.4.9 Seasonal Disinfection

Disinfection shall be provided from May 1 through September 30 of each year. Monitoring requirements and the limitations for Fecal Coliform (interim) and *E. coli* apply only during the period in which disinfection is required. Whenever chlorine is used for disinfection or other uses, the limitations and monitoring requirements for residual chlorine shall apply. A dechlorination process shall be in operation whenever chlorine is used.

6.4.10 Total Residual Chlorine Requirements (When De-Chlorinating Effluent)

Test methods for total residual chlorine, approved in ch. NR 219 - Table B, Wis. Adm. Code, normally achieve a limit of detection of about 20 to 50 micrograms per liter and a limit of quantitation of about 100 micrograms per liter. Reporting of test results and compliance with effluent limitations for chlorine residual and total residual halogens shall be as follows:

- Sample results which show no detectable levels are in compliance with the limit. These test results shall be reported on Wastewater Discharge Monitoring Report Forms as "< 100 µg/L". (Note: 0.1 mg/L converts to 100 µg/L)
- Samples showing detectable traces of chlorine are in compliance if measured at less than 100 µg/L, unless there is a consistent pattern of detectable values in this range. These values shall also be reported on Wastewater Discharge Monitoring Report Forms as "<100 µg/L." The facility operating staff shall record actual readings on logs maintained at the plant, shall take action to determine the reliability of detected results (such as re-sampling and/or calculating dosages), and shall adjust the chemical feed system if necessary to reduce the chances of detects.
- Samples showing detectable levels greater than 100 µg/L shall be considered as exceedances, and shall be reported as measured.
- To calculate average or mass discharge values, a "0" (zero) may be substituted for any test result less than 100 µg/L. Calculated values shall then be compared directly to the average or mass limitations to determine compliance.

6.4.11 Whole Effluent Toxicity (WET) Monitoring Requirements

In order to determine the potential impact of the discharge on aquatic organisms, static-renewal toxicity tests shall be performed on the effluent in accordance with the procedures specified in the "*State of Wisconsin Aquatic Life Toxicity Testing Methods Manual, 2nd Edition*" (PUB-WT-797, November 2004) as required by NR 219.04, Table A, Wis. Adm. Code). All of the WET tests required in this permit, including any required retests, shall be conducted on the *Ceriodaphnia dubia* and fathead minnow species. Receiving water samples shall not be collected from any point in contact with the permittee's mixing zone and every attempt shall be made to avoid contact with any other discharge's mixing zone.

6.4.12 Whole Effluent Toxicity (WET) Identification and Reduction

Within 60 days of a retest which showed positive results, the permittee shall submit a written report to the Biomonitoring Coordinator, Bureau of Water Quality, 101 S. Webster St., PO Box 7921, Madison, WI 53707-7921, which details the following:

- A description of actions the permittee has taken or will take to remove toxicity and to prevent the recurrence of toxicity;
- A description of toxicity reduction evaluation (TRE) investigations that have been or will be done to identify potential sources of toxicity, including some or all of the following actions:
 - (a) Evaluate the performance of the treatment system to identify deficiencies contributing to effluent toxicity (e.g., operational problems, chemical additives, incomplete treatment)
 - (b) Identify the compound(s) causing toxicity
 - (c) Trace the compound(s) causing toxicity to their sources (e.g., industrial, commercial, domestic)
 - (d) Evaluate, select, and implement methods or technologies to control effluent toxicity (e.g., in-plant or pretreatment controls, source reduction or removal)
- Where corrective actions including a TRE have not been completed, an expeditious schedule under which corrective actions will be implemented;

- If no actions have been taken, the reason for not taking action.

The permittee may also request approval from the Department to postpone additional retests in order to investigate the source(s) of toxicity. Postponed retests must be completed after toxicity is believed to have been removed.

6.5 Pretreatment Program Requirements

The permittee is required to operate an industrial pretreatment program as described in the program initially approved by the Department of Natural Resources including any subsequent program modifications approved by the Department, and including commitments to program implementation activities provided in the permittee's annual pretreatment program report, and that complies with the requirements set forth in 40 CFR Part 403 and ch. NR 211, Wis. Adm. Code. To ensure that the program is operated in accordance with these requirements, the following general conditions and requirements are hereby established:

6.5.1 Inventories

The permittee shall implement methods to maintain a current inventory of the general character and volume of wastewater that industrial users discharge to the treatment works and shall provide an updated industrial user listing annually and report any changes in the listing to the Department by March 31 of each year as part of the annual pretreatment program report required herein.

6.5.2 Regulation of Industrial Users

6.5.2.1 Limitations for Industrial Users:

The permittee shall develop, maintain, enforce and revise as necessary local limits to implement the general and specific prohibitions of the state and federal General Pretreatment Regulations.

6.5.2.2 Control Documents for Industrial Users (IUs)

The permittee shall control the discharge from each significant industrial user through individual discharge permits as required by s. NR 211.235, Wis. Adm. Code and in accordance with the approved pretreatment program procedures and the permittee's sewer use ordinance. The discharge permits shall be modified in a timely manner during the stated term of the discharge permits according to the sewer use ordinance as conditions warrant. The discharge permits shall include at a minimum the elements found in s. NR 211.235(1), Wis. Adm. Code and references to the approved pretreatment program procedures and the sewer use ordinance.

6.5.2.3 Review of Industrial User Reports, Inspections and Compliance Monitoring

The permittee shall require the submission of, receive, and review self-monitoring reports and other notices from industrial users in accordance with the approved pretreatment program procedures. The permittee shall randomly sample and analyze industrial user discharges and conduct surveillance activities to determine independent of information supplied by the industrial users, whether the industrial users are in compliance with pretreatment standards and requirements. The inspections and monitoring shall also be conducted to maintain accurate knowledge of local industrial processes, including changes in the discharge, pretreatment equipment operation, spill prevention control plans, slug control plans, and implementation of solvent management plans.

The permittee shall inspect and sample the discharge from each significant industrial user as specified in the permittee's approved pretreatment program or as specified in NR 211.235(3). The permittee shall evaluate whether industrial users identified as significant need a slug control plan according to the requirements of NR 211.235(4). If a slug control plan is needed, the plan shall contain at a minimum the elements specified in s. NR 211.235(4)(b), Wis. Adm. Code.

6.5.2.4 Enforcement and Industrial User Compliance Evaluation & Violation Reports

The permittee shall enforce the industrial pretreatment requirements including the industrial user discharge limitations of the permittee's sewer use ordinance. The permittee shall investigate instances of noncompliance by collecting and analyzing samples and collecting other information with sufficient care to produce evidence admissible in enforcement proceedings or in judicial actions. Investigation and response to instances of noncompliance shall be in accordance with the permittee's sewer use ordinance and approved Enforcement Response Plan.

The permittee shall make a semiannual report on forms provided or approved by the Department. The semiannual report shall include an analysis of industrial user significant noncompliance (i.e. the Industrial User Compliance Evaluation, also known as the SNC Analysis) as outlined in s.NR 211.23(1)(j), Wis. Adm. Code, and a summary of the permittee's response to all industrial noncompliance (i.e. the Industrial User Violation Report). The Industrial User Compliance Evaluation Report shall include monitoring results received from industrial users pursuant to s. NR 211.15(1)-(5), Wis. Adm. Code. The Industrial User Violation Report shall include copies of all notices of noncompliance, notices of violation and other enforcement correspondence sent by the permittee to industrial users, together with the industrial user's response. The Industrial User Compliance Evaluation and Violation Reports for the period January through June shall be provided to the Department by September 30 of each year and for the period July through December shall be provided to the Department by March 31 of the succeeding year, unless alternate submittal dates are approved.

6.5.2.5 Publication of Violations

The permittee shall publish a list of industrial users that have significantly violated the municipal sewer use ordinance during the calendar year, in the largest daily newspaper in the area by March 31 of the following year pursuant to s. NR 211.23(1)(j), Wis. Adm. Code. A copy of the newspaper publication shall be provided as part of the annual pretreatment report specified herein.

6.5.2.6 Multijurisdictional Agreements

The permittee shall establish agreements with all contributing jurisdictions as necessary to ensure compliance with pretreatment standards and requirements by all industrial users discharging to the permittee's wastewater treatment system. Any such agreement shall identify who will be responsible for maintaining the industrial user inventory, issuance of industrial user control mechanisms, inspections and sampling, pretreatment program implementation, and enforcement.

6.5.3 Annual Pretreatment Program Report

The permittee shall evaluate the pretreatment program, and submit the Pretreatment Program Report to the Department on forms provided or approved by the Department by March 31 annually, unless an alternate submittal date is approved. The report shall include a brief summary of the work performed during the preceding calendar year, including the numbers of discharge permits issued and in effect, pollution prevention activities, number of inspections and monitoring surveys conducted, budget and personnel assigned to the program, a general discussion of program progress in meeting the objectives of the permittee's pretreatment program together with summary comments and recommendations.

6.5.4 Pretreatment Program Modifications

- **Future Modifications:** The permittee shall within one year of any revisions to federal or state General Pretreatment Regulations submit an application to the Department in duplicate to modify and update its approved pretreatment program to incorporate such regulatory changes as applicable to the permittee. Additionally, the Department or the permittee may request an application for program modification at any time where necessary to improve program effectiveness based on program experience to date.

- **Modifications Subject to Department Approval:** The permittee shall submit all proposed pretreatment program modifications to the Department for determination of significance and opportunity for comment in accordance with the requirements and conditions of s. NR 211.27, Wis. Adm. Code. Any substantial proposed program modification shall be subject to Department public noticing and formal approval prior to implementation. A substantial program modification includes, but is not limited to, changes in enabling legal authority to administer and enforce pretreatment conditions and requirements; significant changes in program administrative or operational procedures; significant reductions in monitoring frequencies; significant reductions in program resources including personnel commitments, equipment, and funding levels; changes (including any relaxation) in the local limitations for substances enforced and applied to users of the sewerage treatment works; changes in treatment works sludge disposal or management practices which impact the pretreatment program; or program modifications which increase pollutant loadings to the treatment works. The Department shall use the procedures outlined in s. NR 211.30, Wis. Adm. Code for review and approval/denial of proposed pretreatment program modifications. The permittee shall comply with local public participation requirements when implementing the pretreatment program.

6.5.5 Program Resources

The permittee shall have sufficient resources and qualified personnel to carry out the pretreatment program responsibilities as listed in ss. NR 211.22 and NR 211.23, Wis. Adm. Code.

6.6 Land Application Requirements

6.6.1 Sludge Management Program Standards And Requirements Based Upon Federally Promulgated Regulations

In the event that new federal sludge standards or regulations are promulgated, the permittee shall comply with the new sludge requirements by the dates established in the regulations, if required by federal law, even if the permit has not yet been modified to incorporate the new federal regulations.

6.6.2 General Sludge Management Information

The General Sludge Management Form 3400-48 shall be completed and submitted prior to any significant sludge management changes.

6.6.3 Sludge Samples

All sludge samples shall be collected at a point and in a manner which will yield sample results which are representative of the sludge being tested, and collected at the time which is appropriate for the specific test.

6.6.4 Land Application Characteristic Report

Each report shall consist of a Characteristic Form 3400-49 and Lab Report. The Characteristic Report Form 3400-49 shall be submitted electronically by January 31 following each year of analysis.

Following submittal of the electronic Characteristic Report Form 3400-49, this form shall be certified electronically via the 'eReport Certify' page by a responsible executive or municipal officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The 'eReport Certify' page certifies that the electronic report is true, accurate and complete. The Lab Report must be sent directly to the facility's DNR sludge representative or basin engineer unless approval for not submitting the lab reports has been given.

The permittee shall use the following convention when reporting sludge monitoring results: Pollutant concentrations less than the limit of detection shall be reported as < (less than) the value of the limit of detection. For example, if a substance is not detected at a detection limit of 1.0 mg/kg, report the pollutant concentration as < 1.0 mg/kg .

All results shall be reported on a dry weight basis.

6.6.5 Calculation of Water Extractable Phosphorus

When sludge analysis for Water Extractable Phosphorus is required by this permit, the permittee shall use the following formula to calculate and report Water Extractable Phosphorus:

Water Extractable Phosphorus (% of Total P) =

$$[\text{Water Extractable Phosphorus (mg/kg, dry wt)} \div \text{Total Phosphorus (mg/kg, dry wt)}] \times 100$$

6.6.6 Monitoring and Calculating PCB Concentrations in Sludge

When sludge analysis for “PCB, Total Dry Wt” is required by this permit, the PCB concentration in the sludge shall be determined as follows.

Either congener-specific analysis or Aroclor analysis shall be used to determine the PCB concentration. The permittee may determine whether Aroclor or congener specific analysis is performed. Analyses shall be performed in accordance with the following provisions and Table EM in s. NR 219.04, Wis. Adm. Code.

- EPA Method 1668 may be used to test for all PCB congeners. If this method is employed, all PCB congeners shall be delineated. Non-detects shall be treated as zero. The values that are between the limit of detection and the limit of quantitation shall be used when calculating the total value of all congeners. All results shall be added together and the total PCB concentration by dry weight reported. **Note:** It is recognized that a number of the congeners will co-elute with others, so there will not be 209 results to sum.
- EPA Method 8082A shall be used for PCB-Aroclor analysis and may be used for congener specific analysis as well. If congener specific analysis is performed using Method 8082A, the list of congeners tested shall include at least congener numbers 5, 18, 31, 44, 52, 66, 87, 101, 110, 138, 141, 151, 153, 170, 180, 183, 187, and 206 plus any other additional congeners which might be reasonably expected to occur in the particular sample. For either type of analysis, the sample shall be extracted using the Soxhlet extraction (EPA Method 3540C) (or the Soxhlet Dean-Stark modification) or the pressurized fluid extraction (EPA Method 3545A). If Aroclor analysis is performed using Method 8082A, clean up steps of the extract shall be performed as necessary to remove interference and to achieve as close to a limit of detection of 0.11 mg/kg as possible. Reporting protocol, consistent with s. NR 106.07(6)(e), should be as follows: If all Aroclors are less than the LOD, then the Total PCB Dry Wt result should be reported as less than the highest LOD. If a single Aroclor is detected then that is what should be reported for the Total PCB result. If multiple Aroclors are detected, they should be summed and reported as Total PCBs. If congener specific analysis is done using Method 8082A, clean up steps of the extract shall be performed as necessary to remove interference and to achieve as close to a limit of detection of 0.003 mg/kg as possible for each congener. If the aforementioned limits of detection cannot be achieved after using the appropriate clean up techniques, a reporting limit that is achievable for the Aroclors or each congener for the sample shall be determined. This reporting limit shall be reported and qualified indicating the presence of an interference. The lab conducting the analysis shall perform as many of the following methods as necessary to remove interference:

3620C – Florisil	3611B - Alumina
3640A - Gel Permeation	3660B - Sulfur Clean Up (using copper shot instead of powder)
3630C - Silica Gel	3665A - Sulfuric Acid Clean Up

6.6.7 Annual Land Application Report

Land Application Report Form 3400-55 shall be submitted electronically by January 31, each year whether or not non-exceptional quality sludge is land applied. Non-exceptional quality sludge is defined in s. NR 204.07(4), Wis. Adm. Code. Following submittal of the electronic Annual Land Application Report Form 3400-55, this form shall be certified electronically via the ‘eReport Certify’ page by a responsible executive or municipal officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The ‘eReport Certify’ page certifies that the electronic report form is true, accurate and complete.

6.6.8 Other Methods of Disposal or Distribution Report

The permittee shall submit electronically the Other Methods of Disposal or Distribution Report Form 3400-52 by January 31, each year whether or not sludge is hauled, landfilled, incinerated, or exceptional quality sludge is distributed or land applied. Following submittal of the electronic Report Form 3400-52, this form shall be certified electronically via the ‘eReport Certify’ page by a responsible executive or municipal officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The ‘eReport Certify’ page certifies that the electronic report form is true, accurate and complete.

6.6.9 Approval to Land Apply

Bulk non-exceptional quality sludge as defined in s. NR 204.07(4), Wis. Adm. Code, may not be applied to land without a written approval letter or Form 3400-122 from the Department unless the Permittee has obtained permission from the Department to self approve sites in accordance with s. NR 204.06 (6), Wis. Adm. Code. Analysis of sludge characteristics is required prior to land application. Application on frozen or snow covered ground is restricted to the extent specified in s. NR 204.07(3) (1), Wis. Adm. Code.

6.6.10 Soil Analysis Requirements

Each site requested for approval for land application must have the soil tested prior to use. Each approved site used for land application must subsequently be soil tested such that there is at least one valid soil test in the four years prior to land application. All soil sampling and submittal of information to the testing laboratory shall be done in accordance with UW Extension Bulletin A-2100. The testing shall be done by the UW Soils Lab in Madison or Marshfield, WI or at a lab approved by UW. The test results including the crop recommendations shall be submitted to the DNR contact listed for this permit, as they are available. Application rates shall be determined based on the crop nitrogen recommendations and with consideration for other sources of nitrogen applied to the site.

6.6.11 Land Application Site Evaluation

For non-exceptional quality sludge, as defined in s. NR 204.07(4), Wis. Adm. Code, a Land Application Site Request Form 3400-053 shall be submitted to the Department for the proposed land application site. The Department will evaluate the proposed site for acceptability and will either approve or deny use of the proposed site. The permittee may obtain permission to approve their own sites in accordance with s. NR 204.06(6), Wis. Adm. Code.

6.6.12 Class B Sludge: Fecal Coliform Limitation

Compliance with the fecal coliform limitation for Class B sludge shall be demonstrated by calculating the geometric mean of at least 7 separate samples. (Note that a Total Solids analysis must be done on each sample). The geometric mean shall be less than 2,000,000 MPN or CFU/g TS. Calculation of the geometric mean can be done using one of the following 2 methods.

Method 1:

$$\text{Geometric Mean} = (X_1 \times X_2 \times X_3 \dots \times X_n)^{1/n}$$

Where X = Coliform Density value of the sludge sample, and where n = number of samples (at least 7)

Method 2:

Geometric Mean = $\text{antilog}[(X_1 + X_2 + X_3 \dots + X_n) \div n]$

Where X = \log_{10} of Coliform Density value of the sludge sample, and where n = number of samples (at least 7)

Example for Method 2

Sample Number	Coliform Density of Sludge Sample	\log_{10}
1	6.0×10^5	5.78
2	4.2×10^6	6.62
3	1.6×10^6	6.20
4	9.0×10^5	5.95
5	4.0×10^5	5.60
6	1.0×10^6	6.00
7	5.1×10^5	5.71

The geometric mean for the seven samples is determined by averaging the \log_{10} values of the coliform density and taking the antilog of that value.

$$(5.78 + 6.62 + 6.20 + 5.95 + 5.60 + 6.00 + 5.71) \div 7 = 5.98$$

The antilog of 5.98 = 9.5×10^5

6.6.13 Class B Sludge: Anaerobic Digestion

Treat the sludge in the absence of air for a specific mean cell residence time at a specific temperature. Values for the mean cell residence time and temperature shall be between 15 days at 35° C to 55° C and 60 days at 20° C. Straight-line interpolation to calculate mean cell residence time is allowable when the temperature falls between 35° C and 20° C.

6.6.14 Vector Control: Drying Without Primary Solids

Dry the sludge to 75% total solids when the sludge contains no unstabilized solids from primary treatment. This shall be met at the time the sludge is bagged, distributed, land applied or disposed of.

6.6.15 Class B Sludge - Vector Control: Injection

No significant amount of the sewage sludge shall be present on the land surface within one hour after the sludge is injected.

6.6.16 Class B Sludge - Vector Control: Incorporation

Class B sludge shall be incorporated within 6 hours of surface application, or as approved by the Department.

6.6.17 Landfilling of Sludge

General: Sewage sludge may not be disposed of in a municipal solid waste landfill unless the landfill meets the requirements of chs. NR 500 to 536, Wis. Adm. Code, and is an approved facility as defined in s. 289.01(3), Wis. Stats. Any facility accepting sewage sludge shall be approved by the Department in writing to accept sewage sludge. Disposal of sewage sludge in a municipal solid waste landfill shall be in accordance with ss. NR 506.13 and 506.14. Sewage sludge may not be disposed of in a surface disposal unit as defined in s. NR 204.03(62).

Approval: The permittee shall obtain approval from the Department prior to the disposal of sludge at a Wisconsin licensed landfill.

6.6.18 Sludge Landfilling Reports

The permittee shall report the volume of sludge disposed of at any landfill facility on Form 3400-52. The permittee shall include the name and address of the landfill, the Department license number or other state's designation or license number for all landfills used during the report period and a letter of acceptability from the landfill owner. In addition, any permittee utilizing landfills as a disposal method shall submit to the Department any test results used to indicate acceptability of the sludge at a landfill. Form 3400-52 shall be submitted annually by January 31, each year whether or not sludge is landfilled.

7 Summary of Reports Due

FOR INFORMATIONAL PURPOSES ONLY

Description	Date	Page
Effluent Limitations for E. coli -Status Update	November 21, 2020	19
Effluent Limitations for E. coli -Operational Evaluation Report	October 31, 2021	19
Effluent Limitations for E. coli -Construction Upgrade Progress Report	September 30, 2022	19
Effluent Limitations for E. coli -Complete Construction	March 31, 2023	19
Effluent Limitations for E. coli -Achieve Compliance	April 30, 2023	19
Mercury Pollutant Minimization Plan -Final Mercury Report	March 31, 2025	20
Water Quality Trading (WQT) Management Plan -Submit Progress Report on Management Practices Installation	March 31, 2022	20
Water Quality Trading (WQT) Management Plan -Complete Installation of Management Practices	June 30, 2022	20
Water Quality Trading (WQT) Management Plan -Management Practices	June 30, 2022	20
Water Quality Trading (WQT) Management Plan -Comply with Total Phosphorus Limits	July 1, 2022	20
Annual Water Quality Trading (WQT) Report -Annual WQT Report	January 31, 2023	20
Annual Water Quality Trading (WQT) Report -Annual WQT Report #2	January 31, 2024	20
Annual Water Quality Trading (WQT) Report -Annual WQT Report #3	January 31, 2025	20
Annual Water Quality Trading (WQT) Report -Annual WQT Report #4	January 31, 2026	20
Annual Water Quality Trading (WQT) Report -Annual WQT Report Required After Permit Expiration	See Permit	21
Compliance Maintenance Annual Reports (CMAR)	by June 30, each year	23
Industrial User Compliance Evaluation and Violation Reports	Semiannual	33
Pretreatment Program Report	Annually	33
General Sludge Management Form 3400-48	prior to any significant sludge management changes	34
Characteristic Form 3400-49 and Lab Report	by January 31 following each year of analysis	34
Land Application Report Form 3400-55	by January 31, each year whether or not non-exceptional quality sludge is land applied	36
Other Methods of Disposal or Distribution Report Form 3400-52	by January 31, each year whether or not	36

	sludge is hauled, landfilled, incinerated, or exceptional quality sludge is distributed or land applied	
Wastewater Discharge Monitoring Report	no later than the date indicated on the form	22

Report forms shall be submitted electronically in accordance with the reporting requirements herein. Any facility plans or plans and specifications for municipal, industrial, industrial pretreatment and non industrial wastewater systems shall be submitted to the Bureau of Water Quality, P.O. Box 7921, Madison, WI 53707-7921. All other submittals required by this permit shall be submitted to:
 South Central Region, 3911 Fish Hatchery Road, Fitchburg, WI 53711-5397