

STATE OF WISCONSIN DEPARTMENT OF NATURAL RESOURCES

PUBLIC NOTICE OF INTENT TO REISSUE A WISCONSIN POLLUTANT DISCHARGE ELIMINATION SYSTEM (WPDES) PERMIT No.WI-0029726-09-0

Permittee: ELCHO SANITARY DISTRICT #1, P O Box 86, Elcho, WI, 54428-0086

Facility Where Discharge Occurs: Elcho Sanitary District #1, N11394 Lagoon Road, Elcho, Wisconsin

Receiving Water And Location: The Groundwater within the Lily River Watershed in the Upper Wolf River Basin, Langlade County.

Brief Facility Description: The Elcho Sanitary District #1 wastewater treatment system consists of two aerated lagoons divided into cells, one settling lagoon, and three seepage cells. There are four monitoring wells located around the seepage cells to assess any groundwater impacts from the discharge.

Permit Drafter's Name, Address, Phone and Email: Sheri A. Snowbank, DNR, 810 W Maple St, Spooner, WI, 54801, (715) 635-4131, Sheri.Snowbank@wisconsin.gov

Basin Engineer's Name, Address, Phone and Email: Brooke Klingbeil, 225051RibMtnDr, Wausau, WI 54401, (715) 495-1336, brooke.klingbeil@wisconsin.gov

The Department has tentatively decided that the above-specified WPDES permit should be reissued. Limitations and conditions which the Department believes adequately protect the receiving water are included in the proposed permit.

Persons wishing to comment on or object to the proposed permit action, or to request a public hearing, may write to the Department of Natural Resources at the above-named permit drafter's address. All comments or suggestions received no later than 30 days after the publication date of this public notice will be considered along with other information on file in making a final decision regarding the permit. Anyone providing comments in response to this public notice will receive a notification of the Department's final decision when the permit is issued. Where designated as a reviewable surface water discharge permit, the U.S. Environmental Protection Agency is allowed up to 90 days to submit comments or objections regarding this permit determination. If no comments are received on the proposed permit from anyone, including U.S. EPA, the permit will be issued as proposed.

The Department may schedule a public informational hearing if requested by any person and shall schedule a public informational hearing if a petition requesting a hearing is received from 5 or more persons or if response to this notice indicates significant public interest pursuant to s. 283.49, Wis. Stats. Requests for a public informational hearing shall state the following: the name and address of the person(s) requesting the hearing; the interest in the proposed permit of the person(s) requesting the hearing; the reasons for the request; and the issues proposed to be considered at the hearing.

Information on file for this permit action, including the draft permit, fact sheet and permit application, may be inspected and copied at either the above-named permit drafter's office or the above named basin engineer's office, Monday through Friday (except holidays), between 9:00 a.m. and 3:30 p.m. Please call the permit drafter or basin engineer for directions to their office location, if necessary. Information on this permit action may also be obtained by calling the permit drafter at (715) 635-4131 or by writing to the Department. Reasonable costs (15 cents per page for copies and 7 cents per page for scanning) will be charged for information in the file other than the public notice, permit and fact sheet. Permit information is also available on the internet at:

<http://dnr.wi.gov/topic/wastewater/PublicNotices.html>. Pursuant to the Americans with Disabilities Act, reasonable accommodation, including the provision of informational material in an alternative format, will be made to qualified individuals upon request.

NAME OF PUBLISHING NEWSPAPER and ADDRESS OF PUBLISHING NEWSPAPER: Antigo Daily Journal, 612 Superior Street, Antigo, WI 54409-2086

Date Notice Issued: April 22, 2026