



WPDES PERMIT

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
**PERMIT TO DISCHARGE UNDER THE WISCONSIN POLLUTANT DISCHARGE
ELIMINATION SYSTEM**

ELCHO SANITARY DISTRICT #1

is permitted, under the authority of Chapter 283, Wisconsin Statutes, to discharge from a facility
located at

N11394 LAGOON ROAD, ELCHO, WISCONSIN

to

**THE GROUNDWATER WITHIN THE LILY RIVER WATERSHED IN THE UPPER WOLF RIVER BASIN
IN LANGLADE COUNTY**

in accordance with the effluent limitations, monitoring requirements and other conditions set
forth in this permit.

The permittee shall not discharge after the date of expiration. If the permittee wishes to continue to discharge after this expiration date an application shall be filed for reissuance of this permit, according to Chapter NR 200, Wis. Adm. Code, at least 180 days prior to the expiration date given below.

State of Wisconsin Department of Natural Resources
For the Secretary

By _____
Michelle BalkLudwig
Wastewater Field Supervisor

Date Permit Signed/Issued

PERMIT TERM: EFFECTIVE DATE - July 01, 2026

EXPIRATION DATE - June 30, 2031

TABLE OF CONTENTS

1 INFLUENT REQUIREMENTS	1
1.1 SAMPLING POINT(S)	1
1.2 MONITORING REQUIREMENTS	1
1.2.1 <i>Sampling Point 701 - INFLUENT FROM THE COMMUNITY</i>	1
1.2.2 <i>Sampling Point 702 - SEPTAGE RECEIVING TANK</i>	1
2 LAND TREATMENT REQUIREMENTS	3
2.1 SAMPLING POINT(S)	3
2.2 MONITORING REQUIREMENTS AND LIMITATIONS	3
2.2.1 <i>Sampling Point (Outfall) 003 - PRIOR TO SEEPAGE CELLS, Absorption Pond (Seepage Cell)</i>	3
3 GROUNDWATER REQUIREMENTS	5
3.1 MONITORING REQUIREMENTS AND LIMITATIONS	5
3.1.1 <i>Groundwater Monitoring System for Groundwater Monitoring System</i>	5
4 LAND APPLICATION REQUIREMENTS	6
4.1 SAMPLING POINT(S)	6
4.2 MONITORING REQUIREMENTS AND LIMITATIONS	6
4.2.1 <i>Sampling Point (Outfall) 004 - LAGOON SLUDGE</i>	6
4.2.2 <i>Sampling Point (Outfall) 005 - SEEPAGE CELL MEDIA</i>	13
5 SCHEDULES	16
5.1 INFILTRATION RATE STUDY	16
5.2 FACILITY PLAN	16
5.3 LAND TREATMENT MANAGEMENT PLAN	17
5.4 GROUNDWATER MONITORING WELL SITE MAP SUBMITTAL	17
5.5 SLUDGE MANAGEMENT PLAN	17
6 STANDARD REQUIREMENTS	18
6.1 REPORTING AND MONITORING REQUIREMENTS	18
6.1.1 <i>Monitoring Results</i>	18
6.1.2 <i>Sampling and Testing Procedures</i>	18
6.1.3 <i>Recording of Results</i>	18
6.1.4 <i>Reporting of Monitoring Results</i>	19
6.1.5 <i>Compliance Maintenance Annual Reports</i>	19
6.1.6 <i>Records Retention</i>	19
6.1.7 <i>Other Information</i>	19
6.1.8 <i>Reporting Requirements – Alterations or Additions</i>	20
6.2 SYSTEM OPERATING REQUIREMENTS	20
6.2.1 <i>Noncompliance Reporting</i>	20
6.2.2 <i>Flow Meters</i>	20
6.2.3 <i>Raw Grit and Screenings</i>	20
6.2.4 <i>Sludge Management</i>	21
6.2.5 <i>Prohibited Wastes</i>	21
6.2.6 <i>Bypass</i>	21
6.2.7 <i>Scheduled Bypass</i>	21
6.2.8 <i>Controlled Diversions</i>	22
6.2.9 <i>Proper Operation and Maintenance</i>	22
6.2.10 <i>Operator Certification</i>	22
6.3 SEWAGE COLLECTION SYSTEMS	22
6.3.1 <i>Sanitary Sewage Overflows and Sewage Treatment Facility Overflows</i>	22
6.3.2 <i>Capacity, Management, Operation and Maintenance (CMOM) Program</i>	24
6.3.3 <i>Sewer Cleaning Debris and Materials</i>	24

6.4 LAND TREATMENT (LAND DISPOSAL) REQUIREMENTS	24
6.4.1 <i>Application of NR 140 to Substances Discharged</i>	25
6.4.2 <i>Appropriate Formulas for Land Treatment Calculations – Nitrogen & Chloride</i>	25
6.4.3 <i>Toxic or Hazardous Pollutants</i>	25
6.4.4 <i>Industrial Waste - Pretreatment Requirements</i>	25
6.4.5 <i>Overflow</i>	25
6.4.6 <i>Management Plan Requirements</i>	25
6.5 GROUNDWATER STANDARD REQUIREMENTS	26
6.5.1 <i>Application of NR 140 to Substances Discharged</i>	26
6.5.2 <i>Groundwater Sampling</i>	26
6.5.3 <i>Indicator Parameter Preventive Action Limits and Alternative Concentration Limits</i>	26
6.5.4 <i>Groundwater Monitoring Forms</i>	26
6.5.5 <i>Notification of Attaining or Exceeding Groundwater Quality Standards</i>	26
6.5.6 <i>Preventive Action Limit (PAL) Exceedance</i>	26
6.5.7 <i>Enforcement Standard (ES) Exceedance Within the Design Management Zone</i>	26
6.5.8 <i>Enforcement Standard Exceedance Outside the Design Management Zone</i>	27
6.5.9 <i>New Monitoring Wells Installed During the Current Permit-Term</i>	27
6.6 LAND APPLICATION REQUIREMENTS	27
6.6.1 <i>Sludge Management Program Standards And Requirements Based Upon Federally Promulgated Regulations</i>	27
6.6.2 <i>General Sludge Management Information</i>	27
6.6.3 <i>Sludge Samples</i>	27
6.6.4 <i>Land Application Characteristic Report</i>	27
6.6.5 <i>Calculation of Water Extractable Phosphorus</i>	28
6.6.6 <i>Monitoring and Calculating PCB Concentrations in Sludge</i>	28
6.6.7 <i>Annual Land Application Report</i>	28
6.6.8 <i>Other Methods of Disposal or Distribution Report</i>	28
6.6.9 <i>Approval to Land Apply</i>	29
6.6.10 <i>Soil Analysis Requirements</i>	29
6.6.11 <i>Land Application Site Evaluation</i>	29
7 SUMMARY OF REPORTS DUE	30

1 Influent Requirements

1.1 Sampling Point(s)

Sampling Point Designation	
Sampling Point Number	Sampling Point Location, Waste Type/Sample Contents and Treatment Description (as applicable)
701	Representative samples shall be collected from the main lift station.
702	Representative samples shall be collected from the septage receiving tank.

1.2 Monitoring Requirements

The permittee shall comply with the following monitoring requirements.

1.2.1 Sampling Point 701 - INFLUENT FROM THE COMMUNITY

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Daily	Continuous	
BOD ₅ , Total		mg/L	Monthly	3-Hr Comp	
CBOD ₅		mg/L	Monthly	3-Hr Comp	
Suspended Solids, Total		mg/L	Monthly	3-Hr Comp	
Nitrogen, Total Kjeldahl		mg/L	Monthly	3-Hr Comp	
Nitrogen, Organic Total		mg/L	Monthly	Calculated	Organic Nitrogen = Total Kjeldahl Nitrogen - Ammonia
Nitrogen, Ammonia (NH ₃ -N) Total		mg/L	Monthly	3-Hr Comp	

1.2.2 Sampling Point 702 - SEPTAGE RECEIVING TANK

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Daily	Total Daily	
BOD ₅ , Total		mg/L	Monthly	Grab	
CBOD ₅		mg/L	Monthly	Grab	
Suspended Solids, Total		mg/L	Monthly	Grab	
Nitrogen, Total Kjeldahl		mg/L	Monthly	Grab	

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Nitrogen, Organic Total		mg/L	Monthly	Calculated	Organic Nitrogen = Total Kjeldahl Nitrogen - Ammonia
Nitrogen, Ammonia (NH ₃ -N) Total		mg/L	Monthly	Grab	

2 Land Treatment Requirements

2.1 Sampling Point(s)

Sampling Point Designation	
Sampling Point Number	Sampling Point Location, Waste Description/Sample Contents and Treatment Description (as applicable)
003	Representative samples shall be collected after lagoon #3 settling cell, prior to discharge to the seepage cells in the effluent pump station..

2.2 Monitoring Requirements and Limitations

The permittee shall comply with the following monitoring requirements and limitations.

2.2.1 Sampling Point (Outfall) 003 - PRIOR TO SEEPAGE CELLS, Absorption Pond (Seepage Cell)

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Daily	Continuous	
Suspended Solids, Total		mg/L	Monthly	Grab	
CBOD ₅	Monthly Avg	45 mg/L	Monthly	Grab	
pH Field		su	Monthly	Grab	
Nitrogen, Total Kjeldahl		mg/L	Monthly	Grab	
Nitrogen, Organic Total		mg/L	Monthly	Calculated	Organic Nitrogen = Total Kjeldahl Nitrogen - Ammonia
Nitrogen, Ammonia (NH ₃ -N) Total		mg/L	Monthly	Grab	
Nitrogen, Nitrite + Nitrate Total		mg/L	Monthly	Grab	
Nitrogen, Total		mg/L	Monthly	Calculated	Total Nitrogen = Total Kjeldahl Nitrogen + (Nitrite + Nitrate)
Chloride		mg/L	Monthly	Grab	

Daily Log – Monitoring Requirements and Limitations

All discharge and monitoring activity shall be documented on log sheets. Originals of the log sheets shall be kept by the permittee as described under “Records Retention” in the Standard Requirements section, and if requested, made available to the Department.

Parameters	Limit	Units	Sample Frequency	Sample Type
Cell(s) Being Loaded	-	Cell Number	Daily	Log
Volume per Cell		Gallons	Daily	Log
Start to End Time	-	Date, Hour	Daily	Log

2.2.1.1 Average Annual Design Flow

The average annual design flow of the permittee’s wastewater treatment facility is 0.125 MGD.

2.2.1.2 Chloride and Total Nitrogen

Effluent limitations are not included for chloride and total nitrogen, in accordance with s. NR 206.06(2), Wis. Adm. Code, based on compliance with ch. NR 140 groundwater quality enforcement standards.

3 Groundwater Requirements

3.1 Monitoring Requirements and Limitations

3.1.1 Groundwater Monitoring System for Groundwater Monitoring System

Location of Monitoring System: Adjacent to Seepage Cells

Groundwater Monitoring Well(s) to be Sampled: 802 (MW-6), 803 (MW-7), 804 (MW-8), 805 (MW-9)

Groundwater Monitoring Well(s) Used to Evaluate Background Groundwater Quality: 804 (MW-8)

Preventive Action Limits (PAL) and Enforcement Standards (ES) listed in the table below are from ss. NR 140.10 and NR.140.12, Wis. Adm. Code. PALs for s. NR 140.20 Wis. Adm. Code Indicator Parameters and s. NR 140.28 Wis. Adm. Code Exemptions with Alternative Concentration Limits listed in the table below have been calculated based on background groundwater quality data from this/these designated well(s). Groundwater contaminant concentrations shall be minimized and PALs met in groundwater monitoring wells to the extent it is technically and economically feasible.

Groundwater Monitoring Well(s) Used for Point of Standards Application: 805 (MW-9)

“Point of standards application” refers to any point of present groundwater use (i.e., potable well) or a specific groundwater monitoring well that is located beyond the design management zone or the property boundary, whichever is closer to the land treatment/disposal system at which the concentration of a substance in groundwater is measured for purposes of determining whether a PAL or an ES has been attained or exceeded. See the Standard Requirements section of this permit for additional conditions related to exceedance of groundwater standards.

Required Monitoring: Grab samples shall be collected from each monitoring well and analyzed for the parameters per the frequency shown in the table below.

PARAMETER	UNITS	PREVENTIVE ACTION LIMIT	ENFORCEMENT STANDARD	FREQUENCY
Depth To Groundwater	feet	N/A	N/A	1/ 6 Months
Groundwater Elevation	feet MSL	N/A	N/A	1/ 6 Months
Nitrogen, Nitrite + Nitrate (as N) Dissolved	mg/L	2.0	10	1/ 6 Months
Chloride Dissolved	mg/L	125	250	1/ 6 Months
pH Field	su	7.0	N/A	1/ 6 Months
Nitrogen, Ammonia Dissolved	mg/L	0.97	9.7	1/ 6 Months
Nitrogen, Organic Dissolved	mg/L	2.1	N/A	1/ 6 Months
Solids, Total Dissolved	mg/L	320	N/A	1/ 6 Months

3.1.1.1 Preventive Action Limits for pH

A result for pH is considered to have exceeded the pH PAL for this site if the result is less than **5.0 s.u.** or greater than **7.0 s.u.**

3.1.1.2 Preventive Action Limits for Indicator Parameters

PALs for Indicator Parameters have been established for this site. For more information see “Indicator Parameter Preventive Action Limits and Alternative Concentration Limits” in the Standard Requirements section.

4 Land Application Requirements

4.1 Sampling Point(s)

The discharge(s) shall be limited to land application of the waste type(s) designated for the listed sampling point(s) on Department approved land spreading sites or by hauling to another facility.

Sampling Point Designation	
Sampling Point Number	Sampling Point Location, Waste Type/Sample Contents and Treatment Description (as applicable)
004	Representative samples shall be collected from the accumulated sludge in the lagoons at various locations and depths that are composited for analysis.
005	Multiple representative samples shall be collected from the media when it is removed from the seepage cells and composited for analysis.

4.2 Monitoring Requirements and Limitations

The permittee shall comply with the following monitoring requirements and limitations.

4.2.1 Sampling Point (Outfall) 004 - LAGOON SLUDGE

Sludge Management: The permittee shall contact the Department prior to recycling/disposing of any sludge. The permittee shall monitor for the following parameters during the second year of the permit, (2027). Analysis shall be submitted by **January 31, 2028**.

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Solids, Total		Percent	Once	Composite	
Arsenic Dry Wt	Ceiling	75 mg/kg	Once	Composite	
Arsenic Dry Wt	High Quality	41 mg/kg	Once	Composite	
Cadmium Dry Wt	Ceiling	85 mg/kg	Once	Composite	
Cadmium Dry Wt	High Quality	39 mg/kg	Once	Composite	
Copper Dry Wt	Ceiling	4,300 mg/kg	Once	Composite	
Copper Dry Wt	High Quality	1,500 mg/kg	Once	Composite	
Lead Dry Wt	Ceiling	840 mg/kg	Once	Composite	
Lead Dry Wt	High Quality	300 mg/kg	Once	Composite	
Mercury Dry Wt	Ceiling	57 mg/kg	Once	Composite	
Mercury Dry Wt	High Quality	17 mg/kg	Once	Composite	
Molybdenum Dry Wt	Ceiling	75 mg/kg	Once	Composite	

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Nickel Dry Wt	Ceiling	420 mg/kg	Once	Composite	
Nickel Dry Wt	High Quality	420 mg/kg	Once	Composite	
Selenium Dry Wt	Ceiling	100 mg/kg	Once	Composite	
Selenium Dry Wt	High Quality	100 mg/kg	Once	Composite	
Zinc Dry Wt	Ceiling	7,500 mg/kg	Once	Composite	
Zinc Dry Wt	High Quality	2,800 mg/kg	Once	Composite	
Nitrogen, Total Kjeldahl		Percent	Per Application	Composite	
Nitrogen, Ammonium (NH ₄ -N) Total		Percent	Per Application	Composite	
Phosphorus, Total		Percent	Per Application	Composite	
Phosphorus, Water Extractable		% of Tot P	Per Application	Composite	
Potassium, Total Recoverable		Percent	Per Application	Composite	
PCB Total Dry Wt	Ceiling	50 mg/kg	Once	Composite	See the Sludge Analysis for PCBs permit section.
PCB Total Dry Wt	High Quality	10 mg/kg	Once	Composite	See the Sludge Analysis for PCBs permit section.
PFOA + PFOS		µg/kg	Once	Calculated	Report the sum of PFOA and PFOS. See PFAS permit sections for more information.
PFAS Dry Wt			Once	Grab	Perfluoroalkyl and Polyfluoroalkyl Substances based on updated DNR PFAS List. See PFAS Permit Sections for more information.

Other Sludge Requirements	
Sludge Requirements	Sample Frequency
List 3 Requirements – Pathogen Control: The requirements in List 3 shall be met prior to land application of sludge.	Required only when sludge is land applied
List 4 Requirements – Vector Attraction Reduction: The vector attraction reduction shall be satisfied prior to, or at the time of land application as specified in List 4.	Required only when sludge is land applied

4.2.1.1 Requirements for Potential and/or Unscheduled Land Application of Sludge

Monitoring for List 1, PCBs, and PFAS shall occur in year two of permit term (2027) unless a sludge removal date has been established which would occur within the permit term, but in a different year. Monitoring for List 2 is highly recommended during the same sampling event to determine acreage needs for land application of sludge should it be necessary at a future date.

If a sludge removal date has been established other than in year two (2027), monitoring for Lists 1, 2, 3 & 4, PCBs and PFAS shall occur in the year of, but prior to, land application of the removed sludge. Monitoring must be done, and compliance assured, prior to land application, in addition to all other requirements specified herein and in ch. NR 204, Wis. Adm. Code. The permittee shall notify the Department prior to such land application. If sludge removal and land application are necessary after the monitoring for List 1, PCBs and PFAS in year two of the permit, monitoring for Lists 2, 3 & 4 shall be done in the year of and prior to land application.

4.2.1.2 Changes in Feed Sludge Characteristics

If a change in feed sludge characteristics, treatment process, or operational procedures occurs which may result in a significant shift in sludge characteristics, the permittee shall reanalyze the sludge for List 1, 2, 3 and 4 parameters each time such change occurs.

4.2.1.3 Sludge Which Exceeds the High Quality Limit

Cumulative pollutant loading records shall be kept for all bulk land application of sludge which does not meet the high quality limit for any parameter. This requirement applies for the entire calendar year in which any exceedance of Table 3 of s. NR 204.07(5)(c), Wis. Adm. Code, is experienced. Such loading records shall be kept for all List 1 parameters for each site land applied in that calendar year. The formula to be used for calculating cumulative loading is as follows:

$$[(\text{Pollutant concentration (mg/kg)} \times \text{dry tons applied/ac}) \div 500] + \text{previous loading (lbs/acre)} = \text{cumulative lbs pollutant per acre}$$

When a site reaches 90% of the allowable cumulative loading for any metal established in Table 2 of s. NR 204.07(5)(b), Wis. Adm. Code, the Department shall be so notified through letter or in the comment section of the annual land application report (3400-55).

4.2.1.4 Sludge Analysis for PCBs

The permittee shall analyze the sludge for Total PCBs one time during 2027. The results shall be reported as "PCB Total Dry Wt". Either congener-specific analysis or Aroclor analysis shall be used to determine the PCB concentration. The permittee may determine whether Aroclor or congener specific analysis is performed. Analyses shall be performed in accordance with Table EM in s. NR 219.04, Wis. Adm. Code and the conditions specified in Standard Requirements of this permit. PCB results shall be submitted by January 31, following the specified year of analysis.

4.2.1.5 Lists 1, 2, 3, and 4

List 1	
TOTAL SOLIDS AND METALS	
See the Monitoring Requirements and Limitations table above for monitoring frequency and limitations for the List 1 parameters	
Solids, Total (percent)	
Arsenic, mg/kg (dry weight)	
Cadmium, mg/kg (dry weight)	
Copper, mg/kg (dry weight)	
Lead, mg/kg (dry weight)	
Mercury, mg/kg (dry weight)	
Molybdenum, mg/kg (dry weight)	
Nickel, mg/kg (dry weight)	
Selenium, mg/kg (dry weight)	
Zinc, mg/kg (dry weight)	

List 2	
NUTRIENTS	
See the Monitoring Requirements and Limitations table above for monitoring frequency for the List 2 parameters	
Solids, Total (percent)	
Nitrogen Total Kjeldahl (percent)	
Nitrogen Ammonium (NH ₄ -N) Total (percent)	
Phosphorus Total as P (percent)	
Phosphorus, Water Extractable (as percent of Total P)	
Potassium Total Recoverable (percent)	

List 3		
PATHOGEN CONTROL FOR CLASS B SLUDGE		
The permittee shall implement pathogen control as listed in List 3. The Department shall be notified of the pathogen control utilized and shall be notified when the permittee decides to utilize alternative pathogen control.		
The following requirements shall be met prior to land application of sludge.		
Parameter	Unit	Limit
Fecal Coliform*	MPN/gTS or CFU/gTS	2,000,000
OR, ONE OF THE FOLLOWING PROCESS OPTIONS		
Aerobic Digestion	Air Drying	
Anaerobic Digestion	Composting	
Alkaline Stabilization	PSRP Equivalent Process	
* The Fecal Coliform limit shall be reported as the geometric mean of 7 discrete samples on a dry weight basis.		

**List 4
VECTOR ATTRACTION REDUCTION**

The permittee shall implement any one of the vector attraction reduction options specified in List 4. The Department shall be notified of the option utilized and shall be notified when the permittee decides to utilize an alternative option.

One of the following shall be satisfied prior to, or at the time of land application as specified in List 4.

Option	Limit	Where/When it Shall be Met
Volatile Solids Reduction	≥38%	Across the process
Specific Oxygen Uptake Rate	≤1.5 mg O ₂ /hr/g TS	On aerobic stabilized sludge
Anaerobic bench-scale test	<17 % VS reduction	On anaerobic digested sludge
Aerobic bench-scale test	<15 % VS reduction	On aerobic digested sludge
Aerobic Process	>14 days, Temp >40°C and Avg. Temp > 45°C	On composted sludge
pH adjustment	>12 S.U. (for 2 hours) and >11.5 (for an additional 22 hours)	During the process
Drying without primary solids	>75 % TS	When applied or bagged
Drying with primary solids	>90 % TS	When applied or bagged
Equivalent Process	Approved by the Department	Varies with process
Injection	-	When applied
Incorporation	-	Within 6 hours of application

4.2.1.6 Daily Land Application Log

Daily Land Application Log		
Discharge Monitoring Requirements and Limitations		
<p>The permittee shall maintain a daily land application log for biosolids land applied each day when land application occurs. The following minimum records must be kept, in addition to all analytical results for the biosolids land applied. The log book records shall form the basis for the annual land application report requirements.</p>		
Parameters	Units	Sample Frequency
DNR Site Number(s)	Number	Daily as used
Outfall number applied	Number	Daily as used
Acres applied	Acres	Daily as used
Amount applied	As appropriate * /day	Daily as used
Application rate per acre	unit */acre	Daily as used
Nitrogen applied per acre	lb/acre	Daily as used
Method of Application	Injection, Incorporation, or surface applied	Daily as used

*gallons, cubic yards, dry US Tons or dry Metric Tons

4.2.1.7 Sludge Monitoring for PFAS

Sampling shall occur for perfluoroalkyl and polyfluoroalkyl compounds (PFAS) listed in the table below and as indicated in sampling point sections above. Monitoring shall occur at each sample point when sludge is generated regardless of the end use (i.e. land applied, hauled to another facility, landfilled).

PERFLUOROALKYLCARBOXYLIC Acids (PFCAs)	
PFBA	Perfluorobutanoic acid
PFPeA	Perfluroropentanoic acid
PFHxA	Perfluorohexanoic acid
PFHpA	Perfluoroheptanoic acid
PFOA	Perfluorooctanoic acid
PFNA	Perfluorononanoic acid
PFDA	Perfluorodecanoic acid
PFUnA	Perfluroundecanoic acid
PFDoA	Perfluorododecanoic acid
PFTrDA	Perfluorotridecanoic acid
PFTeDA	Perfluorotetradecanoic acid
PERFLUOROALKYLSULFONIC Acids (PFSAs)	
PFBS	Perfluorobutane sulfonic acid
PFPeS	Perfluroropentane sulfonic acid
PFHxS	Perfluorohexane sulfonic acid
PFHpS	Perfluoroheptane sulfonic acid
PFOS	Perfluorooctane sulfonic acid
PFNS	Perfluorononane sulfonic acid
PFDS	Perfluorodecane sulfonic acid
PFDoS	Perfluorododecane sulfonic acid
TELOMER SULFONIC Acids	
4:2FTSA	<i>1H,1H,2H,2H</i> -Perfluorohexane sulfonic acid
6:2FTSA	<i>1H,1H,2H,2H</i> -Perfluorooctane sulfonic acid
8:2FTSA	<i>1H,1H,2H,2H</i> -Perfluorodecane sulfonic acid
PERFLUOROOCETANCESULFONAMIDES (FOSAs)	
PFOSA	Perflurorooctane sulfonamide
NMeFOSA	N-Methyl perfluorooctane sulfonamide
NEtFOSA	N-Ethyl perfluorooctane sulfonamide
PERFLUOROOCETANCESULFONAMIDOACETIC Acids	
NMeFOSAA	N-Methyl perfluorooctane sulfonamidoacetic acid
NEtFOSAA	N-Ethyl perfluorooctane sulfonamidoacetic acid
NATIVE PERFLUOROOCETANCESULFONAMIDOETHANOLS (FOSEs)	
NMeFOSE	N-Methyl perfluorooctane sulfonamidoethanol
NEtFOSE	N-Ethyl perfluorooctane sulfonamidoethanol
PERFLUOROALKYLETHERCARBOXYLIC Acids (PFECAs)	
HFPO-DA	Hexafluoropropylene oxide dimer acid

ADONA	4,8-dioxa-3 <i>H</i> -perfluorononanoic acid
PFMPA	Perfluoro-3-methoxypropanoic acid
PFMBA	Perfluoro-4-methoxybutanoic acid
NFDHA	Nonafluoro-3,6-dioxaheptaonic acid
CHLORO-PERFLUOROALKYLSULFONATE	
9Cl-PF3ONS	9-chlorohexadecafluoro-3-oxanone-1-sulfonic acid
11Cl-PF3OUdS	11-chloroelcosafluoro-3-oxaundecane-1-sulfonic acid
PFEESA	Perfluro(2-ethoxyethane)sulfonic acid
TELOMER SULFONIC Acids	
3:3FTCA	3-Perfluoropropyl propanoic acid
5:3FTCA	<i>2H,2H,3H,3H</i> -Perfluorooctanoic acid
7:3FTCA	3-Perfluoroheptyl propanoic acid

Note: If WDNR Lab Certification removes a particular compound from the reporting list above and upon receiving written communication from the department, reporting for that compound is no longer required.

4.2.1.8 Sampling and Reporting Sludge Samples for PFAS

Representative sludge samples shall be collected at each sample point as listed. At minimum, liquid sludge storage/digesters should be thoroughly mixed prior to sampling. Cake sludge samples should consist of seven equal size discrete samples and be collected from different areas and depths then composited into one sample for laboratory analysis.

Note: If additional equipment is used for collecting sludge samples (i.e., shovels, compositing buckets, bottles, etc.), then a one-time equipment blank is recommended to be collected with the first sample. An equipment blank sample is collected by passing laboratory verified PFAS-free water over or through field sampling equipment before the collection of a representative sludge sample. The equipment blank result shall be reported on the annual Sludge Characteristics Form (3400-049) in the comment section when reporting PFAS concentrations in the sludge.

The permittee shall report each of the PFAS sludge monitoring results on the annual Sludge Characteristics and Monitoring Form (3400-049) as provided by the department. The permittee shall also report the summation of PFOS and PFOA on this same form. All results shall be reported in dry weight. The annual Sludge Characteristics and Monitoring Form (3400-049) are due January 31, of the year following the collection of the sludge samples.

The laboratory performing the analysis on any samples shall be certified for the applicable PFAS compounds in the solids matrix by the Wisconsin Laboratory Certification Program established under s. 299.11, Wis. Stats., and in accordance with s. NR 149.41, Wis. Adm. Code. The department may reject any sample results if results are produced by a laboratory that is not in compliance with certification requirements under ch. NR 149, Wis. Adm. Code.

4.2.1.9 PFAS Land Application Requirements

The department recommends the landspreading and/or land application of sludge be done in a manner consistent with the most recent version of the [“Interim Strategy for Land Application of Biosolids and Industrial Sludges containing PFAS”](#).

4.2.2 Sampling Point (Outfall) 005 - SEEPAGE CELL MEDIA

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Solids, Total		Percent	Annual	Composite	
Arsenic Dry Wt	Ceiling	75 mg/kg	Annual	Composite	
Arsenic Dry Wt	High Quality	41 mg/kg	Annual	Composite	
Cadmium Dry Wt	Ceiling	85 mg/kg	Annual	Composite	
Cadmium Dry Wt	High Quality	39 mg/kg	Annual	Composite	
Copper Dry Wt	Ceiling	4,300 mg/kg	Annual	Composite	
Copper Dry Wt	High Quality	1,500 mg/kg	Annual	Composite	
Lead Dry Wt	Ceiling	840 mg/kg	Annual	Composite	
Lead Dry Wt	High Quality	300 mg/kg	Annual	Composite	
Mercury Dry Wt	Ceiling	57 mg/kg	Annual	Composite	
Mercury Dry Wt	High Quality	17 mg/kg	Annual	Composite	
Molybdenum Dry Wt	Ceiling	75 mg/kg	Annual	Composite	
Nickel Dry Wt	Ceiling	420 mg/kg	Annual	Composite	
Nickel Dry Wt	High Quality	420 mg/kg	Annual	Composite	
Selenium Dry Wt	Ceiling	100 mg/kg	Annual	Composite	
Selenium Dry Wt	High Quality	100 mg/kg	Annual	Composite	
Zinc Dry Wt	Ceiling	7,500 mg/kg	Annual	Composite	
Zinc Dry Wt	High Quality	2,800 mg/kg	Annual	Composite	
Nitrogen, Total Kjeldahl		Percent	Annual	Composite	
Nitrogen, Ammonium (NH ₄ -N) Total		Percent	Annual	Composite	
Phosphorus, Total		Percent	Annual	Composite	
Phosphorus, Water Extractable		% of Tot P	Annual	Composite	
Potassium, Total Recoverable		Percent	Annual	Composite	
PCB Total Dry Wt	Ceiling	50 mg/kg	Once	Composite	
PCB Total Dry Wt	High Quality	10 mg/kg	Once	Composite	

4.2.2.1 Requirements for Potential Land Application of Seepage Cell Media

Monitoring for Lists 1, 2, 3 & 4 and PCBs shall occur prior to land application of the removed seepage cell media. Monitoring must be done, and compliance assured, prior to land application, in addition to all other requirements specified herein and in ch. NR 204, Wis. Adm. Code. The permittee shall notify the Department prior to such land application.

4.2.2.2 Sludge Which Exceeds the High Quality Limit

Cumulative pollutant loading records shall be kept for all bulk land application of sludge which does not meet the high quality limit for any parameter. This requirement applies for the entire calendar year in which any exceedance of Table 3 of s. NR 204.07(5)(c), Wis. Adm. Code, is experienced. Such loading records shall be kept for all List 1 parameters for each site land applied in that calendar year. The formula to be used for calculating cumulative loading is as follows:

$$[(\text{Pollutant concentration (mg/kg)} \times \text{dry tons applied/ac}) \div 500] + \text{previous loading (lbs/acre)} = \text{cumulative lbs pollutant per acre}$$

When a site reaches 90% of the allowable cumulative loading for any metal established in Table 2 of s. NR 204.07(5)(b), Wis. Adm. Code, the Department shall be so notified through letter or in the comment section of the annual land application report (3400-55).

4.2.2.3 Sludge Analysis for PCBs

The permittee shall analyze the sludge for Total PCBs prior to disposal of the media. The results shall be reported as "PCB Total Dry Wt". Either congener-specific analysis or Aroclor analysis shall be used to determine the PCB concentration. The permittee may determine whether Aroclor or congener specific analysis is performed. Analyses shall be performed in accordance with Table EM in s. NR 219.04, Wis. Adm. Code and the conditions specified in Standard Requirements of this permit. PCB results shall be submitted by January 31, following the specified year of analysis.

4.2.2.4 Daily Land Application Log

Daily Land Application Log		
Discharge Monitoring Requirements and Limitations		
The permittee shall maintain a daily land application log for biosolids land applied each day when land application occurs. The following minimum records must be kept, in addition to all analytical results for the biosolids land applied. The log book records shall form the basis for the annual land application report requirements.		
Parameters	Units	Sample Frequency
DNR Site Number(s)	Number	Daily as used
Outfall number applied	Number	Daily as used
Acres applied	Acres	Daily as used
Amount applied	As appropriate * /day	Daily as used
Application rate per acre	unit */acre	Daily as used
Nitrogen applied per acre	lb/acre	Daily as used

Daily Land Application Log		
Discharge Monitoring Requirements and Limitations		
<p>The permittee shall maintain a daily land application log for biosolids land applied each day when land application occurs. The following minimum records must be kept, in addition to all analytical results for the biosolids land applied. The log book records shall form the basis for the annual land application report requirements.</p>		
Parameters	Units	Sample Frequency
Method of Application	Injection, Incorporation, or surface applied	Daily as used

*gallons, cubic yards, dry US Tons or dry Metric Tons

5 Schedules

5.1 Infiltration Rate Study

Required Action	Due Date
Final Report: Submit a final report summarizing results and recommendations from the infiltration rate study that was performed in the spring of 2026.	09/30/2026

5.2 Facility Plan

The facility plan shall address the seepage cells and influent sample points 701 and 702.

Required Action	Due Date
Intent to Apply: Provide confirmation that a notice of Intent to Apply (ITA) with Priority Evaluation and Ranking Formula (PERF), as authorized by s. 281.58, Wis. Stats., and Ch. NR 162, Wis. Adm. Code, was submitted online to the Department's Clean Water Fund Program by October 31, 2026.	11/01/2026
Submit Facility Plan: The permittee shall submit a facility plan, pursuant to s. NR 110.09, Wis. Adm. Code, to the Department addressing seepage cell rehabilitation, if applicable. The plan shall also address influent control manhole for domestic and septage influent waste, pursuant to s. NR 110.09, Wis. Adm. Code.	03/31/2027
Final Plans and Specifications: The permittee shall submit final construction plans to the Department for approval pursuant to s. 281.41, Stats., specifying treatment plant upgrades and a schedule for completing construction of the upgrades by the complete construction date specified below.	09/30/2027
Desludging Management Plan: Submit a management plan to optimize the seepage cell media removal during this permit term. At a minimum, the plan shall address how the media will be sampled, removed, transported, and disposed of. No removal may occur without plan approval. This plan is due ninety days prior to removal.	
Land Spreading Management Plan: Submit a management plan to optimize landspreading system performance and demonstrate compliance with Ch. NR 204, Wis. Adm. Code. At minimum, the plan shall describe how the application rate has been calculated as well as how the sludge will be land applied and incorporated. This plan is due ninety days prior to land spreading.	
Financial Assistance Application: Provide confirmation that a Financial Assistance Application and Principal Forgiveness (PF) request, as authorized by s. 281.58, Wis. Stats., and Ch. NR 162, Wis. Adm. Code, was submitted online to the Department's Clean Water Fund Program by September 30, 2027.	10/01/2027
Treatment Plant Upgrade to Meet WQBELs: Provide confirmation that the permittee has awarded construction contracts and initiated construction of the upgrades. The permittee shall obtain approval of the final construction plans and schedule from the Department pursuant to s. 281.41, Wis. Stats. Upon approval of the final construction plans and schedule by the Department pursuant to s. 281.41, Wis. Stats., the permittee shall construct the treatment plant upgrades in accordance with the approved plans and specifications.	03/31/2028
Complete Construction: The permittee shall complete construction of wastewater treatment system upgrades and shall inform the Department of the substantial completion.	09/30/2028

5.3 Land Treatment Management Plan

A management plan is required for the land treatment system.

Required Action	Due Date
Land Treatment Management Plan Submittal: Submit an update to the management plan to optimize the land treatment system performance and demonstrate compliance with ch. NR 206, Wis. Adm. Code. The land treatment system shall be operated in accordance with the approved management plan.	09/30/2026

5.4 Groundwater Monitoring Well Site Map Submittal

Required Action	Due Date
Monitoring Well Site Map: Submit a site map in accordance with s. NR 141.065, Wis. Adm. Code. This site map must include a scale bar and directional arrow and accurately show site structures (including septage receiving tank), property boundaries, nearby surface water and water supply wells and all site groundwater monitoring wells. The Groundwater well survey should include the elevation of the top of casing (TOC) for the wells and a calculated ground surface elevation.	09/30/2026

5.5 Sludge Management Plan

Required Action	Due Date
Final Report: Submit a final report summarizing results and recommendations from the infiltraton rate study that was performed in the spring of 2026.	09/30/2026
<p>Submit a Sludge Management Plan: The permittee shall submit an update to the management plan for approval if removal of sludge will occur during this permit term. The plan shall demonstrate compliance with ch. NR 204 Wis. Adm. Code and at minimum address 1) How and where is sludge sampled; 2) Available sludge storage details and location(s); 3)How will the sludge be removed with details on vol-ume, characterization and how will the treatment plant continue to function during the draw-down; 4) Describe the type of transportation and spreading vehicles and loading and unloading practices; 5) Identify approved land application sites, apply for needed sites, site limitations, total acres needed and vegetative cover management; 6) Specify record keeping procedures including site loading; 7) Address contingency plans for adverse weather and odor/nuisance abatement; and 8) Include any other pertinent information such as other disposal options that may be used or specifications of any pretreatment processes</p> <p>Once approved, all sludge management activities shall be conducted in accordance with the plan. Any changes to the plan must be approved by the Department prior to implementing the changes. No desludging may occur unless approval from the Department is obtained. Daily logs shall be kept that record where the sludge has been disposed.</p> <p>The plan is due at least 60 days prior to desludging.</p>	

6 Standard Requirements

Chapter NR 205, Wisconsin Administrative Code: The conditions in ss. NR 205.07(1) and NR 205.07(2), Wis. Adm. Code, are included by reference in this permit. The permittee shall comply with all of these requirements. Some of these requirements are outlined in the Standard Requirements section of this permit. Requirements not specifically outlined in the Standard Requirement section of this permit can be found in ss. NR 205.07(1) and NR 205.07(2), Wis. Adm. Code.

6.1 Reporting and Monitoring Requirements

6.1.1 Monitoring Results

Monitoring results obtained during the previous month shall be summarized and reported on a Department Wastewater Discharge Monitoring Report. The report may require reporting of any or all of the information specified below under 'Recording of Results'. This report is to be returned to the Department no later than the date indicated on the form. A copy of the Wastewater Discharge Monitoring Report Form or an electronic file of the report shall be retained by the permittee.

Monitoring results shall be reported on an electronic discharge monitoring report (eDMR). The eDMR shall be certified electronically by a responsible executive or municipal officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The 'eReport Certify' page certifies that the electronic report form is true, accurate and complete.

If the permittee monitors any pollutant more frequently than required by this permit, the results of such monitoring shall be included on the Wastewater Discharge Monitoring Report.

The permittee shall comply with all limits for each parameter regardless of monitoring frequency. For example, monthly, weekly, and/or daily limits shall be met even with monthly monitoring. The permittee may monitor more frequently than required for any parameter.

6.1.2 Sampling and Testing Procedures

Sampling and laboratory testing procedures shall be performed in accordance with Chapters NR 218 and NR 219, Wis. Adm. Code, and completed by a laboratory certified or registered in accordance with the requirements of ch. NR 149, Wis. Adm. Code. Groundwater sampling shall be performed in accordance with procedures contained in s. NR 140.16, Wis. Adm. Code, and the WDNR publications, Groundwater Sampling Desk Reference (PUBL-DG-037-96) and Groundwater Sampling Field Manual (PUBL-DG-038-96). The analytical methodologies used shall enable the laboratory to quantitate all substances for which monitoring is required at levels below the effluent limitation and/or groundwater standard. If the required level cannot be met by any of the methods available in ch. NR 219, Wis. Adm. Code, then the method with the lowest limit of detection shall be selected. Additional test procedures may be specified in this permit.

6.1.3 Recording of Results

The permittee shall maintain records which provide the following information for each effluent measurement or sample taken:

- The date, exact place, method and time of sampling or measurements;
- The individual who performed the sampling or measurements;
- The date the analysis was performed;
- The individual who performed the analysis;
- The analytical techniques or methods used; and

- The results of the analysis.

6.1.4 Reporting of Monitoring Results

The permittee shall use the following conventions when reporting effluent monitoring results:

- Pollutant concentrations less than the limit of detection shall be reported as < (less than) the value of the limit of detection. For example, if a substance is not detected at a detection limit of 0.1 mg/L, report the pollutant concentration as < 0.1 mg/L.
- Pollutant concentrations equal to or greater than the limit of detection, but less than the limit of quantitation, shall be reported and the limit of quantitation shall be specified.
- For purposes of calculating fees under ch. NR 101, Wis. Adm. Code, a reporting limit of 2.0 mg/L for BOD₅ and 2.5 mg/L Total Suspended Solids shall be considered to be limits of quantitation.
- For the purposes of reporting a calculated result, average or a mass discharge value, the permittee may substitute a “0” (zero) for any pollutant concentration that is less than the limit of detection. However, if the effluent limitation is less than the limit of detection, the department may substitute a value other than zero for results less than the limit of detection, after considering the number of monitoring results that are greater than the limit of detection and if warranted when applying appropriate statistical techniques.
- If no discharge occurs through an outfall, flow related parameters (e.g. flow rate, hydraulic application rate, volume, etc.) should be reported as “0” (zero) at the required sample frequency specified for the outfall. For example: if the sample frequency is daily, “0” would be reported for any day during the month that no discharge occurred.

6.1.5 Compliance Maintenance Annual Reports

Compliance Maintenance Annual Reports (CMAR) shall be completed using information obtained over each calendar year regarding the wastewater conveyance and treatment system. The CMAR shall be submitted and certified by the permittee in accordance with ch. NR 208, Wis. Adm. Code, by June 30, each year on an electronic report form provided by the Department.

In the case of a publicly owned treatment works, a resolution shall be passed by the governing body and submitted as part of the CMAR, verifying its review of the report and providing responses as required. Private owners of wastewater treatment works are not required to pass a resolution; but they must provide an Owner Statement and responses as required, as part of the CMAR submittal.

The CMAR shall be certified electronically by a responsible executive or municipal officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The certification verifies that the electronic report is true, accurate and complete.

6.1.6 Records Retention

The permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings or electronic data records for continuous monitoring instrumentation, copies of all reports required by the permit, and records of all data used to complete the application for the permit for a period of at least 3 years from the date of the sample, measurement, report or application. All pertinent sludge information, including permit application information and other documents specified in this permit or s. NR 204.06(9), Wis. Adm. Code shall be retained for a minimum of 5 years.

6.1.7 Other Information

Where the permittee becomes aware that it failed to submit any relevant facts in a permit application or submitted incorrect information in a permit application or in any report to the Department, it shall promptly submit such facts or correct information to the Department.

6.1.8 Reporting Requirements – Alterations or Additions

The permittee shall give notice to the Department as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is only required when:

- The alteration or addition to the permitted facility may meet one of the criteria for determining whether a facility is a new source.
- The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification requirement applies to pollutants which are not subject to effluent limitations in the existing permit.
- The alteration or addition results in a significant change in the permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use of disposal sites not reported during the permit application process nor reported pursuant to an approved land application plan. Additional sites may not be used for the land application of sludge until department approval is received.

6.2 System Operating Requirements

6.2.1 Noncompliance Reporting

Sanitary sewer overflows and sewage treatment facility overflows shall be reported according to the 'Sanitary Sewer Overflows and Sewage Treatment Facility Overflows' section of this permit.

The permittee shall report the following types of noncompliance by a telephone call to the Department's regional office within 24 hours after becoming aware of the noncompliance:

- Any noncompliance which may endanger health or the environment;
- Any violation of an effluent limitation resulting from a bypass;
- Any violation of an effluent limitation resulting from an upset; and
- Any violation of a maximum discharge limitation for any of the pollutants listed by the Department in the permit, either for effluent or sludge.

A written report describing the noncompliance shall also be submitted to the Department's regional office within 5 days after the permittee becomes aware of the noncompliance. On a case-by-case basis, the Department may waive the requirement for submittal of a written report within 5 days and instruct the permittee to submit the written report with the next regularly scheduled monitoring report. In either case, the written report shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times; the steps taken or planned to reduce, eliminate and prevent reoccurrence of the noncompliance; and if the noncompliance has not been corrected, the length of time it is expected to continue.

A scheduled bypass approved by the Department under the 'Scheduled Bypass' section of this permit shall not be subject to the reporting required under this section.

NOTE: Section 292.11(2)(a), Wisconsin Statutes, requires any person who possesses or controls a hazardous substance or who causes the discharge of a hazardous substance to notify the Department of Natural Resources **immediately** of any discharge not authorized by the permit. **The discharge of a hazardous substance that is not authorized by this permit or that violates this permit may be a hazardous substance spill. To report a hazardous substance spill, call DNR's 24-hour HOTLINE at 1-800-943-0003.**

6.2.2 Flow Meters

Flow meters shall be calibrated annually, as per s. NR 218.06, Wis. Adm. Code.

6.2.3 Raw Grit and Screenings

All raw grit and screenings shall be disposed of at a properly licensed solid waste facility or picked up by a licensed waste hauler. If the facility or hauler are located in Wisconsin, then they shall be licensed under chs. NR 500-555, Wis. Adm. Code.

6.2.4 Sludge Management

All sludge management activities shall be conducted in compliance with ch. NR 204 "Domestic Sewage Sludge Management", Wis. Adm. Code.

6.2.5 Prohibited Wastes

Under no circumstances may the introduction of wastes prohibited by s. NR 211.10, Wis. Adm. Code, be allowed into the waste treatment system. Prohibited wastes include those:

- Which create a fire or explosion hazard in the treatment work;
- Which will cause corrosive structural damage to the treatment work;
- Solid or viscous substances in amounts which cause obstructions to the flow in sewers or interference with the proper operation of the treatment work;
- Wastewaters at a flow rate or pollutant loading which are excessive over relatively short time periods so as to cause a loss of treatment efficiency; and
- Changes in discharge volume or composition from contributing industries which overload the treatment works or cause a loss of treatment efficiency.

6.2.6 Bypass

This condition applies only to bypassing at a sewage treatment facility that is not a scheduled bypass, approved blending as a specific condition of this permit, a sewage treatment facility overflow or a controlled diversion as provided in the sections titled 'Scheduled Bypass', 'Blending' (if approved), 'SSO's and Sewage Treatment Facility Overflows' and 'Controlled Diversions' of this permit. Any other bypass at the sewage treatment facility is prohibited and the Department may take enforcement action against a permittee for such occurrences under s. 283.89, Wis. Stats. The Department may approve a bypass if the permittee demonstrates all the following conditions apply:

- The bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
- There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities or adequate back-up equipment, retention of untreated wastes, reduction of inflow and infiltration, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventative maintenance. When evaluating feasibility of alternatives, the department may consider factors such as technical achievability, costs and affordability of implementation and risks to public health, the environment and, where the permittee is a municipality, the welfare of the community served; and
- The bypass was reported in accordance with the Noncompliance Reporting section of this permit.

6.2.7 Scheduled Bypass

Whenever the permittee anticipates the need to bypass for purposes of efficient operations and maintenance and the permittee may not meet the conditions for controlled diversions in the 'Controlled Diversions' section of this permit, the permittee shall obtain prior written approval from the Department for the scheduled bypass. A permittee's written request for Department approval of a scheduled bypass shall demonstrate that the conditions for bypassing specified in the above section titled 'Bypass' are met and include the proposed date and reason for the bypass, estimated volume and duration of the bypass, alternatives to bypassing and measures to mitigate environmental harm caused by the bypass. The department may require the permittee to provide public notification for a scheduled bypass if it is

determined there is significant public interest in the proposed action and may recommend mitigation measures to minimize the impact of such bypass.

6.2.8 Controlled Diversions

Controlled diversions are allowed only when necessary for essential maintenance to assure efficient operation. Sewage treatment facilities that have multiple treatment units to treat variable or seasonal loading conditions may shut down redundant treatment units when necessary for efficient operation. The following requirements shall be met during controlled diversions:

- Effluent from the sewage treatment facility shall meet the effluent limitations established in the permit. Wastewater that is diverted around a treatment unit or treatment process during a controlled diversion shall be recombined with wastewater that is not diverted prior to the effluent sampling location and prior to effluent discharge;
- A controlled diversion does not include blending as defined in s. NR 210.03(2e), Wis. Adm. Code, and as may only be approved under s. NR 210.12. A controlled diversion may not occur during periods of excessive flow or other abnormal wastewater characteristics;
- A controlled diversion may not result in a wastewater treatment facility overflow; and
- All instances of controlled diversions shall be documented in sewage treatment facility records and such records shall be available to the department on request.

6.2.9 Proper Operation and Maintenance

The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance includes effective performance, adequate funding, adequate operator staffing and training as required in ch. NR 114, Wis. Adm. Code, and adequate laboratory and process controls, including appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems only when necessary to achieve compliance with the conditions of the permit.

6.2.10 Operator Certification

The wastewater treatment facility shall be under the direct supervision of a state certified operator. In accordance with s. NR 114.53, Wis. Adm. Code, every WPDES permitted treatment plant shall have a designated operator-in-charge holding a current and valid certificate. The designated operator-in-charge shall be certified at the level and in all subclasses of the treatment plant, except laboratory. Treatment plant owners shall notify the department of any changes in the operator-in-charge within 30 days. Note that s. NR 114.52(22), Wis. Adm. Code, lists types of facilities that are excluded from operator certification requirements (i.e. private sewage systems, pretreatment facilities discharging to public sewers, industrial wastewater treatment that consists solely of land disposal, agricultural digesters and concentrated aquatic production facilities with no biological treatment).

6.3 Sewage Collection Systems

6.3.1 Sanitary Sewage Overflows and Sewage Treatment Facility Overflows

6.3.1.1 Overflows Prohibited

Any overflow or discharge of wastewater from the sewage collection system or at the sewage treatment facility, other than from permitted outfalls, is prohibited. The permittee shall provide information on whether any of the following conditions existed when an overflow occurred:

- The sanitary sewer overflow or sewage treatment facility overflow was unavoidable to prevent loss of life, personal injury or severe property damage;

- There were no feasible alternatives to the sanitary sewer overflow or sewage treatment facility overflow such as the use of auxiliary treatment facilities or adequate back-up equipment, retention of untreated wastes, reduction of inflow and infiltration, or preventive maintenance activities;
- The sanitary sewer overflow or the sewage treatment facility overflow was caused by unusual or severe weather-related conditions such as large or successive precipitation events, snowmelt, saturated soil conditions, or severe weather occurring in the area served by the sewage collection system or sewage treatment facility; and
- The sanitary sewer overflow or the sewage treatment facility overflow was unintentional, temporary, and caused by an accident or other factors beyond the reasonable control of the permittee.

6.3.1.2 Permittee Response to Overflows

Whenever a sanitary sewer overflow or sewage treatment facility overflow occurs, the permittee shall take all feasible steps to control or limit the volume of untreated or partially treated wastewater discharged, and terminate the discharge as soon as practicable. Remedial actions, including those in s. NR 210.21 (3), Wis. Adm. Code, shall be implemented consistent with an emergency response plan developed under the CMOM program.

6.3.1.3 Permittee Reporting

Permittees shall report all sanitary sewer overflows and sewage treatment overflows as follows:

- The permittee shall notify the department by telephone, fax or email as soon as practicable, but no later than 24 hours from the time the permittee becomes aware of the overflow;
- The permittee shall, no later than five days from the time the permittee becomes aware of the overflow, provide to the department the information identified in this paragraph using department form number 3400-184. If an overflow lasts for more than five days, an initial report shall be submitted within 5 days as required in this paragraph and an updated report submitted following cessation of the overflow. At a minimum, the following information shall be included in the report:
 - a) The date and location of the overflow;
 - b) The surface water to which the discharge occurred, if any;
 - c) The duration of the overflow and an estimate of the volume of the overflow;
 - d) A description of the sewer system or treatment facility component from which the discharge occurred such as manhole, lift station, constructed overflow pipe, or crack or other opening in a pipe;
 - e) The estimated date and time when the overflow began and stopped or will be stopped;
 - f) The cause or suspected cause of the overflow including, if appropriate, precipitation, runoff conditions, areas of flooding, soil moisture and other relevant information;
 - g) Steps taken or planned to reduce, eliminate and prevent reoccurrence of the overflow and a schedule of major milestones for those steps;
 - h) A description of the actual or potential for human exposure and contact with the wastewater from the overflow;
 - i) Steps taken or planned to mitigate the impacts of the overflow and a schedule of major milestones for those steps;
 - j) To the extent known at the time of reporting, the number and location of building backups caused by excessive flow or other hydraulic constraints in the sewage collection system that occurred concurrently with the sanitary sewer overflow and that were within the same area of the sewage collection system as the sanitary sewer overflow; and
 - k) The reason the overflow occurred or explanation of other contributing circumstances that resulted in the overflow event. This includes any information available including whether the overflow was

unavoidable to prevent loss of life, personal injury, or severe property damage and whether there were feasible alternatives to the overflow.

NOTE: A copy of form 3400-184 for reporting sanitary sewer overflows and sewage treatment facility overflows may be obtained from the department or accessed on the department's web site at <http://dnr.wi.gov/topic/wastewater/SSOreport.html>. As indicated on the form, additional information may be submitted to supplement the information required by the form.

- The permittee shall identify each specific location and each day on which a sanitary sewer overflow or sewage treatment facility overflow occurs as a discrete sanitary sewer overflow or sewage treatment facility overflow occurrence. An occurrence may be more than one day if the circumstances causing the sanitary sewer overflow or sewage treatment facility overflow results in a discharge duration of greater than 24 hours. If there is a stop and restart of the overflow at the same location within 24 hours and the overflow is caused by the same circumstance, it may be reported as one occurrence. Sanitary sewer overflow occurrences at a specific location that are separated by more than 24 hours shall be reported as separate occurrences; and
- A permittee that is required to submit wastewater discharge monitoring reports under s. NR 205.07 (1) (r), Wis. Adm. Code, shall also report all sanitary sewer overflows and sewage treatment facility overflows on that report.

6.3.1.4 Public Notification

The permittee shall notify the public of any sanitary sewer and sewage treatment facility overflows consistent with its emergency response plan required under the CMOM (Capacity, Management, Operation and Maintenance) section of this permit and s. NR 210.23 (4) (f), Wis. Adm. Code. Such public notification shall occur promptly following any overflow event using the most effective and efficient communications available in the community. At minimum, a daily newspaper of general circulation in the county(s) and municipality whose waters may be affected by the overflow shall be notified by written or electronic communication.

6.3.2 Capacity, Management, Operation and Maintenance (CMOM) Program

- The permittee shall have written documentation of the Capacity, Management, Operation and Maintenance (CMOM) program components in accordance with s. NR 210.23(4), Wis. Adm. Code. Such documentation shall be available for Department review upon request. The Department may request that the permittee provide this documentation or prepare a summary of the permittee's CMOM program at the time of application for reissuance of the WPDES permit.
- The permittee shall implement a CMOM program in accordance with s. NR 210.23, Wis. Adm. Code.
- The permittee shall at least annually conduct a self-audit of activities conducted under the permittee's CMOM program to ensure CMOM components are being implemented as necessary to meet the general standards of s. NR 210.23(3), Wis. Adm. Code.

6.3.3 Sewer Cleaning Debris and Materials

All debris and material removed from cleaning sanitary sewers shall be managed to prevent nuisances, run-off, ground infiltration or prohibited discharges.

- Debris and solid waste shall be dewatered, dried and then disposed of at a licensed solid waste facility.
- Liquid waste from the cleaning and dewatering operations shall be collected and disposed of at a permitted wastewater treatment facility.
- Combination waste including liquid waste along with debris and solid waste may be disposed of at a licensed solid waste facility or wastewater treatment facility willing to accept the waste.

6.4 Land Treatment (Land Disposal) Requirements

6.4.1 Application of NR 140 to Substances Discharged

This permit does not authorize the permittee to discharge any substance in a concentration which would cause an applicable groundwater standard of ch. NR 140, Wis. Adm. Code, to be exceeded. The Department may seek a response under NR 140 if the permittee's discharge causes an exceedance of an applicable groundwater standard for any substance, including substances not specifically limited or monitored under this permit.

6.4.2 Appropriate Formulas for Land Treatment Calculations – Nitrogen & Chloride

The permittee shall use the following formulas for nitrogen and chloride calculations.

6.4.2.1 Nitrogen Formulas

Total Nitrogen = Total Kjeldahl Nitrogen + Nitrite + Nitrate, Nitrogen

Organic Nitrogen = Total Kjeldahl Nitrogen - Ammonia Nitrogen

6.4.2.2 Annual Total Nitrogen per Cell or per Zone

$$\frac{(\text{annual ave. concentration in mg/L}) (\text{tot. annual flow in million gallons per cell or zone}) (8.34)}{\text{acreage of cell or zone}} = \text{lbs/ac/yr}$$

6.4.2.3 Annual Total Chloride per Cell or per Zone

$$\frac{(\text{annual ave. concentration in mg/L}) (\text{tot. annual flow in million gallons per cell or zone}) (8.34)}{\text{acreage of cell or zone}} = \text{lbs/ac/yr}$$

6.4.3 Toxic or Hazardous Pollutants

The discharge of toxic or hazardous pollutants to land treatment systems is prohibited unless the applicant can demonstrate and the department determines that the discharge of such pollutants will be in such small quantities that no detrimental effect on groundwater or surface water will result pursuant to ss. NR 206.07(2)(c) and NR 214.04(1), Wis. Adm. Code. The criteria used shall include but not be limited to the toxicity of the pollutant, capacity of the soil to remove the pollutant, degradability, usual or potential presence of the pollutant in the existing environment, method of application and all other relevant factors.

6.4.4 Industrial Waste - Pretreatment Requirements

Industrial waste discharges to municipal land treatment systems shall be in compliance with the applicable pretreatment standards under ch. NR 211, Wis. Adm. Code, pursuant to s. NR 206.07(2)(e), Wis. Adm. Code.

6.4.5 Overflow

Discharge to a land treatment system shall be limited so that the discharge and any precipitation which falls within the boundary of the disposal system during such discharge does not overflow the boundary of the system unless the WPDES permit authorizes collection and discharge of runoff to surface water pursuant to s. NR 206.07(2)(g), Wis. Adm. Code.

6.4.6 Management Plan Requirements

All land disposal or land treatment systems shall be operated in accordance with an approved management plan. The management plan for municipal and domestic wastewaters shall conform to the requirements of s. NR 110.25(3m), Wis. Adm. Code, per s. NR 206.07(2)(h), Wis. Adm. Code. The management plan for industrial wastewaters shall conform to the applicable requirements of ss. NR 214.12(5)(b), NR 214.13(5)(e), NR 214.14(5)(d), NR 214.15(5)(c), and NR 214.16(5), Wis. Adm. Code.

6.5 Groundwater Standard Requirements

6.5.1 Application of NR 140 to Substances Discharged

This permit does not authorize the permittee to discharge any substance in a concentration which would cause an applicable groundwater standard of ch. NR 140, Wis. Adm. Code, to be exceeded. The Department may seek a response under NR 140 if the permittee's discharge causes exceedance of an applicable groundwater standard for any substance, including substances not specifically limited or monitored under this permit.

6.5.2 Groundwater Sampling

Groundwater sampling shall be performed in accordance with the procedures contained in s. NR 140.16, Wis. Adm. Code, and the WDNR publications, Groundwater Sampling Desk Reference (PUBL-DG-037-96) and Groundwater Sampling Field Manual (PUBL-DG-038-96).

6.5.3 Indicator Parameter Preventive Action Limits and Alternative Concentration Limits

The methodology for the assessment of background groundwater quality and calculation of indicator PALs and ACLs can be found in "Calculating Preventive Action Limits and Evaluating Groundwater Quality Exemptions for Groundwater Discharges (3400-2024-04).

6.5.4 Groundwater Monitoring Forms

Results of the groundwater analyses shall be summarized and reported on a Groundwater Monitoring Form. This report form is to be returned to the Department no later than the date indicated on the form. A copy of the Groundwater Monitoring Form or an electronic file of the form shall be retained by the permittee. Groundwater monitoring results shall be reported on an electronic Groundwater Monitoring Form and certified electronically via the 'eReport Certify' page by a responsible executive or municipal officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The 'eReport Certify' page certifies that the electronic report form is true, accurate and complete.

6.5.5 Notification of Attaining or Exceeding Groundwater Quality Standards

The permittee shall notify the Department when monitoring results indicate that a Preventive Action Limit or Enforcement Standard has been attained or exceeded per ss. NR 140.24 (1)(a) and NR 140.26 (1)(a) Wis. Adm. Code. This notification may be provided in the general remarks section of the groundwater monitoring form or by letter attached to the groundwater monitoring form. Any values reported as exceeding a groundwater standard shall be confirmed as being from a representative sample and as a correct laboratory analysis result.

6.5.6 Preventive Action Limit (PAL) Exceedance

Sections NR 206.07 (1)(c) and NR 214.07 (1), Wis. Adm. Code, require all land disposal and land treatment system to be designed and operated to prevent exceedances of PALs. Results from groundwater samples that are less than this permit's PALs indicate that operation of the land treatment system is protective of groundwater quality. Substance concentrations that exhibit a trend over time of being greater than the PAL may indicate that additional technically and economically feasible actions are needed to reduce the discharge of the substance to the groundwater. In such a case, the Department may request an evaluation and response or propose a permit modification to require submittal of a groundwater evaluation report and implementation of a feasible response as specified in s. NR 140.24, Wis. Adm. Code.

6.5.7 Enforcement Standard (ES) Exceedance Within the Design Management Zone

Substance concentrations greater than this permit's ES in a permittee's monitoring well located within the property boundary and within the design management zone of the land treatment system may indicate that the groundwater concentration exceeds an ES outside of these boundaries. If the Department determines there is reasonable evidence that an ES is being attained or exceeded beyond the property boundary or beyond the design management zone, the Department may request an evaluation and response or propose a permit modification to require an evaluation report and appropriate response as specified in s. NR 140.24, Wis. Adm. Code, per s. NR 140.27, Wis. Adm. Code.

6.5.8 Enforcement Standard Exceedance Outside the Design Management Zone

The permittee's land treatment system shall not cause the concentration of a substance in groundwater to attain or exceed this permit's ES at any point of present groundwater use, at any point beyond the property boundary, or at any point beyond the design management zone established under s. NR 140.22, Wis. Adm. Code. When this condition is not met, **the permittee shall, within 120 days following notification to the Department of the attainment or exceedance of an ES beyond the compliance boundary, submit a groundwater quality evaluation and response report** as specified in s. NR 140.26(1)(b), Wis. Adm. Code. The Department may propose modification of this permit to require the permittee to implement additional treatment or other actions as specified in s. NR 140.26, Wis. Adm. Code.

6.5.9 New Monitoring Wells Installed During the Current Permit-Term

If the new monitoring well is proposed to act as a background monitoring well for the use in calculating indicator parameter PALs and ACLs, then a minimum of eight rounds of sampling results are required prior to the calculation of indicator parameter PALs and ACLs for inclusion in a modified permit. The methodology and requirements for the assessment of background groundwater quality and calculation of indicator PALs and ACLs can be found in Evaluating and Calculating Preventative Action Limits and Alternative Concentration Limits for Groundwater Discharges (3400-2020-10).

6.6 Land Application Requirements

6.6.1 Sludge Management Program Standards And Requirements Based Upon Federally Promulgated Regulations

In the event that new federal sewage sludge standards or regulations are promulgated, the permittee shall comply with the new sewage sludge requirements by the dates established in the regulations, if required by federal law, even if the permit has not yet been modified to incorporate the new federal regulations.

6.6.2 General Sludge Management Information

The General Sludge Management Form 3400-48 shall be completed and submitted prior to any significant sludge management changes.

6.6.3 Sludge Samples

All sludge samples shall be collected at a point and in a manner which will yield sample results which are representative of the sludge being tested, and collected at the time which is appropriate for the specific test.

6.6.4 Land Application Characteristic Report

Each report shall consist of a Characteristic Form 3400-49 and Lab Report. The Characteristic Report Form 3400-49 shall be submitted electronically by January 31 following each year whether or not samples are analyzed. In years in which monitoring does not occur, the report shall be completed by checking on the form that monitoring/land application did not occur.

Following submittal of the electronic Characteristic Report Form 3400-49, this form shall be certified electronically via the 'eReport Certify' page by a responsible executive or municipal officer, manager, partner or proprietor as

specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The 'eReport Certify' page certifies that the electronic report is true, accurate and complete. The Lab Report must be sent directly to the facility's DNR sludge representative or basin engineer unless approval for not submitting the lab reports has been given.

The permittee shall use the following convention when reporting sludge monitoring results: Pollutant concentrations less than the limit of detection shall be reported as < (less than) the value of the limit of detection. For example, if a substance is not detected at a detection limit of 1.0 mg/kg, report the pollutant concentration as < 1.0 mg/kg .

All results shall be reported on a dry weight basis.

6.6.5 Calculation of Water Extractable Phosphorus

When sludge analysis for Water Extractable Phosphorus is required by this permit, the permittee shall use the following formula to calculate and report Water Extractable Phosphorus:

Water Extractable Phosphorus (% of Total P) =

$[\text{Water Extractable Phosphorus (mg/kg, dry wt)} \div \text{Total Phosphorus (mg/kg, dry wt)}] \times 100$

6.6.6 Monitoring and Calculating PCB Concentrations in Sludge

When sludge analysis for "PCB, Total Dry Wt" is required by this permit, the PCB concentration in the sludge shall be determined using either congener-specific analysis or Aroclor analysis. The permittee may decide which of these analyses is performed. Analyses shall be performed in accordance with the following provisions and Table EM in s. NR 219.04, Wis. Adm. Code:

- If congener-specific analysis is employed: All PCB congeners shall be delineated. Non-detects shall be treated as zero. The values that are between the limit of detection (LOD) and the limit of quantitation shall be used when calculating the total value of all congeners. All results shall be added together and the total PCB concentration by dry weight reported.
- If Aroclor analysis is employed, reporting protocols, consistent with s. NR 106.07(6)(e), should be as follows: If all Aroclors are less than the LOD, then the Total PCB Dry Wt result should be reported as less than the highest LOD. If a single Aroclor is detected, then that is what should be reported for the Total PCB result. If multiple Aroclors are detected, they should be summed and reported as Total PCBs. If the LOD cannot be achieved after using the appropriate clean up techniques, a reporting limit that is achievable for the Aroclors or each congener for the sample shall be determined. This reporting limit shall be reported and qualified indicating the presence of an interference.

6.6.7 Annual Land Application Report

Land Application Report Form 3400-55 shall be submitted electronically by January 31, each year whether or not non-exceptional quality sludge is land applied. Non-exceptional quality sludge is defined in s. NR 204.07(4), Wis. Adm. Code. Following submittal of the electronic Annual Land Application Report Form 3400-55, this form shall be certified electronically via the 'eReport Certify' page by a responsible executive or municipal officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The 'eReport Certify' page certifies that the electronic report form is true, accurate and complete.

6.6.8 Other Methods of Disposal or Distribution Report

The permittee shall submit electronically the Other Methods of Disposal or Distribution Report Form 3400-52 by January 31, each year whether or not sludge is hauled, landfilled, incinerated, or exceptional quality sludge is distributed or land applied. Following submittal of the electronic Report Form 3400-52, this form shall be certified electronically via the 'eReport Certify' page by a responsible executive or municipal officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner

or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The 'eReport Certify' page certifies that the electronic report form is true, accurate and complete.

6.6.9 Approval to Land Apply

Bulk non-exceptional quality sludge as defined in s. NR 204.07(4), Wis. Adm. Code, may not be applied to land without a written approval letter or Form 3400-122 from the Department unless the Permittee has obtained permission from the Department to self-approve sites in accordance with s. NR 204.06(6), Wis. Adm. Code. Analysis of sludge characteristics is required prior to land application. Application on frozen or snow-covered ground is restricted to the extent specified in s. NR 204.07(3)(1), Wis. Adm. Code.

6.6.10 Soil Analysis Requirements

Each site requested for approval for land application must have the soil tested prior to use. Each approved site used for land application must subsequently be soil tested such that there is at least one valid soil test in the four years prior to land application. All soil sampling and submittal of information to the testing laboratory shall be done in accordance with UW Extension Bulletin A-2100. The testing shall be done by the UW Soils Lab in Madison or Marshfield, WI or at a lab approved by UW. The test results including the crop recommendations shall be submitted to the DNR contact listed for this permit, as they are available. Application rates shall be determined based on the crop nitrogen recommendations and with consideration for other sources of nitrogen applied to the site.

6.6.11 Land Application Site Evaluation

For non-exceptional quality sludge, as defined in s. NR 204.07(4), Wis. Adm. Code, a Land Application Site Request Form 3400-053 shall be submitted to the Department for the proposed land application site. The Department will evaluate the proposed site for acceptability and will either approve or deny use of the proposed site. The permittee may obtain permission to approve their own sites in accordance with s. NR 204.06(6), Wis. Adm. Code.

7 Summary of Reports Due

FOR INFORMATIONAL PURPOSES ONLY

Description	Date	Page
Infiltration Rate Study -Final Report	September 30, 2026	16
Facility Plan -Intent to Apply	November 1, 2026	16
Facility Plan -Submit Facility Plan	March 31, 2027	16
Facility Plan -Final Plans and Specifications	September 30, 2027	16
Facility Plan -Desludging Management Plan	See Permit	16
Facility Plan -Land Spreading Management Plan	See Permit	16
Facility Plan -Financial Assistance Application	October 1, 2027	16
Facility Plan -Treatment Plant Upgrade to Meet WQBELs	March 31, 2028	16
Facility Plan -Complete Construction	September 30, 2028	16
Land Treatment Management Plan -Land Treatment Management Plan Submittal	September 30, 2026	17
Groundwater Monitoring Well Site Map Submittal -Monitoring Well Site Map	September 30, 2026	17
Sludge Management Plan -Final Report	September 30, 2026	17
Sludge Management Plan -Submit a Sludge Management Plan	See Permit	17
Compliance Maintenance Annual Reports (CMAR)	by June 30, each year	19
General Sludge Management Form 3400-48	prior to any significant sludge management changes	27
Characteristic Form 3400-49 and Lab Report	by January 31 following each year whether or not samples are analyzed	27
Land Application Report Form 3400-55	by January 31, each year whether or not non-exceptional quality sludge is land applied	28
Other Methods of Disposal or Distribution Report Form 3400-52	by January 31, each year whether or not sludge is hauled, landfilled, incinerated, or exceptional quality sludge is distributed or land applied	28
Groundwater Monitoring Form	no later than the date indicated on the form	26

Wastewater Discharge Monitoring Report	no later than the date indicated on the form	18
--	--	----

Report forms shall be submitted electronically in accordance with the reporting requirements herein. Any facility plans or plans and specifications for municipal, industrial, industrial pretreatment and non industrial wastewater systems shall be submitted to the Bureau of Water Quality, P.O. Box 7921, Madison, WI 53707-7921. All other submittals required by this permit shall be submitted to: Northern Region - Spooner, 810 W. Maple St, Spooner, WI 54801-1255.