



# WPDES PERMIT

*STATE OF WISCONSIN*  
*DEPARTMENT OF NATURAL RESOURCES*  
**PERMIT TO DISCHARGE UNDER THE WISCONSIN POLLUTANT DISCHARGE  
ELIMINATION SYSTEM**

**HEART OF THE VALLEY METRO SEW DIST**

is permitted, under the authority of Chapter 283, Wisconsin Statutes, to discharge from a facility  
located at

801 Thilmany Road  
to

**a side channel of the Fox River (WBIC 117900), in the Lower Fox-Appleton Watershed (LF04) of the Lower  
Fox River Basin**

in accordance with the effluent limitations, monitoring requirements and other conditions set  
forth in this permit.

The permittee shall not discharge after the date of expiration. If the permittee wishes to continue to discharge after this expiration date an application shall be filed for reissuance of this permit, according to Chapter NR 200, Wis. Adm. Code, at least 180 days prior to the expiration date given below.

State of Wisconsin Department of Natural Resources  
For the Secretary

By \_\_\_\_\_  
Heidi Schmitt Marquez  
Wastewater Field Supervisor

\_\_\_\_\_  
Date Permit Signed/Issued

**PERMIT TERM: EFFECTIVE DATE – January 1, 2026**

**EXPIRATION DATE – December 31, 2030**

## TABLE OF CONTENTS

|                                                                            |           |
|----------------------------------------------------------------------------|-----------|
| <b>1 INFLUENT REQUIREMENTS</b>                                             | <b>1</b>  |
| 1.1 SAMPLING POINT(S)                                                      | 1         |
| 1.2 MONITORING REQUIREMENTS                                                | 1         |
| 1.2.1 <i>Sampling Point 701 - Influent</i>                                 | 1         |
| <b>2 IN-PLANT REQUIREMENTS</b>                                             | <b>3</b>  |
| 2.1 SAMPLING POINT(S)                                                      | 3         |
| 2.2 MONITORING REQUIREMENTS AND LIMITATIONS                                | 3         |
| 2.2.1 <i>Sampling Point 101 - Effluent Reuse</i>                           | 3         |
| 2.2.2 <i>Sampling Point 111 - Field Blank</i>                              | 3         |
| 2.2.3 <i>Sampling Point 112 - BLENDING</i>                                 | 3         |
| <b>3 SURFACE WATER REQUIREMENTS</b>                                        | <b>5</b>  |
| 3.1 SAMPLING POINT(S)                                                      | 5         |
| 3.2 MONITORING REQUIREMENTS AND EFFLUENT LIMITATIONS                       | 5         |
| 3.2.1 <i>Sampling Point (Outfall) 001 - Effluent</i>                       | 5         |
| 3.2.2 <i>Sampling Point 601 - River Monitoring</i>                         | 14        |
| <b>4 LAND APPLICATION REQUIREMENTS</b>                                     | <b>15</b> |
| 4.1 SAMPLING POINT(S)                                                      | 15        |
| 4.2 MONITORING REQUIREMENTS AND LIMITATIONS                                | 15        |
| 4.2.1 <i>Sampling Point (Outfall) 003 - Class A Liquid Sludge</i>          | 15        |
| 4.2.2 <i>Sampling Point (Outfall) 012 - Class A Liquid Sludge</i>          | 22        |
| 4.2.3 <i>Sampling Point (Outfall) 011 - In-Plant Pre-VSR Liquid Sludge</i> | 25        |
| 4.2.4 <i>Sampling Point (Outfall) 008 - Class B Liquid Sludge</i>          | 25        |
| <b>5 SCHEDULES</b>                                                         | <b>32</b> |
| 5.1 MERCURY POLLUTANT MINIMIZATION PROGRAM                                 | 32        |
| 5.2 PFOS/PFOA MINIMIZATION PLAN DETERMINATION OF NEED                      | 32        |
| 5.3 SLUDGE MANAGEMENT PLAN                                                 | 33        |
| <b>6 STANDARD REQUIREMENTS</b>                                             | <b>35</b> |
| 6.1 REPORTING AND MONITORING REQUIREMENTS                                  | 35        |
| 6.1.1 <i>Monitoring Results</i>                                            | 35        |
| 6.1.2 <i>Sampling and Testing Procedures</i>                               | 35        |
| 6.1.3 <i>Recording of Results</i>                                          | 35        |
| 6.1.4 <i>Reporting of Monitoring Results</i>                               | 36        |
| 6.1.5 <i>Compliance Maintenance Annual Reports</i>                         | 36        |
| 6.1.6 <i>Records Retention</i>                                             | 36        |
| 6.1.7 <i>Other Information</i>                                             | 36        |
| 6.1.8 <i>Reporting Requirements – Alterations or Additions</i>             | 36        |
| 6.2 SYSTEM OPERATING REQUIREMENTS                                          | 37        |
| 6.2.1 <i>Noncompliance Reporting</i>                                       | 37        |
| 6.2.2 <i>Flow Meters</i>                                                   | 37        |
| 6.2.3 <i>Raw Grit and Screenings</i>                                       | 37        |
| 6.2.4 <i>Sludge Management</i>                                             | 38        |
| 6.2.5 <i>Prohibited Wastes</i>                                             | 38        |
| 6.2.6 <i>Bypass</i>                                                        | 38        |
| 6.2.7 <i>Scheduled Bypass</i>                                              | 38        |
| 6.2.8 <i>Controlled Diversions</i>                                         | 38        |
| 6.2.9 <i>Proper Operation and Maintenance</i>                              | 39        |
| 6.2.10 <i>Operator Certification</i>                                       | 39        |
| 6.3 SEWAGE COLLECTION SYSTEMS                                              | 39        |

|                                                                                                         |           |
|---------------------------------------------------------------------------------------------------------|-----------|
| 6.3.1 Sanitary Sewage Overflows and Sewage Treatment Facility Overflows                                 | 39        |
| 6.3.2 Capacity, Management, Operation and Maintenance (CMOM) Program                                    | 41        |
| 6.3.3 Sewer Cleaning Debris and Materials                                                               | 41        |
| 6.4 SURFACE WATER REQUIREMENTS                                                                          | 41        |
| 6.4.1 Permittee-Determined Limit of Quantitation Incorporated into this Permit                          | 41        |
| 6.4.2 Appropriate Formulas for Effluent Calculations                                                    | 42        |
| 6.4.3 Effluent Temperature Requirements                                                                 | 42        |
| 6.4.4 Visible Foam or Floating Solids                                                                   | 42        |
| 6.4.5 Surface Water Uses and Criteria                                                                   | 42        |
| 6.4.6 Percent Removal                                                                                   | 43        |
| 6.4.7 Chloride Notification                                                                             | 43        |
| 6.4.8 E. coli                                                                                           | 43        |
| 6.4.9 Seasonal Disinfection                                                                             | 43        |
| 6.4.10 Total Residual Chlorine Requirements                                                             | 43        |
| 6.4.11 Whole Effluent Toxicity (WET) Monitoring Requirements                                            | 44        |
| 6.4.12 Whole Effluent Toxicity (WET) Identification and Reduction                                       | 44        |
| 6.4.13 PFOS and PFOA Requirements                                                                       | 45        |
| 6.5 LAND APPLICATION REQUIREMENTS                                                                       | 45        |
| 6.5.1 Sludge Management Program Standards And Requirements Based Upon Federally Promulgated Regulations | 45        |
| 6.5.2 General Sludge Management Information                                                             | 45        |
| 6.5.3 Sludge Samples                                                                                    | 45        |
| 6.5.4 Land Application Characteristic Report                                                            | 45        |
| 6.5.5 Calculation of Water Extractable Phosphorus                                                       | 46        |
| 6.5.6 Monitoring and Calculating PCB Concentrations in Sludge                                           | 46        |
| 6.5.7 Annual Land Application Report                                                                    | 46        |
| 6.5.8 Other Methods of Disposal or Distribution Report                                                  | 46        |
| 6.5.9 Approval to Land Apply                                                                            | 47        |
| 6.5.10 Soil Analysis Requirements                                                                       | 47        |
| 6.5.11 Land Application Site Evaluation                                                                 | 47        |
| 6.5.12 Class A Sludge: Fecal Coliform Density Requirement                                               | 47        |
| 6.5.13 Class A Sludge: Temperature/Time Process                                                         | 47        |
| 6.5.14 Class A Sludge: Thermophilic Aerobic Digestion Process                                           | 48        |
| 6.5.15 Class B Sludge: Fecal Coliform Limitation                                                        | 48        |
| 6.5.16 Vector Control: Volatile Solids Reduction                                                        | 48        |
| 6.5.17 Class A Sludge - Vector Control: Injection                                                       | 48        |
| 6.5.18 Class B Sludge - Vector Control: Injection                                                       | 49        |
| 6.5.19 Class A Sludge - Vector Control: Incorporation                                                   | 49        |
| 6.5.20 Class B Sludge - Vector Control: Incorporation                                                   | 49        |
| 6.5.21 Landfilling of Sludge                                                                            | 49        |
| 6.5.22 Sludge Landfilling Reports                                                                       | 49        |
| 6.5.23 Sludge Hauling                                                                                   | 49        |
| 6.5.24 Land Application of Sludge Which Contains Elevated Levels of Radium-226                          | 49        |
| <b>7 SUMMARY OF REPORTS DUE</b>                                                                         | <b>50</b> |

# 1 Influent Requirements

## 1.1 Sampling Point(s)

| Sampling Point Designation |                                                                                                                                                    |
|----------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------|
| Sampling Point Number      | Sampling Point Location, Waste Type/Sample Contents and Treatment Description (as applicable)                                                      |
| 701                        | Influent: 24-Hr flow proportional sampler located at the headworks prior to the bar screen. Flow meter located ahead of the influent step screens. |

## 1.2 Monitoring Requirements

The permittee shall comply with the following monitoring requirements.

### 1.2.1 Sampling Point 701 - Influent

| Monitoring Requirements and Limitations |            |                 |                  |                      |                      |
|-----------------------------------------|------------|-----------------|------------------|----------------------|----------------------|
| Parameter                               | Limit Type | Limit and Units | Sample Frequency | Sample Type          | Notes                |
| Flow Rate                               |            | MGD             | Daily            | Continuous           |                      |
| BOD <sub>5</sub> , Total                |            | mg/L            | Daily            | 24-Hr Flow Prop Comp |                      |
| Suspended Solids, Total                 |            | mg/L            | Daily            | 24-Hr Flow Prop Comp |                      |
| Cadmium, Total Recoverable              |            | µg/L            | Monthly          | 24-Hr Flow Prop Comp |                      |
| Chromium, Total Recoverable             |            | µg/L            | Monthly          | 24-Hr Flow Prop Comp |                      |
| Copper, Total Recoverable               |            | µg/L            | Monthly          | 24-Hr Flow Prop Comp |                      |
| Lead, Total Recoverable                 |            | µg/L            | Monthly          | 24-Hr Flow Prop Comp |                      |
| Nickel, Total Recoverable               |            | µg/L            | Monthly          | 24-Hr Flow Prop Comp |                      |
| Zinc, Total Recoverable                 |            | µg/L            | Monthly          | 24-Hr Flow Prop Comp |                      |
| Mercury, Total Recoverable              |            | ng/L            | Quarterly        | Grab                 | See Mercury section. |

#### 1.2.1.1 Total Metals Analyses

Measurements of total metals and total recoverable metals shall be considered as equivalent.

#### 1.2.1.2 Sample Analysis

Samples shall be analyzed using a method which provides adequate sensitivity so that results can be qualified as a level of quantitation below the calculated/potential effluent limit, unless not possible using the most sensitive approved method.

### **1.2.1.3 Mercury Monitoring**

The permittee shall collect and analyze all mercury samples according to the data quality requirements of ss. NR 106.145(9) and (10), Wisconsin Administrative Code. The limit of quantitation (LOQ) used for the effluent and field blank shall be less than 1.3 ng/L, unless the samples are quantified at levels above 1.3 ng/L. The permittee shall collect at least one mercury field blank for each set of mercury samples (a set of samples may include combinations of intake, influent, effluent or other samples all collected on the same day). The permittee shall report results of samples and field blanks to the Department on Discharge Monitoring Reports.

## 2 In-Plant Requirements

### 2.1 Sampling Point(s)

| Sampling Point Designation |                                                                                                                                                                                                                                                                                                                    |
|----------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Sampling Point Number      | Sampling Point Location, Waste Type/Sample Contents and Treatment Description (as applicable)                                                                                                                                                                                                                      |
| 101                        | Effluent Reuse: Sample point for reporting amount of effluent flow diverted to the Fox Energy LLC electric generating power plant for its process water needs.                                                                                                                                                     |
| 111                        | Field Blank - Sample point for reporting results of Mercury field blanks collected using standard sample handling procedures.                                                                                                                                                                                      |
| 112                        | Blending: Sample point for reporting diverted flow from the Actiflo process during high flow events. Wastewater flow bypasses the Actiflo process and the Biostyr. The permittee shall notify the Department when blending occurs. See "Blending" requirements in the Standard Requirements section of the permit. |

### 2.2 Monitoring Requirements and Limitations

The permittee shall comply with the following monitoring requirements and limitations.

#### 2.2.1 Sampling Point 101 - Effluent Reuse

| Monitoring Requirements and Limitations |            |                 |                  |             |       |
|-----------------------------------------|------------|-----------------|------------------|-------------|-------|
| Parameter                               | Limit Type | Limit and Units | Sample Frequency | Sample Type | Notes |
| Flow Unregulated                        |            | MGD             | Daily            | Continuous  |       |

#### 2.2.2 Sampling Point 111 - Field Blank

| Monitoring Requirements and Limitations |            |                 |                  |             |       |
|-----------------------------------------|------------|-----------------|------------------|-------------|-------|
| Parameter                               | Limit Type | Limit and Units | Sample Frequency | Sample Type | Notes |
| Mercury, Total Recoverable              |            | ng/L            | Quarterly        | Blank       |       |

##### 2.2.2.1 Mercury Monitoring

The permittee shall collect and analyze all mercury samples according to the data quality requirements of ss. NR 106.145(9) and (10), Wisconsin Administrative Code. The limit of quantitation (LOQ) used for the effluent and field blank shall be less than 1.3 ng/L, unless the samples are quantified at levels above 1.3 ng/L. The permittee shall collect at least one mercury field blank for each set of mercury samples (a set of samples may include combinations of intake, influent, effluent or other samples all collected on the same day). The permittee shall report results of samples and field blanks to the Department on Discharge Monitoring Reports.

#### 2.2.3 Sampling Point 112 - BLENDING

| Monitoring Requirements and Limitations |            |                 |                  |             |                            |
|-----------------------------------------|------------|-----------------|------------------|-------------|----------------------------|
| Parameter                               | Limit Type | Limit and Units | Sample Frequency | Sample Type | Notes                      |
| Flow Rate                               |            | MGD             | Per              | Continuous  | See 'Blending Flow' permit |

WPDES Permit No. WI-0031232-10-0  
HEART OF THE VALLEY METRO SEW DIST

|      |  |       |                   |            |                                                                                                                                            |
|------|--|-------|-------------------|------------|--------------------------------------------------------------------------------------------------------------------------------------------|
|      |  |       | Occurrence        |            | section.                                                                                                                                   |
| Time |  | hours | Per<br>Occurrence | Continuous | Report the total duration of blending within a given day (12:00am - 11:59pm) in which blending occurs. See 'Blending Flow' permit section. |

### 2.2.3.1 Blending Flow

Flow measurement shall start at the commencement of blending operations and shall be maintained for the duration of the blending operation. Measure flow in daily increments until operation ends and report daily flow on the eDMR. The permittee shall report the volume of wastewater that is diverted around secondary treatment processes whenever in-plant diversion (blending) occurs. See “Blending” requirements in the Standard Requirements section for additional requirements.

### 3 Surface Water Requirements

#### 3.1 Sampling Point(s)

| Sampling Point Designation |                                                                                                                                                                                                                                                                                                                    |
|----------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Sampling Point Number      | Sampling Point Location, Waste Type/Sample Contents and Treatment Description (as applicable)                                                                                                                                                                                                                      |
| 001                        | Effluent: 24-Hr flow proportional sampler located after the "Biostyr" biological treatment system. Grab samples collected at the Biostry outfall manhole 4 after dechlorination. Flow meter located at the outfall of the chlorine contact tank.                                                                   |
| 601                        | River Monitoring - Lower Fox River data collected at the Appleton Lutz Park-USGS/ACOE Gauge Station - and/or other alternative method or site approved by the Department - as reported by the Lower Fox River Discharger's Association shall be used in the determination of the daily BOD5 waste load allocation. |

#### 3.2 Monitoring Requirements and Effluent Limitations

The permittee shall comply with the following monitoring requirements and limitations.

##### 3.2.1 Sampling Point (Outfall) 001 - Effluent

| Monitoring Requirements and Effluent Limitations |             |                 |                  |                      |                                                                                                                                 |
|--------------------------------------------------|-------------|-----------------|------------------|----------------------|---------------------------------------------------------------------------------------------------------------------------------|
| Parameter                                        | Limit Type  | Limit and Units | Sample Frequency | Sample Type          | Notes                                                                                                                           |
| Flow Rate                                        |             | MGD             | Daily            | Continuous           |                                                                                                                                 |
| BOD <sub>5</sub> , Total                         | Weekly Avg  | 45 mg/L         | Daily            | 24-Hr Flow Prop Comp | November – April                                                                                                                |
| BOD <sub>5</sub> , Total                         | Monthly Avg | 30 mg/L         | Daily            | 24-Hr Flow Prop Comp | November – April                                                                                                                |
| Suspended Solids, Total                          | Weekly Avg  | 45 mg/L         | Daily            | 24-Hr Flow Prop Comp |                                                                                                                                 |
| Suspended Solids, Total                          | Monthly Avg | 30 mg/L         | Daily            | 24-Hr Flow Prop Comp |                                                                                                                                 |
| Suspended Solids, Total                          | Weekly Avg  | 990 lbs/day     | Daily            | Calculated           |                                                                                                                                 |
| Suspended Solids, Total                          | Monthly Avg | 650 lbs/day     | Daily            | Calculated           |                                                                                                                                 |
| Suspended Solids, Total                          |             | lbs/month       | Monthly          | Calculated           | Calculate the Total Monthly Discharge of TSS and report on the last day of the month on the DMR. See TMDL Calculations section. |

WPDES Permit No. WI-0031232-10-0  
HEART OF THE VALLEY METRO SEW DIST

| Monitoring Requirements and Effluent Limitations |                          |                 |                  |                      |                                                                                                                                                               |
|--------------------------------------------------|--------------------------|-----------------|------------------|----------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Parameter                                        | Limit Type               | Limit and Units | Sample Frequency | Sample Type          | Notes                                                                                                                                                         |
| Suspended Solids, Total                          |                          | lbs/yr          | Monthly          | Calculated           | Calculate the 12-month rolling sum of total monthly mass of TSS discharged and report on the last day of the month on the DMR. See TMDL Calculations section. |
| pH Field                                         | Daily Max                | 9.0 su          | Daily            | Grab                 |                                                                                                                                                               |
| pH Field                                         | Daily Min                | 6.0 su          | Daily            | Grab                 |                                                                                                                                                               |
| E. coli                                          | Geometric Mean - Monthly | 126 #/100 ml    | Weekly           | Grab                 | May - September                                                                                                                                               |
| E. coli                                          | % Exceedance             | 10 Percent      | Monthly          | Calculated           | May - September. See the E. coli Percent Limit section. Enter the result in the DMR on the last day of the month.                                             |
| Chlorine, Total Residual                         | Daily Max                | 38 µg/L         | Daily            | Grab                 | May - September                                                                                                                                               |
| Chlorine, Total Residual                         | Weekly Avg               | 38 µg/L         | Daily            | Grab                 | May - September                                                                                                                                               |
| Chlorine, Total Residual                         | Monthly Avg              | 38 µg/L         | Daily            | Grab                 | May - September                                                                                                                                               |
| Nitrogen, Ammonia (NH <sub>3</sub> -N) Total     | Daily Max                | 17 mg/L         | Daily            | 24-Hr Flow Prop Comp |                                                                                                                                                               |
| Nitrogen, Ammonia (NH <sub>3</sub> -N) Total     | Weekly Avg               | 28 mg/L         | Daily            | 24-Hr Flow Prop Comp | January - March                                                                                                                                               |
| Nitrogen, Ammonia (NH <sub>3</sub> -N) Total     | Weekly Avg               | 29 mg/L         | Daily            | 24-Hr Flow Prop Comp | April                                                                                                                                                         |
| Nitrogen, Ammonia (NH <sub>3</sub> -N) Total     | Weekly Avg               | 17 mg/L         | Daily            | 24-Hr Flow Prop Comp | May, and October - December                                                                                                                                   |
| Nitrogen, Ammonia (NH <sub>3</sub> -N) Total     | Weekly Avg               | 11 mg/L         | Daily            | 24-Hr Flow Prop Comp | June - September                                                                                                                                              |
| Nitrogen, Ammonia (NH <sub>3</sub> -N) Total     | Monthly Avg              | 10 mg/L         | Daily            | 24-Hr Flow Prop Comp | January - March                                                                                                                                               |
| Nitrogen, Ammonia (NH <sub>3</sub> -N) Total     | Monthly Avg              | 11 mg/L         | Daily            | 24-Hr Flow Prop Comp | April - May                                                                                                                                                   |
| Nitrogen, Ammonia (NH <sub>3</sub> -N) Total     | Monthly Avg              | 4.4 mg/L        | Daily            | 24-Hr Flow Prop Comp | June - September                                                                                                                                              |
| Nitrogen, Ammonia (NH <sub>3</sub> -N) Total     | Monthly Avg              | 18 mg/L         | Daily            | 24-Hr Flow Prop Comp | October - December                                                                                                                                            |
| Phosphorus, Total                                | Monthly Avg              | 1.0 mg/L        | Daily            | 24-Hr Flow Prop Comp |                                                                                                                                                               |
| Phosphorus, Total                                | Monthly Avg              | 31.5 lbs/day    | Daily            | Calculated           |                                                                                                                                                               |
| Phosphorus, Total                                | 6-Month Avg              | 10.5 lbs/day    | Daily            | Calculated           |                                                                                                                                                               |

WPDES Permit No. WI-0031232-10-0  
HEART OF THE VALLEY METRO SEW DIST

| Monitoring Requirements and Effluent Limitations |            |                 |                  |                      |                                                                                                                                                                      |
|--------------------------------------------------|------------|-----------------|------------------|----------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Parameter                                        | Limit Type | Limit and Units | Sample Frequency | Sample Type          | Notes                                                                                                                                                                |
| Phosphorus, Total                                |            | lbs/month       | Monthly          | Calculated           | Calculate the Total Monthly Discharge of phosphorus and report on the last day of the month on the DMR. See TMDL Calculations section.                               |
| Phosphorus, Total                                |            | lbs/yr          | Monthly          | Calculated           | Calculate the 12-month rolling sum of total monthly mass of phosphorus discharged and report on the last day of the month on the DMR. See TMDL Calculations section. |
| Mercury, Total Recoverable                       |            | ng/L            | Quarterly        | Grab                 | See permit for pollutant minimization measures and report submittal.                                                                                                 |
| Cadmium, Total Recoverable                       |            | µg/L            | Monthly          | 24-Hr Flow Prop Comp |                                                                                                                                                                      |
| Chromium, Total Recoverable                      |            | µg/L            | Monthly          | 24-Hr Flow Prop Comp |                                                                                                                                                                      |
| Copper, Total Recoverable                        |            | µg/L            | Monthly          | 24-Hr Flow Prop Comp |                                                                                                                                                                      |
| Lead, Total Recoverable                          |            | µg/L            | Monthly          | 24-Hr Flow Prop Comp |                                                                                                                                                                      |
| Nickel, Total Recoverable                        |            | µg/L            | Monthly          | 24-Hr Flow Prop Comp |                                                                                                                                                                      |
| Zinc, Total Recoverable                          |            | µg/L            | Monthly          | 24-Hr Flow Prop Comp |                                                                                                                                                                      |
| Chloride                                         |            | mg/L            | Monthly          | 24-Hr Comp           | Monitoring only in 2028.                                                                                                                                             |
| PFOS                                             |            | ng/L            | 1/ 2 Months      | Grab                 | Monitoring only. See 'PFOS/PFOA Minimization Plan Determination of Need' in the schedules section.                                                                   |
| PFOA                                             |            | ng/L            | 1/ 2 Months      | Grab                 | Monitoring only. See 'PFOS/PFOA Minimization Plan Determination of Need' in the schedules section.                                                                   |
| Nitrogen, Total Kjeldahl                         |            | mg/L            | Quarterly        | 24-Hr Flow Prop Comp |                                                                                                                                                                      |
| Nitrogen, Nitrite + Nitrate Total                |            | mg/L            | Quarterly        | 24-Hr Flow Prop Comp |                                                                                                                                                                      |

| Monitoring Requirements and Effluent Limitations |                      |                    |                   |                      |                                                                                                                                    |
|--------------------------------------------------|----------------------|--------------------|-------------------|----------------------|------------------------------------------------------------------------------------------------------------------------------------|
| Parameter                                        | Limit Type           | Limit and Units    | Sample Frequency  | Sample Type          | Notes                                                                                                                              |
| Nitrogen, Total                                  |                      | mg/L               | Quarterly         | Calculated           | Total Nitrogen shall be calculated as the sum of reported values for Total Kjeldahl Nitrogen and Total Nitrite + Nitrate Nitrogen. |
| Acute WET                                        |                      | TU <sub>a</sub>    | See Listed Qtr(s) | 24-Hr Flow Prop Comp | See WET section.                                                                                                                   |
| Chronic WET                                      | Monthly Avg          | 11 TU <sub>c</sub> | See Listed Qtr(s) | 24-Hr Flow Prop Comp | See WET section.                                                                                                                   |
| WLA BOD5 Value                                   |                      | lbs/day            | Daily             | See Table            | May - October                                                                                                                      |
| WLA Adjusted Value                               |                      | lbs/day            | Daily             | Calculated           | May - October                                                                                                                      |
| WLA BOD5 Discharged                              | Daily Max - Variable | lbs/day            | Daily             | Calculated           | May - October                                                                                                                      |
| WLA 7 Day Sum Of WLA Values                      |                      | lbs/day            | Daily             | Calculated           | May - October                                                                                                                      |
| WLA 7 Day Sum Of BOD5 Discharged                 | Daily Max - Variable | lbs/day            | Daily             | Calculated           | May - October                                                                                                                      |

### 3.2.1.1 Annual Average Design Flow

The annual average design flow of the permittee's wastewater treatment facility is 8.5 MGD.

### 3.2.1.2 *E. coli* Percent Limit

No more than 10 percent of *E. coli* bacteria samples collected in any calendar month may exceed 410 #/100 ml. Bacteria samples may be collected more frequently than required. All samples shall be reported on the monthly discharge monitoring reports (DMRs). The following calculation should be used to calculate percent exceedances.

$$\frac{\text{\# of Samples greater than 410 \#/100 mL}}{\text{Total \# of samples}} \times 100 = \% \text{ Exceedance}$$

### 3.2.1.3 Lower Fox Total Maximum Daily Load (TMDL) Calculations

**Approved TMDL:** The Lower Fox River Basin TMDL Waste Load Allocation (WLA) for total phosphorus and total suspended solids was approved by the U.S. Environmental Protection Agency in March 2012 TMDL total lbs/month and lbs/yr effluent results shall be calculated as follows:

**Total Monthly Discharge (lbs/month):** = monthly average concentration (mg/L) x total flow for the month (MG/month) x 8.34.

**12-Month Rolling Sum of Total Monthly Discharge (lbs/yr):** =the sum of the most recent 12 consecutive months of Total Monthly Discharges.

### 3.2.1.4 TMDL Limitations for Total Phosphorus

The approved TMDL phosphorus WLA for this permittee is 3,467 lbs/yr, which results in calculated phosphorus mass limits of 31.5 lbs/day monthly average and 10.5 lbs/day 6-month average mass limits. The 6-month average limit is expressed as a seasonal average with averaging periods occurring from May through October and November through April. Compliance with the 6-month average limit is evaluated at the end of each 6-month period on April 30th and October 31st annually. The 12-month rolling sum of total monthly phosphorus (lbs/yr) shall be reported each month for direct comparison to the facility's WLA.

### **3.2.1.5 TMDL Limitations for Total Suspended Solids**

The approved TMDL TSS WLA for this permittee is 147,003 lbs/yr WLA, which results in calculated TSS mass limits of 1,100 lbs/day weekly average and 700 lbs/day monthly average mass limits. The 12-month rolling sum of total monthly TSS (lbs/yr) shall be reported each month for direct comparison to the facility's WLA.

### **3.2.1.6 Sample Analysis**

Samples shall be analyzed using a method which provides adequate sensitivity so that results can be quantified at a level of quantitation below the calculated/potential effluent limit, unless not possible using the most sensitive approved method.

### **3.2.1.7 Mercury Monitoring**

The permittee shall collect and analyze all mercury samples according to the data quality requirements of ss. NR 106.145(9) and (10), Wis. Adm. Code. The limit of quantitation (LOQ) used for the effluent and field blank shall be less than 1.3 ng/L, unless the samples are quantified at levels above 1.3 ng/L. The permittee shall collect at least one mercury field blank for each set of mercury samples (a set of samples may include combinations of intake, influent, effluent or other samples all collected on the same day). The permittee shall report results of samples and field blanks to the Department on Discharge Monitoring Reports.

### **3.2.1.8 Mercury – Implement Pollutant Minimization Program Plan**

This permit contains monitoring for mercury following previous permit terms that contained a variance for mercury approved in accordance with s. 283.15, Stats. As conditions of this permit the permittee shall continue to implement the mercury pollutant minimization measures specified in the facility's Pollutant Minimization Program Plan.

### **3.2.1.9 PFOS/PFOA Sampling and Reporting Requirements**

For grab samples, as defined per s. NR 218.04(10), Wis. Adm. Code, a single sample at a location as defined by the sample point description shall be taken during the time of the day most representative to capture all potential discharges. If extra equipment besides the sample bottle is used to collect the sample, it is recommended that a one-time equipment blank is collected with the first sample. An equipment blank would be collected by passing laboratory-verified PFAS-free water over or through field sampling equipment before the collection of a grab sample to evaluate potential contamination from the equipment used during sample.

If any equipment blanks are performed, these results shall be reported in the comments section of the eDMR and shall also be documented in the reports submitted as part of the PFOS/PFOA Minimization Plan Determination of Need schedule of the permit.

### **3.2.1.10 PFOS/PFOA Minimization Plan Determination of Need**

The permittee shall monitor PFOS and PFOA as specified in the table above and report on the effluent concentrations including trends in monthly and annual average PFOS and PFOA concentrations as specified in the PFOS/PFOA Minimization Plan Determination of Need Schedule.

If, after reviewing the data, the Department determines that a minimization plan for PFOS and PFOA is necessary based on the procedures in s. NR 106.98(4), Wis. Adm. Code, the Department will notify the permittee in writing that a PFOS and PFOA minimization plan that satisfies the requirements in s. NR 106.99, Wis. Adm. Code, is required. The permittee shall submit an initial plan for Department approval no later than 90 days after written notification was sent from the Department in accordance with s. NR 106.985(2)(a), Wis. Adm. Code. Pursuant to s. NR 106.985(2)(b), Wis. Adm. Code, as soon as possible after Department approval of the PFOS and PFOA minimization plan, the Department will modify or revoke and reissue the permit in accordance with public notice procedures under ch. 283, Wis. Stats., and ch. NR 203, Wis. Adm. Code, to include the PFOS and PFOA minimization plan and other related terms and condition.

If, however, the Department determines that a PFOS and PFOA minimization plan is unnecessary based on the procedures in s. NR 106.98(4), Wis. Adm. Code, the Department shall notify the permittee that no further action is required. Per s. NR 106.98(3)(a), Wis. Adm. Code, the Department may reduce monitoring frequency to once every 3 months (quarterly) on a case-by-case basis, but only after at least 12 representative results have been generated. If the permittee requests a reduction in monitoring and the Department agrees a reduction would be appropriate, the permit may be modified in accordance with public notice procedures under ch. 283, Wis. Stats., and ch. NR 203, Wis. Adm. Code, to incorporate this change.

### 3.2.1.11 Whole Effluent Toxicity (WET) Testing

**Primary Control Water:** Fox River upstream of the influence of the permittee's discharge, a synthetic (standard) laboratory water may be used as the dilution water and primary control in acute WET tests.

**Instream Waste Concentration (IWC):** 9%

**Dilution series:** At least five effluent concentrations and dual controls must be included in each test.

- **Acute:** 100, 50, 25, 12.5, 6.25% and any additional selected by the permittee.
- **Chronic:** 100, 30, 10, 3, 1% and any additional selected by the permittee.

#### WET Testing Frequency:

**Acute** tests are required during the following quarters:

- **Acute:** January – March 2026; April – June 2027; July – September 2028; October – December 2029; October – December 2030

Acute WET testing shall continue after the permit expiration date (until the permit is reissued) in accordance with the WET requirements specified for the last full calendar year of this permit. For example, the next test would be required in **October – December 2031**.

**Chronic** tests are required during the following quarters:

- **Chronic:** January – March 2026; April – June 2027; July – September 2028; October – December 2029; October – December 2025

Chronic WET testing shall continue after the permit expiration date (until the permit is reissued) in accordance with the WET requirements specified for the last full calendar year of this permit. For example, the next test would be required in **October – December 2031**.

**Testing:** WET testing shall be performed during normal operating conditions. Permittees are not allowed to turn off or otherwise modify treatment systems, production processes, or change other operating or treatment conditions during WET tests.

**Reporting:** The permittee shall report test results on the Discharge Monitoring Report form, and also complete the "Whole Effluent Toxicity Test Report Form" (Section 6, "*State of Wisconsin Aquatic Life Toxicity Testing Methods Manual, 2<sup>nd</sup> Edition*"), for each test. The original, complete, signed version of the Whole Effluent Toxicity Test Report Form shall be sent to the Biomonitoring Coordinator, Bureau of Water Quality, 101 S. Webster St., P.O. Box 7921, Madison, WI 53707-7921, within 45 days of test completion. The Discharge Monitoring Report (DMR) form shall be submitted electronically by the required deadline.

**Determination of Positive Results:** An acute toxicity test shall be considered positive if the Toxic Unit - Acute ( $TU_a$ ) is greater than 1.0 for either species (fathead minnow (*Pimephales promelas*) and waterflea (*Ceriodaphnia dubia*)). The  $TU_a$  shall be calculated as follows:  $TU_a = 100 \div LC_{50}$ . A chronic toxicity test shall be considered positive if the Toxic Unit - Chronic ( $TU_c$ ) is greater than 11 for either species. The  $TU_c$  shall be calculated as follows:  $TU_c = 100 \div IC_{25}$ .

**Additional Testing Requirements:** Within 90 days of a test which showed positive results, the permittee shall submit the results of at least 2 retests to the Biomonitoring Coordinator on "Whole Effluent Toxicity Test Report Forms". The 90-day reporting period shall begin the day after the test which showed a positive result. The retests shall be completed using the same species and test methods specified for the original test (see the Standard Requirements section herein).

### **3.2.1.12 Waste Load Allocation Requirements**

Each year during the months of May through October, the discharge of BOD<sub>5</sub> from Sample Point/Outfall 001 is limited to the following waste load allocated water quality related effluent limitations in addition to the effluent limitations contained in section 3.2.1.

#### **3.2.1.12.1 Definitions**

- *BOD<sub>5</sub> Allocation:* Heart of the Valley MSD's allocation of BOD<sub>5</sub> (pounds per day BOD<sub>5</sub>), as listed in Tables 1 through 5, represent water quality based effluent limitations. The flow and temperature conditions used to determine the BOD<sub>5</sub> allocation for a given day are defined below.
- *Flow:* A representative measurement of flow is the previous four-day average flow derived daily from continuous river flow monitoring data for the Fox River. These daily measurements of river flow are collected at the Appleton Lutz Park- USGS/ACOE Gauge Station – or other alternative method or site approved by the Department –and reported by the Lower Fox River Dischargers Association.
- *Temperature:* A representative measurement of temperature is the daily average temperature value of the previous day derived from continuous river temperature monitoring data for the Fox River as reported by the Lower Fox River Discharger's Association.

#### **3.2.1.12.2 Determination of Effluent Limitations**

For purposes of determining compliance with the waste load allocated water quality related BOD<sub>5</sub> effluent limitations, the following conditions shall be met:

- For any one-day period, the actual discharge of BOD<sub>5</sub> shall not exceed 1.38 times the BOD<sub>5</sub> allocation value from Tables 1 through 5 for that day (the "WLA Adjusted Value").
- The sum of the actual daily discharges of BOD<sub>5</sub> for any 7-consecutive-day period (the "WLA 7 Day Sum of WLA Values") shall not exceed the sum of the daily BOD<sub>5</sub> allocation values from Tables 1 through 5 for the same 7-consecutive-day period (the "WLA 7 Day Sum of BOD<sub>5</sub> Discharged").
- The sum of values for a 7-consecutive-day period as referenced in section 3.2.1 equals the sum of the present day value and the 6 previous day's values.

#### **3.2.1.12.3 Monitoring Requirements**

The same 24-hour period shall be used for the collection of composite and continuous samples for river flow and temperature and all effluent characteristics listed in Table 3.2.1, including effluent flow and BOD<sub>5</sub>.

#### **3.2.1.12.4 Reporting Requirements**

During the months of May through October inclusive the permittee shall report, the following information:

- The daily average river flow in cfs ("WLA Previous Day River Flow")
- The average of the previous 4 day's river flow in cfs ("WLA Previous 4 Day Avg River Flow")
- The previous day's river temperature in °F ("WLA Previous Day River Temp")
- The daily BOD<sub>5</sub> allocation in pounds of BOD<sub>5</sub> per day from Tables 1 through 4 ("WLA BOD<sub>5</sub> Value")
- The daily adjusted BOD<sub>5</sub> allocation ("WLA Adjusted Value")
- The discharge of BOD<sub>5</sub> in pounds of BOD<sub>5</sub> per day from Outfall 001 ("WLA BOD<sub>5</sub> Discharged")
- The sum of the daily BOD<sub>5</sub> allocations in pounds of BOD<sub>5</sub> for each 7-consecutive-day period ("WLA 7 Day Sum of WLA Values")

- The sum of the daily discharge of BOD<sub>5</sub> in pounds of BOD<sub>5</sub> for each 7-consecutive-day period (“WLA 7 Day Sum of BOD<sub>5</sub> Discharged”)

### 3.2.1.12.5 Waste Load Allocation Tables 1 – 5

**Table 1 – Point Source Waste Load Allocated Values (lbs per day of BOD5)  
(River mile 32.4 to 19.2)**

#### MAY – JUNE

| River<br>Temperature<br>(previous day<br>average in °F) | Flow at Appleton Lutz Park (previous four-day average in cfs) |                   |                    |                    |                    |                    |                    |                    |                    |                    |                    |                    |                    |                    |                    |
|---------------------------------------------------------|---------------------------------------------------------------|-------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|
|                                                         | 750<br>OR<br>LESS                                             | 751<br>TO<br>1000 | 1001<br>TO<br>1250 | 1251<br>TO<br>1500 | 1501<br>TO<br>1750 | 1751<br>TO<br>2000 | 2001<br>TO<br>2250 | 2251<br>TO<br>2500 | 2501<br>TO<br>2750 | 2751<br>TO<br>3000 | 3001<br>TO<br>3500 | 3501<br>TO<br>4000 | 4001<br>TO<br>5000 | 5001<br>TO<br>8000 | 8001<br>OR<br>MORE |
| 86 OR MORE                                              | 1081                                                          | 1130              | 1222               | 1331               | 1447               | 1564               | 1679               | 1785               | 1899               | 2012               | 2192               | 2450               | 2824               | 3538               | 4070               |
| 82 TO 85                                                | 1075                                                          | 1131              | 1230               | 1350               | 1476               | 1599               | 1718               | 1827               | 1950               | 2105               | 2303               | 2583               | 2978               | 3766               | 4409               |
| 78 TO 81                                                | 1060                                                          | 1130              | 1247               | 1386               | 1526               | 1659               | 1798               | 1962               | 2146               | 2285               | 2484               | 2827               | 3278               | 4162               | 5055               |
| 74 TO 77                                                | 1045                                                          | 1128              | 1271               | 1427               | 1576               | 1762               | 1956               | 2145               | 2298               | 2449               | 2701               | 3061               | 3529               | 4652               | 5568               |
| 70 TO 73                                                | 1033                                                          | 1133              | 1299               | 1473               | 1687               | 1908               | 2121               | 2282               | 2457               | 2640               | 2917               | 3354               | 3797               | 5265               | 5568               |
| 66 TO 69                                                | 1034                                                          | 1157              | 1344               | 1584               | 1833               | 2080               | 2266               | 2455               | 2672               | 2878               | 3191               | 3637               | 4174               | 5568               | 5568               |
| 62 TO 65                                                | 1055                                                          | 1197              | 1461               | 1746               | 2036               | 2254               | 2481               | 2723               | 2958               | 3195               | 3597               | 4015               | 4735               | 5568               | 5568               |
| 58 TO 61                                                | 1103                                                          | 1320              | 1652               | 1999               | 2266               | 2548               | 2838               | 3100               | 3406               | 3712               | 4071               | 4659               | 5568               | 5568               | 5568               |
| 54 TO 57                                                | 1248                                                          | 1532              | 1962               | 2297               | 2661               | 3003               | 3355               | 3752               | 4047               | 4375               | 4910               | 5568               | 5568               | 5568               | 5568               |
| 50 TO 53                                                | 1501                                                          | 1892              | 2340               | 2817               | 3250               | 3753               | 4173               | 4595               | 5065               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               |
| 46 TO 49                                                | 1948                                                          | 2364              | 2974               | 3600               | 4275               | 4843               | 5477               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               |
| 42 TO 45                                                | 2561                                                          | 3130              | 4040               | 4989               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               |
| 41 OR LESS                                              | 3541                                                          | 4506              | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               |

**Table 2 – Point Source Waste Load Allocated Values (lbs per day of BOD5)  
(River mile 32.4 to 19.2)**

#### JULY

| River<br>Temperature<br>(previous day<br>average in °F) | Flow at Appleton Lutz Park (previous four-day average in cfs) |                   |                    |                    |                    |                    |                    |                    |                    |                    |                    |                    |                    |                    |                    |
|---------------------------------------------------------|---------------------------------------------------------------|-------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|
|                                                         | 750<br>OR<br>LESS                                             | 751<br>TO<br>1000 | 1001<br>TO<br>1250 | 1251<br>TO<br>1500 | 1501<br>TO<br>1750 | 1751<br>TO<br>2000 | 2001<br>TO<br>2250 | 2251<br>TO<br>2500 | 2501<br>TO<br>2750 | 2751<br>TO<br>3000 | 3001<br>TO<br>3500 | 3501<br>TO<br>4000 | 4001<br>TO<br>5000 | 5001<br>TO<br>8000 | 8001<br>OR<br>MORE |
| 86 OR MORE                                              | 1075                                                          | 1119              | 1218               | 1328               | 1423               | 1449               | 1494               | 1560               | 1619               | 1649               | 1734               | 1891               | 2130               | 2817               | 3291               |
| 82 TO 85                                                | 1083                                                          | 1137              | 1228               | 1345               | 1455               | 1521               | 1569               | 1610               | 1653               | 1745               | 1877               | 2043               | 2369               | 3081               | 3667               |
| 78 TO 81                                                | 1076                                                          | 1146              | 1252               | 1372               | 1485               | 1584               | 1667               | 1758               | 1869               | 1966               | 2104               | 2382               | 2737               | 3569               | 4374               |
| 74 TO 77                                                | 1077                                                          | 1145              | 1271               | 1398               | 1514               | 1655               | 1830               | 1960               | 2078               | 2191               | 2413               | 2701               | 3058               | 4124               | 5182               |
| 70 TO 73                                                | 1067                                                          | 1155              | 1285               | 1421               | 1602               | 1819               | 2032               | 2167               | 2312               | 2478               | 2709               | 2990               | 3404               | 4786               | 5568               |
| 66 TO 69                                                | 1065                                                          | 1169              | 1311               | 1516               | 1768               | 2020               | 2211               | 2407               | 2601               | 2779               | 2984               | 3306               | 3840               | 5568               | 5568               |
| 62 TO 65                                                | 1080                                                          | 1194              | 1410               | 1695               | 2000               | 2229               | 2465               | 2717               | 2897               | 3059               | 3326               | 3747               | 4444               | 5568               | 5568               |
| 61 OR LESS                                              | 1115                                                          | 1289              | 1615               | 1984               | 2265               | 2564               | 2856               | 3046               | 3257               | 3484               | 3855               | 4431               | 5393               | 5568               | 5568               |

**Table 3 – Point Source Waste Load Allocated Values (lbs per day of BOD5)**

**(River mile 32.4 to 19.2)**

## AUGUST

| River Temperature<br>(previous day average in °F) | Flow at Appleton Lutz Park (previous four-day average in cfs) |                   |                    |                    |                    |                    |                    |                    |                    |                    |                    |                    |                    |                    |                    |
|---------------------------------------------------|---------------------------------------------------------------|-------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|
|                                                   | 750<br>OR<br>LESS                                             | 751<br>TO<br>1000 | 1001<br>TO<br>1250 | 1251<br>TO<br>1500 | 1501<br>TO<br>1750 | 1751<br>TO<br>2000 | 2001<br>TO<br>2250 | 2251<br>TO<br>2500 | 2501<br>TO<br>2750 | 2751<br>TO<br>3000 | 3001<br>TO<br>3500 | 3501<br>TO<br>4000 | 4001<br>TO<br>5000 | 5001<br>TO<br>8000 | 8001<br>OR<br>MORE |
| 86 OR MORE                                        | 947                                                           | 987               | 1082               | 1199               | 1315               | 1419               | 1509               | 1587               | 1658               | 1723               | 1812               | 1893               | 2079               | 2655               | 3040               |
| 82 TO 85                                          | 947                                                           | 995               | 1098               | 1221               | 1337               | 1444               | 1537               | 1617               | 1696               | 1759               | 1883               | 1999               | 2304               | 2917               | 3385               |
| 78 TO 81                                          | 947                                                           | 1010              | 1123               | 1253               | 1377               | 1488               | 1587               | 1675               | 1808               | 1942               | 2057               | 2318               | 2617               | 3343               | 4054               |
| 74 TO 77                                          | 947                                                           | 1020              | 1148               | 1287               | 1417               | 1534               | 1681               | 1856               | 1995               | 2125               | 2338               | 2588               | 2926               | 3854               | 4814               |
| 70 TO 73                                          | 947                                                           | 1031              | 1173               | 1319               | 1459               | 1666               | 1863               | 2018               | 2175               | 2343               | 2586               | 2865               | 3225               | 4486               | 5568               |
| 66 TO 69                                          | 947                                                           | 1056              | 1210               | 1382               | 1622               | 1854               | 2038               | 2217               | 2421               | 2639               | 2863               | 3151               | 3631               | 5256               | 5568               |
| 62 TO 65                                          | 972                                                           | 1093              | 1285               | 1561               | 1837               | 2056               | 2276               | 2512               | 2784               | 2934               | 3173               | 3556               | 4208               | 5568               | 5568               |
| 61 OR LESS                                        | 1015                                                          | 1175              | 1489               | 1821               | 2091               | 2374               | 2674               | 2927               | 3118               | 3324               | 3663               | 4206               | 5113               | 5568               | 5568               |

**Table 4 – Point Source Waste Load Allocated Values (lbs per day of BOD5)**

**(River mile 32.4 to 19.2)**

## SEPTEMBER

| River Temperature<br>(previous day average in °F) | Flow at Appleton Lutz Park (previous four-day average in cfs) |                   |                    |                    |                    |                    |                    |                    |                    |                    |                    |                    |                    |                    |                    |
|---------------------------------------------------|---------------------------------------------------------------|-------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|
|                                                   | 750<br>OR<br>LESS                                             | 751<br>TO<br>1000 | 1001<br>TO<br>1250 | 1251<br>TO<br>1500 | 1501<br>TO<br>1750 | 1751<br>TO<br>2000 | 2001<br>TO<br>2250 | 2251<br>TO<br>2500 | 2501<br>TO<br>2750 | 2751<br>TO<br>3000 | 3001<br>TO<br>3500 | 3501<br>TO<br>4000 | 4001<br>TO<br>5000 | 5001<br>TO<br>8000 | 8001<br>OR<br>MORE |
| 86 OR MORE                                        | 947                                                           | 947               | 947                | 1049               | 1178               | 1297               | 1408               | 1511               | 1608               | 1697               | 1814               | 1934               | 2120               | 2666               | 3057               |
| 82 TO 85                                          | 947                                                           | 947               | 947                | 1076               | 1207               | 1329               | 1439               | 1540               | 1643               | 1735               | 1810               | 1994               | 2310               | 2910               | 3387               |
| 78 TO 81                                          | 947                                                           | 947               | 975                | 1119               | 1257               | 1385               | 1502               | 1608               | 1704               | 1780               | 1953               | 2261               | 2576               | 3303               | 4054               |
| 74 TO 77                                          | 947                                                           | 947               | 1010               | 1160               | 1303               | 1436               | 1558               | 1679               | 1819               | 1956               | 2180               | 2517               | 2866               | 3803               | 4810               |
| 70 TO 73                                          | 947                                                           | 947               | 1044               | 1201               | 1347               | 1523               | 1676               | 1827               | 1994               | 2160               | 2456               | 2785               | 3137               | 4434               | 5568               |
| 66 TO 69                                          | 947                                                           | 947               | 1090               | 1254               | 1478               | 1665               | 1845               | 2031               | 2234               | 2455               | 2761               | 3053               | 3526               | 5208               | 5568               |
| 62 TO 65                                          | 947                                                           | 970               | 1148               | 1417               | 1645               | 1860               | 2085               | 2317               | 2594               | 2826               | 3059               | 3441               | 4108               | 5568               | 5568               |
| 58 TO 61                                          | 947                                                           | 1036              | 1342               | 1623               | 1888               | 2171               | 2469               | 2795               | 2995               | 3195               | 3529               | 4079               | 5001               | 5568               | 5568               |
| 54 TO 57                                          | 980                                                           | 1240              | 1592               | 1928               | 2291               | 2688               | 3003               | 3250               | 3529               | 3838               | 4343               | 5142               | 5568               | 5568               | 5568               |
| 50 TO 53                                          | 1218                                                          | 1534              | 1966               | 2454               | 2950               | 3301               | 3654               | 4057               | 4502               | 4983               | 5568               | 5568               | 5568               | 5568               | 5568               |
| 46 TO 49                                          | 1568                                                          | 1977              | 2637               | 3280               | 3752               | 4289               | 4892               | 5561               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               |
| 42 TO 45                                          | 2144                                                          | 2796              | 3683               | 4414               | 5253               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               |
| 41 OR LESS                                        | 3152                                                          | 4096              | 5330               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               |

**Table 5 – Point Source Waste Load Allocated Values (lbs per day of BOD5)**

**(River mile 32.4 to 19.2)**

## OCTOBER

| River | Flow at Appleton Lutz Park (previous four-day average in cfs) |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
|-------|---------------------------------------------------------------|--|--|--|--|--|--|--|--|--|--|--|--|--|--|
|-------|---------------------------------------------------------------|--|--|--|--|--|--|--|--|--|--|--|--|--|--|

WPDES Permit No. WI-0031232-10-0  
HEART OF THE VALLEY METRO SEW DIST

|                                                |                   |                   |                    |                    |                    |                    |                    |                    |                    |                    |                    |                    |                    |                    |                    |
|------------------------------------------------|-------------------|-------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|
| Temperature<br>(previous day<br>average in °F) | 750<br>OR<br>LESS | 751<br>TO<br>1000 | 1001<br>TO<br>1250 | 1251<br>TO<br>1500 | 1501<br>TO<br>1750 | 1751<br>TO<br>2000 | 2001<br>TO<br>2250 | 2251<br>TO<br>2500 | 2501<br>TO<br>2750 | 2751<br>TO<br>3000 | 3001<br>TO<br>3500 | 3501<br>TO<br>4000 | 4001<br>TO<br>5000 | 5001<br>TO<br>8000 | 8001<br>OR<br>MORE |
| 66 OR MORE                                     | 947               | 947               | 960                | 1127               | 1277               | 1443               | 1642               | 1817               | 2027               | 2260               | 2662               | 2995               | 3515               | 5323               | 5568               |
| 62 TO 65                                       | 947               | 947               | 1012               | 1225               | 1422               | 1635               | 1868               | 2102               | 2392               | 2705               | 2978               | 3385               | 4087               | 5568               | 5568               |
| 58 TO 61                                       | 947               | 947               | 1158               | 1396               | 1657               | 1944               | 2245               | 2583               | 2894               | 3097               | 3444               | 4019               | 4995               | 5568               | 5568               |
| 54 TO 57                                       | 947               | 1048              | 1354               | 1683               | 2048               | 2445               | 2864               | 3130               | 3413               | 3728               | 4249               | 5084               | 5568               | 5568               | 5568               |
| 50 TO 53                                       | 1006              | 1279              | 1702               | 2186               | 2721               | 3155               | 3510               | 3913               | 4367               | 4857               | 5568               | 5568               | 5568               | 5568               | 5568               |
| 46 TO 49                                       | 1288              | 1683              | 2323               | 3024               | 3568               | 4106               | 4712               | 5384               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               |
| 42 TO 45                                       | 1806              | 2444              | 3369               | 4179               | 5010               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               |
| 41 OR LESS                                     | 2798              | 3701              | 5022               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               | 5568               |

### 3.2.2 Sampling Point 601 - River Monitoring

| Monitoring Requirements and Effluent Limitations |            |                 |                  |               |               |
|--------------------------------------------------|------------|-----------------|------------------|---------------|---------------|
| Parameter                                        | Limit Type | Limit and Units | Sample Frequency | Sample Type   | Notes         |
| WLA Previous Day River Flow                      |            | cfs             | Daily            | Gauge Station | May - October |
| WLA Previous 4 Day Avg River Flow                |            | cfs             | Daily            | Calculated    | May - October |
| WLA Previous Day River Temp                      |            | deg F           | Daily            | Calculated    | May - October |

## 4 Land Application Requirements

### 4.1 Sampling Point(s)

The discharge(s) shall be limited to land application of the waste type(s) designated for the listed sampling point(s) on Department approved land spreading sites or by hauling to another facility.

| Sampling Point Designation |                                                                                                                        |
|----------------------------|------------------------------------------------------------------------------------------------------------------------|
| Sampling Point Number      | Sampling Point Location, Waste Type/Sample Contents and Treatment Description (as applicable)                          |
| 003                        | Land Application: Class A, Autothermal Thermophylic Aerobically Digested (ATAD) treated, Liquid Sludge from storage.   |
| 012                        | Land Application: Class A, Autothermal Thermophilic Aerobically Digested (ATAD) treated, VSR-Post ATAD, Liquid Sludge. |
| 011                        | Land Application (In-Plant): Class B, Pre-ATAD, Pre-VSR, Liquid Sludge.                                                |
| 008                        | Land Application: Class B, DAF treated, Thickened Liquid Sludge.                                                       |

### 4.2 Monitoring Requirements and Limitations

The permittee shall comply with the following monitoring requirements and limitations.

#### 4.2.1 Sampling Point (Outfall) 003 - Class A Liquid Sludge

| Monitoring Requirements and Limitations |              |                 |                  |             |       |
|-----------------------------------------|--------------|-----------------|------------------|-------------|-------|
| Parameter                               | Limit Type   | Limit and Units | Sample Frequency | Sample Type | Notes |
| Solids, Total                           |              | Percent         | Quarterly        | Composite   |       |
| Arsenic Dry Wt                          | Ceiling      | 75 mg/kg        | Quarterly        | Composite   |       |
| Arsenic Dry Wt                          | High Quality | 41 mg/kg        | Quarterly        | Composite   |       |
| Cadmium Dry Wt                          | Ceiling      | 85 mg/kg        | Quarterly        | Composite   |       |
| Cadmium Dry Wt                          | High Quality | 39 mg/kg        | Quarterly        | Composite   |       |
| Copper Dry Wt                           | Ceiling      | 4,300 mg/kg     | Quarterly        | Composite   |       |
| Copper Dry Wt                           | High Quality | 1,500 mg/kg     | Quarterly        | Composite   |       |
| Lead Dry Wt                             | Ceiling      | 840 mg/kg       | Quarterly        | Composite   |       |
| Lead Dry Wt                             | High Quality | 300 mg/kg       | Quarterly        | Composite   |       |
| Mercury Dry Wt                          | Ceiling      | 57 mg/kg        | Quarterly        | Composite   |       |
| Mercury Dry Wt                          | High Quality | 17 mg/kg        | Quarterly        | Composite   |       |
| Molybdenum Dry Wt                       | Ceiling      | 75 mg/kg        | Quarterly        | Composite   |       |
| Nickel Dry Wt                           | Ceiling      | 420 mg/kg       | Quarterly        | Composite   |       |

| Monitoring Requirements and Limitations       |              |                 |                  |             |                                                                                                                              |
|-----------------------------------------------|--------------|-----------------|------------------|-------------|------------------------------------------------------------------------------------------------------------------------------|
| Parameter                                     | Limit Type   | Limit and Units | Sample Frequency | Sample Type | Notes                                                                                                                        |
| Nickel Dry Wt                                 | High Quality | 420 mg/kg       | Quarterly        | Composite   |                                                                                                                              |
| Selenium Dry Wt                               | Ceiling      | 100 mg/kg       | Quarterly        | Composite   |                                                                                                                              |
| Selenium Dry Wt                               | High Quality | 100 mg/kg       | Quarterly        | Composite   |                                                                                                                              |
| Zinc Dry Wt                                   | Ceiling      | 7,500 mg/kg     | Quarterly        | Composite   |                                                                                                                              |
| Zinc Dry Wt                                   | High Quality | 2,800 mg/kg     | Quarterly        | Composite   |                                                                                                                              |
| Radium 226 Dry Wt                             |              | pCi/g           | Quarterly        | Composite   |                                                                                                                              |
| Nitrogen, Total Kjeldahl                      |              | Percent         | Quarterly        | Composite   | Required in quarters in which land application and/or EQ distribution occurs.                                                |
| Nitrogen, Ammonium (NH <sub>4</sub> -N) Total |              | Percent         | Quarterly        | Composite   | Required in quarters in which land application and/or EQ distribution occurs.                                                |
| Phosphorus, Total                             |              | Percent         | Quarterly        | Composite   | Required in quarters in which land application and/or EQ distribution occurs.                                                |
| Phosphorus, Water Extractable                 |              | % of Tot P      | Quarterly        | Composite   | Required in quarters in which land application and/or EQ distribution occurs.                                                |
| Potassium, Total Recoverable                  |              | Percent         | Quarterly        | Composite   | Required in quarters in which land application and/or EQ distribution occurs.                                                |
| PCB Total Dry Wt                              | Ceiling      | 50 mg/kg        | Once             | Composite   | Once in 2027.                                                                                                                |
| PCB Total Dry Wt                              | High Quality | 10 mg/kg        | Once             | Composite   | Once in 2027.                                                                                                                |
| PFOA + PFOS                                   |              | µg/kg           | Annual           | Calculated  | Report the sum of PFOA and PFOS. See PFAS Permit Sections for more information.                                              |
| PFAS Dry Wt                                   |              |                 | Annual           | Calculated  | Perfluoroalkyl and Polyfluoroalkyl Substances based on updated DNR PFAS List. See PFAS Permit Sections for more information. |

| Monitoring Requirements and Limitations  |            |                 |                  |             |                                                     |
|------------------------------------------|------------|-----------------|------------------|-------------|-----------------------------------------------------|
| Parameter                                | Limit Type | Limit and Units | Sample Frequency | Sample Type | Notes                                               |
| Municipal Sludge Priority Pollutant Scan |            |                 | Once             | Composite   | As specified in ch. NR 215.03 (1-4), Wis. Adm. Code |

| Other Sludge Requirements                                                                                                                                                                                                                                                                                                                                                                                                                                                                      |                  |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------|
| Sludge Requirements                                                                                                                                                                                                                                                                                                                                                                                                                                                                            | Sample Frequency |
| <b>List 3 Requirements – Pathogen Control:</b> The requirements in List 3 shall be met prior to land application or EQ distribution of sludge.                                                                                                                                                                                                                                                                                                                                                 | <b>Quarterly</b> |
| <b>List 4 Requirements – Vector Attraction Reduction:</b> For Class A sludge, the vector attraction reduction shall be satisfied at the same times or after the Class A sludge treatment process including at the time of land application. For EQ sludge, the vector attraction reduction (volatile solids reduction) shall be satisfied at the same time or after the Class A sludge treatment process, but does not include vector attraction reduction options incorporation or injection. | <b>Quarterly</b> |

#### 4.2.1.1 List 2 Analysis

If the monitoring frequency for List 2 parameters is more frequent than "Annual" then the sludge may be analyzed for the List 2 parameters just prior to each land application season or EQ distribution rather than at the more frequent interval specified.

#### 4.2.1.2 Changes in Feed Sludge Characteristics

If a change in feed sludge characteristics, treatment process, or operational procedures occurs which may result in a significant shift in sludge characteristics, the permittee shall reanalyze the sludge for List 1, 2, 3 and 4 parameters each time such change occurs.

#### 4.2.1.3 Multiple Sludge Sample Points (Outfalls)

If there are multiple sludge sample points (outfalls), but the sludges are not subject to different sludge treatment processes, then a separate List 2 analysis shall be conducted for each sludge type which is land applied, just prior to land application, and the application rate shall be calculated for each sludge type. In this case, List 1, 3, and 4 and PCBs need only be analyzed on a single sludge type, at the specified frequency. If there are multiple sludge sample points (outfalls), due to multiple treatment processes, List 1, 2, 3 and 4 and PCBs shall be analyzed for each sludge type at the specified frequency.

#### 4.2.1.4 Sludge Which Exceeds the High Quality Limit

Cumulative pollutant loading records shall be kept for all bulk land application of sludge which does not meet the high quality limit for any parameter. This requirement applies for the entire calendar year in which any exceedance of Table 3 of s. NR 204.07(5)(c), Wis. Adm. Code, is experienced. Such loading records shall be kept for all List 1 parameters for each site land applied in that calendar year. The formula to be used for calculating cumulative loading is as follows:

$[(\text{Pollutant concentration (mg/kg)} \times \text{dry tons applied/ac}) \div 500] + \text{previous loading (lbs/acre)} = \text{cumulative lbs pollutant per acre}$

When a site reaches 90% of the allowable cumulative loading for any metal established in Table 2 of s. NR 204.07(5)(b), Wis. Adm. Code, the Department shall be so notified through letter or in the comment section of the annual land application report (3400-55).

#### 4.2.1.5 Sludge Analysis for PCBs

The permittee shall analyze the sludge for Total PCBs one time during 2026. The results shall be reported as "PCB Total Dry Wt". Either congener-specific analysis or Aroclor analysis shall be used to determine the PCB concentration. The permittee may determine whether Aroclor or congener specific analysis is performed. Analyses shall be performed in accordance with Table EM in s. NR 219.04, Wis. Adm. Code and the conditions specified in Standard Requirements of this permit. PCB results shall be submitted by January 31, following the specified year of analysis.

#### 4.2.1.6 Lists 1, 2, 3, and 4

| List 1<br>TOTAL SOLIDS AND METALS                                                                                              |  |
|--------------------------------------------------------------------------------------------------------------------------------|--|
| See the Monitoring Requirements and Limitations table above for monitoring frequency and limitations for the List 1 parameters |  |
| Solids, Total (percent)                                                                                                        |  |
| Arsenic, mg/kg (dry weight)                                                                                                    |  |
| Cadmium, mg/kg (dry weight)                                                                                                    |  |
| Copper, mg/kg (dry weight)                                                                                                     |  |
| Lead, mg/kg (dry weight)                                                                                                       |  |
| Mercury, mg/kg (dry weight)                                                                                                    |  |
| Molybdenum, mg/kg (dry weight)                                                                                                 |  |
| Nickel, mg/kg (dry weight)                                                                                                     |  |
| Selenium, mg/kg (dry weight)                                                                                                   |  |
| Zinc, mg/kg (dry weight)                                                                                                       |  |
| Radium-226, pCi/g (dry weight)                                                                                                 |  |

| List 2<br>NUTRIENTS                                                                                            |  |
|----------------------------------------------------------------------------------------------------------------|--|
| See the Monitoring Requirements and Limitations table above for monitoring frequency for the List 2 parameters |  |
| Solids, Total (percent)                                                                                        |  |
| Nitrogen Total Kjeldahl (percent)                                                                              |  |
| Nitrogen Ammonium (NH <sub>4</sub> -N) Total (percent)                                                         |  |
| Phosphorus Total as P (percent)                                                                                |  |
| Phosphorus, Water Extractable (as percent of Total P)                                                          |  |
| Potassium Total Recoverable (percent)                                                                          |  |

| List 3                                                                                                                                                                                                                          |                                                 |       |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------|-------|
| PATHOGEN CONTROL FOR CLASS A SLUDGE                                                                                                                                                                                             |                                                 |       |
| The permittee shall implement pathogen control as listed in List 3. The Department shall be notified of the pathogen control utilized and shall be notified when the permittee decides to utilize alternative pathogen control. |                                                 |       |
| The following requirements shall be met prior to land application or EQ distribution of sludge.                                                                                                                                 |                                                 |       |
| Parameter                                                                                                                                                                                                                       | Unit                                            | Limit |
| Fecal Coliform*                                                                                                                                                                                                                 | MPN/gTS                                         | 1000  |
| OR                                                                                                                                                                                                                              |                                                 |       |
| Salmonella                                                                                                                                                                                                                      | MPN/4gTS                                        | 3     |
| AND, ONE OF THE FOLLOWING PROCESS OPTIONS                                                                                                                                                                                       |                                                 |       |
| Temp/Time based on % Solids                                                                                                                                                                                                     | Alkaline Treatment                              |       |
| Prior test for Enteric Virus/Viable Helminth Ova                                                                                                                                                                                | Post test for Enteric Virus/Viable Helminth Ova |       |
| Composting                                                                                                                                                                                                                      | Heat Drying                                     |       |
| Heat Treatment                                                                                                                                                                                                                  | Thermophilic Aerobic Digestion                  |       |
| Beta Ray Irradiation                                                                                                                                                                                                            | Gamma Ray Irradiation                           |       |
| Pasteurization                                                                                                                                                                                                                  | PFRP Equivalent Process                         |       |
| * The Fecal Coliform limit shall be reported as 7 discrete samples on a dry weight basis.                                                                                                                                       |                                                 |       |

| <p style="text-align: center;"><b>List 4</b><br/><b>VECTOR ATTRACTION REDUCTION</b></p> <p>The permittee shall implement any one of the vector attraction reduction options specified in List 4. The Department shall be notified of the option utilized and shall be notified when the permittee decides to utilize an alternative option.</p> <p>For Class A sludge, the vector attraction reduction shall be satisfied at the same times or after the Class A sludge treatment process including at the time of land application. For EQ sludge, the vector attraction reduction (volatile solids reduction) shall be satisfied at the same time or after the Class A sludge treatment process, but does not include vector attraction reduction options incorporation or injection.</p> |                                                               |                              |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------|------------------------------|
| Option                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                      | Limit                                                         | Where/When it Shall be Met   |
| Volatile Solids Reduction                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   | ≥38%                                                          | Across the process           |
| Specific Oxygen Uptake Rate                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 | ≤1.5 mg O <sub>2</sub> /hr/g TS                               | On aerobic stabilized sludge |
| Anaerobic bench-scale test                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  | <17 % VS reduction                                            | On anaerobic digested sludge |
| Aerobic bench-scale test                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                    | <15 % VS reduction                                            | On aerobic digested sludge   |
| Aerobic Process                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                             | >14 days, Temp >40°C and Avg. Temp > 45°C                     | On composted sludge          |
| pH adjustment                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                               | >12 S.U. (for 2 hours) and >11.5 (for an additional 22 hours) | During the process           |
| Drying without primary solids                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                               | >75 % TS                                                      | When applied or bagged       |
| Drying with primary solids                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  | >90 % TS                                                      | When applied or bagged       |
| Equivalent Process                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                          | Approved by the Department                                    | Varies with process          |
| Injection                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   | -                                                             | When applied                 |

**List 4**

**VECTOR ATTRACTION REDUCTION**

The permittee shall implement any one of the vector attraction reduction options specified in List 4. The Department shall be notified of the option utilized and shall be notified when the permittee decides to utilize an alternative option.

For Class A sludge, the vector attraction reduction shall be satisfied at the same times or after the Class A sludge treatment process including at the time of land application. For EQ sludge, the vector attraction reduction (volatile solids reduction) shall be satisfied at the same time or after the Class A sludge treatment process, but does not include vector attraction reduction options incorporation or injection.

| Option        | Limit | Where/When it Shall be Met    |
|---------------|-------|-------------------------------|
| Incorporation | -     | Within 6 hours of application |

**4.2.1.7 Daily Land Application Log**

| Daily Land Application Log                                                                                                                                                                                                                                                                                                                   |                                              |                  |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------|------------------|
| Discharge Monitoring Requirements and Limitations                                                                                                                                                                                                                                                                                            |                                              |                  |
| The permittee shall maintain a daily land application log for biosolids land applied each day when land application occurs. The following minimum records must be kept, in addition to all analytical results for the biosolids land applied. The log book records shall form the basis for the annual land application report requirements. |                                              |                  |
| Parameters                                                                                                                                                                                                                                                                                                                                   | Units                                        | Sample Frequency |
| DNR Site Number(s)                                                                                                                                                                                                                                                                                                                           | Number                                       | Daily as used    |
| Outfall number applied                                                                                                                                                                                                                                                                                                                       | Number                                       | Daily as used    |
| Acres applied                                                                                                                                                                                                                                                                                                                                | Acres                                        | Daily as used    |
| Amount applied                                                                                                                                                                                                                                                                                                                               | As appropriate * /day                        | Daily as used    |
| Application rate per acre                                                                                                                                                                                                                                                                                                                    | unit */acre                                  | Daily as used    |
| Nitrogen applied per acre                                                                                                                                                                                                                                                                                                                    | lb/acre                                      | Daily as used    |
| Method of Application                                                                                                                                                                                                                                                                                                                        | Injection, Incorporation, or surface applied | Daily as used    |

\*gallons, cubic yards, dry US Tons or dry Metric Tons

**4.2.1.8 Sludge Monitoring for PFAS**

Sampling shall occur for perfluoroalkyl and polyfluoroalkyl compounds (PFAS) listed in the table below and as indicated in sampling point sections above. Monitoring shall occur at each sample point when sludge is generated regardless of the end use (i.e. land applied, hauled to another facility, landfilled).

| PERFLUOROALKYLCARBOXYLIC Acids (PFCAs) |                          |
|----------------------------------------|--------------------------|
| PFBA                                   | Perfluorobutanoic acid   |
| PFPeA                                  | Perfluroropentanoic acid |
| PFHxA                                  | Perfluorohexanoic acid   |

|                                                           |                                                     |
|-----------------------------------------------------------|-----------------------------------------------------|
| PFHpA                                                     | Perfluoroheptanoic acid                             |
| PFOA                                                      | Perfluorooctanoic acid                              |
| PFNA                                                      | Perfluorononanoic acid                              |
| PFDA                                                      | Perfluorodecanoic acid                              |
| PFUnA                                                     | Perfluroundecanoic acid                             |
| PFDoA                                                     | Perfluorododecanoic acid                            |
| PFTTrDA                                                   | Perfluorotridecanoic acid                           |
| PFTeDA                                                    | Perfluorotetradecanoic acid                         |
| <b>PERFLUOROALKYLSULFONIC Acids (PFSAs)</b>               |                                                     |
| PFBS                                                      | Perfluorobutane sulfonic acid                       |
| PFPeS                                                     | Perfluroropentane sulfonic acid                     |
| PFHxS                                                     | Perfluorohexane sulfonic acid                       |
| PFHpS                                                     | Perfluoroheptane sulfonic acid                      |
| PFOS                                                      | Perfluorooctane sulfonic acid                       |
| PFNS                                                      | Perfluorononane sulfonic acid                       |
| PFDS                                                      | Perfluorodecane sulfonic acid                       |
| PFDoS                                                     | Perfluorododecane sulfonic acid                     |
| <b>TELOMER SULFONIC Acids</b>                             |                                                     |
| 4:2FTSA                                                   | <i>1H,1H,2H,2H</i> -Perfluorohexane sulfonic acid   |
| 6:2FTSA                                                   | <i>1H,1H,2H,2H</i> -Perfluorooctane sulfonic acid   |
| 8:2FTSA                                                   | <i>1H,1H,2H,2H</i> -Perfluorodecane sulfonic acid   |
| <b>PERFLUOROOCTANCESULFONAMIDES (FOSAs)</b>               |                                                     |
| PFOSA                                                     | Perfluroroctane sulfonamide                         |
| NMeFOSA                                                   | N-Methyl perfluoroocatane sulfonamide               |
| NEtFOSA                                                   | N-Ethyl perfluorooctane sulfonamide                 |
| <b>PERFLUOROOCTANCESULFONAMIDOACETIC Acids</b>            |                                                     |
| NMeFOSAA                                                  | N-Methyl perfluoroocatane sulfonamidoacetic acid    |
| NEtFOSAA                                                  | N-Ethyl perfluorooctane sulfonamidoacetic acid      |
| <b>NATIVE PERFLUOROOCTANCESULFONAMIDOETHANOLS (FOSEs)</b> |                                                     |
| NMeFOSE                                                   | N-Methyl perfluorooctane sulfonamideoethanol        |
| NEtFOSE                                                   | N-Ethyl perfluorooctane sulfonamideoethanol         |
| <b>PERFLUOROALKYLETHERCARBOXYLIC Acids (PFECAs)</b>       |                                                     |
| HFPO-DA                                                   | Hexafluoropropylene oxide dimer acid                |
| ADONA                                                     | 4,8-dioxa-3 <i>H</i> -perfluorononanoic acid        |
| PFMPA                                                     | Perfluoro-3-methoxypropanoic acid                   |
| PFMBA                                                     | Perfluoro-4-methoxybutanoic acid                    |
| NFDHA                                                     | Nonafluoro-3,6-dioxaheptaoc acid                    |
| <b>CHLORO-PERFLUOROALKYLSULFONATE</b>                     |                                                     |
| 9Cl-PF3ONS                                                | 9-chloroehexadecafluoro-3-oxanone-1-sulfonic acid   |
| 11Cl-PF3OUdS                                              | 11-chloroelcosafluoro-3-oxaundecane-1-sulfonic acid |
| PFEESA                                                    | Perfluroro(2-ethoxyethane)sulfonic acid             |
| <b>TELOMER SULFONIC Acids</b>                             |                                                     |

|         |                                    |
|---------|------------------------------------|
| 3:3FTCA | 3-Perfluoropropyl propanoic acid   |
| 5:3FTCA | 2H,2H,3H,3H-Perfluorooctanoic acid |
| 7:3FTCA | 3-Perfluoroheptyl propanoic acid   |

Note: If WDNR Lab Certification removes a particular compound from the reporting list above and upon receiving written communication from the department, reporting for that compound is no longer required.

#### 4.2.1.9 Sampling and Reporting Sludge Samples for PFAS

Representative sludge samples shall be collected at each sample point as listed. At minimum, liquid sludge storage/digesters should be thoroughly mixed prior to sampling. Cake sludge samples should consist of seven equal size discrete samples and be collected from different areas and depths then composited into one sample for laboratory analysis.

Note: If additional equipment is used for collecting sludge samples (i.e., shovels, compositing buckets, bottles, etc.), then a one-time equipment blank is recommended to be collected with the first sample. An equipment blank sample is collected by passing laboratory verified PFAS-free water over or through field sampling equipment before the collection of a representative sludge sample. The equipment blank result shall be reported on the annual Sludge Characteristics Form (3400-049) in the comment section when reporting PFAS concentrations in the sludge.

The permittee shall report each of the PFAS sludge monitoring results on the annual Sludge Characteristics and Monitoring Form (3400-049) as provided by the department. The permittee shall also report the summation of PFOS and PFOA on this same form. All results shall be reported in dry weight. The annual Sludge Characteristics and Monitoring Form (3400-049) are due January 31, of the year following the collection of the sludge samples.

The laboratory performing the analysis on any samples shall be certified for the applicable PFAS compounds in the solids matrix by the Wisconsin Laboratory Certification Program established under s. 299.11, Wis. Stats., and in accordance with s. NR 149.41, Wis. Adm. Code. The department may reject any sample results if results are produced by a laboratory that is not in compliance with certification requirements under ch. NR 149, Wis. Adm. Code.

#### 4.2.1.10 PFAS Land Application Requirements

The department recommends the landspreading and/or land application of sludge be done in a manner consistent with the most recent version of the “Interim Strategy for Land Application of Biosolids and Industrial Sludges containing PFAS”.

#### 4.2.2 Sampling Point (Outfall) 012 - Class A Liquid Sludge

| Monitoring Requirements and Limitations |            |                 |                  |             |       |
|-----------------------------------------|------------|-----------------|------------------|-------------|-------|
| Parameter                               | Limit Type | Limit and Units | Sample Frequency | Sample Type | Notes |
| Solids, Total                           |            | Percent         | Quarterly        | Composite   |       |

| Other Sludge Requirements                                                                                                                                                                                                                                                                                                                                                                                                                                                                      |                  |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------|
| Sludge Requirements                                                                                                                                                                                                                                                                                                                                                                                                                                                                            | Sample Frequency |
| <b>List 3 Requirements – Pathogen Control:</b> The requirements in List 3 shall be met prior to land application or EQ distribution of sludge.                                                                                                                                                                                                                                                                                                                                                 | <b>Quarterly</b> |
| <b>List 4 Requirements – Vector Attraction Reduction:</b> For Class A sludge, the vector attraction reduction shall be satisfied at the same times or after the Class A sludge treatment process including at the time of land application. For EQ sludge, the vector attraction reduction (volatile solids reduction) shall be satisfied at the same time or after the Class A sludge treatment process, but does not include vector attraction reduction options incorporation or injection. | <b>Quarterly</b> |

#### 4.2.2.1 Changes in Feed Sludge Characteristics

If a change in feed sludge characteristics, treatment process, or operational procedures occurs which may result in a significant shift in sludge characteristics, the permittee shall reanalyze the sludge for List 1, 2, 3 and 4 parameters each time such change occurs.

#### 4.2.2.2 Multiple Sludge Sample Points (Outfalls)

If there are multiple sludge sample points (outfalls), but the sludges are not subject to different sludge treatment processes, then a separate List 2 analysis shall be conducted for each sludge type which is land applied, just prior to land application, and the application rate shall be calculated for each sludge type. In this case, List 1, 3, and 4 and PCBs need only be analyzed on a single sludge type, at the specified frequency. If there are multiple sludge sample points (outfalls), due to multiple treatment processes, List 1, 2, 3 and 4 and PCBs shall be analyzed for each sludge type at the specified frequency.

#### 4.2.2.3 Lists 3 & 4

| List 3<br>PATHOGEN CONTROL FOR CLASS A SLUDGE                                                                                                                                                                                   |                                                 |       |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------|-------|
| The permittee shall implement pathogen control as listed in List 3. The Department shall be notified of the pathogen control utilized and shall be notified when the permittee decides to utilize alternative pathogen control. |                                                 |       |
| The following requirements shall be met prior to land application or EQ distribution of sludge.                                                                                                                                 |                                                 |       |
| Parameter                                                                                                                                                                                                                       | Unit                                            | Limit |
| Fecal Coliform*                                                                                                                                                                                                                 | MPN/gTS                                         | 1000  |
| <b>OR</b>                                                                                                                                                                                                                       |                                                 |       |
| Salmonella                                                                                                                                                                                                                      | MPN/4gTS                                        | 3     |
| <b>AND, ONE OF THE FOLLOWING PROCESS OPTIONS</b>                                                                                                                                                                                |                                                 |       |
| Temp/Time based on % Solids                                                                                                                                                                                                     | Alkaline Treatment                              |       |
| Prior test for Enteric Virus/Viable Helminth Ova                                                                                                                                                                                | Post test for Enteric Virus/Viable Helminth Ova |       |
| Composting                                                                                                                                                                                                                      | Heat Drying                                     |       |
| Heat Treatment                                                                                                                                                                                                                  | Thermophilic Aerobic Digestion                  |       |
| Beta Ray Irradiation                                                                                                                                                                                                            | Gamma Ray Irradiation                           |       |
| Pasteurization                                                                                                                                                                                                                  | PFRP Equivalent Process                         |       |

**List 3**

**PATHOGEN CONTROL FOR CLASS A SLUDGE**

The permittee shall implement pathogen control as listed in List 3. The Department shall be notified of the pathogen control utilized and shall be notified when the permittee decides to utilize alternative pathogen control.

The following requirements shall be met prior to land application or EQ distribution of sludge.

| Parameter       | Unit    | Limit |
|-----------------|---------|-------|
| Fecal Coliform* | MPN/gTS | 1000  |

\* The Fecal Coliform limit shall be reported as 7 discrete samples on a dry weight basis.

**List 4**

**VECTOR ATTRACTION REDUCTION**

The permittee shall implement any one of the vector attraction reduction options specified in List 4. The Department shall be notified of the option utilized and shall be notified when the permittee decides to utilize an alternative option.

For Class A sludge, the vector attraction reduction shall be satisfied at the same times or after the Class A sludge treatment process including at the time of land application. For EQ sludge, the vector attraction reduction (volatile solids reduction) shall be satisfied at the same time or after the Class A sludge treatment process, but does not include vector attraction reduction options incorporation or injection.

| Option                        | Limit                                                               | Where/When it Shall be Met    |
|-------------------------------|---------------------------------------------------------------------|-------------------------------|
| Volatile Solids Reduction     | ≥38%                                                                | Across the process            |
| Specific Oxygen Uptake Rate   | ≤1.5 mg O <sub>2</sub> /hr/g TS                                     | On aerobic stabilized sludge  |
| Anaerobic bench-scale test    | <17 % VS reduction                                                  | On anaerobic digested sludge  |
| Aerobic bench-scale test      | <15 % VS reduction                                                  | On aerobic digested sludge    |
| Aerobic Process               | >14 days, Temp >40°C and<br>Avg. Temp > 45°C                        | On composted sludge           |
| pH adjustment                 | >12 S.U. (for 2 hours)<br>and >11.5<br>(for an additional 22 hours) | During the process            |
| Drying without primary solids | >75 % TS                                                            | When applied or bagged        |
| Drying with primary solids    | >90 % TS                                                            | When applied or bagged        |
| Equivalent Process            | Approved by the Department                                          | Varies with process           |
| Injection                     | -                                                                   | When applied                  |
| Incorporation                 | -                                                                   | Within 6 hours of application |

#### 4.2.2.4 Daily Land Application Log

| Daily Land Application Log                                                                                                                                                                                                                                                                                                                   |                                              |                  |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------|------------------|
| Discharge Monitoring Requirements and Limitations                                                                                                                                                                                                                                                                                            |                                              |                  |
| The permittee shall maintain a daily land application log for biosolids land applied each day when land application occurs. The following minimum records must be kept, in addition to all analytical results for the biosolids land applied. The log book records shall form the basis for the annual land application report requirements. |                                              |                  |
| Parameters                                                                                                                                                                                                                                                                                                                                   | Units                                        | Sample Frequency |
| DNR Site Number(s)                                                                                                                                                                                                                                                                                                                           | Number                                       | Daily as used    |
| Outfall number applied                                                                                                                                                                                                                                                                                                                       | Number                                       | Daily as used    |
| Acres applied                                                                                                                                                                                                                                                                                                                                | Acres                                        | Daily as used    |
| Amount applied                                                                                                                                                                                                                                                                                                                               | As appropriate * /day                        | Daily as used    |
| Application rate per acre                                                                                                                                                                                                                                                                                                                    | unit */acre                                  | Daily as used    |
| Nitrogen applied per acre                                                                                                                                                                                                                                                                                                                    | lb/acre                                      | Daily as used    |
| Method of Application                                                                                                                                                                                                                                                                                                                        | Injection, Incorporation, or surface applied | Daily as used    |

\*gallons, cubic yards, dry US Tons or dry Metric Tons

#### 4.2.3 Sampling Point (Outfall) 011 - In-Plant Pre-VSR Liquid Sludge

| Monitoring Requirements and Limitations |            |                 |                  |             |       |
|-----------------------------------------|------------|-----------------|------------------|-------------|-------|
| Parameter                               | Limit Type | Limit and Units | Sample Frequency | Sample Type | Notes |
| Solids, Total                           |            | Percent         | Quarterly        | Composite   |       |

#### 4.2.4 Sampling Point (Outfall) 008 - Class B Liquid Sludge

| Monitoring Requirements and Limitations |              |                 |                  |             |       |
|-----------------------------------------|--------------|-----------------|------------------|-------------|-------|
| Parameter                               | Limit Type   | Limit and Units | Sample Frequency | Sample Type | Notes |
| Solids, Total                           |              | Percent         | Quarterly        | Composite   |       |
| Arsenic Dry Wt                          | Ceiling      | 75 mg/kg        | Quarterly        | Composite   |       |
| Arsenic Dry Wt                          | High Quality | 41 mg/kg        | Quarterly        | Composite   |       |
| Cadmium Dry Wt                          | Ceiling      | 85 mg/kg        | Quarterly        | Composite   |       |
| Cadmium Dry Wt                          | High Quality | 39 mg/kg        | Quarterly        | Composite   |       |
| Copper Dry Wt                           | Ceiling      | 4,300 mg/kg     | Quarterly        | Composite   |       |
| Copper Dry Wt                           | High Quality | 1,500 mg/kg     | Quarterly        | Composite   |       |

| Monitoring Requirements and Limitations       |              |                 |                  |             |                                                        |
|-----------------------------------------------|--------------|-----------------|------------------|-------------|--------------------------------------------------------|
| Parameter                                     | Limit Type   | Limit and Units | Sample Frequency | Sample Type | Notes                                                  |
| Lead Dry Wt                                   | Ceiling      | 840 mg/kg       | Quarterly        | Composite   |                                                        |
| Lead Dry Wt                                   | High Quality | 300 mg/kg       | Quarterly        | Composite   |                                                        |
| Mercury Dry Wt                                | Ceiling      | 57 mg/kg        | Quarterly        | Composite   |                                                        |
| Mercury Dry Wt                                | High Quality | 17 mg/kg        | Quarterly        | Composite   |                                                        |
| Molybdenum Dry Wt                             | Ceiling      | 75 mg/kg        | Quarterly        | Composite   |                                                        |
| Nickel Dry Wt                                 | Ceiling      | 420 mg/kg       | Quarterly        | Composite   |                                                        |
| Nickel Dry Wt                                 | High Quality | 420 mg/kg       | Quarterly        | Composite   |                                                        |
| Selenium Dry Wt                               | Ceiling      | 100 mg/kg       | Quarterly        | Composite   |                                                        |
| Selenium Dry Wt                               | High Quality | 100 mg/kg       | Quarterly        | Composite   |                                                        |
| Zinc Dry Wt                                   | Ceiling      | 7,500 mg/kg     | Quarterly        | Composite   |                                                        |
| Zinc Dry Wt                                   | High Quality | 2,800 mg/kg     | Quarterly        | Composite   |                                                        |
| Nitrogen, Total Kjeldahl                      |              | Percent         | Quarterly        | Composite   | Required in quarters in which land application occurs. |
| Nitrogen, Ammonium (NH <sub>4</sub> -N) Total |              | Percent         | Quarterly        | Composite   | Required in quarters in which land application occurs. |
| Phosphorus, Total                             |              | Percent         | Quarterly        | Composite   | Required in quarters in which land application occurs. |
| Phosphorus, Water Extractable                 |              | % of Tot P      | Quarterly        | Composite   | Required in quarters in which land application occurs. |
| Potassium, Total Recoverable                  |              | Percent         | Quarterly        | Composite   | Required in quarters in which land application occurs. |

| Other Sludge Requirements                                                                                                                                                         |                  |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------|
| Sludge Requirements                                                                                                                                                               | Sample Frequency |
| <b>List 3 Requirements – Pathogen Control:</b> The requirements in List 3 shall be met prior to land application of sludge.                                                       | <b>Quarterly</b> |
| <b>List 4 Requirements – Vector Attraction Reduction:</b> The vector attraction reduction shall be satisfied prior to, or at the time of land application as specified in List 4. | <b>Quarterly</b> |

#### 4.2.4.1 List 2 Analysis

If the monitoring frequency for List 2 parameters is more frequent than "Annual" then the sludge may be analyzed for the List 2 parameters just prior to each land application season rather than at the more frequent interval specified.

#### 4.2.4.2 Changes in Feed Sludge Characteristics

If a change in feed sludge characteristics, treatment process, or operational procedures occurs which may result in a significant shift in sludge characteristics, the permittee shall reanalyze the sludge for List 1, 2, 3 and 4 parameters each time such change occurs.

#### 4.2.4.3 Multiple Sludge Sample Points (Outfalls)

If there are multiple sludge sample points (outfalls), but the sludges are not subject to different sludge treatment processes, then a separate List 2 analysis shall be conducted for each sludge type which is land applied, just prior to land application, and the application rate shall be calculated for each sludge type. In this case, List 1, 3, and 4 and PCBs need only be analyzed on a single sludge type, at the specified frequency. If there are multiple sludge sample points (outfalls), due to multiple treatment processes, List 1, 2, 3 and 4 and PCBs shall be analyzed for each sludge type at the specified frequency.

#### 4.2.4.4 Sludge Which Exceeds the High Quality Limit

Cumulative pollutant loading records shall be kept for all bulk land application of sludge which does not meet the high quality limit for any parameter. This requirement applies for the entire calendar year in which any exceedance of Table 3 of s. NR 204.07(5)(c), Wis. Adm. Code, is experienced. Such loading records shall be kept for all List 1 parameters for each site land applied in that calendar year. The formula to be used for calculating cumulative loading is as follows:

$$[(\text{Pollutant concentration (mg/kg)} \times \text{dry tons applied/ac}) \div 500] + \text{previous loading (lbs/acre)} = \text{cumulative lbs pollutant per acre}$$

When a site reaches 90% of the allowable cumulative loading for any metal established in Table 2 of s. NR 204.07(5)(b), Wis. Adm. Code, the Department shall be so notified through letter or in the comment section of the annual land application report (3400-55).

#### 4.2.4.5 Sludge Analysis for PCBs

The permittee shall analyze the sludge for Total PCBs one time during **2026**. The results shall be reported as "PCB Total Dry Wt". Either congener-specific analysis or Aroclor analysis shall be used to determine the PCB concentration. The permittee may determine whether Aroclor or congener specific analysis is performed. Analyses shall be performed in accordance with Table EM in s. NR 219.04, Wis. Adm. Code and the conditions specified in Standard Requirements of this permit. PCB results shall be submitted by January 31, following the specified year of analysis.

#### 4.2.4.6 Lists 1, 2, 3, and 4

| <b>List 1</b><br><b>TOTAL SOLIDS AND METALS</b>                                                                                |  |
|--------------------------------------------------------------------------------------------------------------------------------|--|
| See the Monitoring Requirements and Limitations table above for monitoring frequency and limitations for the List 1 parameters |  |
| Solids, Total (percent)                                                                                                        |  |
| Arsenic, mg/kg (dry weight)                                                                                                    |  |
| Cadmium, mg/kg (dry weight)                                                                                                    |  |

| <b>List 1</b><br><b>TOTAL SOLIDS AND METALS</b><br>See the Monitoring Requirements and Limitations table above for monitoring frequency and limitations for the List 1 parameters |  |  |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--|--|
| Copper, mg/kg (dry weight)                                                                                                                                                        |  |  |
| Lead, mg/kg (dry weight)                                                                                                                                                          |  |  |
| Mercury, mg/kg (dry weight)                                                                                                                                                       |  |  |
| Molybdenum, mg/kg (dry weight)                                                                                                                                                    |  |  |
| Nickel, mg/kg (dry weight)                                                                                                                                                        |  |  |
| Selenium, mg/kg (dry weight)                                                                                                                                                      |  |  |
| Zinc, mg/kg (dry weight)                                                                                                                                                          |  |  |

| <b>List 2</b><br><b>NUTRIENTS</b><br>See the Monitoring Requirements and Limitations table above for monitoring frequency for the List 2 parameters |  |  |
|-----------------------------------------------------------------------------------------------------------------------------------------------------|--|--|
| Solids, Total (percent)                                                                                                                             |  |  |
| Nitrogen Total Kjeldahl (percent)                                                                                                                   |  |  |
| Nitrogen Ammonium (NH <sub>4</sub> -N) Total (percent)                                                                                              |  |  |
| Phosphorus Total as P (percent)                                                                                                                     |  |  |
| Phosphorus, Water Extractable (as percent of Total P)                                                                                               |  |  |
| Potassium Total Recoverable (percent)                                                                                                               |  |  |

| <b>List 3</b><br><b>PATHOGEN CONTROL FOR CLASS B SLUDGE</b><br>The permittee shall implement pathogen control as listed in List 3. The Department shall be notified of the pathogen control utilized and shall be notified when the permittee decides to utilize alternative pathogen control.<br>The following requirements shall be met prior to land application of sludge. |                       |                         |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------|-------------------------|
| Parameter                                                                                                                                                                                                                                                                                                                                                                      | Unit                  | Limit                   |
| Fecal Coliform*                                                                                                                                                                                                                                                                                                                                                                | MPN/gTS or<br>CFU/gTS | 2,000,000               |
| <b>OR, ONE OF THE FOLLOWING PROCESS OPTIONS</b>                                                                                                                                                                                                                                                                                                                                |                       |                         |
| Aerobic Digestion                                                                                                                                                                                                                                                                                                                                                              |                       | Air Drying              |
| Anaerobic Digestion                                                                                                                                                                                                                                                                                                                                                            |                       | Composting              |
| Alkaline Stabilization                                                                                                                                                                                                                                                                                                                                                         |                       | PSRP Equivalent Process |
| * The Fecal Coliform limit shall be reported as the geometric mean of 7 discrete samples on a dry weight basis.                                                                                                                                                                                                                                                                |                       |                         |

| <b>List 4</b><br><b>VECTOR ATTRACTION REDUCTION</b><br>The permittee shall implement any one of the vector attraction reduction options specified in List 4. The Department shall be notified of the option utilized and shall be notified when the permittee decides to utilize an alternative option.<br>One of the following shall be satisfied prior to, or at the time of land application as specified in List 4. |                                 |                              |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------|------------------------------|
| Option                                                                                                                                                                                                                                                                                                                                                                                                                  | Limit                           | Where/When it Shall be Met   |
| Volatile Solids Reduction                                                                                                                                                                                                                                                                                                                                                                                               | ≥38%                            | Across the process           |
| Specific Oxygen Uptake Rate                                                                                                                                                                                                                                                                                                                                                                                             | ≤1.5 mg O <sub>2</sub> /hr/g TS | On aerobic stabilized sludge |

| <p style="text-align: center;"><b>List 4</b><br/><b>VECTOR ATTRACTION REDUCTION</b></p> <p>The permittee shall implement any one of the vector attraction reduction options specified in List 4. The Department shall be notified of the option utilized and shall be notified when the permittee decides to utilize an alternative option.</p> <p>One of the following shall be satisfied prior to, or at the time of land application as specified in List 4.</p> |                                                                     |                                   |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------|-----------------------------------|
| <b>Option</b>                                                                                                                                                                                                                                                                                                                                                                                                                                                       | <b>Limit</b>                                                        | <b>Where/When it Shall be Met</b> |
| Anaerobic bench-scale test                                                                                                                                                                                                                                                                                                                                                                                                                                          | <17 % VS reduction                                                  | On anaerobic digested sludge      |
| Aerobic bench-scale test                                                                                                                                                                                                                                                                                                                                                                                                                                            | <15 % VS reduction                                                  | On aerobic digested sludge        |
| Aerobic Process                                                                                                                                                                                                                                                                                                                                                                                                                                                     | >14 days, Temp >40°C and<br>Avg. Temp > 45°C                        | On composted sludge               |
| pH adjustment                                                                                                                                                                                                                                                                                                                                                                                                                                                       | >12 S.U. (for 2 hours)<br>and >11.5<br>(for an additional 22 hours) | During the process                |
| Drying without primary solids                                                                                                                                                                                                                                                                                                                                                                                                                                       | >75 % TS                                                            | When applied or bagged            |
| Drying with primary solids                                                                                                                                                                                                                                                                                                                                                                                                                                          | >90 % TS                                                            | When applied or bagged            |
| Equivalent Process                                                                                                                                                                                                                                                                                                                                                                                                                                                  | Approved by the Department                                          | Varies with process               |
| Injection                                                                                                                                                                                                                                                                                                                                                                                                                                                           | -                                                                   | When applied                      |
| Incorporation                                                                                                                                                                                                                                                                                                                                                                                                                                                       | -                                                                   | Within 6 hours of application     |

#### 4.2.4.7 Daily Land Application Log

| <b>Daily Land Application Log</b>                                                                                                                                                                                                                                                                                                                   |                                              |                         |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------|-------------------------|
| <b>Discharge Monitoring Requirements and Limitations</b>                                                                                                                                                                                                                                                                                            |                                              |                         |
| <p>The permittee shall maintain a daily land application log for biosolids land applied each day when land application occurs. The following minimum records must be kept, in addition to all analytical results for the biosolids land applied. The log book records shall form the basis for the annual land application report requirements.</p> |                                              |                         |
| <b>Parameters</b>                                                                                                                                                                                                                                                                                                                                   | <b>Units</b>                                 | <b>Sample Frequency</b> |
| DNR Site Number(s)                                                                                                                                                                                                                                                                                                                                  | Number                                       | Daily as used           |
| Outfall number applied                                                                                                                                                                                                                                                                                                                              | Number                                       | Daily as used           |
| Acres applied                                                                                                                                                                                                                                                                                                                                       | Acres                                        | Daily as used           |
| Amount applied                                                                                                                                                                                                                                                                                                                                      | As appropriate * /day                        | Daily as used           |
| Application rate per acre                                                                                                                                                                                                                                                                                                                           | unit */acre                                  | Daily as used           |
| Nitrogen applied per acre                                                                                                                                                                                                                                                                                                                           | lb/acre                                      | Daily as used           |
| Method of Application                                                                                                                                                                                                                                                                                                                               | Injection, Incorporation, or surface applied | Daily as used           |

\*gallons, cubic yards, dry US Tons or dry Metric Tons

#### 4.2.4.8 Sludge Monitoring for PFAS

Sampling shall occur for perfluoroalkyl and polyfluoroalkyl compounds (PFAS) listed in the table below and as indicated in sampling point sections above. Monitoring shall occur at each sample point when sludge is generated regardless of the end use (i.e. land applied, hauled to another facility, landfilled).

| <b>PERFLUOROALKYLCARBOXYLIC Acids (PFCAs)</b>              |                                                 |
|------------------------------------------------------------|-------------------------------------------------|
| PFBA                                                       | Perfluorobutanoic acid                          |
| PFPeA                                                      | Perfluoropentanoic acid                         |
| PFHxA                                                      | Perfluorohexanoic acid                          |
| PFHpA                                                      | Perfluoroheptanoic acid                         |
| PFOA                                                       | Perfluorooctanoic acid                          |
| PFNA                                                       | Perfluorononanoic acid                          |
| PFDA                                                       | Perfluorodecanoic acid                          |
| PFUnA                                                      | Perfluoroundecanoic acid                        |
| PFDoA                                                      | Perfluorododecanoic acid                        |
| PFTTrDA                                                    | Perfluorotridecanoic acid                       |
| PFTeDA                                                     | Perfluorotetradecanoic acid                     |
| <b>PERFLUOROALKYLSULFONIC Acids (PFSA's)</b>               |                                                 |
| PFBS                                                       | Perfluorobutane sulfonic acid                   |
| PFPeS                                                      | Perfluoropentane sulfonic acid                  |
| PFHxS                                                      | Perfluorohexane sulfonic acid                   |
| PFHpS                                                      | Perfluoroheptane sulfonic acid                  |
| PFOS                                                       | Perfluorooctane sulfonic acid                   |
| PFNS                                                       | Perfluorononane sulfonic acid                   |
| PFDS                                                       | Perfluorodecane sulfonic acid                   |
| PFDoS                                                      | Perfluorododecane sulfonic acid                 |
| <b>TELOMER SULFONIC Acids</b>                              |                                                 |
| 4:2FTSA                                                    | 1H,1H,2H,2H-Perfluorohexane sulfonic acid       |
| 6:2FTSA                                                    | 1H,1H,2H,2H-Perfluorooctane sulfonic acid       |
| 8:2FTSA                                                    | 1H,1H,2H,2H-Perfluorodecane sulfonic acid       |
| <b>PERFLUOROOCTANCESULFONAMIDES (FOSA's)</b>               |                                                 |
| PFOSA                                                      | Perfluorooctane sulfonamide                     |
| NMeFOSA                                                    | N-Methyl perfluorooctane sulfonamide            |
| NEtFOSA                                                    | N-Ethyl perfluorooctane sulfonamide             |
| <b>PERFLUOROOCTANCESULFONAMIDOACETIC Acids</b>             |                                                 |
| NMeFOSAA                                                   | N-Methyl perfluorooctane sulfonamidoacetic acid |
| NEtFOSAA                                                   | N-Ethyl perfluorooctane sulfonamidoacetic acid  |
| <b>NATIVE PERFLUOROOCTANCESULFONAMIDOETHANOLS (FOSE's)</b> |                                                 |
| NMeFOSE                                                    | N-Methyl perfluorooctane sulfonamidoethanol     |
| NEtFOSE                                                    | N-Ethyl perfluorooctane sulfonamidoethanol      |
| <b>PERFLUOROALKYLETHERCARBOXYLIC Acids (PFECAs)</b>        |                                                 |
| HFPO-DA                                                    | Hexafluoropropylene oxide dimer acid            |

|                                       |                                                                        |
|---------------------------------------|------------------------------------------------------------------------|
| ADONA                                 | 4,8-dioxa-3 <i>H</i> -perfluorononanoic acid                           |
| PFMPA                                 | Perfluoro-3-methoxypropanoic acid                                      |
| PFMBA                                 | Perfluoro-4-methoxybutanoic acid                                       |
| NFDHA                                 | Nonafluoro-3,6-dioxaheptaioic acid                                     |
| <b>CHLORO-PERFLUOROALKYLSULFONATE</b> |                                                                        |
| 9Cl-PF3ONS                            | 9-chlorohexadecafluoro-3-oxanone-1-sulfonic acid                       |
| 11Cl-PF3OUdS                          | 11-chloroelcosafluoro-3-oxaundecane-1-sulfonic acid                    |
| PFEESA                                | Perfluoro(2-ethoxyethane)sulfonic acid                                 |
| <b>TELOMER SULFONIC Acids</b>         |                                                                        |
| 3:3FTCA                               | 3-Perfluoropropyl propanoic acid                                       |
| 5:3FTCA                               | 2 <i>H</i> ,2 <i>H</i> ,3 <i>H</i> ,3 <i>H</i> -Perfluorooctanoic acid |
| 7:3FTCA                               | 3-Perfluoroheptyl propanoic acid                                       |

Note: If WDNR Lab Certification removes a particular compound from the reporting list above and upon receiving written communication from the department, reporting for that compound is no longer required.

#### 4.2.4.9 Sampling and Reporting Sludge Samples for PFAS

Representative sludge samples shall be collected at each sample point as listed. At minimum, liquid sludge storage/digesters should be thoroughly mixed prior to sampling. Cake sludge samples should consist of seven equal size discrete samples and be collected from different areas and depths then composited into one sample for laboratory analysis.

Note: If additional equipment is used for collecting sludge samples (i.e., shovels, compositing buckets, bottles, etc.), then a one-time equipment blank is recommended to be collected with the first sample. An equipment blank sample is collected by passing laboratory verified PFAS-free water over or through field sampling equipment before the collection of a representative sludge sample. The equipment blank result shall be reported on the annual Sludge Characteristics Form (3400-049) in the comment section when reporting PFAS concentrations in the sludge.

The permittee shall report each of the PFAS sludge monitoring results on the annual Sludge Characteristics and Monitoring Form (3400-049) as provided by the department. The permittee shall also report the summation of PFOS and PFOA on this same form. All results shall be reported in dry weight. The annual Sludge Characteristics and Monitoring Form (3400-049) are due January 31, of the year following the collection of the sludge samples.

The laboratory performing the analysis on any samples shall be certified for the applicable PFAS compounds in the solids matrix by the Wisconsin Laboratory Certification Program established under s. 299.11, Wis. Stats., and in accordance with s. NR 149.41, Wis. Adm. Code. The department may reject any sample results if results are produced by a laboratory that is not in compliance with certification requirements under ch. NR 149, Wis. Adm. Code.

#### 4.2.4.10 PFAS Land Application Requirements

The department recommends the landspreading and/or land application of sludge be done in a manner consistent with the most recent version of the “Interim Strategy for Land Application of Biosolids and Industrial Sludges containing PFAS”.

## 5 Schedules

### 5.1 Mercury Pollutant Minimization Program

As a condition of the variance to the water quality based effluent limitation(s) for mercury granted in accordance with s. NR 106.145(6), Wis. Adm. Code, the permittee shall perform the following actions.

| Required Action                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                | Due Date   |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------|
| <p><b>Mercury Report:</b> Submit a mercury report. The mercury progress report shall summarize success in maintaining mercury concentrations in the effluent, as well as the anticipated future efforts to maintain mercury concentrating in the effluent.</p> <p>The report shall summarize mercury pollutant minimization activities that have been implemented during the current permit term. The report shall include an analysis of trends in quarterly and annual total effluent mercury concentrations based on mercury sampling during the current permit term. The report shall also include an analysis of how influent and effluent mercury varies with time and with significant loading of mercury such as loads from industries into the collection system.</p> | 12/31/2029 |

### 5.2 PFOS/PFOA Minimization Plan Determination of Need

| Required Action                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                             | Due Date   |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------|
| <p><b>Report on Effluent Discharge:</b> Submit a report on effluent PFOS and PFOA concentrations and include an analysis of trends in monthly and annual average PFOS and PFOA concentrations. This analysis should also include a comparison to the applicable narrative standard in s. NR 102.04(8)(d), Wis. Adm. Code.</p> <p>This report shall include all additional PFOS and PFOA data that may be collected including any influent, intake, in-plant, collection system sampling, and blank sample results.</p>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                      | 01/01/2027 |
| <p><b>Report on Effluent Discharge and Evaluation of Need:</b> Submit a final report on effluent PFOS and PFOA concentrations and include an analysis of trends in monthly and annual average PFOS and PFOA concentrations of data collected over the last 24 months. The report shall also provide a comparison on the likelihood of the facility needing to develop a PFOS/PFOA minimization plan.</p> <p>This report shall include all additional PFOS and PFOA data that may be collected including any influent, intake, in-plant, collection system sampling, and blank sample results.</p> <p>The permittee shall also submit a request to the department to evaluate the need for a PFOS/PFOA minimization plan.</p> <p>If the Department determines a PFOS/PFOA minimization plan is needed based on a reasonable potential evaluation, the permittee will be required to develop a minimization plan for Department approval no later than 90 days after written notification was sent from the Department. The Department will modify or revoke and reissue the permit to include PFOS/PFOA minimization plan reporting requirements along with a schedule of compliance to meet WQBELs. Effluent monitoring of PFOS and PFOA shall continue as specified in the permit until the modified permit is issued.</p> <p>If, however, the Department determines there is no reasonable potential for the facility to discharge PFOS or PFOA above the narrative standard in s. NR 102.04(8)(d), Wis. Adm. Code, no further action is required and effluent monitoring of PFOS and PFOA shall continue as specified in the permit.</p> | 01/01/2028 |

### 5.3 Sludge Management Plan

A sludge management plan is required.

| Required Action                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                    | Due Date   |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------|
| <p><b>Sludge Management Plan Submittal for Class A facilities:</b> Submit a sludge management plan (SMP) to optimize the sludge management performance and demonstrate compliance with Ch. NR 204, Wis. Adm. Code, by the Due Date. This management plan shall include sufficient detail of the sludge management program for the facility. The plan shall include separate sections for each type of sewage sludge included in this permit.</p> <p>The SMP shall provide standardized information for communication to operators and the department including but not limited to the following:</p> <ol style="list-style-type: none"> <li>1) Specify information on the sludge treatment processes for each sampling point and outfall;</li> <li>2) Show and describe sample point and outfall monitoring locations on a schematic and provide photos of the specific sampling points;</li> <li>3) Show, describe and tabulate the monitoring requirements at each sampling point and outfall locations;</li> <li>4) Show, describe and explain sampling protocols for each location listing parameters to be monitored including: <ol style="list-style-type: none"> <li>a) Pollutants,</li> <li>b) Nutrients,</li> <li>c) Pathogen treatment process requirements including treatment temperature, moisture content (total solids) and pathogen densities (fecal concentrations),</li> <li>d) Vector Reduction appropriate for the pathogen treatment process such as but not limited to temperatures, volatile solids reduction, moisture content, etc. as required by the WPDES permit and Ch. NR 204, Wis. Adm. Code;</li> </ol> </li> <li>5) Monitoring frequencies at each sample point and outfall;</li> <li>6) Analytical methods with appropriate hold times and chain of custody procedures;</li> <li>7) Documentation relating to temperature monitoring data recording, retrieval and printing out the data when requested;</li> <li>8) Storage, verification monitoring, loading, transportation and discharge details associated with all outfalls;</li> <li>9) Collection, storage, disposal information for sludge detailing pickups including loading and similar details;</li> <li>10) Collection, storage and disposal processes of sludge when the sludge does not meet minimum requires to meet Class A and EQ requirements. [Note: EQ and Class A are similar, but are different. Explain.]</li> <li>11) Identify land application sites;</li> <li>12) Describe site limitations;</li> <li>13) Address vegetative cover management and removal including loading to crop needs, crop harvesting;</li> <li>14) Specific the availability of storage for sludge;</li> </ol> | 01/01/2027 |

|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                               |  |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--|
| <p>15) Describe the type of transportation and spreading vehicles;</p> <p>16) Track site loadings to facility's land application sites;</p> <p>17) Address contingency plans for adverse weather and odor/nuisance abatement;</p> <p>18) Address construction contingencies when treatment equipment is out of service; and</p> <p>19) Include any other pertinent information.</p> <p>Once approved, all sludge management activities shall be conducted in accordance with the plan. Any changes to the plan must be approved by the department prior to implementing the changes.</p> <p>Note: The SMP is a living document and should be designed and constructed to allow for future updates. Consider providing an overview to explain the facilities solids flow processes, then using sections and appendices to provide more details. The use of appendices to explain start up, operation and shutdown of the sludge treatment units is encouraged to show that all sludge particles meet Class A requirements.</p> |  |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--|

## 6 Standard Requirements

**Chapter NR 205, Wisconsin Administrative Code:** The conditions in ss. NR 205.07(1) and NR 205.07(2), Wis. Adm. Code, are included by reference in this permit. The permittee shall comply with all of these requirements. Some of these requirements are outlined in the Standard Requirements section of this permit. Requirements not specifically outlined in the Standard Requirement section of this permit can be found in ss. NR 205.07(1) and NR 205.07(2), Wis. Adm. Code.

### 6.1 Reporting and Monitoring Requirements

#### 6.1.1 Monitoring Results

Monitoring results obtained during the previous month shall be summarized and reported on a Department Wastewater Discharge Monitoring Report. The report may require reporting of any or all of the information specified below under 'Recording of Results'. This report is to be returned to the Department no later than the date indicated on the form. A copy of the Wastewater Discharge Monitoring Report Form or an electronic file of the report shall be retained by the permittee.

Monitoring results shall be reported on an electronic discharge monitoring report (eDMR). The eDMR shall be certified electronically by a responsible executive or municipal officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The 'eReport Certify' page certifies that the electronic report form is true, accurate and complete.

If the permittee monitors any pollutant more frequently than required by this permit, the results of such monitoring shall be included on the Wastewater Discharge Monitoring Report.

The permittee shall comply with all limits for each parameter regardless of monitoring frequency. For example, monthly, weekly, and/or daily limits shall be met even with monthly monitoring. The permittee may monitor more frequently than required for any parameter.

#### 6.1.2 Sampling and Testing Procedures

Sampling and laboratory testing procedures shall be performed in accordance with Chapters NR 218 and NR 219, Wis. Adm. Code, and completed by a laboratory certified or registered in accordance with the requirements of ch. NR 149, Wis. Adm. Code. Groundwater sampling shall be performed in accordance with procedures contained in s. NR 140.16, Wis. Adm. Code, and the WDNR publications, Groundwater Sampling Desk Reference (PUBL-DG-037-96) and Groundwater Sampling Field Manual (PUBL-DG-038-96). The analytical methodologies used shall enable the laboratory to quantitate all substances for which monitoring is required at levels below the effluent limitation and/or groundwater standard. If the required level cannot be met by any of the methods available in ch. NR 219, Wis. Adm. Code, then the method with the lowest limit of detection shall be selected. Additional test procedures may be specified in this permit.

#### 6.1.3 Recording of Results

The permittee shall maintain records which provide the following information for each effluent measurement or sample taken:

- the date, exact place, method and time of sampling or measurements;
- the individual who performed the sampling or measurements;
- the date the analysis was performed;
- the individual who performed the analysis;
- the analytical techniques or methods used; and
- the results of the analysis.

#### **6.1.4 Reporting of Monitoring Results**

The permittee shall use the following conventions when reporting effluent monitoring results:

- Pollutant concentrations less than the limit of detection shall be reported as < (less than) the value of the limit of detection. For example, if a substance is not detected at a detection limit of 0.1 mg/L, report the pollutant concentration as < 0.1 mg/L.
- Pollutant concentrations equal to or greater than the limit of detection, but less than the limit of quantitation, shall be reported and the limit of quantitation shall be specified.
- For purposes of calculating fees under ch. NR 101, Wis. Adm. Code, a reporting limit of 2.0 mg/L for BOD<sub>5</sub> and 2.5 mg/L Total Suspended Solids shall be considered to be limits of quantitation.
- For the purposes of reporting a calculated result, average or a mass discharge value, the permittee may substitute a "0" (zero) for any pollutant concentration that is less than the limit of detection. However, if the effluent limitation is less than the limit of detection, the department may substitute a value other than zero for results less than the limit of detection, after considering the number of monitoring results that are greater than the limit of detection and if warranted when applying appropriate statistical techniques.
- If no discharge occurs through an outfall, flow related parameters (e.g. flow rate, hydraulic application rate, volume, etc.) should be reported as "0" (zero) at the required sample frequency specified for the outfall. For example: if the sample frequency is daily, "0" would be reported for any day during the month that no discharge occurred.

#### **6.1.5 Compliance Maintenance Annual Reports**

Compliance Maintenance Annual Reports (CMAR) shall be completed using information obtained over each calendar year regarding the wastewater conveyance and treatment system. The CMAR shall be submitted and certified by the permittee in accordance with ch. NR 208, Wis. Adm. Code, by June 30, each year on an electronic report form provided by the Department.

In the case of a publicly owned treatment works, a resolution shall be passed by the governing body and submitted as part of the CMAR, verifying its review of the report and providing responses as required. Private owners of wastewater treatment works are not required to pass a resolution; but they must provide an Owner Statement and responses as required, as part of the CMAR submittal.

The CMAR shall be certified electronically by a responsible executive or municipal officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The certification verifies that the electronic report is true, accurate and complete.

#### **6.1.6 Records Retention**

The permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings or electronic data records for continuous monitoring instrumentation, copies of all reports required by the permit, and records of all data used to complete the application for the permit for a period of at least 3 years from the date of the sample, measurement, report or application. All pertinent sludge information, including permit application information and other documents specified in this permit or s. NR 204.06(9), Wis. Adm. Code shall be retained for a minimum of 5 years.

#### **6.1.7 Other Information**

Where the permittee becomes aware that it failed to submit any relevant facts in a permit application or submitted incorrect information in a permit application or in any report to the Department, it shall promptly submit such facts or correct information to the Department.

#### **6.1.8 Reporting Requirements – Alterations or Additions**

The permittee shall give notice to the Department as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is only required when:

- The alteration or addition to the permitted facility may meet one of the criteria for determining whether a facility is a new source.
- The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification requirement applies to pollutants which are not subject to effluent limitations in the existing permit.
- The alteration or addition results in a significant change in the permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use of disposal sites not reported during the permit application process nor reported pursuant to an approved land application plan. Additional sites may not be used for the land application of sludge until department approval is received.

## 6.2 System Operating Requirements

### 6.2.1 Noncompliance Reporting

Sanitary sewer overflows and sewage treatment facility overflows shall be reported according to the 'Sanitary Sewer Overflows and Sewage Treatment Facility Overflows' section of this permit.

The permittee shall report the following types of noncompliance by a telephone call to the Department's regional office within 24 hours after becoming aware of the noncompliance:

- any noncompliance which may endanger health or the environment;
- any violation of an effluent limitation resulting from a bypass;
- any violation of an effluent limitation resulting from an upset; and
- any violation of a maximum discharge limitation for any of the pollutants listed by the Department in the permit, either for effluent or sludge.

A written report describing the noncompliance shall also be submitted to the Department's regional office within 5 days after the permittee becomes aware of the noncompliance. On a case-by-case basis, the Department may waive the requirement for submittal of a written report within 5 days and instruct the permittee to submit the written report with the next regularly scheduled monitoring report. In either case, the written report shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times; the steps taken or planned to reduce, eliminate and prevent reoccurrence of the noncompliance; and if the noncompliance has not been corrected, the length of time it is expected to continue.

A scheduled bypass approved by the Department under the 'Scheduled Bypass' section of this permit shall not be subject to the reporting required under this section.

**NOTE:** Section 292.11(2)(a), Wisconsin Statutes, requires any person who possesses or controls a hazardous substance or who causes the discharge of a hazardous substance to notify the Department of Natural Resources immediately of any discharge not authorized by the permit. **The discharge of a hazardous substance that is not authorized by this permit or that violates this permit may be a hazardous substance spill. To report a hazardous substance spill, call DNR's 24-hour HOTLINE at 1-800-943-0003.**

### 6.2.2 Flow Meters

Flow meters shall be calibrated annually, as per s. NR 218.06, Wis. Adm. Code.

### 6.2.3 Raw Grit and Screenings

All raw grit and screenings shall be disposed of at a properly licensed solid waste facility or picked up by a licensed waste hauler. If the facility or hauler are located in Wisconsin, then they shall be licensed under chs. NR 500-555, Wis. Adm. Code.

### **6.2.4 Sludge Management**

All sludge management activities shall be conducted in compliance with ch. NR 204 "Domestic Sewage Sludge Management", Wis. Adm. Code.

### **6.2.5 Prohibited Wastes**

Under no circumstances may the introduction of wastes prohibited by s. NR 211.10, Wis. Adm. Code, be allowed into the waste treatment system. Prohibited wastes include those:

- which create a fire or explosion hazard in the treatment work;
- which will cause corrosive structural damage to the treatment work;
- solid or viscous substances in amounts which cause obstructions to the flow in sewers or interference with the proper operation of the treatment work;
- wastewaters at a flow rate or pollutant loading which are excessive over relatively short time periods so as to cause a loss of treatment efficiency; and
- changes in discharge volume or composition from contributing industries which overload the treatment works or cause a loss of treatment efficiency.

### **6.2.6 Bypass**

This condition applies only to bypassing at a sewage treatment facility that is not a scheduled bypass, approved blending as a specific condition of this permit, a sewage treatment facility overflow or a controlled diversion as provided in the sections titled 'Scheduled Bypass', 'Blending' (if approved), 'SSO's and Sewage Treatment Facility Overflows' and 'Controlled Diversions' of this permit. Any other bypass at the sewage treatment facility is prohibited and the Department may take enforcement action against a permittee for such occurrences under s. 283.89, Wis. Stats. The Department may approve a bypass if the permittee demonstrates all the following conditions apply:

- The bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
- There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities or adequate back-up equipment, retention of untreated wastes, reduction of inflow and infiltration, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance. When evaluating feasibility of alternatives, the department may consider factors such as technical achievability, costs and affordability of implementation and risks to public health, the environment and, where the permittee is a municipality, the welfare of the community served; and
- The bypass was reported in accordance with the Noncompliance Reporting section of this permit.

### **6.2.7 Scheduled Bypass**

Whenever the permittee anticipates the need to bypass for purposes of efficient operations and maintenance and the permittee may not meet the conditions for controlled diversions in the 'Controlled Diversions' section of this permit, the permittee shall obtain prior written approval from the Department for the scheduled bypass. A permittee's written request for Department approval of a scheduled bypass shall demonstrate that the conditions for bypassing specified in the above section titled 'Bypass' are met and include the proposed date and reason for the bypass, estimated volume and duration of the bypass, alternatives to bypassing and measures to mitigate environmental harm caused by the bypass. The department may require the permittee to provide public notification for a scheduled bypass if it is determined there is significant public interest in the proposed action and may recommend mitigation measures to minimize the impact of such bypass.

### **6.2.8 Controlled Diversions**

Controlled diversions are allowed only when necessary for essential maintenance to assure efficient operation. Sewage treatment facilities that have multiple treatment units to treat variable or seasonal loading conditions may shut down redundant treatment units when necessary for efficient operation. The following requirements shall be met during controlled diversions:

- Effluent from the sewage treatment facility shall meet the effluent limitations established in the permit. Wastewater that is diverted around a treatment unit or treatment process during a controlled diversion shall be recombined with wastewater that is not diverted prior to the effluent sampling location and prior to effluent discharge;
- A controlled diversion does not include blending as defined in s. NR 210.03(2e), Wis. Adm. Code, and as may only be approved under s. NR 210.12, Wis. Adm. Code. A controlled diversion may not occur during periods of excessive flow or other abnormal wastewater characteristics;
- A controlled diversion may not result in a wastewater treatment facility overflow; and
- All instances of controlled diversions shall be documented in sewage treatment facility records and such records shall be available to the department on request.

### **6.2.9 Proper Operation and Maintenance**

The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance includes effective performance, adequate funding, adequate operator staffing and training as required in ch. NR 114, Wis. Adm. Code, and adequate laboratory and process controls, including appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems only when necessary to achieve compliance with the conditions of the permit.

### **6.2.10 Operator Certification**

The wastewater treatment facility shall be under the direct supervision of a state certified operator. In accordance with s. NR 114.53, Wis. Adm. Code, every WPDES permitted treatment plant shall have a designated operator-in-charge holding a current and valid certificate. The designated operator-in-charge shall be certified at the level and in all subclasses of the treatment plant, except laboratory. Treatment plant owners shall notify the department of any changes in the operator-in-charge within 30 days. Note that s. NR 114.52(22), Wis. Adm. Code, lists types of facilities that are excluded from operator certification requirements (i.e. private sewage systems, pretreatment facilities discharging to public sewers, industrial wastewater treatment that consists solely of land disposal, agricultural digesters and concentrated aquatic production facilities with no biological treatment).

## **6.3 Sewage Collection Systems**

### **6.3.1 Sanitary Sewage Overflows and Sewage Treatment Facility Overflows**

#### **6.3.1.1 Overflows Prohibited**

Any overflow or discharge of wastewater from the sewage collection system or at the sewage treatment facility, other than from permitted outfalls, is prohibited. The permittee shall provide information on whether any of the following conditions existed when an overflow occurred:

- The sanitary sewer overflow or sewage treatment facility overflow was unavoidable to prevent loss of life, personal injury or severe property damage;
- There were no feasible alternatives to the sanitary sewer overflow or sewage treatment facility overflow such as the use of auxiliary treatment facilities or adequate back-up equipment, retention of untreated wastes, reduction of inflow and infiltration, or preventive maintenance activities;
- The sanitary sewer overflow or the sewage treatment facility overflow was caused by unusual or severe weather-related conditions such as large or successive precipitation events, snowmelt, saturated soil

conditions, or severe weather occurring in the area served by the sewage collection system or sewage treatment facility; and

- The sanitary sewer overflow or the sewage treatment facility overflow was unintentional, temporary, and caused by an accident or other factors beyond the reasonable control of the permittee.

### 6.3.1.2 Permittee Response to Overflows

Whenever a sanitary sewer overflow or sewage treatment facility overflow occurs, the permittee shall take all feasible steps to control or limit the volume of untreated or partially treated wastewater discharged, and terminate the discharge as soon as practicable. Remedial actions, including those in s. NR 210.21 (3), Wis. Adm. Code, shall be implemented consistent with an emergency response plan developed under the CMOM program.

### 6.3.1.3 Permittee Reporting

Permittees shall report all sanitary sewer overflows and sewage treatment overflows as follows:

- The permittee shall notify the department by telephone, fax or email as soon as practicable, but no later than 24 hours from the time the permittee becomes aware of the overflow;
- The permittee shall, no later than five days from the time the permittee becomes aware of the overflow, provide to the department the information identified in this paragraph using department form number 3400-184. If an overflow lasts for more than five days, an initial report shall be submitted within 5 days as required in this paragraph and an updated report submitted following cessation of the overflow. At a minimum, the following information shall be included in the report:
  - The date and location of the overflow;
  - The surface water to which the discharge occurred, if any;
  - The duration of the overflow and an estimate of the volume of the overflow;
  - A description of the sewer system or treatment facility component from which the discharge occurred such as manhole, lift station, constructed overflow pipe, or crack or other opening in a pipe;
  - The estimated date and time when the overflow began and stopped or will be stopped;
  - The cause or suspected cause of the overflow including, if appropriate, precipitation, runoff conditions, areas of flooding, soil moisture and other relevant information;
  - Steps taken or planned to reduce, eliminate and prevent reoccurrence of the overflow and a schedule of major milestones for those steps;
  - A description of the actual or potential for human exposure and contact with the wastewater from the overflow;
  - Steps taken or planned to mitigate the impacts of the overflow and a schedule of major milestones for those steps;
  - To the extent known at the time of reporting, the number and location of building backups caused by excessive flow or other hydraulic constraints in the sewage collection system that occurred concurrently with the sanitary sewer overflow and that were within the same area of the sewage collection system as the sanitary sewer overflow; and
  - The reason the overflow occurred or explanation of other contributing circumstances that resulted in the overflow event. This includes any information available including whether the overflow was unavoidable to prevent loss of life, personal injury, or severe property damage and whether there were feasible alternatives to the overflow.

**NOTE:** A copy of form 3400-184 for reporting sanitary sewer overflows and sewage treatment facility overflows may be obtained from the department or accessed on the department's web site at <http://dnr.wi.gov/topic/wastewater/SSOreport.html>. As indicated on the form, additional information may be submitted to supplement the information required by the form.

- The permittee shall identify each specific location and each day on which a sanitary sewer overflow or sewage treatment facility overflow occurs as a discrete sanitary sewer overflow or sewage treatment facility overflow occurrence. An occurrence may be more than one day if the circumstances causing the sanitary sewer overflow or sewage treatment facility overflow results in a discharge duration of greater than 24 hours. If there is a stop and restart of the overflow at the same location within 24 hours and the overflow is caused by the same circumstance, it may be reported as one occurrence. Sanitary sewer overflow occurrences at a specific location that are separated by more than 24 hours shall be reported as separate occurrences; and
- A permittee that is required to submit wastewater discharge monitoring reports under s. NR 205.07 (1) (r), Wis. Adm. Code, shall also report all sanitary sewer overflows and sewage treatment facility overflows on that report.

#### **6.3.1.4 Public Notification**

The permittee shall notify the public of any sanitary sewer and sewage treatment facility overflows consistent with its emergency response plan required under the CMOM (Capacity, Management, Operation and Maintenance) section of this permit and s. NR 210.23 (4) (f), Wis. Adm. Code. Such public notification shall occur promptly following any overflow event using the most effective and efficient communications available in the community. At minimum, a daily newspaper of general circulation in the county(s) and municipality whose waters may be affected by the overflow shall be notified by written or electronic communication.

#### **6.3.2 Capacity, Management, Operation and Maintenance (CMOM) Program**

- The permittee shall have written documentation of the Capacity, Management, Operation and Maintenance (CMOM) program components in accordance with s. NR 210.23(4), Wis. Adm. Code. Such documentation shall be available for Department review upon request. The Department may request that the permittee provide this documentation or prepare a summary of the permittee's CMOM program at the time of application for reissuance of the WPDES permit.
- The permittee shall implement a CMOM program in accordance with s. NR 210.23, Wis. Adm. Code.
- The permittee shall at least annually conduct a self-audit of activities conducted under the permittee's CMOM program to ensure CMOM components are being implemented as necessary to meet the general standards of s. NR 210.23(3), Wis. Adm. Code.

#### **6.3.3 Sewer Cleaning Debris and Materials**

All debris and material removed from cleaning sanitary sewers shall be managed to prevent nuisances, run-off, ground infiltration or prohibited discharges.

- Debris and solid waste shall be dewatered, dried and then disposed of at a licensed solid waste facility.
- Liquid waste from the cleaning and dewatering operations shall be collected and disposed of at a permitted wastewater treatment facility.
- Combination waste including liquid waste along with debris and solid waste may be disposed of at a licensed solid waste facility or wastewater treatment facility willing to accept the waste.

### **6.4 Surface Water Requirements**

#### **6.4.1 Permittee-Determined Limit of Quantitation Incorporated into this Permit**

For pollutants with water quality-based effluent limits below the Limit of Quantitation (LOQ) in this permit, the LOQ calculated by the permittee and reported on the Discharge Monitoring Reports (DMRs) is incorporated by reference into this permit. The LOQ shall be reported on the DMRs, shall be the lowest quantifiable level practicable, and shall be no greater than the minimum level (ML) specified in or approved under 40 CFR Part 136 for the pollutant at the time this permit was issued, unless this permit specifies a higher LOQ.

## 6.4.2 Appropriate Formulas for Effluent Calculations

The permittee shall use the following formulas for calculating effluent results to determine compliance with average concentration limits and mass limits and total load limits:

**Weekly/Monthly/Six-Month/Annual Average Concentration** = the sum of all daily results for that week/month/six-month/year, divided by the number of results during that time period. [Note: When a six-month average effluent limit is specified for Total Phosphorus the applicable periods are May through October and November through April, except in cases of Water Quality Trading, wherein the applicable periods are January through June and July through December.]

**Weekly Average Mass Discharge (lbs/day)**: Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the week.

**Monthly Average Mass Discharge (lbs/day)**: Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the month.

**Six-Month Average Mass Discharge (lbs/day)**: Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the six-month period. [Note: When a six-month average effluent limit is specified for Total Phosphorus the applicable periods are May through October and November through April.]

**Annual Average Mass Discharge (lbs/day)**: Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the entire year.

**Total Monthly Discharge**: = monthly average concentration (mg/L) x total flow for the month (MG/month) x 8.34.

**Total Annual Discharge**: = sum of total monthly discharges for the calendar year.

**12-Month Rolling Sum of Total Monthly Discharge**: = the sum of the most recent 12 consecutive months of Total Monthly Discharges.

## 6.4.3 Effluent Temperature Requirements

**Weekly Average Temperature** – If temperature limits are included in this permit, Weekly Average Temperature shall be calculated as the sum of all daily maximum results for that week divided by the number of daily maximum results during that time period.

**Cold Shock Standard** – Water temperatures of the discharge shall be controlled in a manner as to protect fish and aquatic life uses from the deleterious effects of cold shock pursuant to Wis. Adm. Code, s. NR 102.28. ‘Cold Shock’ means exposure of aquatic organisms to a rapid decrease in temperature and a sustained exposure to low temperature that induces abnormal behavior or physiological performance and may lead to death.

**Rate of Temperature Change Standard** – Temperature of a water of the state or discharge to a water of the state may not be artificially raised or lowered at such a rate that it causes detrimental health or reproductive effects to fish or aquatic life of the water of the state pursuant to Wis. Adm. Code, s. NR 102.29.

## 6.4.4 Visible Foam or Floating Solids

There shall be no discharge of floating solids or visible foam in other than trace amounts.

## 6.4.5 Surface Water Uses and Criteria

In accordance with NR 102.04, Wis. Adm. Code, surface water uses and criteria are established to govern water management decisions. Practices attributable to municipal, industrial, commercial, domestic, agricultural, land development or other activities shall be controlled so that all surface waters including the mixing zone meet the following conditions at all times and under all flow and water level conditions:

- a) Substances that will cause objectionable deposits on the shore or in the bed of a body of water, shall not be present in such amounts as to interfere with public rights in waters of the state.

- b) Floating or submerged debris, oil, scum or other material shall not be present in such amounts as to interfere with public rights in waters of the state.
- c) Materials producing color, odor, taste or unsightliness shall not be present in such amounts as to interfere with public rights in waters of the state.
- d) Substances in concentrations or in combinations which are toxic or harmful to humans shall not be present in amounts found to be of public health significance, nor shall substances be present in amounts which are acutely harmful to animal, plant or aquatic life.

#### **6.4.6 Percent Removal**

During any 30 consecutive days, the average effluent concentrations of BOD<sub>5</sub> and of total suspended solids shall not exceed 15% of the average influent concentrations, respectively. This requirement does not apply to removal of total suspended solids if the permittee operates a lagoon system and has received a variance for suspended solids granted under NR 210.07(2), Wis. Adm. Code.

#### **6.4.7 Chloride Notification**

The permittee shall notify the Department in writing of any proposed changes which may affect the characteristics of the wastewater, which results in an increase in the concentration of chloride, under the authority of sections 283.31(4)(b) and 283.59(1), Stats. This notification shall include a description of the proposed source of chlorides and the anticipated increase in concentration. Following receipt of the notification, the Department may propose a modification to the permit.

#### **6.4.8 *E. coli***

The monthly limit for *E. coli* shall be expressed as a geometric mean. In calculating the geometric mean, a value of 1 is used for any result of 0.

#### **6.4.9 Seasonal Disinfection**

Disinfection shall be provided from May 1 through September 30 of each year. Monitoring requirements and the limitations for Fecal Coliform (interim) and *E. coli* apply only during the period in which disinfection is required. Whenever chlorine is used for disinfection or other uses, the limitations and monitoring requirements for residual chlorine shall apply. A dechlorination process shall be in operation whenever chlorine is used.

#### **6.4.10 Total Residual Chlorine Requirements**

When total residual chlorine (TRC) limit(s) or monitoring are included in a permit, the permittee shall comply with the following conditions:

- a) The permittee shall perform TRC monitoring required in this permit using an approved method from ch. NR 219, Wis. Adm. Code, which produces a detection limit that is less than or equal to the permitted limit or produces the lowest economically feasible detection limit if the approved methods cannot meet the permit limit. If the facility cannot achieve a detection limit less than or equal to the permit limit using the approved methods, contact the laboratory accreditation program for guidance.
- b) The permittee shall determine the limit of detection (LOD) as specified in s. NR 149.48 (2)(b), Wis. Adm. Code, or the permittee shall contact the laboratory accreditation program for information on how to determine a verified detection limit allowed just for TRC. If the verified detection limit is determined using the special procedure, then the LOD and limit of quantitation (LOQ) shall be set to be equal to the verified detection limit determined from this special procedure.
- c) The permittee shall determine compliance with the TRC limit(s) as follows:

1. If the facility determines a statistical LOD as specified in s. NR 149.48 (2)(b), Wis. Adm. Code, and the measured TRC levels are less than the LOD, the permittee shall report the results as less than the LOD (<LOD). For this situation the LOQ shall be established at 3.33 times the LOD or at the concentration of the lowest standard in the calibration curve. TRC levels that are < LOD are in compliance with the TRC limit.
2. If the facility determines the verified detection limit using the laboratory accreditation program special procedure, this verified detection limit shall be reported as the LOD and LOQ. If the measured TRC levels are less than the LOD, the permittee shall report the results as < LOD. TRC levels that are < LOD are in compliance with the TRC limit.
3. If the facility determines the statistical LOD as specified in s. NR 149.48 (2)(b), Wis. Adm. Code, and the measured TRC levels are greater than the statistical LOD but less than the LOQ, TRC levels are in compliance with the TRC limit - except when the measured levels are consistently reported between the LOD and LOQ. When the measured TRC levels are consistently reported between the LOD and LOQ, the facility shall take action to determine the reliability of detected results (such as resampling and/or re-calculating dosages) and shall adjust the chemical feed system if necessary to reduce the chances of detecting levels between the statistical LOD and LOQ.
4. If the facility determines the statistical LOQ as specified in s. NR 149.48 (2)(b), Wis. Adm. Code, or determines the verified detection limit using the laboratory accreditation program special procedure, TRC measured levels that are greater than the statistical LOQ and the TRC limit, are not in compliance with the TRC limit. The permittee shall report the level as a limit exceedance.
5. If the facility determines the statistical LOD as specified in s. NR 149.48 (2)(b), Wis. Adm. Code, and the measured level is < LOD, then a "0" (zero) value may be substituted for any test result less than the statistical LOD when calculating the average or mass discharge values. Calculated values shall then be compared directly to the average or mass limits to determine compliance.
6. If the facility determines the verified detection limit using the laboratory accreditation program special procedure and the measured level is < LOD (set equal to the verified detection limit), then a "0" (zero) value may be substituted for any test result less than the LOD when calculating the average or mass discharge values. Calculated values shall then be compared directly to the average or mass limits to determine compliance.

#### **6.4.11 Whole Effluent Toxicity (WET) Monitoring Requirements**

In order to determine the potential impact of the discharge on aquatic organisms, static-renewal toxicity tests shall be performed on the effluent in accordance with the procedures specified in the *"State of Wisconsin Aquatic Life Toxicity Testing Methods Manual, 2<sup>nd</sup> Edition"* (PUB-WT-797, November 2004) as required by NR 219.04, Table A, Wis. Adm. Code). All of the WET tests required in this permit, including any required retests, shall be conducted on the *Ceriodaphnia dubia* and fathead minnow species. Receiving water samples shall not be collected from any point in contact with the permittee's mixing zone and every attempt shall be made to avoid contact with any other discharge's mixing zone.

#### **6.4.12 Whole Effluent Toxicity (WET) Identification and Reduction**

Within 60 days of a retest which showed positive results, the permittee shall submit a written report to the Biomonitoring Coordinator, Bureau of Water Quality, 101 S. Webster St., PO Box 7921, Madison, WI 53707-7921, which details the following:

- A description of actions the permittee has taken or will take to remove toxicity and to prevent the recurrence of toxicity;

- A description of toxicity reduction evaluation (TRE) investigations that have been or will be done to identify potential sources of toxicity, including the following actions:
  - a) Evaluate the performance of the treatment system to identify deficiencies contributing to effluent toxicity (e.g., operational problems, chemical additives, incomplete treatment)
  - b) Identify the compound(s) causing toxicity. Conduct toxicity screening tests on the effluent at a minimum of once per month for six months to determine if toxicity recurs. Screening tests are WET tests using fewer effluent concentrations conducted on the most sensitive species. If any of the screening tests contain toxicity, conduct a toxicity identification evaluation (TIE) to determine the cause. TIE methods are available from USEPA “Methods for Aquatic Toxicity Identification Evaluations: Phase I Toxicity Characterization Procedures (EPA/600/6-91/003) and “Toxicity Identification Evaluation: Characterization of Chronically Toxic Effluents, Phase I” (EPA/600/6-91/005F).
  - c) Trace the compound(s) causing toxicity to their sources (e.g., industrial, commercial, domestic)
  - d) Evaluate, select, and implement methods or technologies to control effluent toxicity (e.g., in-plant or pretreatment controls, source reduction or removal)
- Where corrective actions including a TRE have not been completed, an expeditious schedule under which corrective actions will be implemented;
- If no actions have been taken, the reason for not taking action.

The permittee may also request approval from the Department to postpone additional retests in order to investigate the source(s) of toxicity. Postponed retests must be completed after toxicity is believed to have been removed.

#### **6.4.13 PFOS and PFOA Requirements**

The laboratory performing the analysis on any samples shall be certified for the applicable PFAS compounds in the aqueous matrix by the Wisconsin Laboratory Certification Program established under s. 299.11, Wis. Stats., in accordance with s. NR 149.41, Wis. Adm. Code. If the EPA Office of Water publishes a 1600 series isotope dilution method for the analysis of PFAS in wastewater, the department recommends the use of the EPA method. The Department may reject any sample results if results are produced by a laboratory that is not in compliance with certification requirements under ch. NR 149, Wis. Adm. Code.

### **6.5 Land Application Requirements**

#### **6.5.1 Sludge Management Program Standards And Requirements Based Upon Federally Promulgated Regulations**

In the event that new federal sewage sludge standards or regulations are promulgated, the permittee shall comply with the new sewage sludge requirements by the dates established in the regulations, if required by federal law, even if the permit has not yet been modified to incorporate the new federal regulations.

#### **6.5.2 General Sludge Management Information**

The General Sludge Management Form 3400-48 shall be completed and submitted prior to any significant sludge management changes.

#### **6.5.3 Sludge Samples**

All sludge samples shall be collected at a point and in a manner which will yield sample results which are representative of the sludge being tested, and collected at the time which is appropriate for the specific test.

#### **6.5.4 Land Application Characteristic Report**

Each report shall consist of a Characteristic Form 3400-49 and Lab Report. The Characteristic Report Form 3400-49 shall be submitted electronically by January 31 following each year of analysis.

Following submittal of the electronic Characteristic Report Form 3400-49, this form shall be certified electronically via the 'eReport Certify' page by a responsible executive or municipal officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The 'eReport Certify' page certifies that the electronic report is true, accurate and complete. The Lab Report must be sent directly to the facility's DNR sludge representative or basin engineer unless approval for not submitting the lab reports has been given.

The permittee shall use the following convention when reporting sludge monitoring results: Pollutant concentrations less than the limit of detection shall be reported as < (less than) the value of the limit of detection. For example, if a substance is not detected at a detection limit of 1.0 mg/kg, report the pollutant concentration as < 1.0 mg/kg .

All results shall be reported on a dry weight basis.

### **6.5.5 Calculation of Water Extractable Phosphorus**

When sludge analysis for Water Extractable Phosphorus is required by this permit, the permittee shall use the following formula to calculate and report Water Extractable Phosphorus:

Water Extractable Phosphorus (% of Total P) =

$$[\text{Water Extractable Phosphorus (mg/kg, dry wt)} \div \text{Total Phosphorus (mg/kg, dry wt)}] \times 100$$

### **6.5.6 Monitoring and Calculating PCB Concentrations in Sludge**

When sludge analysis for "PCB, Total Dry Wt" is required by this permit, the PCB concentration in the sludge shall be determined using either congener-specific analysis or Aroclor analysis. The permittee may decide which of these analyses is performed. Analyses shall be performed in accordance with the following provisions and Table EM in s. NR 219.04, Wis. Adm. Code:

- If congener-specific analysis is employed: All PCB congeners shall be delineated. Non-detects shall be treated as zero. The values that are between the limit of detection (LOD) and the limit of quantitation shall be used when calculating the total value of all congeners. All results shall be added together and the total PCB concentration by dry weight reported.
- If Aroclor analysis is employed, reporting protocols, consistent with s. NR 106.07(6)(e), should be as follows: If all Aroclors are less than the LOD, then the Total PCB Dry Wt result should be reported as less than the highest LOD. If a single Aroclor is detected, then that is what should be reported for the Total PCB result. If multiple Aroclors are detected, they should be summed and reported as Total PCBs. If the LOD cannot be achieved after using the appropriate clean up techniques, a reporting limit that is achievable for the Aroclors or each congener for the sample shall be determined. This reporting limit shall be reported and qualified indicating the presence of an interference.

### **6.5.7 Annual Land Application Report**

Land Application Report Form 3400-55 shall be submitted electronically by January 31, each year whether or not non-exceptional quality sludge is land applied. Non-exceptional quality sludge is defined in s. NR 204.07(4), Wis. Adm. Code. Following submittal of the electronic Annual Land Application Report Form 3400-55, this form shall be certified electronically via the 'eReport Certify' page by a responsible executive or municipal officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The 'eReport Certify' page certifies that the electronic report form is true, accurate and complete.

### **6.5.8 Other Methods of Disposal or Distribution Report**

The permittee shall submit electronically the Other Methods of Disposal or Distribution Report Form 3400-52 by January 31, each year whether or not sludge is hauled, landfilled, incinerated, or exceptional quality sludge is

distributed or land applied. Following submittal of the electronic Report Form 3400-52, this form shall be certified electronically via the 'eReport Certify' page by a responsible executive or municipal officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The 'eReport Certify' page certifies that the electronic report form is true, accurate and complete.

### 6.5.9 Approval to Land Apply

Bulk non-exceptional quality sludge as defined in s. NR 204.07(4), Wis. Adm. Code, may not be applied to land without a written approval letter or Form 3400-122 from the Department unless the Permittee has obtained permission from the Department to self-approve sites in accordance with s. NR 204.06(6), Wis. Adm. Code. Analysis of sludge characteristics is required prior to land application. Application on frozen or snow-covered ground is restricted to the extent specified in s. NR 204.07(3)(l), Wis. Adm. Code.

### 6.5.10 Soil Analysis Requirements

Each site requested for approval for land application must have the soil tested prior to use. Each approved site used for land application must subsequently be soil tested such that there is at least one valid soil test in the four years prior to land application. All soil sampling and submittal of information to the testing laboratory shall be done in accordance with UW Extension Bulletin A-2100. The testing shall be done by the UW Soils Lab in Madison or Marshfield, WI or at a lab approved by UW. The test results including the crop recommendations shall be submitted to the DNR contact listed for this permit, as they are available. Application rates shall be determined based on the crop nitrogen recommendations and with consideration for other sources of nitrogen applied to the site.

### 6.5.11 Land Application Site Evaluation

For non-exceptional quality sludge, as defined in s. NR 204.07(4), Wis. Adm. Code, a Land Application Site Request Form 3400-053 shall be submitted to the Department for the proposed land application site. The Department will evaluate the proposed site for acceptability and will either approve or deny use of the proposed site. The permittee may obtain permission to approve their own sites in accordance with s. NR 204.06(6), Wis. Adm. Code.

### 6.5.12 Class A Sludge: Fecal Coliform Density Requirement

The fecal coliform density which must be < 1000 MPN/g TS as required in s. NR 204.07, Wis. Adm. Code, shall be satisfied immediately after the treatment process is completed. If the material is bagged or distributed at that time, no re-testing is required. If the material is bagged, distributed or land applied at a later time, the sludge shall be re-tested and this requirement satisfied at that time also, to ensure that regrowth of bacteria has not occurred.

### 6.5.13 Class A Sludge: Temperature/Time Process

An increased sewage sludge temperature shall be maintained for a prescribed period of time according to the following guidelines:

| TOTAL SOLIDS | TEMP   | TIME                       | EQUATION<br>Where: D = time in days<br>t = temp in °C | NOTES                                                               |
|--------------|--------|----------------------------|-------------------------------------------------------|---------------------------------------------------------------------|
| ≥7%          | ≥50° C | ≥20 min.                   | $D = \frac{131,700,000}{10^{0.14t}}$                  | No heating of small particles by warmed gases or immiscible liquid. |
| ≥7%          | ≥50° C | ≥15 sec.                   | $D = \frac{131,700,000}{10^{0.14t}}$                  | Small particles heated by warmed gases or immiscible liquid.        |
| <7%          | >50° C | ≥15 sec.<br>To<br><30 min. | $D = \frac{131,700,000}{10^{0.14t}}$                  |                                                                     |

|     |        |          |                                     |  |
|-----|--------|----------|-------------------------------------|--|
| <7% | ≥50° C | ≥30 min. | $D = \frac{50,070,000}{10^{0.14t}}$ |  |
|-----|--------|----------|-------------------------------------|--|

In no case shall temperatures calculated using the appropriate equation be less than 50°C.

#### 6.5.14 Class A Sludge: Thermophilic Aerobic Digestion Process

Agitate liquid sludge with air or oxygen to maintain aerobic conditions. The mean cell residence time for the sludge shall be 10 days at 55 to 60 degrees Celsius.

#### 6.5.15 Class B Sludge: Fecal Coliform Limitation

Compliance with the fecal coliform limitation for Class B sludge shall be demonstrated by calculating the geometric mean of at least 7 separate samples. (Note that a Total Solids analysis must be done on each sample). The geometric mean shall be less than 2,000,000 MPN or CFU/g TS. Calculation of the geometric mean can be done using one of the following 2 methods.

Method 1:

$$\text{Geometric Mean} = (X_1 \times X_2 \times X_3 \dots \times X_n)^{1/n}$$

Where X = Coliform Density value of the sludge sample, and where n = number of samples (at least 7)

Method 2:

$$\text{Geometric Mean} = \text{antilog}[(X_1 + X_2 + X_3 \dots + X_n) \div n]$$

Where X =  $\log_{10}$  of Coliform Density value of the sludge sample, and where n = number of samples (at least 7)

Example for Method 2

| Sample Number | Coliform Density of Sludge Sample | $\log_{10}$ |
|---------------|-----------------------------------|-------------|
| 1             | $6.0 \times 10^5$                 | 5.78        |
| 2             | $4.2 \times 10^6$                 | 6.62        |
| 3             | $1.6 \times 10^6$                 | 6.20        |
| 4             | $9.0 \times 10^5$                 | 5.95        |
| 5             | $4.0 \times 10^5$                 | 5.60        |
| 6             | $1.0 \times 10^6$                 | 6.00        |
| 7             | $5.1 \times 10^5$                 | 5.71        |

The geometric mean for the seven samples is determined by averaging the  $\log_{10}$  values of the coliform density and taking the antilog of that value.

$$(5.78 + 6.62 + 6.20 + 5.95 + 5.60 + 6.00 + 5.71) \div 7 = 5.98$$

$$\text{The antilog of } 5.98 = 9.5 \times 10^5$$

#### 6.5.16 Vector Control: Volatile Solids Reduction

The mass of volatile solids in the sludge shall be reduced by a minimum of 38% between the time the sludge enters the digestion process and the time it either exits the digester or a storage facility. For calculation of volatile solids reduction, the permittee shall use the Van Kleeck equation or one of the other methods described in "Determination of Volatile Solids Reduction in Digestion" by J.B. Farrell, which is Appendix C of EPA's *Control of Pathogens in Municipal Wastewater Sludge* (EPA/625/R-92/013). The Van Kleeck equation is:

$$\text{VSR}\% = \frac{\text{VS}_{\text{IN}} - \text{VS}_{\text{OUT}}}{\text{VS}_{\text{IN}} - (\text{VS}_{\text{OUT}} \times \text{VS}_{\text{IN}})} \times 100$$

Where:  $\text{VS}_{\text{IN}}$  = Volatile Solids in Feed Sludge (g VS/g TS)

$\text{VS}_{\text{OUT}}$  = Volatile Solids in Final Sludge (g VS/g TS)

VSR% = Volatile Solids Reduction, (Percent)

#### 6.5.17 Class A Sludge - Vector Control: Injection

The sludge shall be injected within 8 hours after being discharged from the pathogen treatment process. No significant amount of the sewage sludge shall be present on the land surface within one hour after the sludge is injected.

#### **6.5.18 Class B Sludge - Vector Control: Injection**

No significant amount of the sewage sludge shall be present on the land surface within one hour after the sludge is injected.

#### **6.5.19 Class A Sludge - Vector Control: Incorporation**

Class A sludge shall be surface applied within 8 hours after being discharged from a pathogen treatment process and then be incorporated within 6 hours of surface application.

#### **6.5.20 Class B Sludge - Vector Control: Incorporation**

Class B sludge shall be incorporated within 6 hours of surface application, or as approved by the Department.

#### **6.5.21 Landfilling of Sludge**

General: Sewage sludge may not be disposed of in a municipal solid waste landfill unless the landfill meets the requirements of chs. NR 500 to 536, Wis. Adm. Code, and is an approved facility as defined in s. 289.01(3), Wis. Stats. Any facility accepting sewage sludge shall be approved by the Department in writing to accept sewage sludge. Disposal of sewage sludge in a municipal solid waste landfill shall be in accordance with ss. NR 506.13 and 506.14. Sewage sludge may not be disposed of in a surface disposal unit as defined in s. NR 204.03(63).

Approval: The permittee shall obtain approval from the Department prior to the disposal of sludge at a Wisconsin licensed landfill.

#### **6.5.22 Sludge Landfilling Reports**

The permittee shall report the volume of sludge disposed of at any landfill facility on Form 3400-52. The permittee shall include the name and address of the landfill, the Department license number or other state's designation or license number for all landfills used during the report period and a letter of acceptability from the landfill owner. In addition, any permittee utilizing landfills as a disposal method shall submit to the Department any test results used to indicate acceptability of the sludge at a landfill. Form 3400-52 shall be submitted annually by January 31, each year whether or not sludge is landfilled.

#### **6.5.23 Sludge Hauling**

The permittee is required to submit Form 3400-52 to the Department. If sludge is hauled to another facility, information shall include the quantity of sludge hauled, the name, address, phone number, contact person, and permit number of the receiving facility. Form 3400-52 shall be submitted annually by January 31 each year whether or not sludge is hauled.

#### **6.5.24 Land Application of Sludge Which Contains Elevated Levels of Radium-226**

When contributory water supplies exceed 2 pci per liter of Radium 226, monitoring for Radium 226 in sludge is required. Sludge containing Radium 226 shall be land applied in accordance with the requirements in s. NR 204.07(3)(n), Wis. Adm. Code.

## 7 Summary of Reports Due

FOR INFORMATIONAL PURPOSES ONLY

| Description                                                                                            | Date                                                                                                                                            | Page |
|--------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------|------|
| Mercury Pollutant Minimization Program -Mercury Report                                                 | December 31, 2029                                                                                                                               | 32   |
| PFOS/PFOA Minimization Plan Determination of Need -Report on Effluent Discharge                        | January 1, 2027                                                                                                                                 | 32   |
| PFOS/PFOA Minimization Plan Determination of Need -Report on Effluent Discharge and Evaluation of Need | January 1, 2028                                                                                                                                 | 32   |
| Sludge Management Plan -Sludge Management Plan Submittal for Class A facilities                        | January 1, 2027                                                                                                                                 | 33   |
| Compliance Maintenance Annual Reports (CMAR)                                                           | by June 30, each year                                                                                                                           | 36   |
| General Sludge Management Form 3400-48                                                                 | prior to any significant sludge management changes                                                                                              | 45   |
| Characteristic Form 3400-49 and Lab Report                                                             | by January 31 following each year of analysis                                                                                                   | 46   |
| Land Application Report Form 3400-55                                                                   | by January 31, each year whether or not non-exceptional quality sludge is land applied                                                          | 46   |
| Other Methods of Disposal or Distribution Report Form 3400-52                                          | by January 31, each year whether or not sludge is hauled, landfilled, incinerated, or exceptional quality sludge is distributed or land applied | 46   |
| Wastewater Discharge Monitoring Report                                                                 | no later than the date indicated on the form                                                                                                    | 35   |

Report forms shall be submitted electronically in accordance with the reporting requirements herein. Any facility plans or plans and specifications for municipal, industrial, industrial pretreatment and non industrial wastewater systems shall be submitted to the Bureau of Water Quality, P.O. Box 7921, Madison, WI 53707-7921. All other submittals required by this permit shall be submitted to:

Northeast Region - Oshkosh, 625 E Cty Rd Y, Suite 700, Oshkosh, WI 54901