



# WPDES PERMIT

*STATE OF WISCONSIN*  
*DEPARTMENT OF NATURAL RESOURCES*  
**PERMIT TO DISCHARGE UNDER THE WISCONSIN POLLUTANT DISCHARGE  
ELIMINATION SYSTEM**

**City of Kiel**

is permitted, under the authority of Chapter 283, Wisconsin Statutes, to discharge from a facility  
located at  
100 E Park Ave, Kiel, Wisconsin  
to

**the Sheboygan River (Water Body Identification Code number 50700) at Rockville Flowage in the Sheboygan  
River Watershed (SH03) of the Sheboygan River Drainage Basin in Manitowoc County  
and**

**Groundwater via land application in Calumet and Manitowoc Counties**

in accordance with the effluent limitations, monitoring requirements and other conditions set  
forth in this permit.

The permittee shall not discharge after the date of expiration. If the permittee wishes to continue to discharge after  
this expiration date an application shall be filed for reissuance of this permit, according to Chapter NR 200, Wis.  
Adm. Code, at least 180 days prior to the expiration date given below.

State of Wisconsin Department of Natural Resources  
For the Secretary

By \_\_\_\_\_  
Heidi Schmitt Marquez  
Wastewater Field Supervisor

\_\_\_\_\_  
Date Permit Signed/Issued

**PERMIT TERM: EFFECTIVE DATE - July 01, 2024**

**EXPIRATION DATE - June 30, 2029**

## TABLE OF CONTENTS

<b>1 INFLUENT REQUIREMENTS</b>	<b>1</b>
1.1 SAMPLING POINT(S)	1
1.2 MONITORING REQUIREMENTS	1
1.2.1 <i>Sampling Point 701 - INFLUENT</i>	1
<b>2 IN-PLANT REQUIREMENTS</b>	<b>2</b>
2.1 SAMPLING POINT(S)	2
2.2 MONITORING REQUIREMENTS AND LIMITATIONS	2
2.2.1 <i>Sampling Point 105 - OTHER BYPASS</i>	2
<b>3 SURFACE WATER REQUIREMENTS</b>	<b>4</b>
3.1 SAMPLING POINT(S)	4
3.2 MONITORING REQUIREMENTS AND EFFLUENT LIMITATIONS	4
3.2.1 <i>Sampling Point (Outfall) 001 - EFFLUENT</i>	4
<b>4 LAND APPLICATION REQUIREMENTS</b>	<b>11</b>
4.1 SAMPLING POINT(S)	11
4.2 MONITORING REQUIREMENTS AND LIMITATIONS	11
4.2.1 <i>Sampling Point (Outfall) 005 - DRIED CLASS A EQ SLUDGE</i>	12
4.2.2 <i>Sampling Point (Outfall) 006 - CLASS A EQ CAKE SLUDGE STORAGE</i>	18
4.2.3 <i>Sampling Point (Outfall) 007 - CLASS B CAKE SLUDGE</i>	19
<b>5 SCHEDULES</b>	<b>26</b>
5.1 PFOS/PFOA MINIMIZATION PLAN DETERMINATION OF NEED	26
5.2 SLUDGE MANAGEMENT PLAN	26
5.3 CAPACITY, MANAGEMENT, OPERATION, AND MAINTENANCE (CMOM) PROGRAM	27
<b>6 STANDARD REQUIREMENTS</b>	<b>28</b>
6.1 REPORTING AND MONITORING REQUIREMENTS	28
6.1.1 <i>Monitoring Results</i>	28
6.1.2 <i>Sampling and Testing Procedures</i>	28
6.1.3 <i>Recording of Results</i>	28
6.1.4 <i>Reporting of Monitoring Results</i>	29
6.1.5 <i>Compliance Maintenance Annual Reports</i>	29
6.1.6 <i>Records Retention</i>	29
6.1.7 <i>Other Information</i>	29
6.1.8 <i>Reporting Requirements – Alterations or Additions</i>	30
6.2 SYSTEM OPERATING REQUIREMENTS	30
6.2.1 <i>Noncompliance Reporting</i>	30
6.2.2 <i>Flow Meters</i>	30
6.2.3 <i>Raw Grit and Screenings</i>	31
6.2.4 <i>Sludge Management</i>	31
6.2.5 <i>Prohibited Wastes</i>	31
6.2.6 <i>Bypass</i>	31
6.2.7 <i>Scheduled Bypass</i>	31
6.2.8 <i>Controlled Diversions</i>	32
6.2.9 <i>Proper Operation and Maintenance</i>	32
6.2.10 <i>Operator Certification</i>	32
6.3 SEWAGE COLLECTION SYSTEMS	32
6.3.1 <i>Sanitary Sewage Overflows and Sewage Treatment Facility Overflows</i>	32
6.3.2 <i>Capacity, Management, Operation and Maintenance (CMOM) Program</i>	34
6.3.3 <i>Sewer Cleaning Debris and Materials</i>	34
6.4 SURFACE WATER REQUIREMENTS	35

<i>6.4.1 Permittee-Determined Limit of Quantitation Incorporated into this Permit</i>	35
<i>6.4.2 Appropriate Formulas for Effluent Calculations</i>	35
<i>6.4.3 Effluent Temperature Requirements</i>	35
<i>6.4.4 Visible Foam or Floating Solids</i>	35
<i>6.4.5 Surface Water Uses and Criteria</i>	36
<i>6.4.6 Percent Removal</i>	36
<i>6.4.7 E. coli</i>	36
<i>6.4.8 Seasonal Disinfection</i>	36
<i>6.4.9 Total Residual Chlorine Requirements</i>	36
<i>6.4.10 Whole Effluent Toxicity (WET) Monitoring Requirements</i>	37
<i>6.4.11 Whole Effluent Toxicity (WET) Identification and Reduction</i>	37
<i>6.4.12 PFOS and PFOA Requirements</i>	38
<b>6.5 LAND APPLICATION REQUIREMENTS</b>	38
<i>6.5.1 Sludge Management Program Standards And Requirements Based Upon Federally Promulgated Regulations</i>	38
<i>6.5.2 General Sludge Management Information</i>	38
<i>6.5.3 Sludge Samples</i>	38
<i>6.5.4 Land Application Characteristic Report</i>	38
<i>6.5.5 Calculation of Water Extractable Phosphorus</i>	39
<i>6.5.6 Monitoring and Calculating PCB Concentrations in Sludge</i>	39
<i>6.5.7 Annual Land Application Report</i>	39
<i>6.5.8 Other Methods of Disposal or Distribution Report</i>	39
<i>6.5.9 Approval to Land Apply</i>	40
<i>6.5.10 Soil Analysis Requirements</i>	40
<i>6.5.11 Land Application Site Evaluation</i>	40
<i>6.5.12 Class A Sludge: Fecal Coliform Density Requirement</i>	40
<i>6.5.13 Class A Sludge: Salmonella Density Requirements</i>	40
<i>6.5.14 Class A Sludge: Heat Drying Process</i>	40
<i>6.5.15 Class B Sludge: Fecal Coliform Limitation</i>	40
<i>6.5.16 Class B Sludge: Anaerobic Digestion</i>	41
<i>6.5.17 Vector Control: Drying With Primary Solids</i>	41
<i>6.5.18 Class A Sludge - Vector Control: Incorporation</i>	41
<i>6.5.19 Class B Sludge - Vector Control: Incorporation</i>	41
<i>6.5.20 Landfilling of Sludge</i>	41
<i>6.5.21 Sludge Landfilling Reports</i>	42
<i>6.5.22 Sludge Hauling</i>	42
<b>7 SUMMARY OF REPORTS DUE</b>	<b>43</b>

# 1 Influent Requirements

## 1.1 Sampling Point(s)

Sampling Point Designation	
Sampling Point Number	Sampling Point Location, WasteType/Sample Contents and Treatment Description (as applicable)
701	INFLUENT - Total combined influent from the sanitary sewage collection system and hauled waste receiving station. At Sampling Point 701, the permittee shall collect representative samples of influent from the influent automatic sampler drawing 24-hour flow proportional composite samples from the open channel after screening and prior to the grit tank and primary clarifiers. The permittee shall measure the influent flow rate using a continuous flow recording device after the main lift station.

## 1.2 Monitoring Requirements

The permittee shall comply with the following monitoring requirements.

### 1.2.1 Sampling Point 701 - INFLUENT

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Continuous	Continuous	
BOD <sub>5</sub> , Total		mg/L	2/Week	24-Hr Flow Prop Comp	
Suspended Solids, Total		mg/L	2/Week	24-Hr Flow Prop Comp	
Phosphorus, Total		mg/L	2/Week	24-Hr Flow Prop Comp	

## 2 In-Plant Requirements

### 2.1 Sampling Point(s)

Sampling Point Designation	
Sampling Point Number	Sampling Point Location, WasteType/Sample Contents and Treatment Description (as applicable)
105	At Sampling Point 105, the permittee shall report the diverted flow which bypasses the tertiary filtration system prior to disinfection.

### 2.2 Monitoring Requirements and Limitations

The permittee shall comply with the following monitoring requirements and limitations.

#### 2.2.1 Sampling Point 105 - OTHER BYPASS

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Per Occurrence	Continuous	Start flow measurement at the commencement of bypass operations. Measure flow in daily increments until operation ends and report daily bypass flow on the eDMR. See the Other Bypass Requirements section below.
Time		hours	Per Occurrence	Calculated	Report the total duration of 'Other Bypass' within a given day (12:00 am -11:59 pm) in which the other bypass occurs. See the Other Bypass Requirements section below.

##### 2.2.1.1 Other Bypass Requirements

The department has determined that an 'other bypass' as defined in s. NR 205.07(1)(u)3., Wis. Adm. Code, may occur at this sewage treatment facility. Furthermore, the department has previously approved plans in accordance with s. 281.41, Wis. Stats., for the partial bypass around the tertiary treatment process prior to disinfection. A bypass that is defined as a controlled diversion in s. NR 205.07(1)(v), Wis. Adm. Code, is not covered under this sample point. The following requirements shall apply whenever the 'other bypass' operations are in effect:

- The 'other bypass' may only operate during wet weather or other high flow conditions when peak wastewater flow to the sewage treatment facility exceeds the maximum design and operating capacity of the tertiary treatment facilities and when necessary to avoid severe property damage to the sewage treatment facility as described in s. NR 205.07(1)(u)3.a., Wis. Adm. Code. The 'other bypass' may only divert flow around the tertiary treatment process described under the In-Plant Diversion OTHER BYPASS Sample Point description

above. In no case shall this include flow diversion which would constitute blending, as defined in s. NR 210.03(2e), Wis. Adm. Code, unless otherwise approved in this permit;

- All flow, inclusive of that wastewater treated or not treated by the tertiary treatment process, shall be disinfected, if required by this permit, prior to discharge, and the flows shall be recombined prior to discharge;
- Effluent from the sewage treatment facility shall be monitored to include all wastewater that is discharged from the facility, including those wastewaters that are diverted around tertiary treatment process and shall meet the effluent limitations for outfalls included in this permit;
- Bypassing under this section and the circumstances that lead to the ‘other bypass’ shall be reported to the Department on the permittee’s Discharge Monitoring Report (DMR), and shall include the time, duration, and volume of wastewater routed around the tertiary treatment process.

### 3 Surface Water Requirements

#### 3.1 Sampling Point(s)

Sampling Point Designation	
Sampling Point Number	Sampling Point Location, Waste Type/Sample Contents and Treatment Description (as applicable)
001	EFFLUENT - At Sampling Point 001, the permittee shall collect representative samples of effluent from the effluent automatic composite sampler drawing 24-hour flow proportional composite samples from the post aeration basin following disinfection, except that the permittee shall continuously measure for pH, DO, and temperature from the post aeration basin and collect grab samples of the effluent at the final weir of the post aeration basin for total residual chlorine, E. coli, PFOA, and PFOS prior to being discharged to the Sheboygan River via Outfall 001. The permittee shall measure the effluent flow rate using a continuous flow recording device prior to the tertiary filters.

#### 3.2 Monitoring Requirements and Effluent Limitations

The permittee shall comply with the following monitoring requirements and limitations.

##### 3.2.1 Sampling Point (Outfall) 001 - EFFLUENT

Monitoring Requirements and Effluent Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Daily	Continuous	
BOD <sub>5</sub> , Total	Weekly Avg	9.4 mg/L	2/Week	24-Hr Flow Prop Comp	Limit applies August each year.
BOD <sub>5</sub> , Total	Monthly Avg	9.4 mg/L	2/Week	24-Hr Flow Prop Comp	Limit applies August each year.
BOD <sub>5</sub> , Total	Weekly Avg	9.5 mg/L	2/Week	24-Hr Flow Prop Comp	Limit applies September each year.
BOD <sub>5</sub> , Total	Monthly Avg	9.5 mg/L	2/Week	24-Hr Flow Prop Comp	Limit applies September each year.
BOD <sub>5</sub> , Total	Weekly Avg	10 mg/L	2/Week	24-Hr Flow Prop Comp	Limit applies May through July and October each year.
BOD <sub>5</sub> , Total	Monthly Avg	10 mg/L	2/Week	24-Hr Flow Prop Comp	Limit applies May through July and October each year.
BOD <sub>5</sub> , Total	Weekly Avg	15 mg/L	2/Week	24-Hr Flow Prop Comp	Limit applies November through April each year.
BOD <sub>5</sub> , Total	Monthly Avg	15 mg/L	2/Week	24-Hr Flow Prop Comp	Limit applies November through April each year.
BOD <sub>5</sub> , Total	Weekly Avg	108 lbs/day	2/Week	Calculated	Limit applies May through October each year.
BOD <sub>5</sub> , Total	Weekly Avg	161 lbs/day	2/Week	Calculated	Limit applies November through April each year.
Suspended Solids, Total	Weekly Avg	10 mg/L	2/Week	24-Hr Flow Prop Comp	Limit applies May through October each year.

<b>Monitoring Requirements and Effluent Limitations</b>					
<b>Parameter</b>	<b>Limit Type</b>	<b>Limit and Units</b>	<b>Sample Frequency</b>	<b>Sample Type</b>	<b>Notes</b>
Suspended Solids, Total	Monthly Avg	10 mg/L	2/Week	24-Hr Flow Prop Comp	Limit applies May through October each year.
Suspended Solids, Total	Weekly Avg	15 mg/L	2/Week	24-Hr Flow Prop Comp	Limit applies November through April each year.
Suspended Solids, Total	Monthly Avg	15 mg/L	2/Week	24-Hr Flow Prop Comp	Limit applies November through April each year.
Suspended Solids, Total	Weekly Avg	340 lbs/day	2/Week	Calculated	See the TMDL Limitations section below.
Suspended Solids, Total	Monthly Avg	228 lbs/day	2/Week	Calculated	See the TMDL Limitations section below.
Suspended Solids, Total		lbs/month	Monthly	Calculated	Calculate and report the total monthly mass of TSS discharged in lbs/month on the last day of the month on the eDMR.
Suspended Solids, Total		lbs/yr	Monthly	Calculated	Calculate and report the 12-month rolling sum of the total monthly mass of TSS on the last day of the month on the eDMR.
pH (Minimum)	Daily Min	6.0 su	Daily	Continuous	
pH (Maximum)	Daily Max	9.0 su	Daily	Continuous	
Dissolved Oxygen	Daily Min	7.0 mg/L	Daily	Continuous	
E. coli	Geometric Mean - Monthly	126 #/100 ml	Weekly	Grab	Monitoring and Limit applies May through September each year.
E. coli	% Exceedance	10 Percent	Monthly	Calculated	Monitoring and Limit applies May through September each year. See the E. coli Percent Limit section below. Enter the result in the DMR on the last day of the month.
Chlorine, Total Residual	Daily Max	25 µg/L	5/Week	Grab	Monitoring and Limit applies May through September each year.
Chlorine, Total Residual	Weekly Avg	8.0 µg/L	5/Week	Grab	Monitoring and Limit applies May through September each year.
Chlorine, Total Residual	Monthly Avg	8.0 µg/L	5/Week	Grab	Monitoring and Limit applies May through September each year.
Phosphorus, Total	Monthly Avg	1.0 mg/L	2/Week	24-Hr Flow Prop Comp	
Phosphorus, Total	Monthly Avg	23 lbs/day	2/Week	Calculated	See the TMDL Limitations section below.



<b>Monitoring Requirements and Effluent Limitations</b>					
<b>Parameter</b>	<b>Limit Type</b>	<b>Limit and Units</b>	<b>Sample Frequency</b>	<b>Sample Type</b>	<b>Notes</b>
Phosphorus, Total		lbs/month	Monthly	Calculated	Calculate and report the total monthly mass of TP discharged in lbs/month on the last day of the month on the eDMR.
Phosphorus, Total		lbs/yr	Monthly	Calculated	Calculate and report the 12-month rolling sum of the total monthly mass of TP on the last day of the month on the eDMR.
Nitrogen, Ammonia Variable Limit		mg/L	2/Week	See Table	See the Daily Maximum Ammonia Nitrogen Limits section below.
Nitrogen, Ammonia (NH <sub>3</sub> -N) Total	Daily Max - Variable	mg/L	2/Week	24-Hr Flow Prop Comp	See the Daily Maximum Ammonia Nitrogen Limits section below.
Nitrogen, Ammonia (NH <sub>3</sub> -N) Total	Weekly Avg	15 mg/L	2/Week	24-Hr Flow Prop Comp	Limit applies January through February each year.
Nitrogen, Ammonia (NH <sub>3</sub> -N) Total	Weekly Avg	19 mg/L	2/Week	24-Hr Flow Prop Comp	Limit applies March through April each year.
Nitrogen, Ammonia (NH <sub>3</sub> -N) Total	Weekly Avg	5.2 mg/L	2/Week	24-Hr Flow Prop Comp	Limit applies May each year.
Nitrogen, Ammonia (NH <sub>3</sub> -N) Total	Weekly Avg	3.7 mg/L	2/Week	24-Hr Flow Prop Comp	Limit applies June through September each year.
Nitrogen, Ammonia (NH <sub>3</sub> -N) Total	Weekly Avg	9.4 mg/L	2/Week	24-Hr Flow Prop Comp	Limit applies October each year.
Nitrogen, Ammonia (NH <sub>3</sub> -N) Total	Weekly Avg	13 mg/L	2/Week	24-Hr Flow Prop Comp	Limit applies November each year.
Nitrogen, Ammonia (NH <sub>3</sub> -N) Total	Weekly Avg	12 mg/L	2/Week	24-Hr Flow Prop Comp	Limit applies December each year.
Nitrogen, Ammonia (NH <sub>3</sub> -N) Total	Monthly Avg	5.3 mg/L	2/Week	24-Hr Flow Prop Comp	Limit applies October through March each year.
Nitrogen, Ammonia (NH <sub>3</sub> -N) Total	Monthly Avg	2.2 mg/L	2/Week	24-Hr Flow Prop Comp	Limit applies April through May each year.
Nitrogen, Ammonia (NH <sub>3</sub> -N) Total	Monthly Avg	1.7 mg/L	2/Week	24-Hr Flow Prop Comp	Limit applies June through September each year.
Chloride		mg/L	Monthly	24-Hr Flow Prop Comp	Monitoring only required from January 2027 to December 2027.
Temperature Maximum		deg F	Daily	Continuous	See the Effluent Temperature Monitoring section below.
Nitrogen, Total Kjeldahl		mg/L	Quarterly	24-Hr Flow Prop Comp	See Nitrogen Series Monitoring section below.
Nitrogen, Nitrite + Nitrate Total		mg/L	Quarterly	24-Hr Flow Prop Comp	See Nitrogen Series Monitoring section below.

<b>Monitoring Requirements and Effluent Limitations</b>					
<b>Parameter</b>	<b>Limit Type</b>	<b>Limit and Units</b>	<b>Sample Frequency</b>	<b>Sample Type</b>	<b>Notes</b>
Nitrogen, Total		mg/L	Quarterly	Calculated	See Nitrogen Series Monitoring section below. Total Nitrogen = Total Kjeldahl Nitrogen (mg/L) + Total (Nitrite + Nitrate)
PFOS		ng/L	1/ 2 Months	Grab	Monitoring only. See PFOS/PFOA Sampling and Reporting Requirements section below and PFOS/PFOA Minimization Plan Determination of Need section below and compliance schedule.
PFOA		ng/L	1/ 2 Months	Grab	Monitoring only. See PFOS/PFOA Sampling and Reporting Requirements section below and PFOS/PFOA Minimization Plan Determination of Need section below and compliance schedule.
Acute WET		TU <sub>a</sub>	See Listed Qtr(s)	24-Hr Flow Prop Comp	See the Whole Effluent Toxicity Testing section below.
Chronic WET	Monthly Avg	1.1 TU <sub>c</sub>	See Listed Qtr(s)	24-Hr Flow Prop Comp	See the Whole Effluent Toxicity Testing section below.

### 3.2.1.1 Annual Average Design Flow

The annual average design flow of the permittee’s wastewater treatment facility is 1.43 MGD.

### 3.2.1.2 *E. coli* Percent Limit

No more than 10 percent of *E. coli* bacteria samples collected in any calendar month may exceed 410 #/100 ml. Bacteria samples may be collected more frequently than required. All samples shall be reported on the monthly discharge monitoring reports (DMRs). The following calculation should be used to calculate percent exceedances.

$$\frac{\text{\# of Samples greater than 410 \#/100}}{\text{Total \# of samples}} \times 100 = \% \text{ Exceedance}$$

### 3.2.1.3 Total Maximum Daily Load (TMDL) Limitations

**Approved TMDL:** The Northeast Lakeshore Basin TMDL which includes Waste Load Allocations (WLAs) for total phosphorus and total suspended solids, was approved by the U.S. Environmental Protection Agency (USEPA) on October 30, 2023. The approved TMDL WLA limits are listed in the subsections below. TMDL total lbs/month and lbs/yr effluent results shall be calculated as follows:

**Total Monthly Discharge (lbs/month):** = monthly average concentration (mg/L) x total flow for the month (MG/month) x 8.34.

**12-Month Rolling Sum of Total Monthly Discharge (lbs/yr):** =the sum of the most recent 12 consecutive months of Total Monthly Discharges.

**3.2.1.3.1 TMDL Limitations for Total Suspended Solids**

The approved TMDL TSS WLA for this permittee is 52,306 lbs/yr, and results in calculated TSS mass limits of 340 lbs/day as a weekly average and 228 lbs/day as a monthly average. The 12-month rolling sum of total monthly TSS (lbs/yr) shall be reported each month for direct comparison to the facility’s WLA.

**3.2.1.3.2 TMDL Limitations for Total Phosphorus**

The approved TMDL TP WLA for this permittee is 4,359 lbs/yr, and results in a calculated TP mass limit of 23 lbs/day as a monthly average. The 12-month rolling sum of total monthly TP (lbs/yr) shall be reported each month for direct comparison to the facility’s WLA.

**3.2.1.4 Daily Maximum Ammonia Nitrogen (NH3-N) Limits**

The daily maximum ammonia nitrogen limit is a variable limit, dependent upon the effluent pH. Presented below is a table of daily maximum ammonia nitrogen effluent limits corresponding to various effluent pH values. Measurement of effluent pH is required on the same days as the collection of samples for ammonia analysis.

Effluent pH s.u.	Limit mg/L	Effluent pH s.u.	Limit mg/L	Effluent pH s.u.	Limit mg/L
6.0 ≤ pH ≤ 6.1	108	7.0 < pH ≤ 7.1	66	8.0 < pH ≤ 8.1	14
6.1 < pH ≤ 6.2	106	7.1 < pH ≤ 7.2	59	8.1 < pH ≤ 8.2	11
6.2 < pH ≤ 6.3	104	7.2 < pH ≤ 7.3	52	8.2 < pH ≤ 8.3	9.4
6.3 < pH ≤ 6.4	101	7.3 < pH ≤ 7.4	46	8.3 < pH ≤ 8.4	7.8
6.4 < pH ≤ 6.5	98	7.4 < pH ≤ 7.5	40	8.4 < pH ≤ 8.5	6.4
6.5 < pH ≤ 6.6	94	7.5 < pH ≤ 7.6	34	8.5 < pH ≤ 8.6	5.3
6.6 < pH ≤ 6.7	89	7.6 < pH ≤ 7.7	29	8.6 < pH ≤ 8.7	4.4
6.7 < pH ≤ 6.8	84	7.7 < pH ≤ 7.8	24	8.7 < pH ≤ 8.8	3.7
6.8 < pH ≤ 6.9	78	7.8 < pH ≤ 7.9	20	8.8 < pH ≤ 8.9	3.1
6.9 < pH ≤ 7.0	72	7.9 < pH ≤ 8.0	17	8.9 < pH ≤ 9.0	2.6

For each day that the effluent is monitored for ammonia, report the measured ammonia concentration in the Ammonia column of the electronic Discharge Monitoring Report (eDMR) and the applicable variable limit (from the table above) in the Ammonia Variable Limit column of the eDMR.

**3.2.1.5 Effluent Temperature Monitoring**

For monitoring temperature continuously, the permittee shall collect measurements in accordance with s. NR 218.04(13), Wis. Adm Code. This means that the permittee shall record discrete measurements at intervals of not more than 15 minutes during the 24-hour period. The permittee shall report the maximum temperature measured during the day on the DMR.

**3.2.1.6 Nitrogen Series Monitoring**

The permittee shall monitor for Total Kjeldahl Nitrogen (TKN), Nitrite + Nitrate Nitrogen, and Total Nitrogen quarterly. The permittee shall perform the monitoring during normal operating conditions. The permittee is not allowed to turn off or otherwise modify treatment systems, production processes, or change other operating or treatment conditions during testing.

### 3.2.1.7 PFOS/PFOA Sampling and Reporting Requirements

For grab samples, as defined per s. NR 218.04(10), Wis. Adm. Code, a single sample at a location as defined by the sample point description shall be taken during the time of the day most representative to capture all potential discharges. If extra equipment besides the sample bottle is used to collect the sample, it is recommended that a one-time equipment blank is collected with the first sample. An equipment blank would be collected by passing laboratory-verified PFAS-free water over or through field sampling equipment before the collection of a grab sample to evaluate potential contamination from the equipment used during sample.

If any equipment blanks are performed, these results shall be reported in the comments section of the eDMR and shall also be documented in the reports submitted as part of the PFOS/PFOA Minimization Plan Determination of Need schedule of the permit.

### 3.2.1.8 PFOS/PFOA Minimization Plan Determination of Need

The permittee shall monitor PFOS and PFOA as specified in the table above and report on the effluent concentrations including trends in monthly and annual average PFOS and PFOA concentrations as specified in the PFOS/PFOA Minimization Plan Determination of Need Schedule.

If, after reviewing the data, the Department determines that a minimization plan for PFOS and PFOA is necessary based on the procedures in s. NR 106.98(4), Wis. Adm. Code, the Department will notify the permittee in writing that a PFOS and PFOA minimization plan that satisfies the requirements in s. NR 106.99, Wis. Adm. Code, is required. The permittee shall submit an initial plan for Department approval no later than 90 days after written notification was sent from the Department in accordance with s. NR 106.985(2)(a), Wis. Adm. Code. Pursuant to s. NR 106.985(2)(b), Wis. Adm. Code, as soon as possible after Department approval of the PFOS and PFOA minimization plan, the Department will modify or revoke and reissue the permit in accordance with public notice procedures under ch. 283, Wis. Stats., and ch. NR 203, Wis. Adm. Code, to include the PFOS and PFOA minimization plan and other related terms and condition.

If, however, the Department determines that a PFOS and PFOA minimization plan is unnecessary based on the procedures in s. NR 106.98(4), Wis. Adm. Code, the Department shall notify the permittee that no further action is required. Per s. NR 106.98(3)(a), Wis. Adm. Code, the Department may reduce monitoring frequency to once every 3 months (quarterly) on a case-by-case basis, but only after at least 12 representative results have been generated. If the permittee requests a reduction in monitoring and the Department agrees a reduction would be appropriate, the permit may be modified in accordance with public notice procedures under ch. 283, Wis. Stats., and ch. NR 203, Wis. Adm. Code, to incorporate this change.

### 3.2.1.9 Whole Effluent Toxicity (WET) Testing

**Primary Control Water:** The permittee shall collect grab samples from the Sheboygan River upstream of the discharge from Outfall 001 and out of the influence from any other known discharges unless the use of a different control water source is approved by the department prior to use.

**Instream Waste Concentration (IWC):** 90%

**Dilution series:** At least five effluent concentrations and dual controls must be included in each test.

- **Acute:** 100, 50, 25, 12.5, 6.25% and any additional selected by the permittee.
- **Chronic:** 100, 75, 50, 25, 12.5% and any additional selected by the permittee.

**WET Testing Frequency:**

**Acute and chronic** tests shall be conducted once each year in rotating quarters in order to collect seasonal information about the discharge. Acute and chronic tests are required during the following quarters:

- **4th Quarter (October to December) 2024**
  - **3rd Quarter (July to September) 2025**
  - **2nd Quarter (April to June) 2026**
  - **1st Quarter (January to March) 2027**
  - **4th Quarter (October to December) 2028**
- Acute and Chronic WET testing shall continue after the permit expiration date (until the permit is reissued) in accordance with the WET requirements specified for the last full calendar year of this permit. For example, the next test would be required in **4th Quarter (October to December) 2029**.

**Testing:** WET testing shall be performed during normal operating conditions. Permittees are not allowed to turn off or otherwise modify treatment systems, production processes, or change other operating or treatment conditions during WET tests.

**Reporting:** The permittee shall report test results on the Discharge Monitoring Report form, and also complete the "Whole Effluent Toxicity Test Report Form" (Section 6, "*State of Wisconsin Aquatic Life Toxicity Testing Methods Manual, 2<sup>nd</sup> Edition*"), for each test. The original, complete, signed version of the Whole Effluent Toxicity Test Report Form shall be sent to the Biomonitoring Coordinator, Bureau of Water Quality, 101 S. Webster St., P.O. Box 7921, Madison, WI 53707-7921, within 45 days of test completion. The Discharge Monitoring Report (DMR) form shall be submitted electronically by the required deadline.

**Determination of Positive Results:** An acute toxicity test shall be considered positive if the Toxic Unit - Acute ( $TU_a$ ) is greater than **1.0** for either species. The  $TU_a$  shall be calculated as follows:  $TU_a = 100 \div LC_{50}$ . A chronic toxicity test shall be considered positive if the Toxic Unit - Chronic ( $TU_c$ ) is greater than **1.1** for either species. The  $TU_c$  shall be calculated as follows:  $TU_c = 100 \div IC_{25}$ .

**Additional Testing Requirements:** Within 90 days of a test which showed positive results, the permittee shall submit the results of at least 2 retests to the Biomonitoring Coordinator on "Whole Effluent Toxicity Test Report Forms". The 90-day reporting period shall begin the day after the test which showed a positive result. The retests shall be completed using the same species and test methods specified for the original test (see the Standard Requirements section herein).

## 4 Land Application Requirements

### 4.1 Sampling Point(s)

The discharge(s) shall be limited to land application of the waste type(s) designated for the listed sampling point(s) on Department approved land spreading sites or by hauling to another facility.

<b>Sampling Point Designation</b>	
<b>Sampling Point Number</b>	<b>Sampling Point Location, Waste Type/Sample Contents and Treatment Description (as applicable)</b>
005	DRIED CLASS A EQ SLUDGE - Class A, exceptional quality cake sludge from treatment of primary sludge with anaerobic digestion mixed with waste activated sludge from final clarification in an aerated holding tank, then treated with a screw press (or belt press as emergency back-up) and a dryer. At Sampling Point 005, the permittee shall collect representative grab and/or composite samples of cake sludge immediately following the sludge dryer and be monitored quarterly for metals (List 1), nutrients (List 2), Class A pathogen density requirements (List 3), and vector attraction reduction (List 4) prior to immediately being bagged, distributed or land applied as exceptional quality sludge or being stored on-site in dried cake sludge piles in the storage building. All pathogen control samples shall be discrete samples. Each pathogen control sample shall meet the pathogen limit to prove effective pathogen treatment. Monitoring results for each sampling event shall be reported on a quarterly basis.
006	DRIED CLASS A EQ SLUDGE STORAGE - Class A, exceptional quality cake sludge from treatment of primary sludge with anaerobic digestion mixed with waste activated sludge from final clarification in an aerated holding tank, then treated with a screw press (or belt press as emergency back-up) and a dryer, then transported by a conveyor to an on-site storage building, and stored in piles. At Sampling Point 006, the permittee shall collect representative grab samples of cake sludge from the dried cake sludge piles in the on-site storage building and be monitored for pathogen control (List 3) prior to being distributed or land applied as exceptional quality sludge if the distribution or land application will occur at a later time as specified in the department approved sludge management plan. All pathogen control samples shall be discrete samples. Each pathogen control sample shall meet the pathogen limit to prove effective pathogen treatment. Monitoring results for each sampling event shall be reported on a quarterly basis.
007	CLASS B CAKE SLUDGE - Class B cake sludge from treatment of primary sludge with anaerobic digestion mixed with waste activated sludge from final clarification in an aerated holding tank, then treated with a belt press and loaded onto trucks or stored in an on-site storage building. This outfall has been included for emergency use in case Class A sludge treatment is not available. At Sampling Point 007, the permittee shall collect representative composite samples of cake sludge from truck loadout or cake storage piles in the on-site storage building prior to being land applied on department approved sites via Outfall 007.

### 4.2 Monitoring Requirements and Limitations

The permittee shall comply with the following monitoring requirements and limitations.

### 4.2.1 Sampling Point (Outfall) 005 - DRIED CLASS A EQ SLUDGE

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Solids, Total		Percent	Quarterly	Composite	
Arsenic Dry Wt	Ceiling	75 mg/kg	Quarterly	Composite	
Arsenic Dry Wt	High Quality	41 mg/kg	Quarterly	Composite	
Cadmium Dry Wt	Ceiling	85 mg/kg	Quarterly	Composite	
Cadmium Dry Wt	High Quality	39 mg/kg	Quarterly	Composite	
Copper Dry Wt	Ceiling	4,300 mg/kg	Quarterly	Composite	
Copper Dry Wt	High Quality	1,500 mg/kg	Quarterly	Composite	
Lead Dry Wt	Ceiling	840 mg/kg	Quarterly	Composite	
Lead Dry Wt	High Quality	300 mg/kg	Quarterly	Composite	
Mercury Dry Wt	Ceiling	57 mg/kg	Quarterly	Composite	
Mercury Dry Wt	High Quality	17 mg/kg	Quarterly	Composite	
Molybdenum Dry Wt	Ceiling	75 mg/kg	Quarterly	Composite	
Nickel Dry Wt	Ceiling	420 mg/kg	Quarterly	Composite	
Nickel Dry Wt	High Quality	420 mg/kg	Quarterly	Composite	
Selenium Dry Wt	Ceiling	100 mg/kg	Quarterly	Composite	
Selenium Dry Wt	High Quality	100 mg/kg	Quarterly	Composite	
Zinc Dry Wt	Ceiling	7,500 mg/kg	Quarterly	Composite	
Zinc Dry Wt	High Quality	2,800 mg/kg	Quarterly	Composite	
Nitrogen, Total Kjeldahl		Percent	Quarterly	Composite	
Nitrogen, Ammonium (NH <sub>4</sub> -N) Total		Percent	Quarterly	Composite	
Phosphorus, Total		Percent	Quarterly	Composite	
Phosphorus, Water Extractable		% of Tot P	Quarterly	Composite	
Potassium, Total Recoverable		Percent	Quarterly	Composite	
PCB Total Dry Wt	Ceiling	50 mg/kg	Once	Composite	Monitoring required once in 2026.
PCB Total Dry Wt	High Quality	10 mg/kg	Once	Composite	
PFOA + PFOS		µg/kg	Annual	Calculated	Report the sum of PFOA and PFOS. See PFAS Permit Sections for more information.
PFAS Dry Wt			Annual	Grab	Perfluoroalkyl and Polyfluoroalkyl Substances based on updated DNR PFAS List. See PFAS Permit Sections for more information.

<b>Other Sludge Requirements</b>	
<b>Sludge Requirements</b>	<b>Sample Frequency</b>
<b>List 3 Requirements – Pathogen Control:</b> The requirements in List 3 shall be met immediately following the sludge dryer prior to immediately being bagged, distributed or land applied as exceptional quality sludge or being stored on-site in dried cake sludge piles in the storage building.	<b>Quarterly</b>
<b>List 4 Requirements – Vector Attraction Reduction:</b> The vector attraction reduction shall be satisfied immediately following the sludge dryer prior to immediately being bagged, distributed or land applied as exceptional quality sludge or being stored on-site in dried cake sludge piles in the storage building.	<b>Quarterly</b>

**4.2.1.1 Heat Drying Requirements**

Dry the sludge by direct or indirect contact with hot gases to reduce the moisture content of the sludge to 10% or lower. Either the temperature of the sewage sludge particles shall exceed 80° C (176° F) or the wet bulb temperature of the gas in contact with the sludge as the sludge leaves the dryer shall exceed 80° C. The permittee shall continuously monitor the temperature of sewage sludge particles from the dryer while in operation including start-up and shut down. The permittee shall conduct the temperature monitoring in accordance with s. NR 218.04(13), Wis. Adm. Code. The permittee shall maintain a daily log of the sewage sludge particle temperature and periods of operation for the dryer.

**4.2.1.2 Sewage Sludge for Lawns, Home Gardens, or other Residential Use**

The permittee shall immediately bag any exceptional quality (EQ) sludge following the dryer if it will be distributed to the public for use on lawns, home gardens, or other residential use. This section does not apply to bulk EQ sludge that will be given away to farmers to be applied to agricultural lands.

**4.2.1.3 List 2 Analysis**

If the monitoring frequency for List 2 parameters is more frequent than "Annual" then the sludge may be analyzed for the List 2 parameters just prior to each land application season rather than at the more frequent interval specified.

**4.2.1.4 Changes in Feed Sludge Characteristics**

If a change in feed sludge characteristics, treatment process, or operational procedures occurs which may result in a significant shift in sludge characteristics, the permittee shall reanalyze the sludge for List 1, 2, 3 and 4 parameters each time such change occurs.

**4.2.1.5 Multiple Sludge Sample Points (Outfalls)**

If there are multiple sludge sample points (outfalls), but the sludges are not subject to different sludge treatment processes, then a separate List 2 analysis shall be conducted for each sludge type which is land applied, just prior to land application, and the application rate shall be calculated for each sludge type. In this case, List 1, 3, and 4 and PCBs need only be analyzed on a single sludge type, at the specified frequency. If there are multiple sludge sample points (outfalls), due to multiple treatment processes, List 1, 2, 3 and 4 and PCBs shall be analyzed for each sludge type at the specified frequency.



**4.2.1.6 Sludge Which Exceeds the High-Quality Limit**

Cumulative pollutant loading records shall be kept for all bulk land application of sludge which does not meet the high-quality limit for any parameter. This requirement applies for the entire calendar year in which any exceedance of Table 3 of s. NR 204.07(5)(c), is experienced. Such loading records shall be kept for all List 1 parameters for each site land applied in that calendar year. The formula to be used for calculating cumulative loading is as follows:

$$[(\text{Pollutant concentration (mg/kg)} \times \text{dry tons applied/ac}) \div 500] + \text{previous loading (lbs/acre)} = \text{cumulative lbs pollutant per acre}$$

When a site reaches 90% of the allowable cumulative loading for any metal established in Table 2 of s. NR 204.07(5)(b), the Department shall be so notified through letter or in the comment section of the annual land application report (3400-55).

**4.2.1.7 Sludge Analysis for PCBs**

The permittee shall analyze the sludge for Total PCBs one time during 2026. The results shall be reported as "PCB Total Dry Wt". Either congener-specific analysis or Aroclor analysis shall be used to determine the PCB concentration. The permittee may determine whether Aroclor or congener specific analysis is performed. Analyses shall be performed in accordance with Table EM in s. NR 219.04, Wis. Adm. Code and the conditions specified in Standard Requirements of this permit. PCB results shall be submitted by January 31, following the specified year of analysis.

**4.2.1.8 Lists 1, 2, 3, and 4**

<p><b>List 1</b>  <b>TOTAL SOLIDS AND METALS</b></p> <p>See the Monitoring Requirements and Limitations table above for monitoring frequency and limitations for the List 1 parameters</p>
Solids, Total (percent)
Arsenic, mg/kg (dry weight)
Cadmium, mg/kg (dry weight)
Copper, mg/kg (dry weight)
Lead, mg/kg (dry weight)
Mercury, mg/kg (dry weight)
Molybdenum, mg/kg (dry weight)
Nickel, mg/kg (dry weight)
Selenium, mg/kg (dry weight)
Zinc, mg/kg (dry weight)

<p><b>List 2</b>  <b>NUTRIENTS</b></p> <p>See the Monitoring Requirements and Limitations table above for monitoring frequency for the List 2 parameters</p>
Solids, Total (percent)
Nitrogen Total Kjeldahl (percent)
Nitrogen Ammonium (NH4-N) Total (percent)
Phosphorus Total as P (percent)
Phosphorus, Water Extractable (as percent of Total P)
Potassium Total Recoverable (percent)

**List 3**

**PATHOGEN CONTROL FOR CLASS A SLUDGE**

The permittee shall implement pathogen control as listed in List 3. The Department shall be notified of the pathogen control utilized and shall be notified when the permittee decides to utilize alternative pathogen control.

The following requirements shall be met immediately following the sludge dryer prior to immediately being bagged, distributed or land applied as exceptional quality sludge or being stored on-site in dried cake sludge piles in the storage building.

Parameter	Unit	Limit
Fecal Coliform*	MPN/gTS	1000
<b>OR</b>		
Salmonella	MPN/4gTS	3
<b>AND, ONE OF THE FOLLOWING PROCESS OPTIONS</b>		
Temp/Time based on % Solids	Alkaline Treatment	
Prior test for Enteric Virus/Viable Helminth Ova	Post test for Enteric Virus/Viable Helminth Ova	
Composting	Heat Drying	
Heat Treatment	Thermophilic Aerobic Digestion	
Beta Ray Irradiation	Gamma Ray Irradiation	
Pasteurization	PFRP Equivalent Process	
* The Fecal Coliform limit shall be reported as 7 discrete samples on a dry weight basis.		

**List 4**

**VECTOR ATTRACTION REDUCTION**

The permittee shall implement any one of the vector attraction reduction options specified in List 4. The Department shall be notified of the option utilized and shall be notified when the permittee decides to utilize an alternative option.

One of the following shall be satisfied immediately following the sludge dryer prior to immediately being bagged, distributed or land applied as exceptional quality sludge or being stored on-site in dried cake sludge piles in the storage building, as specified in List 4.

Option	Limit	Where/When it Shall be Met
Volatile Solids Reduction	≥38%	Across the process
Specific Oxygen Uptake Rate	≤1.5 mg O <sub>2</sub> /hr/g TS	On aerobic stabilized sludge
Anaerobic bench-scale test	<17 % VS reduction	On anaerobic digested sludge
Aerobic bench-scale test	<15 % VS reduction	On aerobic digested sludge
Aerobic Process	>14 days, Temp >40°C and Avg. Temp > 45°C	On composted sludge
pH adjustment	>12 S.U. (for 2 hours) and >11.5 (for an additional 22 hours)	During the process
Drying without primary solids	>75 % TS	When applied or bagged
Drying with primary solids	>90 % TS	When applied or bagged
Equivalent Process	Approved by the Department	Varies with process
Injection	-	When applied
Incorporation	-	Within 6 hours of application

#### 4.2.1.9 Daily Land Application Log

Daily Land Application Log		
Discharge Monitoring Requirements and Limitations		
The permittee shall maintain a daily land application log for biosolids land applied each day when land application occurs. The following minimum records must be kept, in addition to all analytical results for the biosolids land applied. The log book records shall form the basis for the annual land application report requirements.		
Parameters	Units	Sample Frequency
DNR Site Number(s)	Number	Daily as used
Outfall number applied	Number	Daily as used
Acres applied	Acres	Daily as used
Amount applied	As appropriate * /day	Daily as used
Application rate per acre	unit */acre	Daily as used
Nitrogen applied per acre	lb/acre	Daily as used
Method of Application	Injection, Incorporation, or surface applied	Daily as used

\*gallons, cubic yards, dry US Tons or dry Metric Tons

#### 4.2.1.10 Sludge Monitoring for PFAS

Sampling shall occur for perfluoroalkyl and polyfluoroalkyl compounds (PFAS) listed in the table below and as indicated in sampling point sections above. Monitoring shall occur at each sample point when sludge is generated regardless of the end use (i.e. land applied, hauled to another facility, landfilled).

PERFLUOROALKYLCARBOXYLIC Acids (PFCAs)	
PFBA	Perfluorobutanoic acid
PFPeA	Perfluroropentanoic acid
PFHxA	Perfluorohexanoic acid
PFHpA	Perfluoroheptanoic acid
PFOA	Perfluorooctanoic acid
PFNA	Perfluorononanoic acid
PFDA	Perfluorodecanoic acid
PFUnA	Perfluroundecanoic acid
PFDoA	Perfluorododecanoic acid
PFTriA	Perfluorotridecanoic acid
PFTeDA	Perfluorotetradecanoic acid
PERFLUOROALKYLSULFONIC Acids (PFSAs)	
PFBS	Perfluorobutane sulfonic acid
PFPeS	Perfluroropentane sulfonic acid
PFHxS	Perfluorohexane sulfonic acid
PFHpS	Perfluoroheptane sulfonic acid

PFOS	Perfluorooctane sulfonic acid
PFNS	Perfluorononane sulfonic acid
PFDS	Perfluorodecane sulfonic acid
PFDoS	Perfluorododecane sulfonic acid
<b>TELOMER SULFONIC Acids</b>	
4:2 FTSA	4:2 fluorotelomersulfonic acid
6:2 FTSA	6:2 fluorotelomersulfonic acid
8:2 FTSA	8:2 fluorotelomersulfonic acid
<b>PERFLUOROOCETANCESULFONAMIDES (FOSAs)</b>	
PFOSA	Perfluorooctane sulfonamide
N-MeFOSA	N-Methyl perfluorooctane sulfonamide
N-EtFOSA	N-Ethyl perfluorooctane sulfonamide
<b>PERFLUOROOCETANCESULFONAMIDOACETIC Acids</b>	
N-MeFOSAA	N-Methyl perfluorooctane sulfonamidoacetic acid
N-EtFOSAA	N-Ethyl perfluorooctane sulfonamidoacetic acid
<b>NATIVE PERFLUOROOCETANCESULFONAMIDOETHANOLS (FOSEs)</b>	
N-MeFOSE	N-Methyl perfluorooctane sulfonamidoethanol
N-EtFOSE	N-Ethyl perfluorooctane sulfonamidoethanol
<b>PERFLUOROALKYLETHERCARBOXYLIC Acids (PFECAs)</b>	
HFPO-DA	Hexafluoropropylene oxide dimer acid
DONA	4,8-dioxa-3H-perfluorononanoic acid
<b>CHLORO-PERFLUOROALKYLSULFONATE</b>	
F-53B Major	9-chlorohexadecafluoro-3-oxanone-1-sulfonic acid
F-53B Minor	11-chloroelcosafluoro-3-oxaundecane-1-sulfonic acid

Note: If WDNR Lab Certification removes a particular compound from the reporting list above and upon receiving written communication from the department, reporting for that compound is no longer required.

#### 4.2.1.11 Sampling and Reporting Sludge Samples for PFAS

Representative sludge samples shall be collected at each sample point as listed. At minimum, liquid sludge storage/digesters should be thoroughly mixed prior to sampling. Cake sludge samples should consist of seven equal size discrete samples and be collected from different areas and depths then composited into one sample for laboratory analysis.

Note: If additional equipment is used for collecting sludge samples (i.e., shovels, compositing buckets, bottles, etc.), then a one-time equipment blank is recommended to be collected with the first sample. An equipment blank sample is collected by passing laboratory verified PFAS-free water over or through field sampling equipment before the collection of a representative sludge sample. The equipment blank result shall be reported on the annual Sludge Characteristics Form (3400-049) in the comment section when reporting PFAS concentrations in the sludge.

The permittee shall report each of the PFAS sludge monitoring results on the annual Sludge Characteristics and Monitoring Form (3400-049) as provided by the department. The permittee shall also report the summation of PFOS and PFOA on this same form. All results shall be reported in dry weight. The annual Sludge Characteristics and Monitoring Form (3400-049) are due January 31, of the year following the collection of the sludge samples.

The laboratory performing the analysis on any samples shall be certified for the applicable PFAS compounds in the solids matrix by the Wisconsin Laboratory Certification Program established under s. 299.11, Wis. Stats., and in accordance with s. NR 149.41, Wis. Adm. Code. If the EPA Office of Water publishes a 1600 series isotope dilution method for the analysis of PFAS in solids, the department recommends the use of the EPA method. The department may reject any sample results if results are produced by a laboratory that is not in compliance with certification requirements under ch. NR 149, Wis. Adm. Code.

**4.2.1.12 PFAS Land Application Requirements**

The department recommends the landspreading and/or land application of sludge be done in a manner consistent with the most recent version of the “Interim Strategy for Land Application of Biosolids and Industrial Sludges containing PFAS”.

**4.2.2 Sampling Point (Outfall) 006 - CLASS A EQ CAKE SLUDGE STORAGE**

<b>Sludge Monitoring Requirements</b>	
<b>Sludge Requirements</b>	<b>Sample Frequency</b>
<b>List 3 Requirements – Pathogen Control:</b> The requirements in List 3 shall be met prior to being distributed or land applied as exceptional quality sludge.	<b>Each time cake sludge is distributed or land applied at a later time (e.g., stored sludge), and described in the department approved management plan</b>

**4.2.2.1 List 3**

<b>List 3 PATHOGEN CONTROL FOR CLASS A SLUDGE</b>		
The permittee shall implement pathogen control as listed in List 3. The Department shall be notified of the pathogen control utilized and shall be notified when the permittee decides to utilize alternative pathogen control.		
The following requirements shall be met prior to being distributed or land applied as exceptional quality sludge.		
<b>Parameter</b>	<b>Unit</b>	<b>Limit</b>
Fecal Coliform*	MPN/gTS	1000
<b>OR</b>		
Salmonella	MPN/4gTS	3
<b>AND, ONE OF THE FOLLOWING PROCESS OPTIONS</b>		
Temp/Time based on % Solids	Alkaline Treatment	
Prior test for Enteric Virus/Viable Helminth Ova	Post test for Enteric Virus/Viable Helminth Ova	
Composting	Heat Drying	
Heat Treatment	Thermophilic Aerobic Digestion	
Beta Ray Irradiation	Gamma Ray Irradiation	
Pasteurization	PFRP Equivalent Process	
* The Fecal Coliform limit shall be reported as 7 discrete samples on a dry weight basis.		

### 4.2.3 Sampling Point (Outfall) 007 - CLASS B CAKE SLUDGE

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Solids, Total		Percent	Quarterly	Composite	Monitoring required only when cake sludge is land applied in any quarter.
Arsenic Dry Wt	Ceiling	75 mg/kg	Quarterly	Composite	Monitoring required and limits applicable only when cake sludge is land applied in any quarter.
Arsenic Dry Wt	High Quality	41 mg/kg	Quarterly	Composite	
Cadmium Dry Wt	Ceiling	85 mg/kg	Quarterly	Composite	
Cadmium Dry Wt	High Quality	39 mg/kg	Quarterly	Composite	
Copper Dry Wt	Ceiling	4,300 mg/kg	Quarterly	Composite	
Copper Dry Wt	High Quality	1,500 mg/kg	Quarterly	Composite	
Lead Dry Wt	Ceiling	840 mg/kg	Quarterly	Composite	
Lead Dry Wt	High Quality	300 mg/kg	Quarterly	Composite	
Mercury Dry Wt	Ceiling	57 mg/kg	Quarterly	Composite	
Mercury Dry Wt	High Quality	17 mg/kg	Quarterly	Composite	
Molybdenum Dry Wt	Ceiling	75 mg/kg	Quarterly	Composite	
Nickel Dry Wt	Ceiling	420 mg/kg	Quarterly	Composite	
Nickel Dry Wt	High Quality	420 mg/kg	Quarterly	Composite	
Selenium Dry Wt	Ceiling	100 mg/kg	Quarterly	Composite	
Selenium Dry Wt	High Quality	100 mg/kg	Quarterly	Composite	
Zinc Dry Wt	Ceiling	7,500 mg/kg	Quarterly	Composite	
Zinc Dry Wt	High Quality	2,800 mg/kg	Quarterly	Composite	
Nitrogen, Total Kjeldahl		Percent	Quarterly	Composite	
Nitrogen, Ammonium (NH <sub>4</sub> -N) Total		Percent	Quarterly	Composite	
Phosphorus, Total		Percent	Quarterly	Composite	
Phosphorus, Water Extractable		% of Tot P	Quarterly	Composite	
Potassium, Total Recoverable		Percent	Quarterly	Composite	
PCB Total Dry Wt	Ceiling	50 mg/kg	Once	Composite	Monitoring required once only when cake sludge is land applied in any year.
PCB Total Dry Wt	High Quality	10 mg/kg	Once	Composite	
PFOA + PFOS		µg/kg	Annual	Calculated	Monitoring required only when cake sludge is land applied in any year. Report the sum of PFOA and PFOS. See PFAS Permit Sections for more information.

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
PFAS Dry Wt			Annual	Grab	Monitoring required only when cake sludge is land applied in any year. Perfluoroalkyl and Polyfluoroalkyl Substances based on updated DNR PFAS List. See PFAS Permit Sections for more information.

Other Sludge Requirements	
Sludge Requirements	Sample Frequency
<b>List 3 Requirements – Pathogen Control:</b> The requirements in List 3 shall be met prior to land application of sludge.	<b>Quarterly if cake sludge is land applied</b>
<b>List 4 Requirements – Vector Attraction Reduction:</b> The vector attraction reduction shall be satisfied prior to, or at the time of land application as specified in List 4.	<b>Quarterly if cake sludge is land applied</b>

#### 4.2.3.1 List 2 Analysis

If the monitoring frequency for List 2 parameters is more frequent than "Annual" then the sludge may be analyzed for the List 2 parameters just prior to each land application season rather than at the more frequent interval specified.

#### 4.2.3.2 Changes in Feed Sludge Characteristics

If a change in feed sludge characteristics, treatment process, or operational procedures occurs which may result in a significant shift in sludge characteristics, the permittee shall reanalyze the sludge for List 1, 2, 3 and 4 parameters each time such change occurs.

#### 4.2.3.3 Multiple Sludge Sample Points (Outfalls)

If there are multiple sludge sample points (outfalls), but the sludges are not subject to different sludge treatment processes, then a separate List 2 analysis shall be conducted for each sludge type which is land applied, just prior to land application, and the application rate shall be calculated for each sludge type. In this case, List 1, 3, and 4 and PCBs need only be analyzed on a single sludge type, at the specified frequency. If there are multiple sludge sample points (outfalls), due to multiple treatment processes, List 1, 2, 3 and 4 and PCBs shall be analyzed for each sludge type at the specified frequency.

#### 4.2.3.4 Sludge Which Exceeds the High-Quality Limit

Cumulative pollutant loading records shall be kept for all bulk land application of sludge which does not meet the high-quality limit for any parameter. This requirement applies for the entire calendar year in which any exceedance of Table 3 of s. NR 204.07(5)(c), is experienced. Such loading records shall be kept for all List 1 parameters for each site land applied in that calendar year. The formula to be used for calculating cumulative loading is as follows:

$[(\text{Pollutant concentration (mg/kg)} \times \text{dry tons applied/ac}) \div 500] + \text{previous loading (lbs/acre)} = \text{cumulative lbs pollutant per acre}$

When a site reaches 90% of the allowable cumulative loading for any metal established in Table 2 of s. NR 204.07(5)(b), the Department shall be so notified through letter or in the comment section of the annual land application report (3400-55).

**4.2.3.5 Sludge Analysis for PCBs**

The permittee shall analyze the sludge for Total PCBs one time during the permit term if the cake sludge will be land applied. The results shall be reported as "PCB Total Dry Wt". Either congener-specific analysis or Aroclor analysis shall be used to determine the PCB concentration. The permittee may determine whether Aroclor or congener specific analysis is performed. Analyses shall be performed in accordance with Table EM in s. NR 219.04, Wis. Adm. Code and the conditions specified in Standard Requirements of this permit. PCB results shall be submitted by January 31, following the specified year of analysis.

**4.2.3.6 Lists 1, 2, 3, and 4**

<p><b>List 1</b> <b>TOTAL SOLIDS AND METALS</b></p> <p>See the Monitoring Requirements and Limitations table above for monitoring frequency and limitations for the List 1 parameters</p>
Solids, Total (percent)
Arsenic, mg/kg (dry weight)
Cadmium, mg/kg (dry weight)
Copper, mg/kg (dry weight)
Lead, mg/kg (dry weight)
Mercury, mg/kg (dry weight)
Molybdenum, mg/kg (dry weight)
Nickel, mg/kg (dry weight)
Selenium, mg/kg (dry weight)
Zinc, mg/kg (dry weight)

<p><b>List 2</b> <b>NUTRIENTS</b></p> <p>See the Monitoring Requirements and Limitations table above for monitoring frequency for the List 2 parameters</p>
Solids, Total (percent)
Nitrogen Total Kjeldahl (percent)
Nitrogen Ammonium (NH <sub>4</sub> -N) Total (percent)
Phosphorus Total as P (percent)
Phosphorus, Water Extractable (as percent of Total P)
Potassium Total Recoverable (percent)



**List 3**

**PATHOGEN CONTROL FOR CLASS B SLUDGE**

The permittee shall implement pathogen control as listed in List 3. The Department shall be notified of the pathogen control utilized and shall be notified when the permittee decides to utilize alternative pathogen control.

The following requirements shall be met prior to land application of sludge.

Parameter	Unit	Limit
Fecal Coliform*	MPN/gTS or CFU/gTS	2,000,000
<b>OR, ONE OF THE FOLLOWING PROCESS OPTIONS</b>		
Aerobic Digestion		Air Drying
Anaerobic Digestion		Composting
Alkaline Stabilization		PSRP Equivalent Process
* The Fecal Coliform limit shall be reported as the geometric mean of 7 discrete samples on a dry weight basis.		

**List 4**

**VECTOR ATTRACTION REDUCTION**

The permittee shall implement any one of the vector attraction reduction options specified in List 4. The Department shall be notified of the option utilized and shall be notified when the permittee decides to utilize an alternative option.

One of the following shall be satisfied prior to, or at the time of land application as specified in List 4.

Option	Limit	Where/When it Shall be Met
Volatile Solids Reduction	≥38%	Across the process
Specific Oxygen Uptake Rate	≤1.5 mg O <sub>2</sub> /hr/g TS	On aerobic stabilized sludge
Anaerobic bench-scale test	<17 % VS reduction	On anaerobic digested sludge
Aerobic bench-scale test	<15 % VS reduction	On aerobic digested sludge
Aerobic Process	>14 days, Temp >40°C and Avg. Temp > 45°C	On composted sludge
pH adjustment	>12 S.U. (for 2 hours) and >11.5 (for an additional 22 hours)	During the process
Drying without primary solids	>75 % TS	When applied or bagged
Drying with primary solids	>90 % TS	When applied or bagged
Equivalent Process	Approved by the Department	Varies with process
Injection	-	When applied
Incorporation	-	Within 6 hours of application

#### 4.2.3.7 Daily Land Application Log

Daily Land Application Log		
Discharge Monitoring Requirements and Limitations		
The permittee shall maintain a daily land application log for biosolids land applied each day when land application occurs. The following minimum records must be kept, in addition to all analytical results for the biosolids land applied. The log book records shall form the basis for the annual land application report requirements.		
Parameters	Units	Sample Frequency
DNR Site Number(s)	Number	Daily as used
Outfall number applied	Number	Daily as used
Acres applied	Acres	Daily as used
Amount applied	As appropriate * /day	Daily as used
Application rate per acre	unit */acre	Daily as used
Nitrogen applied per acre	lb/acre	Daily as used
Method of Application	Injection, Incorporation, or surface applied	Daily as used

\*gallons, cubic yards, dry US Tons or dry Metric Tons

#### 4.2.3.8 Sludge Monitoring for PFAS

Sampling shall occur for perfluoroalkyl and polyfluoroalkyl compounds (PFAS) listed in the table below and as indicated in sampling point sections above. Monitoring shall occur at each sample point when sludge is generated regardless of the end use (i.e. land applied, hauled to another facility, landfilled).

PERFLUOROALKYLCARBOXYLIC Acids (PFCAs)	
PFBA	Perfluorobutanoic acid
PFPeA	Perfluroropentanoic acid
PFHxA	Perfluorohexanoic acid
PFHpA	Perfluoroheptanoic acid
PFOA	Perfluorooctanoic acid
PFNA	Perfluorononanoic acid
PFDA	Perfluorodecanoic acid
PFUnA	Perfluroroundecanoic acid
PFDoA	Perfluorododecanoic acid
PFTriA	Perfluorotridecanoic acid
PFTeDA	Perfluorotetradecanoic acid
PERFLUOROALKYLSULFONIC Acids (PFSAs)	
PFBS	Perfluorobutane sulfonic acid
PFPeS	Perfluroropentane sulfonic acid
PFHxS	Perfluorohexane sulfonic acid
PFHpS	Perfluoroheptane sulfonic acid

PFOS	Perfluorooctane sulfonic acid
PFNS	Perfluorononane sulfonic acid
PFDS	Perfluorodecane sulfonic acid
PFDoS	Perfluorododecane sulfonic acid
<b>TELOMER SULFONIC Acids</b>	
4:2 FTSA	4:2 fluorotelomersulfonic acid
6:2 FTSA	6:2 fluorotelomersulfonic acid
8:2 FTSA	8:2 fluorotelomersulfonic acid
<b>PERFLUOROOCETANCESULFONAMIDES (FOSAs)</b>	
PFOSA	Perflurorooctane sulfonamide
N-MeFOSA	N-Methyl perfluorooctane sulfonamide
N-EtFOSA	N-Ethyl perfluorooctane sulfonamide
<b>PERFLUOROOCETANCESULFONAMIDOACETIC Acids</b>	
N-MeFOSAA	N-Methyl perfluorooctane sulfonamidoacetic acid
N-EtFOSAA	N-Ethyl perfluorooctane sulfonamidoacetic acid
<b>NATIVE PERFLUOROOCETANCESULFONAMIDOETHANOLS (FOSEs)</b>	
N-MeFOSE	N-Methyl perfluorooctane sulfonamidoethanol
N-EtFOSE	N-Ethyl perfluorooctane sulfonamidoethanol
<b>PERFLUOROALKYLETHERCARBOXYLIC Acids (PFECAs)</b>	
HFPO-DA	Hexafluoropropylene oxide dimer acid
DONA	4,8-dioxa-3H-perfluorononanoic acid
<b>CHLORO-PERFLUOROALKYLSULFONATE</b>	
F-53B Major	9-chloroehexadecafluoro-3-oxanone-1-sulfonic acid
F-53B Minor	11-chloroelcosafuoro-3-oxaundecane-1-sulfonic acid

Note: If WDNR Lab Certification removes a particular compound from the reporting list above and upon receiving written communication from the department, reporting for that compound is no longer required.

#### 4.2.3.9 Sampling and Reporting Sludge Samples for PFAS

Representative sludge samples shall be collected at each sample point as listed. At minimum, liquid sludge storage/digesters should be thoroughly mixed prior to sampling. Cake sludge samples should consist of seven equal size discrete samples and be collected from different areas and depths then composited into one sample for laboratory analysis.

Note: If additional equipment is used for collecting sludge samples (i.e., shovels, compositing buckets, bottles, etc.), then a one-time equipment blank is recommended to be collected with the first sample. An equipment blank sample is collected by passing laboratory verified PFAS-free water over or through field sampling equipment before the collection of a representative sludge sample. The equipment blank result shall be reported on the annual Sludge Characteristics Form (3400-049) in the comment section when reporting PFAS concentrations in the sludge.

The permittee shall report each of the PFAS sludge monitoring results on the annual Sludge Characteristics and Monitoring Form (3400-049) as provided by the department. The permittee shall also report the summation of PFOS and PFOA on this same form. All results shall be reported in dry weight. The annual Sludge Characteristics and Monitoring Form (3400-049) are due January 31, of the year following the collection of the sludge samples.

The laboratory performing the analysis on any samples shall be certified for the applicable PFAS compounds in the solids matrix by the Wisconsin Laboratory Certification Program established under s. 299.11, Wis. Stats., and in accordance with s. NR 149.41, Wis. Adm. Code. If the EPA Office of Water publishes a 1600 series isotope dilution method for the analysis of PFAS in solids, the department recommends the use of the EPA method. The department may reject any sample results if results are produced by a laboratory that is not in compliance with certification requirements under ch. NR 149, Wis. Adm. Code.

#### **4.2.3.10 PFAS Land Application Requirements**

The department recommends the landspreading and/or land application of sludge be done in a manner consistent with the most recent version of the “Interim Strategy for Land Application of Biosolids and Industrial Sludges containing PFAS”.

## 5 Schedules

### 5.1 PFOS/PFOA Minimization Plan Determination of Need

Required Action	Due Date
<p><b>Report on Effluent Discharge:</b> Submit a report on effluent PFOS and PFOA concentrations and include an analysis of trends in monthly and annual average PFOS and PFOA concentrations. This analysis should also include a comparison to the applicable narrative standard in s. NR 102.04(8)(d), Wis. Adm. Code.</p> <p>This report shall include all additional PFOS and PFOA data that may be collected including any influent, intake, in-plant, collection system sampling, and blank sample results.</p>	06/30/2025
<p><b>Report on Effluent Discharge and Evaluation of Need:</b> Submit a final report on effluent PFOS and PFOA concentrations and include an analysis of trends in monthly and annual average PFOS and PFOA concentrations of data collected over the last 24 months. The report shall also provide a comparison on the likelihood of the facility needing to develop a PFOS/PFOA minimization plan.</p> <p>This report shall include all additional PFOS and PFOA data that may be collected including any influent, intake, in-plant, collection system sampling, and blank sample results.</p> <p>The permittee shall also submit a request to the department to evaluate the need for a PFOS/PFOA minimization plan.</p> <p>If the Department determines a PFOS/PFOA minimization plan is needed based on a reasonable potential evaluation, the permittee will be required to develop a minimization plan for Department approval no later than 90 days after written notification was sent from the Department. The Department will modify or revoke and reissue the permit to include PFOS/PFOA minimization plan reporting requirements along with a schedule of compliance to meet WQBELs. Effluent monitoring of PFOS and PFOA shall continue as specified in the permit until the modified permit is issued.</p> <p>If, however, the Department determines there is no reasonable potential for the facility to discharge PFOS or PFOA above the narrative standard in s. NR 102.04(8)(d), Wis. Adm. Code, no further action is required and effluent monitoring of PFOS and PFOA shall continue as specified in the permit.</p>	06/30/2026

### 5.2 Sludge Management Plan

A management plan is required for the sludge management program.

Required Action	Due Date
<p><b>Sludge Management Plan Submittal:</b> Submit a sludge management plan to optimize the sludge management program performance and demonstrate compliance with ch. NR 204, Wis. Adm. Code, by the Due Date. This management plan shall include sufficient detail of the sludge management program for the facility. The plan shall include separate sections for each type of sewage sludge included in this permit.</p> <p>The SMP shall provide standardized information for communication to operators and the department including but not limited to the following:</p> <ol style="list-style-type: none"> <li>1) Specify information on sludge treatment processes for each sampling point and outfall;</li> <li>2) Sample point and outfall monitoring locations shown on a schematic and with photos;</li> <li>3) Monitoring requirements at each sampling point(s) and outfall location(s);</li> </ol>	12/31/2024

Required Action	Due Date
<p>4) Sampling protocols for each location and parameters at each location including treatment temperature, moisture content (total solids), fecal concentration as required;</p> <p>5) Monitoring frequencies at each sample point and outfalls;</p> <p>6) Analytical methods with appropriate hold times and chain of custody procedures;</p> <p>7) Provide documentation relating to temperature monitoring data recording, retrieval and printing out the data when requested;</p> <p>8) Storage, pickup and transportation details associated with all outfalls;</p> <p>9) Collection, storage, disposal information for cake sludge detailing pick-ups; and</p> <p>10) Collection, storage, and disposal processes of dried cake sludge when the cake sludge does not meet minimum requirements to meet Class A and EQ requirements.</p> <p>11) Identify land application sites;</p> <p>12) Describe site limitations;</p> <p>13) Address vegetative cover management and removal;</p> <p>14) Specify availability of storage;</p> <p>15) Describe the type of transporting and spreading vehicle(s);</p> <p>16) Track site loadings;</p> <p>17) Address contingency plans for adverse weather and odor/nuisance abatement; and</p> <p>18) Include any other pertinent information.</p> <p>Once approved, all sludge management activities shall be conducted in accordance with the plan. Any changes to the plan must be approved by the department prior to implementing the changes.</p>	

### 5.3 Capacity, Management, Operation, and Maintenance (CMOM) Program

The permittee shall have written documentation of the CMOM program components in accordance with s. NR 210.23(4), Wis. Adm. Code.

Required Action	Due Date
<p><b>Revised CMOM Program:</b> Review and revise the Capacity, Management, Operation and Maintenance (CMOM) Program to meet the requirements of s. NR 210.23, Wis. Adm. Code. A revised copy of the program shall be submitted to the department by the due date.</p>	09/30/2024

## 6 Standard Requirements

**NR 205, Wisconsin Administrative Code:** The conditions in ss. NR 205.07(1) and NR 205.07(2), Wis. Adm. Code, are included by reference in this permit. The permittee shall comply with all of these requirements. Some of these requirements are outlined in the Standard Requirements section of this permit. Requirements not specifically outlined in the Standard Requirement section of this permit can be found in ss. NR 205.07(1) and NR 205.07(2).

### 6.1 Reporting and Monitoring Requirements

#### 6.1.1 Monitoring Results

Monitoring results obtained during the previous month shall be summarized and reported on a Department Wastewater Discharge Monitoring Report. The report may require reporting of any or all of the information specified below under 'Recording of Results'. This report is to be returned to the Department no later than the date indicated on the form. A copy of the Wastewater Discharge Monitoring Report Form or an electronic file of the report shall be retained by the permittee.

Monitoring results shall be reported on an electronic discharge monitoring report (eDMR). The eDMR shall be certified electronically by a responsible executive or municipal officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The 'eReport Certify' page certifies that the electronic report form is true, accurate and complete.

If the permittee monitors any pollutant more frequently than required by this permit, the results of such monitoring shall be included on the Wastewater Discharge Monitoring Report.

The permittee shall comply with all limits for each parameter regardless of monitoring frequency. For example, monthly, weekly, and/or daily limits shall be met even with monthly monitoring. The permittee may monitor more frequently than required for any parameter.

#### 6.1.2 Sampling and Testing Procedures

Sampling and laboratory testing procedures shall be performed in accordance with Chapters NR 218 and NR 219, Wis. Adm. Code and shall be performed by a laboratory certified or registered in accordance with the requirements of ch. NR 149, Wis. Adm. Code. Groundwater sample collection and analysis shall be performed in accordance with ch. NR 140, Wis. Adm. Code. The analytical methodologies used shall enable the laboratory to quantitate all substances for which monitoring is required at levels below the effluent limitation. If the required level cannot be met by any of the methods available in NR 219, Wis. Adm. Code, then the method with the lowest limit of detection shall be selected. Additional test procedures may be specified in this permit.

#### 6.1.3 Recording of Results

The permittee shall maintain records which provide the following information for each effluent measurement or sample taken:

- the date, exact place, method and time of sampling or measurements;
- the individual who performed the sampling or measurements;
- the date the analysis was performed;
- the individual who performed the analysis;
- the analytical techniques or methods used; and
- the results of the analysis.

#### **6.1.4 Reporting of Monitoring Results**

The permittee shall use the following conventions when reporting effluent monitoring results:

- Pollutant concentrations less than the limit of detection shall be reported as < (less than) the value of the limit of detection. For example, if a substance is not detected at a detection limit of 0.1 mg/L, report the pollutant concentration as < 0.1 mg/L.
- Pollutant concentrations equal to or greater than the limit of detection, but less than the limit of quantitation, shall be reported and the limit of quantitation shall be specified.
- For purposes of calculating NR 101 fees, a reporting limit of 2.0 mg/L for BOD<sub>5</sub> and 2.5 mg/L Total Suspended Solids shall be considered to be limits of quantitation.
- For the purposes of reporting a calculated result, average or a mass discharge value, the permittee may substitute a “0” (zero) for any pollutant concentration that is less than the limit of detection. However, if the effluent limitation is less than the limit of detection, the department may substitute a value other than zero for results less than the limit of detection, after considering the number of monitoring results that are greater than the limit of detection and if warranted when applying appropriate statistical techniques.
- If no discharge occurs through an outfall, flow related parameters (e.g. flow rate, hydraulic application rate, volume, etc.) should be reported as “0” (zero) at the required sample frequency specified for the outfall. For example: if the sample frequency is daily, “0” would be reported for any day during the month that no discharge occurred.

#### **6.1.5 Compliance Maintenance Annual Reports**

Compliance Maintenance Annual Reports (CMAR) shall be completed using information obtained over each calendar year regarding the wastewater conveyance and treatment system. The CMAR shall be submitted and certified by the permittee in accordance with ch. NR 208, Wis. Adm. Code, by June 30, each year on an electronic report form provided by the Department.

In the case of a publicly owned treatment works, a resolution shall be passed by the governing body and submitted as part of the CMAR, verifying its review of the report and providing responses as required. Private owners of wastewater treatment works are not required to pass a resolution; but they must provide an Owner Statement and responses as required, as part of the CMAR submittal.

The CMAR shall be certified electronically by a responsible executive or municipal officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The certification verifies that the electronic report is true, accurate and complete.

#### **6.1.6 Records Retention**

The permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings or electronic data records for continuous monitoring instrumentation, copies of all reports required by the permit, and records of all data used to complete the application for the permit for a period of at least 3 years from the date of the sample, measurement, report or application. All pertinent sludge information, including permit application information and other documents specified in this permit or s. NR 204.06(9), Wis. Adm. Code shall be retained for a minimum of 5 years.

#### **6.1.7 Other Information**

Where the permittee becomes aware that it failed to submit any relevant facts in a permit application or submitted incorrect information in a permit application or in any report to the Department, it shall promptly submit such facts or correct information to the Department.



### 6.1.8 Reporting Requirements – Alterations or Additions

The permittee shall give notice to the Department as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is only required when:

- The alteration or addition to the permitted facility may meet one of the criteria for determining whether a facility is a new source.
- The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification requirement applies to pollutants which are not subject to effluent limitations in the existing permit.
- The alteration or addition results in a significant change in the permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use of disposal sites not reported during the permit application process nor reported pursuant to an approved land application plan. Additional sites may not be used for the land application of sludge until department approval is received.

## 6.2 System Operating Requirements

### 6.2.1 Noncompliance Reporting

Sanitary sewer overflows and sewage treatment facility overflows shall be reported according to the 'Sanitary Sewer Overflows and Sewage Treatment Facility Overflows' section of this permit.

The permittee shall report the following types of noncompliance by a telephone call to the Department's regional office within 24 hours after becoming aware of the noncompliance:

- any noncompliance which may endanger health or the environment;
- any violation of an effluent limitation resulting from a bypass;
- any violation of an effluent limitation resulting from an upset; and
- any violation of a maximum discharge limitation for any of the pollutants listed by the Department in the permit, either for effluent or sludge.

A written report describing the noncompliance shall also be submitted to the Department's regional office within 5 days after the permittee becomes aware of the noncompliance. On a case-by-case basis, the Department may waive the requirement for submittal of a written report within 5 days and instruct the permittee to submit the written report with the next regularly scheduled monitoring report. In either case, the written report shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times; the steps taken or planned to reduce, eliminate and prevent reoccurrence of the noncompliance; and if the noncompliance has not been corrected, the length of time it is expected to continue.

A scheduled bypass approved by the Department under the 'Scheduled Bypass' section of this permit shall not be subject to the reporting required under this section.

**NOTE:** Section 292.11(2)(a), Wisconsin Statutes, requires any person who possesses or controls a hazardous substance or who causes the discharge of a hazardous substance to notify the Department of Natural Resources immediately of any discharge not authorized by the permit. **The discharge of a hazardous substance that is not authorized by this permit or that violates this permit may be a hazardous substance spill. To report a hazardous substance spill, call DNR's 24-hour HOTLINE at 1-800-943-0003.**

### 6.2.2 Flow Meters

Flow meters shall be calibrated annually, as per s. NR 218.06, Wis. Adm. Code.

### **6.2.3 Raw Grit and Screenings**

All raw grit and screenings shall be disposed of at a properly licensed solid waste facility or picked up by a licensed waste hauler. If the facility or hauler are located in Wisconsin, then they shall be licensed under chs. NR 500-555, Wis. Adm. Code.

### **6.2.4 Sludge Management**

All sludge management activities shall be conducted in compliance with ch. NR 204 "Domestic Sewage Sludge Management", Wis. Adm. Code.

### **6.2.5 Prohibited Wastes**

Under no circumstances may the introduction of wastes prohibited by s. NR 211.10, Wis. Adm. Code, be allowed into the waste treatment system. Prohibited wastes include those:

- which create a fire or explosion hazard in the treatment work;
- which will cause corrosive structural damage to the treatment work;
- solid or viscous substances in amounts which cause obstructions to the flow in sewers or interference with the proper operation of the treatment work;
- wastewaters at a flow rate or pollutant loading which are excessive over relatively short time periods so as to cause a loss of treatment efficiency; and
- changes in discharge volume or composition from contributing industries which overload the treatment works or cause a loss of treatment efficiency.

### **6.2.6 Bypass**

This condition applies only to bypassing at a sewage treatment facility that is not a scheduled bypass, approved blending as a specific condition of this permit, a sewage treatment facility overflow or a controlled diversion as provided in the sections titled 'Scheduled Bypass', 'Blending' (if approved), 'SSO's and Sewage Treatment Facility Overflows' and 'Controlled Diversions' of this permit. Any other bypass at the sewage treatment facility is prohibited and the Department may take enforcement action against a permittee for such occurrences under s. 283.89, Wis. Stats. The Department may approve a bypass if the permittee demonstrates all the following conditions apply:

- The bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
- There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities or adequate back-up equipment, retention of untreated wastes, reduction of inflow and infiltration, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventative maintenance. When evaluating feasibility of alternatives, the department may consider factors such as technical achievability, costs and affordability of implementation and risks to public health, the environment and, where the permittee is a municipality, the welfare of the community served; and
- The bypass was reported in accordance with the Noncompliance Reporting section of this permit.

### **6.2.7 Scheduled Bypass**

Whenever the permittee anticipates the need to bypass for purposes of efficient operations and maintenance and the permittee may not meet the conditions for controlled diversions in the 'Controlled Diversions' section of this permit, the permittee shall obtain prior written approval from the Department for the scheduled bypass. A permittee's written request for Department approval of a scheduled bypass shall demonstrate that the conditions for bypassing specified in the above section titled 'Bypass' are met and include the proposed date and reason for the bypass, estimated volume and duration of the bypass, alternatives to bypassing and measures to mitigate environmental harm caused by

the bypass. The department may require the permittee to provide public notification for a scheduled bypass if it is determined there is significant public interest in the proposed action and may recommend mitigation measures to minimize the impact of such bypass.

### **6.2.8 Controlled Diversions**

Controlled diversions are allowed only when necessary for essential maintenance to assure efficient operation. Sewage treatment facilities that have multiple treatment units to treat variable or seasonal loading conditions may shut down redundant treatment units when necessary for efficient operation. The following requirements shall be met during controlled diversions:

- Effluent from the sewage treatment facility shall meet the effluent limitations established in the permit. Wastewater that is diverted around a treatment unit or treatment process during a controlled diversion shall be recombined with wastewater that is not diverted prior to the effluent sampling location and prior to effluent discharge;
- A controlled diversion does not include blending as defined in s. NR 210.03(2e), Wis. Adm. Code, and as may only be approved under s. NR 210.12. A controlled diversion may not occur during periods of excessive flow or other abnormal wastewater characteristics;
- A controlled diversion may not result in a wastewater treatment facility overflow; and
- All instances of controlled diversions shall be documented in sewage treatment facility records and such records shall be available to the department on request.

### **6.2.9 Proper Operation and Maintenance**

The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance includes effective performance, adequate funding, adequate operator staffing and training as required in ch. NR 114, Wis. Adm. Code, and adequate laboratory and process controls, including appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems only when necessary to achieve compliance with the conditions of the permit.

### **6.2.10 Operator Certification**

The wastewater treatment facility shall be under the direct supervision of a state certified operator. In accordance with s. NR 114.53, Wis. Adm. Code, every WPDES permitted treatment plant shall have a designated operator-in-charge holding a current and valid certificate. The designated operator-in-charge shall be certified at the level and in all subclasses of the treatment plant, except laboratory. Treatment plant owners shall notify the department of any changes in the operator-in-charge within 30 days. Note that s. NR 114.52(22), Wis. Adm. Code, lists types of facilities that are excluded from operator certification requirements (i.e. private sewage systems, pretreatment facilities discharging to public sewers, industrial wastewater treatment that consists solely of land disposal, agricultural digesters and concentrated aquatic production facilities with no biological treatment).

## **6.3 Sewage Collection Systems**

### **6.3.1 Sanitary Sewage Overflows and Sewage Treatment Facility Overflows**

#### **6.3.1.1 Overflows Prohibited**

Any overflow or discharge of wastewater from the sewage collection system or at the sewage treatment facility, other than from permitted outfalls, is prohibited. The permittee shall provide information on whether any of the following conditions existed when an overflow occurred:

- The sanitary sewer overflow or sewage treatment facility overflow was unavoidable to prevent loss of life, personal injury or severe property damage;

- There were no feasible alternatives to the sanitary sewer overflow or sewage treatment facility overflow such as the use of auxiliary treatment facilities or adequate back-up equipment, retention of untreated wastes, reduction of inflow and infiltration, or preventative maintenance activities;
- The sanitary sewer overflow or the sewage treatment facility overflow was caused by unusual or severe weather related conditions such as large or successive precipitation events, snowmelt, saturated soil conditions, or severe weather occurring in the area served by the sewage collection system or sewage treatment facility; and
- The sanitary sewer overflow or the sewage treatment facility overflow was unintentional, temporary, and caused by an accident or other factors beyond the reasonable control of the permittee.

### 6.3.1.2 Permittee Response to Overflows

Whenever a sanitary sewer overflow or sewage treatment facility overflow occurs, the permittee shall take all feasible steps to control or limit the volume of untreated or partially treated wastewater discharged, and terminate the discharge as soon as practicable. Remedial actions, including those in NR 210.21 (3), Wis. Adm. Code, shall be implemented consistent with an emergency response plan developed under the CMOM program.

### 6.3.1.3 Permittee Reporting

Permittees shall report all sanitary sewer overflows and sewage treatment overflows as follows:

- The permittee shall notify the department by telephone, fax or email as soon as practicable, but no later than 24 hours from the time the permittee becomes aware of the overflow;
- The permittee shall, no later than five days from the time the permittee becomes aware of the overflow, provide to the department the information identified in this paragraph using department form number 3400-184. If an overflow lasts for more than five days, an initial report shall be submitted within 5 days as required in this paragraph and an updated report submitted following cessation of the overflow. At a minimum, the following information shall be included in the report:
  - The date and location of the overflow;
  - The surface water to which the discharge occurred, if any;
  - The duration of the overflow and an estimate of the volume of the overflow;
  - A description of the sewer system or treatment facility component from which the discharge occurred such as manhole, lift station, constructed overflow pipe, or crack or other opening in a pipe;
  - The estimated date and time when the overflow began and stopped or will be stopped;
  - The cause or suspected cause of the overflow including, if appropriate, precipitation, runoff conditions, areas of flooding, soil moisture and other relevant information;
  - Steps taken or planned to reduce, eliminate and prevent reoccurrence of the overflow and a schedule of major milestones for those steps;
  - A description of the actual or potential for human exposure and contact with the wastewater from the overflow;
  - Steps taken or planned to mitigate the impacts of the overflow and a schedule of major milestones for those steps;
  - To the extent known at the time of reporting, the number and location of building backups caused by excessive flow or other hydraulic constraints in the sewage collection system that occurred concurrently with the sanitary sewer overflow and that were within the same area of the sewage collection system as the sanitary sewer overflow; and
  - The reason the overflow occurred or explanation of other contributing circumstances that resulted in the overflow event. This includes any information available including whether the overflow was

unavoidable to prevent loss of life, personal injury, or severe property damage and whether there were feasible alternatives to the overflow.

**NOTE:** A copy of form 3400-184 for reporting sanitary sewer overflows and sewage treatment facility overflows may be obtained from the department or accessed on the department's web site at <http://dnr.wi.gov/topic/wastewater/SSOreport.html>. As indicated on the form, additional information may be submitted to supplement the information required by the form.

- The permittee shall identify each specific location and each day on which a sanitary sewer overflow or sewage treatment facility overflow occurs as a discrete sanitary sewer overflow or sewage treatment facility overflow occurrence. An occurrence may be more than one day if the circumstances causing the sanitary sewer overflow or sewage treatment facility overflow results in a discharge duration of greater than 24 hours. If there is a stop and restart of the overflow at the same location within 24 hours and the overflow is caused by the same circumstance, it may be reported as one occurrence. Sanitary sewer overflow occurrences at a specific location that are separated by more than 24 hours shall be reported as separate occurrences; and
- A permittee that is required to submit wastewater discharge monitoring reports under NR 205.07 (1) (r) shall also report all sanitary sewer overflows and sewage treatment facility overflows on that report.

#### **6.3.1.4 Public Notification**

The permittee shall notify the public of any sanitary sewer and sewage treatment facility overflows consistent with its emergency response plan required under the CMOM (Capacity, Management, Operation and Maintenance) section of this permit and s. NR 210.23 (4) (f), Wis. Adm. Code. Such public notification shall occur promptly following any overflow event using the most effective and efficient communications available in the community. At minimum, a daily newspaper of general circulation in the county(s) and municipality whose waters may be affected by the overflow shall be notified by written or electronic communication.

#### **6.3.2 Capacity, Management, Operation and Maintenance (CMOM) Program**

- The permittee shall have written documentation of the Capacity, Management, Operation and Maintenance (CMOM) program components in accordance with s. NR 210.23(4), Wis. Adm. Code. Such documentation shall be available for Department review upon request. The Department may request that the permittee provide this documentation or prepare a summary of the permittee's CMOM program at the time of application for reissuance of the WPDES permit.
- The permittee shall implement a CMOM program in accordance with s. NR 210.23, Wis. Adm. Code.
- The permittee shall at least annually conduct a self-audit of activities conducted under the permittee's CMOM program to ensure CMOM components are being implemented as necessary to meet the general standards of s. NR 210.23(3), Wis. Adm. Code.

#### **6.3.3 Sewer Cleaning Debris and Materials**

All debris and material removed from cleaning sanitary sewers shall be managed to prevent nuisances, run-off, ground infiltration or prohibited discharges.

- Debris and solid waste shall be dewatered, dried and then disposed of at a licensed solid waste facility.
- Liquid waste from the cleaning and dewatering operations shall be collected and disposed of at a permitted wastewater treatment facility.
- Combination waste including liquid waste along with debris and solid waste may be disposed of at a licensed solid waste facility or wastewater treatment facility willing to accept the waste.

## 6.4 Surface Water Requirements

### 6.4.1 Permittee-Determined Limit of Quantitation Incorporated into this Permit

For pollutants with water quality-based effluent limits below the Limit of Quantitation (LOQ) in this permit, the LOQ calculated by the permittee and reported on the Discharge Monitoring Reports (DMRs) is incorporated by reference into this permit. The LOQ shall be reported on the DMRs, shall be the lowest quantifiable level practicable, and shall be no greater than the minimum level (ML) specified in or approved under 40 CFR Part 136 for the pollutant at the time this permit was issued, unless this permit specifies a higher LOQ.

### 6.4.2 Appropriate Formulas for Effluent Calculations

The permittee shall use the following formulas for calculating effluent results to determine compliance with average concentration limits and mass limits and total load limits:

**Weekly/Monthly/Six-Month/Annual Average Concentration** = the sum of all daily results for that week/month/six-month/year, divided by the number of results during that time period. [Note: When a six-month average effluent limit is specified for Total Phosphorus the applicable periods are May through October and November through April, except in cases of Water Quality Trading, wherein the applicable periods are January through June and July through December.]

**Weekly Average Mass Discharge (lbs/day):** Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the week.

**Monthly Average Mass Discharge (lbs/day):** Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the month.

**Six-Month Average Mass Discharge (lbs/day):** Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the six-month period. [Note: When a six-month average effluent limit is specified for Total Phosphorus the applicable periods are May through October and November through April.]

**Annual Average Mass Discharge (lbs/day):** Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the entire year.

**Total Monthly Discharge:** = monthly average concentration (mg/L) x total flow for the month (MG/month) x 8.34.

**Total Annual Discharge:** = sum of total monthly discharges for the calendar year.

**12-Month Rolling Sum of Total Monthly Discharge:** = the sum of the most recent 12 consecutive months of Total Monthly Discharges.

### 6.4.3 Effluent Temperature Requirements

**Weekly Average Temperature** – If temperature limits are included in this permit, Weekly Average Temperature shall be calculated as the sum of all daily maximum results for that week divided by the number of daily maximum results during that time period.

**Cold Shock Standard** – Water temperatures of the discharge shall be controlled in a manner as to protect fish and aquatic life uses from the deleterious effects of cold shock pursuant to Wis. Adm. Code, s. NR 102.28. ‘Cold Shock’ means exposure of aquatic organisms to a rapid decrease in temperature and a sustained exposure to low temperature that induces abnormal behavior or physiological performance and may lead to death.

**Rate of Temperature Change Standard** – Temperature of a water of the state or discharge to a water of the state may not be artificially raised or lowered at such a rate that it causes detrimental health or reproductive effects to fish or aquatic life of the water of the state pursuant to Wis. Adm. Code, s. NR 102.29.

### 6.4.4 Visible Foam or Floating Solids

There shall be no discharge of floating solids or visible foam in other than trace amounts.

### 6.4.5 Surface Water Uses and Criteria

In accordance with NR 102.04, Wis. Adm. Code, surface water uses and criteria are established to govern water management decisions. Practices attributable to municipal, industrial, commercial, domestic, agricultural, land development or other activities shall be controlled so that all surface waters including the mixing zone meet the following conditions at all times and under all flow and water level conditions:

- a) Substances that will cause objectionable deposits on the shore or in the bed of a body of water, shall not be present in such amounts as to interfere with public rights in waters of the state.
- b) Floating or submerged debris, oil, scum or other material shall not be present in such amounts as to interfere with public rights in waters of the state.
- c) Materials producing color, odor, taste or unsightliness shall not be present in such amounts as to interfere with public rights in waters of the state.
- d) Substances in concentrations or in combinations which are toxic or harmful to humans shall not be present in amounts found to be of public health significance, nor shall substances be present in amounts which are acutely harmful to animal, plant or aquatic life.

### 6.4.6 Percent Removal

During any 30 consecutive days, the average effluent concentrations of BOD<sub>5</sub> and of total suspended solids shall not exceed 15% of the average influent concentrations, respectively. This requirement does not apply to removal of total suspended solids if the permittee operates a lagoon system and has received a variance for suspended solids granted under NR 210.07(2), Wis. Adm. Code.

### 6.4.7 *E. coli*

The monthly limit for *E. coli* shall be expressed as a geometric mean. In calculating the geometric mean, a value of 1 is used for any result of 0.

### 6.4.8 Seasonal Disinfection

Disinfection shall be provided from May 1 through September 30 of each year. Monitoring requirements and the limitations for Fecal Coliform (interim) and *E. coli* apply only during the period in which disinfection is required. Whenever chlorine is used for disinfection or other uses, the limitations and monitoring requirements for residual chlorine shall apply. A dechlorination process shall be in operation whenever chlorine is used.

### 6.4.9 Total Residual Chlorine Requirements

When total residual chlorine (TRC) limit(s) or monitoring are included in a permit, the permittee shall comply with the following conditions:

- a) The permittee shall perform TRC monitoring required in this permit using an approved method from ch. NR 219, Wis. Adm. Code, which produces a detection limit that is less than or equal to the permitted limit or produces the lowest economically feasible detection limit if the approved methods cannot meet the permit limit. If the facility cannot achieve a detection limit less than or equal to the permit limit using the approved methods, contact the laboratory accreditation program for guidance.
- b) The permittee shall determine the limit of detection (LOD) as specified in s. NR 149.48 (2)(b), Wis. Adm. Code, or the permittee shall contact the laboratory accreditation program for information on how to determine a verified detection limit allowed just for TRC. If the verified detection limit is determined using the special procedure, then the LOD and limit of quantitation (LOQ) shall be set to be equal to the verified detection limit determined from this special procedure.
- c) The permittee shall determine compliance with the TRC limit(s) as follows:
  1. If the facility determines a statistical LOD as specified in s. NR 149.48 (2)(b), Wis. Adm. Code, and the measured TRC levels are less than the LOD, the permittee shall report the results as less than the

- LOD (<LOD). For this situation the LOQ shall be established at 3.33 times the LOD or at the concentration of the lowest standard in the calibration curve. TRC levels that are < LOD are in compliance with the TRC limit.
2. If the facility determines the verified detection limit using the laboratory accreditation program special procedure, this verified detection limit shall be reported as the LOD and LOQ. If the measured TRC levels are less than the LOD, the permittee shall report the results as < LOD. TRC levels that are < LOD are in compliance with the TRC limit.
  3. If the facility determines the statistical LOD as specified in s. NR 149.48 (2)(b), Wis. Adm. Code, and the measured TRC levels are greater than the statistical LOD but less than the LOQ, TRC levels are in compliance with the TRC limit - except when the measured levels are consistently reported between the LOD and LOQ. When the measured TRC levels are consistently reported between the LOD and LOQ, the facility shall take action to determine the reliability of detected results (such as resampling and/or re-calculating dosages) and shall adjust the chemical feed system if necessary to reduce the chances of detecting levels between the statistical LOD and LOQ.
  4. If the facility determines the statistical LOQ as specified in s. NR 149.48 (2)(b), Wis. Adm. Code, or determines the verified detection limit using the laboratory accreditation program special procedure, TRC measured levels that are greater than the statistical LOQ and the TRC limit, are not in compliance with the TRC limit. The permittee shall report the level as a limit exceedance.
  5. If the facility determines the statistical LOD as specified in s. NR 149.48 (2)(b), Wis. Adm. Code, and the measured level is < LOD, then a "0" (zero) value may be substituted for any test result less than the statistical LOD when calculating the average or mass discharge values. Calculated values shall then be compared directly to the average or mass limits to determine compliance.
  6. If the facility determines the verified detection limit using the laboratory accreditation program special procedure and the measured level is < LOD (set equal to the verified detection limit), then a "0" (zero) value may be substituted for any test result less than the LOD when calculating the average or mass discharge values. Calculated values shall then be compared directly to the average or mass limits to determine compliance.

#### **6.4.10 Whole Effluent Toxicity (WET) Monitoring Requirements**

In order to determine the potential impact of the discharge on aquatic organisms, static-renewal toxicity tests shall be performed on the effluent in accordance with the procedures specified in the "*State of Wisconsin Aquatic Life Toxicity Testing Methods Manual, 2<sup>nd</sup> Edition*" (PUB-WT-797, November 2004) as required by NR 219.04, Table A, Wis. Adm. Code). All of the WET tests required in this permit, including any required retests, shall be conducted on the *Ceriodaphnia dubia* and fathead minnow species. Receiving water samples shall not be collected from any point in contact with the permittee's mixing zone and every attempt shall be made to avoid contact with any other discharge's mixing zone.

#### **6.4.11 Whole Effluent Toxicity (WET) Identification and Reduction**

Within 60 days of a retest which showed positive results, the permittee shall submit a written report to the Biomonitoring Coordinator, Bureau of Water Quality, 101 S. Webster St., PO Box 7921, Madison, WI 53707-7921, which details the following:

- A description of actions the permittee has taken or will take to remove toxicity and to prevent the recurrence of toxicity;
- A description of toxicity reduction evaluation (TRE) investigations that have been or will be done to identify potential sources of toxicity, including the following actions:
  - a) Evaluate the performance of the treatment system to identify deficiencies contributing to effluent toxicity (e.g., operational problems, chemical additives, incomplete treatment)



- b) Identify the compound(s) causing toxicity. Conduct toxicity screening tests on the effluent at a minimum of once per month for six months to determine if toxicity recurs. Screening tests are WET tests using fewer effluent concentrations conducted on the most sensitive species. If any of the screening tests contain toxicity, conduct a toxicity identification evaluation (TIE) to determine the cause. TIE methods are available from USEPA “Methods for Aquatic Toxicity Identification Evaluations: Phase I Toxicity Characterization Procedures (EPA/600/6-91/003) and “Toxicity Identification Evaluation: Characterization of Chronically Toxic Effluents, Phase I” (EPA/600/6-91/005F).
- c) Trace the compound(s) causing toxicity to their sources (e.g., industrial, commercial, domestic)
- d) Evaluate, select, and implement methods or technologies to control effluent toxicity (e.g., in-plant or pretreatment controls, source reduction or removal)
  - Where corrective actions including a TRE have not been completed, an expeditious schedule under which corrective actions will be implemented;
  - If no actions have been taken, the reason for not taking action.

The permittee may also request approval from the Department to postpone additional retests in order to investigate the source(s) of toxicity. Postponed retests must be completed after toxicity is believed to have been removed.

#### **6.4.12 PFOS and PFOA Requirements**

The laboratory performing the analysis on any samples shall be certified for the applicable PFAS compounds in the aqueous matrix by the Wisconsin Laboratory Certification Program established under s. 299.11, Wis. Stats., in accordance with s. NR 149.41, Wis. Adm. Code. If the EPA Office of Water publishes a 1600 series isotope dilution method for the analysis of PFAS in wastewater, the department recommends the use of the EPA method.

The Department may reject any sample results if results are produced by a laboratory that is not in compliance with certification requirements under ch. NR 149, Wis. Adm. Code.

### **6.5 Land Application Requirements**

#### **6.5.1 Sludge Management Program Standards And Requirements Based Upon Federally Promulgated Regulations**

In the event that new federal sludge standards or regulations are promulgated, the permittee shall comply with the new sludge requirements by the dates established in the regulations, if required by federal law, even if the permit has not yet been modified to incorporate the new federal regulations.

#### **6.5.2 General Sludge Management Information**

The General Sludge Management Form 3400-48 shall be completed and submitted prior to any significant sludge management changes.

#### **6.5.3 Sludge Samples**

All sludge samples shall be collected at a point and in a manner which will yield sample results which are representative of the sludge being tested, and collected at the time which is appropriate for the specific test.

#### **6.5.4 Land Application Characteristic Report**

Each report shall consist of a Characteristic Form 3400-49 and Lab Report. The Characteristic Report Form 3400-49 shall be submitted electronically by January 31 following each year of analysis.

Following submittal of the electronic Characteristic Report Form 3400-49, this form shall be certified electronically via the ‘eReport Certify’ page by a responsible executive or municipal officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor

that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The ‘eReport Certify’ page certifies that the electronic report is true, accurate and complete. The Lab Report must be sent directly to the facility’s DNR sludge representative or basin engineer unless approval for not submitting the lab reports has been given.

The permittee shall use the following convention when reporting sludge monitoring results: Pollutant concentrations less than the limit of detection shall be reported as < (less than) the value of the limit of detection. For example, if a substance is not detected at a detection limit of 1.0 mg/kg, report the pollutant concentration as < 1.0 mg/kg .

All results shall be reported on a dry weight basis.

### 6.5.5 Calculation of Water Extractable Phosphorus

When sludge analysis for Water Extractable Phosphorus is required by this permit, the permittee shall use the following formula to calculate and report Water Extractable Phosphorus:

Water Extractable Phosphorus (% of Total P) =

$[\text{Water Extractable Phosphorus (mg/kg, dry wt)} \div \text{Total Phosphorus (mg/kg, dry wt)}] \times 100$

### 6.5.6 Monitoring and Calculating PCB Concentrations in Sludge

When sludge analysis for “PCB, Total Dry Wt” is required by this permit, the PCB concentration in the sludge shall be determined using either congener-specific analysis or Aroclor analysis. The permittee may decide which of these analyses is performed. Analyses shall be performed in accordance with the following provisions and Table EM in s. NR 219.04, Wis. Adm. Code:

- If congener-specific analysis is employed: All PCB congeners shall be delineated. Non-detects shall be treated as zero. The values that are between the limit of detection (LOD) and the limit of quantitation shall be used when calculating the total value of all congeners. All results shall be added together and the total PCB concentration by dry weight reported.
- If Aroclor analysis is employed, reporting protocols, consistent with s. NR 106.07(6)(e), should be as follows: If all Aroclors are less than the LOD, then the Total PCB Dry Wt result should be reported as less than the highest LOD. If a single Aroclor is detected, then that is what should be reported for the Total PCB result. If multiple Aroclors are detected, they should be summed and reported as Total PCBs. If the LOD cannot be achieved after using the appropriate clean up techniques, a reporting limit that is achievable for the Aroclors or each congener for the sample shall be determined. This reporting limit shall be reported and qualified indicating the presence of an interference.

### 6.5.7 Annual Land Application Report

Land Application Report Form 3400-55 shall be submitted electronically by January 31, each year whether or not non-exceptional quality sludge is land applied. Non-exceptional quality sludge is defined in s. NR 204.07(4), Wis. Adm. Code. Following submittal of the electronic Annual Land Application Report Form 3400-55, this form shall be certified electronically via the ‘eReport Certify’ page by a responsible executive or municipal officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The ‘eReport Certify’ page certifies that the electronic report form is true, accurate and complete.

### 6.5.8 Other Methods of Disposal or Distribution Report

The permittee shall submit electronically the Other Methods of Disposal or Distribution Report Form 3400-52 by January 31, each year whether or not sludge is hauled, landfilled, incinerated, or exceptional quality sludge is distributed or land applied. Following submittal of the electronic Report Form 3400-52, this form shall be certified electronically via the ‘eReport Certify’ page by a responsible executive or municipal officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The ‘eReport Certify’ page certifies that the electronic report form is true, accurate and complete.

### **6.5.9 Approval to Land Apply**

Bulk non-exceptional quality sludge as defined in s. NR 204.07(4), Wis. Adm. Code, may not be applied to land without a written approval letter or Form 3400-122 from the Department unless the Permittee has obtained permission from the Department to self approve sites in accordance with s. NR 204.06 (6), Wis. Adm. Code. Analysis of sludge characteristics is required prior to land application. Application on frozen or snow covered ground is restricted to the extent specified in s. NR 204.07(3) (l), Wis. Adm. Code.

### **6.5.10 Soil Analysis Requirements**

Each site requested for approval for land application must have the soil tested prior to use. Each approved site used for land application must subsequently be soil tested such that there is at least one valid soil test in the four years prior to land application. All soil sampling and submittal of information to the testing laboratory shall be done in accordance with UW Extension Bulletin A-2100. The testing shall be done by the UW Soils Lab in Madison or Marshfield, WI or at a lab approved by UW. The test results including the crop recommendations shall be submitted to the DNR contact listed for this permit, as they are available. Application rates shall be determined based on the crop nitrogen recommendations and with consideration for other sources of nitrogen applied to the site.

### **6.5.11 Land Application Site Evaluation**

For non-exceptional quality sludge, as defined in s. NR 204.07(4), Wis. Adm. Code, a Land Application Site Request Form 3400-053 shall be submitted to the Department for the proposed land application site. The Department will evaluate the proposed site for acceptability and will either approve or deny use of the proposed site. The permittee may obtain permission to approve their own sites in accordance with s. NR 204.06(6), Wis. Adm. Code.

### **6.5.12 Class A Sludge: Fecal Coliform Density Requirement**

The fecal coliform density which must be  $< 1000$  MPN/g TS as required in s. NR 204.07, Wis. Adm. Code, shall be satisfied immediately after the treatment process is completed. If the material is bagged or distributed at that time, no re-testing is required. If the material is bagged, distributed or land applied at a later time, the sludge shall be re-tested and this requirement satisfied at that time also, to ensure that regrowth of bacteria has not occurred. See Municipal Wastewater Sludge Guidance Memo #3 (Fecal Coliform Monitoring - Sampling and Analytical Procedures).

### **6.5.13 Class A Sludge: Salmonella Density Requirements**

The salmonella density which must be  $< 3$  MPN/4 g TS as required in s. NR 204.07, Wis. Adm. Code, shall be satisfied immediately after the treatment process is completed. If the material is bagged or distributed at that time, no re-testing is required. If the material is bagged, distributed or land applied at a later time, the sludge shall be re-tested and this requirement satisfied at that time also, to ensure that regrowth of bacteria has not occurred.

### **6.5.14 Class A Sludge: Heat Drying Process**

Dry the sludge by direct or indirect contact with hot gases to reduce the moisture content of the sludge to 10% or lower. Either the temperature of the sewage sludge particles shall exceed  $80^{\circ}$  C or the wet bulb temperature of the gas in contact with the sludge as the sludge leaves the dryer shall exceed  $80^{\circ}$  C. Permittee shall continuously monitor temperature to ensure all sludge particles are treated to  $80^{\circ}$  C. Permittee shall monitor sludge moisture. Temperature and moisture measurements shall be collected and recorded during startup, operation and shutdown of the dryer. Sludge heat drying treatment records shall be made available to the department upon request.

### **6.5.15 Class B Sludge: Fecal Coliform Limitation**

Compliance with the fecal coliform limitation for Class B sludge shall be demonstrated by calculating the geometric mean of at least 7 separate samples. (Note that a Total Solids analysis must be done on each sample). The geometric mean shall be less than 2,000,000 MPN or CFU/g TS. Calculation of the geometric mean can be done using one of the following 2 methods.

Method 1:

$$\text{Geometric Mean} = (X_1 \times X_2 \times X_3 \dots \times X_n)^{1/n}$$

Where X = Coliform Density value of the sludge sample, and where n = number of samples (at least 7)

Method 2:

$$\text{Geometric Mean} = \text{antilog}[(X_1 + X_2 + X_3 \dots + X_n) \div n]$$

Where X = log<sub>10</sub> of Coliform Density value of the sludge sample, and where n = number of samples (at least 7)

Example for Method 2

Sample Number	Coliform Density of Sludge Sample	log <sub>10</sub>
1	6.0 x 10 <sup>5</sup>	5.78
2	4.2 x 10 <sup>6</sup>	6.62
3	1.6 x 10 <sup>6</sup>	6.20
4	9.0 x 10 <sup>5</sup>	5.95
5	4.0 x 10 <sup>5</sup>	5.60
6	1.0 x 10 <sup>6</sup>	6.00
7	5.1 x 10 <sup>5</sup>	5.71

The geometric mean for the seven samples is determined by averaging the log<sub>10</sub> values of the coliform density and taking the antilog of that value.

$$(5.78 + 6.62 + 6.20 + 5.95 + 5.60 + 6.00 + 5.71) \div 7 = 5.98$$

The antilog of 5.98 = 9.5 x 10<sup>5</sup>

### 6.5.16 Class B Sludge: Anaerobic Digestion

Treat the sludge in the absence of air for a specific mean cell residence time at a specific temperature. Values for the mean cell residence time and temperature shall be between 15 days at 35° C to 55° C and 60 days at 20° C. Straight-line interpolation to calculate mean cell residence time is allowable when the temperature falls between 35° C and 20° C.

### 6.5.17 Vector Control: Drying With Primary Solids

Dry the sludge to 90% total solids when the sludge contains unstabilized solids from primary treatment. This shall be met at the time the sludge is bagged, distributed, land applied or disposed of.

### 6.5.18 Class A Sludge - Vector Control: Incorporation

Class A sludge shall be surface applied within 8 hours after being discharged from a pathogen treatment process and then be incorporated within 6 hours of surface application.

### 6.5.19 Class B Sludge - Vector Control: Incorporation

Class B sludge shall be incorporated within 6 hours of surface application, or as approved by the Department.

### 6.5.20 Landfilling of Sludge

General: Sewage sludge may not be disposed of in a municipal solid waste landfill unless the landfill meets the requirements of chs. NR 500 to 536, Wis. Adm. Code, and is an approved facility as defined in s. 289.01(3), Wis. Stats. Any facility accepting sewage sludge shall be approved by the Department in writing to accept sewage sludge.

Disposal of sewage sludge in a municipal solid waste landfill shall be in accordance with ss. NR 506.13 and 506.14. Sewage sludge may not be disposed of in a surface disposal unit as defined in s. NR 204.03(62).

Approval: The permittee shall obtain approval from the Department prior to the disposal of sludge at a Wisconsin licensed landfill.

### **6.5.21 Sludge Landfilling Reports**

The permittee shall report the volume of sludge disposed of at any landfill facility on Form 3400-52. The permittee shall include the name and address of the landfill, the Department license number or other state's designation or license number for all landfills used during the report period and a letter of acceptability from the landfill owner. In addition, any permittee utilizing landfills as a disposal method shall submit to the Department any test results used to indicate acceptability of the sludge at a landfill. Form 3400-52 shall be submitted annually by January 31, each year whether or not sludge is landfilled.

### **6.5.22 Sludge Hauling**

The permittee is required to submit Form 3400-52 to the Department. If sludge is hauled to another facility, information shall include the quantity of sludge hauled, the name, address, phone number, contact person, and permit number of the receiving facility. Form 3400-52 shall be submitted annually by January 31 each year whether or not sludge is hauled.

## 7 Summary of Reports Due

FOR INFORMATIONAL PURPOSES ONLY

Description	Date	Page
PFOS/PFOA Minimization Plan Determination of Need -Report on Effluent Discharge	June 30, 2025	26
PFOS/PFOA Minimization Plan Determination of Need -Report on Effluent Discharge and Evaluation of Need	June 30, 2026	26
Sludge Management Plan -Sludge Management Plan Submittal	December 31, 2024	26
Capacity, Management, Operation, and Maintenance (CMOM) Program - Revised CMOM Program	September 30, 2024	27
Compliance Maintenance Annual Reports (CMAR)	by June 30, each year	29
General Sludge Management Form 3400-48	prior to any significant sludge management changes	38
Characteristic Form 3400-49 and Lab Report	by January 31 following each year of analysis	38
Land Application Report Form 3400-55	by January 31, each year whether or not non-exceptional quality sludge is land applied	39
Other Methods of Disposal or Distribution Report Form 3400-52	by January 31, each year whether or not sludge is hauled, landfilled, incinerated, or exceptional quality sludge is distributed or land applied	39
Wastewater Discharge Monitoring Report	no later than the date indicated on the form	28

Report forms shall be submitted electronically in accordance with the reporting requirements herein. Any facility plans or plans and specifications for municipal, industrial, industrial pretreatment and non industrial wastewater systems shall be submitted to the Bureau of Water Quality, P.O. Box 7921, Madison, WI 53707-7921. All other submittals required by this permit shall be submitted to:  
Northeast Region - Oshkosh, 625 E Cty Rd Y, Suite 700, Oshkosh, WI 54901