

WPDES PERMIT

STATE OF WISCONSIN DEPARTMENT OF NATURAL RESOURCES permit to discharge under the wisconsin pollutant discharge elimination system

Lactalis USA Belmont Inc

is permitted, under the authority of Chapter 283, Wisconsin Statutes, to discharge from a facility located at 218 Park St, Belmont, WI 53510

to

Bonner Branch of the Sugar-Pecatonica River Basin (Middle Pecatonica Watershed, SP-08) in Lafayette County

in accordance with the effluent limitations, monitoring requirements and other conditions set forth in this permit.

The permittee shall not discharge after the date of expiration. If the permittee wishes to continue to discharge after this expiration date an application shall be filed for reissuance of this permit, according to Chapter NR 200, Wis. Adm. Code, at least 180 days prior to the expiration date given below.

State of Wisconsin Department of Natural Resources For the Secretary

By

Thomas Bauman Wastewater Field Supervisor

Date Permit Signed/Issued

PERMIT TERM: EFFECTIVE DATE - July 01, 2024

EXPIRATION DATE June 30, 2029

TABLE OF CONTENTS

1 SURFACE WATER REQUIREMENTS	1
1.1 SAMPLING POINT(S)	1
1.2 MONITORING REQUIREMENTS AND EFFLUENT LIMITATIONS	1
1.2.1 Sampling Point (Outfall) 002 - Treated Process Wastewater	1
2 LAND APPLICATION REQUIREMENTS	5
2.1 SAMPLING POINT(S)	5
2.2 MONITORING REQUIREMENTS AND LIMITATIONS	5
2.2.1 Sampling Point (Outfall) 003 - Treatment Plant Sludge	5
2.2.2 Sampling Point (Outfall) 004 - High Strength Waste	8
2.2.3 Sampling Point (Outfall) 005 - R/O filtered wastewaters	9
3 SCHEDULES	12
3.1 LAND APPLICATION MANAGEMENT PLAN	12
4 STANDARD REQUIREMENTS	13
4.1 REPORTING AND MONITORING REQUIREMENTS	13
4.1.1 Monitoring Results	13
4.1.2 Sampling and Testing Procedures	13
4.1.3 Recording of Results	13
4.1.4 Reporting of Monitoring Results	14
4.1.5 Records Retention	14
4.1.6 Other Information	14
4.1.7 Reporting Requirements – Alterations or Additions	14
4.2 System Operating Requirements	14
4.2.1 Noncompliance Reporting	15
4.2.2 Bypass	15
4.2.3 Scheduled Bypass	15
4.2.4 Controlled Diversions	16
4.2.5 Proper Operation and Maintenance	16
4.2.6 Operator Certification	16
4.2.7 Spill Reporting	16
4.2.8 Planned Changes 4.2.9 Duty to Halt or Reduce Activity	16 17
4.2.9 Duty to Hall of Reduce Activity 4.3 SURFACE WATER REQUIREMENTS	17
4.5 SURFACE WATER REQUIREMENTS 4.3.1 Permittee-Determined Limit of Quantitation Incorporated into this Permit	17
4.3.2 Appropriate Formulas for Effluent Calculations	17
4.3.3 Effluent Temperature Requirements	17
4.3.4 Visible Foam or Floating Solids	18
4.3.5 Surface Water Uses and Criteria	18
4.3.6 Chloride Notification	18
4.3.7 Compliance with Phosphorus Limitation	18
4.3.8 Additives	19
4.3.9 Whole Effluent Toxicity (WET) Monitoring Requirements	19
4.3.10 Whole Effluent Toxicity (WET) Identification and Reduction	19
4.3.11 Whole Effluent Toxicity (WET) and Chloride Source Reduction Measures	19
4.3.12 PFOS and PFOA Requirements	20
4.4 LAND APPLICATION REQUIREMENTS	20
4.4.1 General Sludge Management Information	20
4.4.2 Land Application Characteristic Report	20
4.4.3 Annual Land Application Report	21
4.4.4 Other Methods of Disposal or Distribution Report	21
4.4.5 Land Application Site Approval	21

WPDES Permit No. WI-0054470-08-0 Lactalis USA Belmont Inc

4.4.6 Operating Requirements/Management Plan	21
4.4.7 Chloride Requirements for Liquid Wastes and By-Product Solids	21
4.4.8 Nitrogen Requirements for Liquid Wastes and By-Product Solids and Sludges	21
4.4.9 Ponding	22
4.4.10 Runoff	22
4.4.11 Soil Incorporation Requirements	22
4.4.12 Field Stockpiles	23
4.4.13 Additional Requirements from ch. NR 214, Wis. Adm. Code	23
5 SUMMARY OF REPORTS DUE	24

Ammonia Variable Limit column on the eDMR.

1 Surface Water Requirements

1.1 Sampling Point(s)

The discharge(s) shall be limited to the waste type(s) designated for the listed sampling point(s).

	Sampling Point Designation					
Sampling	Sampling Point Location, WasteType/Sample Contents and Treatment Description (as applicable)					
Point						
Number						
002	Effluent: 24-Hr flow proportional composite sampler located at the reaeration tank. Representative grab samples collected from the reaeration tank, except for temperature which is monitored continuously at the outfall at Bonner Branch. Flow meter located between the tertiary filters and reaeration tank.					

1.2 Monitoring Requirements and Effluent Limitations

The permittee shall comply with the following monitoring requirements and limitations.

Monitoring Requirements and Effluent Limitations Parameter Limit Type Limit and Sample Sample Notes Units Frequency Type Flow Rate Continuous MGD Daily BOD₅, Total Weekly Avg 32 mg/L 3/Week 24-Hr Flow November through April Prop Comp BOD₅, Total Weekly Avg 15 mg/L 3/Week 24-Hr Flow May through October Prop Comp BOD₅, Total Daily Max 19 lbs/day 3/Week Calculated BOD₅, Total 9.7 lbs/day Monthly Avg 3/Week Calculated Suspended Solids, Weekly Avg 15 mg/L 3/Week 24-Hr Flow May through October Total Prop Comp Suspended Solids, Weekly Avg 32 mg/L 3/Week 24-Hr Flow November through April Total Prop Comp Suspended Solids, Daily Max 24 lbs/day 3/Week Calculated Total Suspended Solids. Monthly Avg 12 lbs/dav 3/Week Calculated Total pH Field Daily Max 9.0 su Daily Grab pH Field Daily Min Daily Grab 6.0 su **Dissolved** Oxygen Daily Min 6.0 mg/L 5/Week Grab Nitrogen, Ammonia 3/Week 24-Hr Flow mg/L Look up the variable Variable Limit Prop Comp ammonia limit from the 'Variable Ammonia Limitation' table and report the variable limit in the

1.2.1 Sampling Point (Outfall) 002 - Treated Process Wastewater

	Monitoring Requirements and Effluent Limitations						
Parameter	Limit Type	Limit and	Sample	Sample	Notes		
		Units	Frequency	Туре			
Nitrogen, Ammonia	Daily Max -	mg/L	3/Week	24-Hr Flow	Report the daily maximum		
(NH ₃ -N) Total	Variable			Prop Comp	Ammonia result in the		
					Nitrogen, Ammonia (NH ₃ -		
					N) Total column of the		
					eDMR. See Ammonia		
					Limitation Section.		
Nitrogen, Ammonia	Weekly Avg	8.8 mg/L	3/Week	24-Hr Flow	April		
(NH ₃ -N) Total				Prop Comp			
Nitrogen, Ammonia	Weekly Avg	7.1 mg/L	3/Week	24-Hr Flow	May through September		
(NH ₃ -N) Total				Prop Comp			
Nitrogen, Ammonia	Monthly Avg	6.7 mg/L	3/Week	24-Hr Flow	October through March		
(NH ₃ -N) Total				Prop Comp			
Nitrogen, Ammonia	Monthly Avg	4.2 mg/L	3/Week	24-Hr Flow	April		
(NH ₃ -N) Total				Prop Comp			
Nitrogen, Ammonia	Monthly Avg	3.6 mg/L	3/Week	24-Hr Flow	May through September		
(NH ₃ -N) Total				Prop Comp			
Chloride		mg/L	Monthly	24-Hr Flow	Monitoring only in 2028.		
				Prop Comp			
Temperature		deg F	Daily	Continuous	Monitoring year-round. See		
Maximum					temperature section.		
Phosphorus, Total	Monthly Avg	0.225 mg/L	3/Week	24-Hr Flow			
				Prop Comp			
Phosphorus, Total	6-Month Avg	0.075 mg/L	3/Week	24-Hr Flow			
				Prop Comp			
Phosphorus, Total	6-Month Avg	0.11 lbs/day	3/Week	Calculated			
Nitrogen, Total		mg/L	Quarterly	24-Hr Flow			
Kjeldahl		_		Prop Comp			
Nitrogen, Nitrite +		mg/L	Quarterly	24-Hr Flow			
Nitrate Total		_		Prop Comp			
Nitrogen, Total		mg/L	Quarterly	Calculated	Total Nitrogen shall be		
-					calculated as the sum of		
					reported values for Total		
					Kjeldahl Nitrogen and		
					Total Nitrite + Nitrate		
					Nitrogen.		
Acute WET	Daily Max	1.0 TU _a	See Listed	24-Hr Flow			
			Qtr(s)	Prop Comp			
Chronic WET	Monthly Avg	2.0 TUc	See Listed	24-Hr Flow	See WET section.		
			Qtr(s)	Prop Comp			

1.2.1.1 Variable Daily Maximum Ammonia Limits

Daily maximum ammonia limits vary based on the effluent pH value. Total ammonia (NH3-N) sampling shall occur on the same day pH sampling occurs. Report the applicable Variable Ammonia Limit from the 'Variable Ammonia Limitation Table' on the Electronic Discharge Monitoring Report (eDMR) in the 'Nitrogen, Ammonia Variable Limit' column. Compare ammonia limits to the reported ammonia result and report exceedances in the box in the right of the zero limit.

Note that pH values should be rounded to the 0.1 s.u. before using the table below. For example, if the pH field reading is 8.04, the value of 8.0 should be used.

Variable Aninoma Emitation Table							
Effluent pH s.u.	Limit mg/L	Effluent pH s.u.	Limit mg/L	Effluent pH s.u.	Limit mg/L		
$6.0 \le pH \le 6.1$	108	$7.0 < pH \leq 7.1$	66	$8.0 < pH \leq 8.1$	14		
$6.1 < pH \leq 6.2$	106	$7.1 < pH \leq 7.2$	59	$8.1 < pH \le 8.2$	11		
$6.2 < pH \leq 6.3$	104	$7.2 < pH \leq 7.3$	52	$8.2 < pH \leq 8.3$	9.4		
$6.3 < pH \leq 6.4$	101	$7.3 < pH \leq 7.4$	46	$8.3 < pH \leq 8.4$	7.8		
$6.4 < pH \leq 6.5$	98	$7.4 < pH \leq 7.5$	40	$8.4 < pH \leq 8.5$	6.4		
$6.5 < pH \leq 6.6$	94	$7.5 < pH \leq 7.6$	34	$8.5 < pH \leq 8.6$	5.3		
$6.6 < pH \leq 6.7$	89	$7.6 < pH \leq 7.7$	29	$8.6 < pH \leq 8.7$	4.4		
$6.7 < pH \leq 6.8$	84	$7.7 < pH \leq 7.8$	24	$8.7 < pH \leq 8.8$	3.7		
$6.8 < pH \leq 6.9$	78	$7.8 < pH \leq 7.9$	20	$8.8 < pH \leq 8.9$	3.1		
$6.9 < pH \leq 7.0$	72	$7.9 < pH \leq 8.0$	17	$8.9 < pH \leq 9.0$	2.6		

Variable Ammonia Limitation Table

1.2.1.2 Effluent Temperature Monitoring

For monitoring temperature continuously, collect measurements in accordance with s. NR 218.04(13), Wis. Adm. Code. This means that discrete measurements shall be recorded at intervals of not more than 15 minutes during the 24-hour period. Report the maximum temperature measured during the day on the DMR.

1.2.1.3 Whole Effluent Toxicity (WET) Testing

Primary Control Water: Bonner Branch

Instream Waste Concentration (IWC): 49%

Acute Mixing Zone Concentration: N/A

Dilution series: At least five effluent concentrations and dual controls must be included in each test.

- Acute: 100, 50, 25, 12.5, 6.25% and any additional selected by the permittee.
- Chronic: 100, 75, 50, 25, 12.5% and any additional selected by the permittee.

WET Testing Frequency:

Acute tests are required during the following quarters:

October – December 2024

April – June 2025; October – December 2025

January – March 2026; July – September 2026

January – March 2027; July – September 2027

April – June 2028; October – December 2028

January – March 2029

Acute WET testing shall continue after the permit expiration date (until the permit is reissued) in accordance with the WET requirements specified for the last full calendar year of this permit. For example, the next test would be required in **October – December 2029 and January – March 2030.**

Chronic tests are required during the following quarters:

October – December 2024 April – June 2025; October – December 2025 January – March 2026; July – September 2026 January – March 2027; July – September 2027 April – June 2028; October – December 2028 January – March 2029

Chronic WET testing shall continue after the permit expiration date (until the permit is reissued) in accordance with the WET requirements specified for the last full calendar year of this permit. For example, the next test would be required in **October – December 2029 and January – March 2030.**

Testing: WET testing shall be performed during normal operating conditions. Permittees are not allowed to turn off or otherwise modify treatment systems, production processes, or change other operating or treatment conditions during WET tests.

Reporting: The permittee shall report test results on the Discharge Monitoring Report form, and also complete the "Whole Effluent Toxicity Test Report Form" (Section 6, "*State of Wisconsin Aquatic Life Toxicity Testing Methods Manual, 2nd Edition*"), for each test. The original, complete, signed version of the Whole Effluent Toxicity Test Report Form shall be sent to the Biomonitoring Coordinator, Bureau of Water Quality, 101 S. Webster St., P.O. Box 7921, Madison, WI 53707-7921, within 45 days of test completion. The Discharge Monitoring Report (DMR) form shall be submitted electronically by the required deadline.

Determination of Positive Results: An acute toxicity test shall be considered positive if the Toxic Unit - Acute (TU_a) is greater than 1.0 for either species. The TU_a shall be calculated as follows: $TU_a = 100 \div LC_{50}$. A chronic toxicity test shall be considered positive if the Toxic Unit – Chronic (TU_c) is greater than 2.0 for either species. The TU_c shall be calculated as follows: $TU_c = 100 \div IC_{50}$.

Additional Testing Requirements: Within 90 days of a test which showed positive results, the permittee shall submit the results of at least 2 retests to the Biomonitoring Coordinator on "Whole Effluent Toxicity Test Report Forms". The 90-day reporting period shall begin the day after the test which showed a positive result. The retests shall be completed using the same species and test methods specified for the original test (see the Standard Requirements section herein).

2 Land Application Requirements

2.1 Sampling Point(s)

The discharge(s) shall be limited to land application of the waste type(s) designated for the listed sampling point(s) on Department approved land spreading sites or by hauling to another facility.

	Sampling Point Designation				
Sampling Point Number	Sampling Point Location, WasteType/Sample Contents and Treatment Description (as applicable)				
003	Land Application: Representative grab samples of industrial sludge from the industrial process wastewater collected prior to land application at the sludge storage tank.				
004	Land Application: Representative grab samples of the industrial liquid high strength wastes (consisting mainly of whey and whey process waste) collected prior to land application at the high-strength storage tank.				
005	Land Application: Representative grab samples of industrial liquid wastewater (reverse osmosis filtered wastewaters) collected prior to land application at the silos. Monitoring is only required when land application occurs.				

2.2 Monitoring Requirements and Limitations

The permittee shall comply with the following monitoring requirements and limitations.

2.2.1 Sampling Point (Outfall) 003 - Treatment Plant Sludge

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Solids, Total		Percent	Monthly	Grab	
Nitrogen, Total Kjeldahl		Percent	Monthly	Grab	
Chloride		Percent	Monthly	Grab	
pH Field		su	Annual	Grab	
Phosphorus, Total		Percent	Annual	Grab	
Phosphorus, Water Extractable		% of Tot P	Annual	Grab	
PFOA + PFOS		µg/kg	Annual	Calculated	Report the sum of PFOA and PFOS. See PFAS Permit Sections for more information.
PFAS Dry Wt			Annual	Grab	Perfluoroalkyl and Polyfluoroalkyl Substances based on updated DNR PFAS List. See PFAS Permit Sections for more information.

Daily

Calculated

Daily Log – Monitoring Requirements and Limitations

All discharge and monitoring activity shall be documented on log sheets. Originals of the log sheets shall be kept by the permittee as described under "Records Retention" in the Standard Requirements section, and if requested, made available to the Department. **Sample Frequency Sample Type Parameters** Limit Units DNR Site Number(s) Number Daily _ Log Acres Applied Acres Daily Log _

_

Gal/Acre/Day

	2 2	ch year for the previou absection in Standard F	•			
ParametersLimitUnitsReporting FrequencySample Type						
DNR Site Number(s)	-	Number	-	-		
Acres Land Applied	_	Acres	Annual	-		
Total Volume Per Site	_	Gallons	Annual	Total Annual		
Total Kjeldahl Nitrogen per Site	165, or alternate approved in writing	Pounds/Acre/Year	Annual	Calculated		
Total Chloride per Site	340	Pounds/Acre per 2 Years	Annual	Calculated		

2.2.1.1 Annual Site Nitrogen Loading

Application Rate

For details on nitrogen loading requirements, including approval of an alternate nitrogen pounds/acre/year site loading, see the "Nitrogen Requirements for Liquid Wastes, By-Product Solids and Sludges" paragraph in the Standard Requirements section of this permit.

2.2.1.2 Biennial Site Chloride Loading

For details on chloride requirements see the "Chloride Requirements for Liquid Wastes and By-Product Solids" paragraph in the Standard Requirements section of this permit.

2.2.1.3 Sludge Monitoring for PFAS

Sampling shall occur for perfluoroalkyl and polyfluoroalkyl compounds (PFAS) listed in the table below and as indicated in sampling point sections above. Monitoring shall occur at each sample point when sludge is generated regardless of the end use (i.e. land applied, hauled to another facility, landfilled).

PERFLUOROALKYLCARBOXILIC Acids (PFCAs)				
PFBA	Perfluorobutanoic acid			
PFPeA	Perfluroropentanoic acid			
PFHxA	Perfluorohexanoic acid			

PFHpA	Perfluoroheptanoic acid				
PFOA	Perfluorooctanoic acid				
PFNA	Perfluorononanoic acid				
PFDA	Perfluorodecanoic acid				
PFUnA	Perfluroroundecanoic acid				
PFDoA	Perfluorododecanoic acid				
PFTriA	Perfluorotridecanoic acid				
PFTeDA	Perfluorotetradecanoic acid				
	PERFLUOROALKYLSULFONIC Acids (PFSAs)				
PFBS	Perfluorobutane sulfonic acid				
PFPeS	Perfluroropentane sulfonic acid				
PFHxS	Perfluorohexane sulfonic acid				
PFHpS	Perfluoroheptane sulfonic acid				
PFOS	Perfluorooctane sulfonic acid				
PFNS	Perfluorononane sulfonic acid				
PFDS	Perfluorodecane sulfonic acid				
PFDoS	Perfluorododecane sulfonic acid				
	TELOMER SULFONIC Acids				
4:2 FTSA	4:2 fluorotelomersulfonic acid				
6:2 FTSA	6:2 fluorotelomersulfonic acid				
8:2 FTSA	8:2 fluorotelomersulfonic acid				
	PERFLUOROOCTANCESULFONAMIDES (FOSAs)				
PFOSA	Perfluroroctane sulfonamide				
N-MeFOSA	N-Methyl perfluoroocatane sulfonamide				
N-EtFOSA	N-Ethyl perfluorooctane sulfonamide				
PI	ERFLUOROOCTANCESULFONAMIDOACETIC Acids				
N-MeFOSAA	N-Methyl perfluoroocatane sulfonamidoacetic acid				
N-EtFOSAA	N-Ethyl perfluorooctane sulfonamidoacetic acid				
NATIVE	E PERFLUOROOCTANCESULFONAMIDOETHANOLS (FOSEs)				
N-MeFOSE	N-Methyl perfluorooctane sulfonamideoethanol				
N-EtFOSE	N-Ethyl perfluorooctane sulfonamidoethanol				
PER	PERFLUOROALKYLETHERCARBOXYLIC Acids (PFECAs)				
HFPO-DA	Hexafluoropropylene oxide dimer acid				
DONA	4,8-dioxa-3H-perfluorononanoic acid				
	CHLORO-PERFLUOROALKYLSULFONATE				
F-53B Major	9-chloroehexadecafluoro-3-oxanone-1-sulfonic acid				
F-53B Minor	11-chloroelcosafluoro-3-oxaundecane-1-sulfonic acid				
Note: If WDND L of					

Note: If WDNR Lab Certification removes a particular compound from the reporting list above and upon receiving written communication from the department, reporting for that compound is no longer required.

2.2.1.4 Sampling and Reporting Sludge Samples for PFAS

Representative sludge samples shall be collected at each sample point as listed. At minimum, liquid sludge storage/digesters should be thoroughly mixed prior to sampling. Cake sludge samples should consist of seven equal

size discrete samples and be collected from different areas and depths then composited into one sample for laboratory analysis.

Note: If additional equipment is used for collecting sludge samples (i.e., shovels, compositing buckets, bottles, etc.), then a one-time equipment blank is recommended to be collected with the first sample. An equipment blank sample is collected by passing laboratory verified PFAS-free water over or through field sampling equipment before the collection of a representative sludge sample. The equipment blank result shall be reported on the annual Sludge Characteristics Form (3400-049) in the comment section when reporting PFAS concentrations in the sludge. The permittee shall report each of the PFAS sludge monitoring results on the annual Sludge Characteristics and Monitoring Form (3400-049) as provided by the department. The permittee shall also report the summation of PFOS and PFOA on this same form. All results shall be reported in dry weight. The annual Sludge Characteristics and Monitoring Form (3400-049) are due January 31, of the year following the collection of the sludge samples. The laboratory performing the analysis on any samples shall be certified for the applicable PFAS compounds in the solids matrix by the Wisconsin Laboratory Certification Program established under s. 299.11, Wis. Stats., and in accordance with s. NR 149.41, Wis. Adm. Code. If the EPA Office of Water publishes a 1600 series isotope dilution method for the analysis of PFAS in solids, the department recommends the use of the EPA method. The department may reject any sample results if results are produced by a laboratory that is not in compliance with certification requirements under ch. NR 149, Wis. Adm. Code.

2.2.1.5 PFAS Land Application Requirements

The department recommends the landspreading and/or land application of sludge be done in a manner consistent with the most recent version of the "Interim Strategy for Land Application of Biosolids and Industrial Sludges containing PFAS".

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Nitrogen, Total Kjeldahl		mg/L	Monthly	Grab	
Chloride		mg/L	Monthly	Grab	
pH Field		su	Annual	Grab	
BOD ₅ , Total		mg/L	Annual	Grab	
Phosphorus, Total		mg/L	Annual	Grab	
Phosphorus, Water Extractable		% of Tot P	Annual	Grab	

2.2.2 Sampling Point (Outfall) 004 - High Strength Waste

Daily Log – Monitoring Requirements and Limitations All discharge and monitoring activity shall be documented on log sheets. Originals of the log sheets shall be kept by the permittee as described under "Records Retention" in the Standard Requirements section, and if requested, made available to the Department.								
Parameters	Limit	LimitUnitsSample FrequencySample Type						
DNR Site Number(s)	-	Number	Daily	Log				
Acres Applied	- Acres Daily Log							
Frozen Site Maximum Daily Loading Volume	6,800	Gal/Acre/Day	Daily	Calculated				

Daily Log – Monitoring Requirements and Limitations

All discharge and monitoring activity shall be documented on log sheets. Originals of the log sheets shall be kept by the permittee as described under "Records Retention" in the Standard Requirements section, and if requested, made available to the Department.				
Parameters	Limit	Units	Sample Frequency	Sample Type
Unfrozen Site Maximum Daily Loading Volume	13,500	Gal/Acre/Day	Daily	Calculated
Weekly Loading Volume	See NR 214 - Tbl 3	Inches/Week	Weekly	Calculated

Annual Report – Summary of Monitoring Requirements and Limitations The Annual Report is due by January 31 st of each year for the previous calendar year. See the 'Annual Land Application Report' subsection in Standard Requirements.				
Parameters	Limit	Units	Reporting Frequency	Sample Type
DNR Site Number(s)	-	Number	-	-
Acres Land Applied	-	Acres	Annual	-
Total Volume Per Site	-	Gallons	Annual	Total Annual
Total Kjeldahl Nitrogen per Site	165, or alternate approved in writing	Pounds/Acre/Year	Annual	Calculated
Total Chloride per Site	340	Pounds/Acre per 2 Years	Annual	Calculated

2.2.2.1 Annual Site Nitrogen Loading

For details on nitrogen loading requirements, including approval of an alternate nitrogen pounds/acre/year site loading, see the "Nitrogen Requirements for Liquid Wastes, By-Product Solids and Sludges" paragraph in the Standard Requirements section of this permit.

2.2.2.2 Biennial Site Chloride Loading

For details on chloride requirements see the "Chloride Requirements for Liquid Wastes and By-Product Solids" paragraph in the Standard Requirements section of this permit.

2.2.3 Sampling Point (Outfall) 005 - R/O filtered wastewaters

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Nitrogen, Total Kjeldahl		mg/L	Monthly	Grab	
Chloride		mg/L	Monthly	Grab	
pH Field		su	Annual	Grab	
Phosphorus, Total		mg/L	Annual	Grab	

	Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and	Sample	Sample	Notes	
		Units	Frequency	Туре		
Phosphorus, Water		% of Tot P	Annual	Grab		
Extractable						

Daily Log – Monitoring Requirements and Limitations All discharge and monitoring activity shall be documented on log sheets. Originals of the log sheets shall be kept by the permittee as described under "Records Retention" in the Standard Requirements section, and if requested, made available to the Department. **Sample Frequency Sample Type Parameters** Limit Units DNR Site Number(s) Number Daily Log _ Acres Applied Acres Daily Log _ Frozen Site Maximum 6,800 Gal/Acre/Day Daily Calculated Daily Loading Volume Unfrozen Site Maximum 13,500 Calculated Gal/Acre/Day Daily Daily Loading Volume Weekly Loading Volume See NR 214 - Tbl 3 Inches/Week Weekly Calculated

Annual Report – Summary of Monitoring Requirements and Limitations The Annual Report is due by January 31 st of each year for the previous calendar year. See the 'Annual Land Application Report' subsection in Standard Requirements.					
Parameters	Limit	Units	Reporting Frequency	Sample Type	
DNR Site Number(s)	-	Number	-	-	
Acres Land Applied	-	Acres	Annual	-	
Total Volume Per Site	-	Gallons	Annual	Total Annual	
Total Kjeldahl Nitrogen per Site	165, or alternate approved in writing	Pounds/Acre/Year	Annual	Calculated	
Total Chloride per Site	340	Pounds/Acre per 2 Years	Annual	Calculated	

2.2.3.1 Annual Site Nitrogen Loading

For details on nitrogen loading requirements, including approval of an alternate nitrogen pounds/acre/year site loading, see the "Nitrogen Requirements for Liquid Wastes, By-Product Solids and Sludges" paragraph in the Standard Requirements section of this permit.

2.2.3.2 Biennial Site Chloride Loading

For details on chloride requirements see the "Chloride Requirements for Liquid Wastes and By-Product Solids" paragraph in the Standard Requirements section of this permit.

3 Schedules

3.1 Land Application Management Plan

A management plan is required for the land application system.

Required Action	Due Date
Land Application Management Plan: Submit an update to the management plan to optimize the land application system performance and demonstrate compliance with Wisconsin Administrative Code NR 214.	07/01/2027

4 Standard Requirements

NR 205, Wisconsin Administrative Code (Conditions for Industrial Dischargers): The conditions in ss. NR 205.07(1) and NR 205.07(3), Wis. Adm. Code, are included by reference in this permit. The permittee shall comply with all of these requirements. Some of these requirements are outlined in the Standard Requirements section of this permit. Requirements not specifically outlined in the Standard Requirement section of this permit can be found in ss. NR 205.07(1) and NR 205.07(3).

4.1 Reporting and Monitoring Requirements

4.1.1 Monitoring Results

Monitoring results obtained during the previous month shall be summarized and reported on a Department Wastewater Discharge Monitoring Report. The report may require reporting of any or all of the information specified below under 'Recording of Results'. This report is to be returned to the Department no later than the date indicated on the form. A copy of the Wastewater Discharge Monitoring Report Form or an electronic file of the report shall be retained by the permittee.

Monitoring results shall be reported on an electronic discharge monitoring report (eDMR). The eDMR shall be certified electronically by a responsible executive or officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The 'eReport Certify' page certifies that the electronic report form is true, accurate and complete.

If the permittee monitors any pollutant more frequently than required by this permit, the results of such monitoring shall be included on the Wastewater Discharge Monitoring Report.

The permittee shall comply with all limits for each parameter regardless of monitoring frequency. For example, monthly, weekly, and/or daily limits shall be met even with monthly monitoring. The permittee may monitor more frequently than required for any parameter.

4.1.2 Sampling and Testing Procedures

Sampling and laboratory testing procedures shall be performed in accordance with Chapters NR 218 and NR 219, Wis. Adm. Code and shall be performed by a laboratory certified or registered in accordance with the requirements of ch. NR 149, Wis. Adm. Code. Groundwater sample collection and analysis shall be performed in accordance with ch. NR 140, Wis. Adm. Code. The analytical methodologies used shall enable the laboratory to quantitate all substances for which monitoring is required at levels below the effluent limitation. If the required level cannot be met by any of the methods available in NR 219, Wis. Adm. Code, then the method with the lowest limit of detection shall be selected. Additional test procedures may be specified in this permit.

4.1.3 Recording of Results

The permittee shall maintain records which provide the following information for each effluent measurement or sample taken:

- the date, exact place, method and time of sampling or measurements;
- the individual who performed the sampling or measurements;
- the date the analysis was performed;
- the individual who performed the analysis;
- the analytical techniques or methods used; and
- the results of the analysis.

4.1.4 Reporting of Monitoring Results

The permittee shall use the following conventions when reporting effluent monitoring results:

- Pollutant concentrations less than the limit of detection shall be reported as < (less than) the value of the limit of detection. For example, if a substance is not detected at a detection limit of 0.1 mg/L, report the pollutant concentration as < 0.1 mg/L.
- Pollutant concentrations equal to or greater than the limit of detection, but less than the limit of quantitation, shall be reported and the limit of quantitation shall be specified.
- For purposes of calculating NR 101 fees, a reporting limit of 2.0 mg/L for BOD₅ and 2.5 mg/L Total Suspended Solids shall be considered to be limits of quantitation.
- For the purposes of reporting a calculated result, average or a mass discharge value, the permittee may substitute a "0" (zero) for any pollutant concentration that is less than the limit of detection. However, if the effluent limitation is less than the limit of detection, the department may substitute a value other than zero for results less than the limit of detection, after considering the number of monitoring results that are greater than the limit of detection and if warranted when applying appropriate statistical techniques.
- If no discharge occurs through an outfall, flow related parameters (e.g. flow rate, hydraulic application rate, volume, etc.) should be reported as "0" (zero) at the required sample frequency specified for the outfall. For example: if the sample frequency is daily, "0" would be reported for any day during the month that no discharge occurred.

4.1.5 Records Retention

The permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings or electronic data records for continuous monitoring instrumentation, copies of all reports required by the permit, and records of all data used to complete the application for the permit for a period of at least 3 years from the date of the sample, measurement, report or application, except for sludge management forms and records, which shall be kept for a period of at least 5 years.

4.1.6 Other Information

Where the permittee becomes aware that it failed to submit any relevant facts in a permit application or submitted incorrect information in a permit application or in any report to the Department, it shall promptly submit such facts or correct information to the Department.

4.1.7 Reporting Requirements – Alterations or Additions

The permittee shall give notice to the Department as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is only required when:

- The alteration or addition to the permitted facility may meet one of the criteria for determining whether a facility is a new source.
- The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification requirement applies to pollutants which are not subject to effluent limitations in the existing permit.
- The alteration or addition results in a significant change in the permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use of disposal sites not reported during the permit application process nor reported pursuant to an approved land application plan. Additional sites may not be used for the land application of sludge until department approval is received.

4.2 System Operating Requirements

4.2.1 Noncompliance Reporting

The permittee shall report the following types of noncompliance by a telephone call to the Department's regional office within 24 hours after becoming aware of the noncompliance:

- any noncompliance which may endanger health or the environment;
- any violation of an effluent limitation resulting from a bypass;
- any violation of an effluent limitation resulting from an upset; and
- any violation of a maximum discharge limitation for any of the pollutants listed by the Department in the permit, either for effluent or sludge.

A written report describing the noncompliance shall also be submitted to the Department as directed at the end of this permit within 5 days after the permittee becomes aware of the noncompliance. On a case-by-case basis, the Department may waive the requirement for submittal of a written report within 5 days and instruct the permittee to submit the written report with the next regularly scheduled monitoring report. In either case, the written report shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times; the steps taken or planned to reduce, eliminate and prevent reoccurrence of the noncompliance; and if the noncompliance has not been corrected, the length of time it is expected to continue.

A scheduled bypass approved by the Department under the 'Scheduled Bypass' section of this permit shall not be subject to the reporting required under this section.

NOTE: Section 292.11(2)(a), Wisconsin Statutes, requires any person who possesses or controls a hazardous substance or who causes the discharge of a hazardous substance to notify the Department of Natural Resources **immediately** of any discharge not authorized by the permit. **The discharge of a hazardous substance that is not authorized by this permit or that violates this permit may be a hazardous substance spill. To report a hazardous substance spill, call DNR's 24-hour HOTLINE at 1-800-943-0003.**

4.2.2 Bypass

Except for a controlled diversion as provided in the 'Controlled Diversions' section of this permit, any bypass is prohibited and the Department may take enforcement action against a permittee for such occurrences under s. 283.89, Wis. Stats. The Department may approve a bypass if the permittee demonstrates all the following conditions apply:

- The bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
- There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities or adequate back-up equipment, retention of untreated wastes, reduction of inflow and infiltration, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventative maintenance. When evaluating feasibility of alternatives, the department may consider factors such as technical achievability, costs and affordability of implementation and risks to public health, the environment and, where the permittee is a municipality, the welfare of the community served; and
- The bypass was reported in accordance with the 'Noncompliance Reporting' section of this permit.

4.2.3 Scheduled Bypass

Whenever the permittee anticipates the need to bypass for purposes of efficient operations and maintenance and the permittee may not meet the conditions for controlled diversions in the 'Controlled Diversions' section of this permit, the permittee shall obtain prior written approval from the Department for the scheduled bypass. A permittee's written request for Department approval of a scheduled bypass shall demonstrate that the conditions for unscheduled bypassing are met and include the proposed date and reason for the bypass, estimated volume and duration of the bypass, alternatives to bypassing and measures to mitigate environmental harm caused by the bypass. The department may require the permittee to provide public notification for a scheduled bypass if it is determined there is significant public interest in the proposed action and may recommend mitigation measures to minimize the impact of such bypass.

4.2.4 Controlled Diversions

Controlled diversions are allowed only when necessary for essential maintenance to assure efficient operation provided the following requirements are met:

- Effluent from the wastewater treatment facility shall meet the effluent limitations established in the permit. Wastewater that is diverted around a treatment unit or treatment process during a controlled diversion shall be recombined with wastewater that is not diverted prior to the effluent sampling location and prior to effluent discharge;
- A controlled diversion may not occur during periods of excessive flow or other abnormal wastewater characteristics;
- A controlled diversion may not result in a wastewater treatment facility overflow; and
- All instances of controlled diversions shall be documented in wastewater treatment facility records and such records shall be available to the department on request.

4.2.5 Proper Operation and Maintenance

The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance includes effective performance, adequate funding, adequate operator staffing and training as required in ch. NR 114, Wis. Adm. Code, and adequate laboratory and process controls, including appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems only when necessary to achieve compliance with the conditions of the permit.

4.2.6 Operator Certification

The wastewater treatment facility shall be under the direct supervision of a state certified operator. In accordance with s. NR 114.53, Wis. Adm. Code, every WPDES permitted treatment plant shall have a designated operator-incharge holding a current and valid certificate. The designated operator-in-charge shall be certified at the level and in all subclasses of the treatment plant, except laboratory. Treatment plant owners shall notify the department of any changes in the operator-in-charge within 30 days. Note that s. NR 114.52(22), Wis. Adm. Code, lists types of facilities that are excluded from operator certification requirements (i.e. private sewage systems, pretreatment facilities discharging to public sewers, industrial wastewater treatment that consists solely of land disposal, agricultural digesters and concentrated aquatic production facilities with no biological treatment).

4.2.7 Spill Reporting

The permittee shall notify the Department in accordance with ch. NR 706 (formerly NR 158), Wis. Adm. Code, in the event that a spill or accidental release of any material or substance results in the discharge of pollutants to the waters of the state at a rate or concentration greater than the effluent limitations established in this permit, or the spill or accidental release of the material is unregulated in this permit, unless the spill or release of pollutants has been reported to the Department in accordance with s. NR 205.07 (1)(s), Wis. Adm. Code.

4.2.8 Planned Changes

In accordance with ss. 283.31(4)(b) and 283.59, Stats., the permittee shall report to the Department any facility expansion, production increase or process modifications which will result in new, different or increased discharges of pollutants. The report shall either be a new permit application, or if the new discharge will not violate the effluent limitations of this permit, a written notice of the new, different or increased discharge. The notice shall contain a description of the new activities, an estimate of the new, different or increased discharge of pollutants and a description of the effect of the new or increased discharge on existing waste treatment facilities. Following receipt of this report, the Department may modify this permit to specify and limit any pollutants not previously regulated in the permit.

4.2.9 Duty to Halt or Reduce Activity

Upon failure or impairment of treatment facility operation, the permittee shall, to the extent necessary to maintain compliance with its permit, curtail production or wastewater discharges or both until the treatment facility operations are restored or an alternative method of treatment is provided.

4.3 Surface Water Requirements

4.3.1 Permittee-Determined Limit of Quantitation Incorporated into this Permit

For pollutants with water quality-based effluent limits below the Limit of Quantitation (LOQ) in this permit, the LOQ calculated by the permittee and reported on the Discharge Monitoring Reports (DMRs) is incorporated by reference into this permit. The LOQ shall be reported on the DMRs, shall be the lowest quantifiable level practicable, and shall be no greater than the minimum level (ML) specified in or approved under 40 CFR Part 136 for the pollutant at the time this permit was issued, unless this permit specifies a higher LOQ.

4.3.2 Appropriate Formulas for Effluent Calculations

The permittee shall use the following formulas for calculating effluent results to determine compliance with average concentration limits and mass limits and total load limits:

Weekly/Monthly/Six-Month/Annual Average Concentration = the sum of all daily results for that week/month/sixmonth/year, divided by the number of results during that time period. [Note: When a six-month average effluent limit is specified for Total Phosphorus the applicable periods are May through October and November through April, except in cases of Water Quality Trading, wherein the applicable periods are January through June and July through December.]

Weekly Average Mass Discharge (lbs/day): Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the week.

Monthly Average Mass Discharge (lbs/day): Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the month.

Six-Month Average Mass Discharge (lbs/day): Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the six-month period. [Note: When a six-month average effluent limit is specified for Total Phosphorus the applicable periods are May through October and November through April.]

Annual Average Mass Discharge (lbs/day): Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the entire year.

Total Monthly Discharge: = monthly average concentration (mg/L) x total flow for the month (MG/month) x 8.34.

Total Annual Discharge: = sum of total monthly discharges for the calendar year.

12-Month Rolling Sum of Total Monthly Discharge: = the sum of the most recent 12 consecutive months of Total Monthly Discharges.

4.3.3 Effluent Temperature Requirements

Weekly Average Temperature – If temperature limits are included in this permit, Weekly Average Temperature shall be calculated as the sum of all daily maximum results for that week divided by the number of daily maximum results during that time period.

Cold Shock Standard – Water temperatures of the discharge shall be controlled in a manner as to protect fish and aquatic life uses from the deleterious effects of cold shock pursuant to Wis. Adm. Code, s. NR 102.28. 'Cold Shock' means exposure of aquatic organisms to a rapid decrease in temperature and a sustained exposure to low temperature that induces abnormal behavior or physiological performance and may lead to death.

WPDES Permit No. WI-0054470-08-0 Lactalis USA Belmont Inc Rate of Temperature Change Standard – Temperature of a water of the state or discharge to a water of the state may not be artificially raised or lowered at such a rate that it causes detrimental health or reproductive effects to fish or aquatic life of the water of the state pursuant to Wis. Adm. Code, s. NR 102.29.

4.3.4 Visible Foam or Floating Solids

There shall be no discharge of floating solids or visible foam in other than trace amounts.

4.3.5 Surface Water Uses and Criteria

In accordance with NR 102.04, Wis. Adm. Code, surface water uses and criteria are established to govern water management decisions. Practices attributable to municipal, industrial, commercial, domestic, agricultural, land development or other activities shall be controlled so that all surface waters including the mixing zone meet the following conditions at all times and under all flow and water level conditions:

- a) Substances that will cause objectionable deposits on the shore or in the bed of a body of water, shall not be present in such amounts as to interfere with public rights in waters of the state.
- b) Floating or submerged debris, oil, scum or other material shall not be present in such amounts as to interfere with public rights in waters of the state.
- c) Materials producing color, odor, taste or unsightliness shall not be present in such amounts as to interfere with public rights in waters of the state.
- d) Substances in concentrations or in combinations which are toxic or harmful to humans shall not be present in amounts found to be of public health significance, nor shall substances be present in amounts which are acutely harmful to animal, plant or aquatic life.

4.3.6 Chloride Notification

The permittee shall notify the Department in writing of any proposed changes which may affect the characteristics of the wastewater, which results in an increase in the concentration of chloride, under the authority of sections 283.31(4)(b) and 283.59(1), Stats. This notification shall include a description of the proposed source of chlorides and the anticipated increase in concentration. Following receipt of the notification, the Department may propose a modification to the permit.

4.3.7 Compliance with Phosphorus Limitation

Compliance with the concentration limitation for phosphorus shall be determined as a rolling twelve-month average and shall be calculated as follows:

First, determine the pounds of phosphorus for an individual month by multiplying the average of all the concentration values for phosphorus (in mg/L) for that month by the total flow for the month in Million Gallons times the conversion factor of 8.34.

Then, the monthly pounds of phosphorus determined in this manner shall be summed for the most recent 12 months and inserted into the numerator of the following equation.

Average concentration of P in mg/L = $\underline{\text{Total lbs of P discharged (most recent 12 months)}}$ Total flow in MG (most recent 12 months) X 8.34

The compliance calculation shall be performed each month with a reported discharge volume after substituting data from the most recent month(s) for the oldest month(s). A calculated value in excess of the concentration limitation will be considered equivalent to a violation of a monthly average.

4.3.8 Additives

In the event that the permittee wishes to commence use of a water treatment additive, or increase the usage of the additives greater than indicated in the permit application, the permittee must get a written approval from the Department prior to initiating such changes. This written approval shall provide authority to utilize the additives at the specific rates until the permit can be either reissued or modified in accordance with s. 283.53, Stats. Restrictions on the use of the additives may be included in the authorization letter.

4.3.9 Whole Effluent Toxicity (WET) Monitoring Requirements

In order to determine the potential impact of the discharge on aquatic organisms, static-renewal toxicity tests shall be performed on the effluent in accordance with the procedures specified in the "State of Wisconsin Aquatic Life Toxicity Testing Methods Manual, 2nd Edition" (PUB-WT-797, November 2004) as required by NR 219.04, Table A, Wis. Adm. Code). All of the WET tests required in this permit, including any required retests, shall be conducted on the Ceriodaphnia dubia and fathead minnow species. Receiving water samples shall not be collected from any point in contact with the permittee's mixing zone and every attempt shall be made to avoid contact with any other discharge's mixing zone.

4.3.10 Whole Effluent Toxicity (WET) Identification and Reduction

Within 60 days of a retest which showed positive results, the permittee shall submit a written report to the Biomonitoring Coordinator, Bureau of Water Quality, 101 S. Webster St., PO Box 7921, Madison, WI 53707-7921, which details the following:

- A description of actions the permittee has taken or will take to remove toxicity and to prevent the recurrence of toxicity;
- A description of toxicity reduction evaluation (TRE) investigations that have been or will be done to identify potential sources of toxicity, including the following actions:
 - a) Evaluate the performance of the treatment system to identify deficiencies contributing to effluent toxicity (e.g., operational problems, chemical additives, incomplete treatment)
 - b) Identify the compound(s) causing toxicity. Conduct toxicity screening tests on the effluent at a minimum of once per month for six months to determine if toxicity recurs. Screening tests are WET tests using fewer effluent concentrations conducted on the most sensitive species. If any of the screening tests contain toxicity, conduct a toxicity identification evaluation (TIE) to determine the cause. TIE methods are available from USEPA "Methods for Aquatic Toxicity Identification Evaluations: Phase I Toxicity Characterization Procedures (EPA/600/6-91/003) and "Toxicity Identification Evaluation: Characterization of Chronically Toxic Effluents, Phase I" (EPA/600/6-91/005F).
 - c) Trace the compound(s) causing toxicity to their sources (e.g., industrial, commercial, domestic)
 - d) Evaluate, select, and implement methods or technologies to control effluent toxicity (e.g., in-plant or pretreatment controls, source reduction or removal)
- Where corrective actions including a TRE have not been completed, an expeditious schedule under which corrective actions will be implemented;
- If no actions have been taken, the reason for not taking action.

The permittee may also request approval from the Department to postpone additional retests in order to investigate the source(s) of toxicity. Postponed retests must be completed after toxicity is believed to have been removed.

4.3.11 Whole Effluent Toxicity (WET) and Chloride Source Reduction Measures

WPDES Permit No. WI-0054470-08-0

Lactalis USA Belmont Inc

Section NR 106.89, Wis. Adm. Code, states that chloride limitations can be used in the permit in lieu of whole effluent toxicity testing requirements and limitations until chloride source reduction actions are completed, under the following conditions.

When an acute chloride limitation is included in the permit, acute whole effluent toxicity testing and limitations may be discontinued until chloride source reduction actions are completed, according to s. NR 106.89, Wis. Adm. Code, if either:

- The permittee can demonstrate to the satisfaction of the department that the effluent concentration of chloride exceeds 2,500 mg/l, or
- The permittee can demonstrate to the satisfaction of the department that the effluent concentration of chloride is less than 2,500 mg/l, but in excess of the calculated acute water quality-based effluent limitation, and additional data are submitted which demonstrate that chloride is the sole source of acute toxicity.

When a chronic chloride limitation is included in the permit, chronic whole effluent toxicity testing and limitations may be discontinued until chloride source reduction actions are completed, according to s. NR 106.89, Wis. Adm. Code, if either:

- The permittee can demonstrate to the satisfaction of the department that the effluent concentration of chloride exceeds 2 times the calculated chronic water quality-based effluent limitation, or
- The permittee can demonstrate to the satisfaction of the department that the effluent concentration of chloride is less than 2 times the calculated chronic water quality-based effluent limitation, but in excess of the calculated chronic water quality-based effluent limitation, and additional data are submitted which demonstrate that chloride is the sole source of chronic toxicity.

Following the completion of chloride source reduction activities, the department shall evaluate the need for whole effluent toxicity monitoring and limitation.

4.3.12 PFOS and PFOA Requirements

The laboratory performing the analysis on any samples shall be certified for the applicable PFAS compounds in the aqueous matrix by the Wisconsin Laboratory Certification Program established under s. 299.11, Wis. Stats., in accordance with s. NR 149.41, Wis. Adm. Code. If the EPA Office of Water publishes a 1600 series isotope dilution method for the analysis of PFAS in wastewater, the department recommends the use of the EPA method. The Department may reject any sample results if results are produced by a laboratory that is not in compliance with certification requirements under ch. NR 149, Wis. Adm. Code.

4.4 Land Application Requirements

4.4.1 General Sludge Management Information

The General Sludge Management Form 3400-48 shall be completed and submitted prior to any significant sludge management changes.

4.4.2 Land Application Characteristic Report

The analytical results from testing of liquid wastes, by-product solids and sludges that are land applied shall be reported annually on the Characteristic Report Form 3400 49. The report form shall be submitted electronically no later than the date indicated on the form. Following submittal of the electronic Characteristic Report Form 3400-49, this form shall be certified electronically via the 'eReport Certify' page by a responsible executive officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The 'eReport Certify' page certifies that the electronic report form is true, accurate and complete. The permittee shall use the following convention when reporting sludge monitoring results: Pollutant concentrations less than the limit of detection shall be reported as < (less than) the value of the limit of detection. For example, if a substance is not detected at a detection limit of 1.0 mg/kg, report the pollutant concentration as < 1.0 mg/kg. All sludge results shall be reported on a dry weight basis.

4.4.3 Annual Land Application Report

The annual totals for the land application loadings of liquid wastes, by-product solids and sludges to field spreading sites shall be submitted electronically on the Annual Land Application Report Form 3400-55 by January 31, each year whether or not waste is land applied. Following submittal of the electronic Annual Land Application Report Form 3400-55, this form shall be certified electronically via the 'eReport Certify' page by a responsible executive officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The 'eReport Certify' page certifies that the electronic report form is true, accurate and complete.

4.4.4 Other Methods of Disposal or Distribution Report

The permittee shall submit electronically the Other Methods of Disposal or Distribution Report Form 3400-52 by January 31, each year whether or not waste is hauled to another facility, landfilled, incinerated, or stored in a manure pit. Following submittal of the electronic Report Form 3400-52, this form shall be certified electronically via the 'eReport Certify' page by a responsible executive officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The 'eReport Certify' page certifies that the electronic report form is true, accurate and complete.

4.4.5 Land Application Site Approval

The permittee is authorized to landspread permitted liquid wastes, by-product solids and sludges on sites approved in writing by the Department in accordance with ss. NR 214.17(2) and 214.18(2), Wis. Adm. Code. Any site use restrictions or granting of case-by-case exceptions shall be identified in the approval letter. If the permittee wishes to have approval for additional sites, application shall be made using Land Application Site Request Form 3400-053. Complete information shall be submitted about each site, including location maps and soil maps, any soil analyses results and other information showing that the site complies with all application requirements and permit conditions. Spreading on a site may commence upon receipt of Department approval. If an existing spreading site is found by the Department to be environmentally unacceptable, a written notice will be issued to withdraw approval of that site.

4.4.6 Operating Requirements/Management Plan

All land application sites used for treatment of liquid wastes, by-product solids and sludges shall be operated in accordance with a Department approved management plan. The management plan shall be consistent with the requirements of this permit, ss. NR 214.17 (3) and (6), and NR 214.18 (3) and (6), Wis. Adm. Code. If operational changes are needed, the land application management plan shall be amended by submitting a written request to the Department for approval. A land application management plan shall be submitted for approval at least 60 days prior to land application.

4.4.7 Chloride Requirements for Liquid Wastes and By-Product Solids

The total pounds of chloride applied shall be limited to 340 pounds per acre per 2 year period. Calculate the chloride loading as follows:

Wet Weight Solids: <u>lbs of solids X %solids X %chloride</u> = lbs chloride/acre acres land applied X 100 X 100

Liquid: $\underline{mg/L \text{ chloride } X \text{ (millions of gallons) } X 8.34} = \text{lbs chloride/acre} acres land applied}$

4.4.8 Nitrogen Requirements for Liquid Wastes and By-Product Solids and Sludges

NR 214.17(4) and NR 214.18(4) Wis. Adm. Code specify that the total pounds of nitrogen land applied per acre per year shall be limited to the nitrogen needs of the cover crop minus any other nitrogen added to the land application

WPDES Permit No. WI-0054470-08-0 Lactalis USA Belmont Inc site, including fertilizer or manure. Nitrogen applied can be calculated on the basis of plant available nitrogen, as long as the release of nitrogen from the organic material is credited to future years. This permit requires that the Total Kjeldahl Nitrogen calendar year application amount shall not exceed 165 pounds per acre per year, except when alternate numerical nitrogen loading limits (consistent with the above sections of NR 214) are approved in writing via the Department's land application management plan approval. Calculate nitrogen loading as follows ("TKN" represents "Total Kjeldahl Nitrogen"):

Wet Weight Solids and Sludges: <u>lbs of solids X % solids X % TKN</u> = lbs TKN/acre acres land applied X 100 X 100

Liquid: $\underline{mg/L TKN X}$ (millions of gallons) X 8.34 = lbs TKN/acre acres land applied

4.4.9 Ponding

The volume of liquid wastes land applied shall be limited to prevent ponding, except for temporary conditions following rainfall events. If ponding occurs all land application shall cease immediately. The permittee shall land apply only the liquid wastes that are permitted.

4.4.10 Runoff

The volume of liquid wastes land applied shall be limited to prevent runoff. If runoff occurs all land application shall cease immediately. The permittee shall land apply only the liquid wastes that are permitted.

4.4.11 Soil Incorporation Requirements

- Liquid Sludge Requirements: The Department may require that liquid sludge be incorporated into the soil on specific land application sites when necessary to prevent surface runoff or objectionable odors. Requirements and procedures for incorporation of liquid sludge, when such incorporation may be necessary, shall be specified in the management plan or in specific site applications, subject to Department approval. The permittee shall comply with the requirements in the Department approved management plan, specific site-approval requirements and the terms and conditions of this permit.
- Cake Sludge Requirements: After land application, cake sludge shall be incorporated into the soil. The timing of such incorporation and other related requirements and procedures shall be specified in the management plan or in specific site applications, subject to Department approval. The permittee shall comply with the requirements in the Department approved management plan, specific site-approval requirements and the terms and conditions of this permit.
- Liquid Wastewater Requirements: The Department may require that liquid wastewater be incorporated or injected into the soil on specific land application sites when necessary to prevent surface runoff or objectionable odors. Requirements and procedures for injection or incorporation of liquid wastewater, when such injection or incorporation is necessary, shall be specified in the management plan or in specific site applications, subject to Department approval. The permittee shall comply with the requirements in the Department approved management plan, specific site-approval requirements and the terms and conditions of this permit.
- By-Product Solids Requirements: The Department may limit the volume of by-products solids that are landspread on a specific site when necessary to prevent surface runoff or leaching of contaminants to groundwater and objectionable odors. By-product solids shall, after application, be plowed, disced, or otherwise incorporated into the soil. Requirements and procedures for the incorporation of byproduct solids into the soil shall be specified in the management plan or in specific site applications, subject to Department approval. The permittee shall comply with the requirements in the Department approved management plan, specific site-approval requirements and the terms and conditions of this permit.

4.4.12 Field Stockpiles

The permittee is encouraged to landspread the by-product solids or sludges as they are transported to the fields; but if it becomes necessary to stockpile solids in the fields, the stockpiles shall be spread within 72 hours or as specified in the approved management plan.

4.4.13 Additional Requirements from ch. NR 214, Wis. Adm. Code

The requirements of s. NR 214.17 (4)(c) [pathogen prohibition for human consumption crop fields], (4)(d)1 [no adverse soil effects], (4)(d)10 [allowable whey spreading rates], and (4)(e)1-3 [by-product solids spreading within agricultural practices and not cause contamination] for landspreading of liquid wastes and by product solids and s. NR 214.18 (4)(b),(d)-(h) [application, nutrient, pH, metals, and PCB limitations] for sludge spreading systems are included by reference in this permit. The permittee shall comply with these requirements.

5 Summary of Reports Due

FOR INFORMATIONAL PURPOSES ONLY

Description	Date	Page
Land Application Management Plan -Land Application Management Plan	July 1, 2027	12
General Sludge Management Form 3400-48	prior to any significant sludge management changes	20
Land Application Report Form 3400-55	January 31, each year whether or not waste is land applied	21
Other Methods of Disposal or Distribution Report Form 3400-52	by January 31, each year whether or not waste is hauled to another facility, landfilled, incinerated, or stored in a manure pit	21
Wastewater Discharge Monitoring Report	no later than the date indicated on the form	13

Report forms shall be submitted electronically in accordance with the reporting requirements herein. Any facility plans or plans and specifications for municipal, industrial, industrial pretreatment and non industrial wastewater systems shall be submitted to the Bureau of Water Quality, P.O. Box 7921, Madison, WI 53707-7921. All <u>other</u> submittals required by this permit shall be submitted to:

South Central Reg - Dodgeville, 1500 N. Johns St, Dodgeville, WI 53533-2116