



# WPDES PERMIT

*STATE OF WISCONSIN*  
*DEPARTMENT OF NATURAL RESOURCES*  
**PERMIT TO DISCHARGE UNDER THE WISCONSIN POLLUTANT DISCHARGE  
ELIMINATION SYSTEM**

**Madison Gas & Electric Company**

is permitted, under the authority of Chapter 283, Wisconsin Statutes, to discharge from a facility  
located at  
717 E Main St  
to  
**Lake Monona**

in accordance with the effluent limitations, monitoring requirements and other conditions set  
forth in this permit.

The permittee shall not discharge after the date of expiration. If the permittee wishes to continue to discharge after  
this expiration date an application shall be filed for reissuance of this permit, according to Chapter NR 200, Wis.  
Adm. Code, at least 180 days prior to the expiration date given below.

State of Wisconsin Department of Natural Resources  
For the Secretary

By \_\_\_\_\_  
Nate Willis  
Wastewater Section Manager

\_\_\_\_\_  
Date Permit Signed/Issued for Modification

**PERMIT TERM: EFFECTIVE DATE - October 01, 2023**  
**EFFECTIVE DATE OF MODIFICATION: July 01, 2026**

**EXPIRATION DATE - September 30, 2028**

## TABLE OF CONTENTS

<b>1 INFLUENT REQUIREMENTS - COOLING WATER INTAKE STRUCTURE (CWIS)</b>	<b>1</b>
1.1 SAMPLING POINT(S)	1
1.2 MONITORING REQUIREMENTS AND BTA DETERMINATIONS	1
1.2.1 <i>Sampling Point 702 - Blount St. Emergency Intake</i>	1
1.2.2 <i>Sampling Point 703 - Livingston Intake</i>	2
1.3 COOLING WATER INTAKE STRUCTURE STANDARD REQUIREMENTS	3
1.3.1 <i>Future BTA for Cooling Water Intake Structure</i>	3
1.3.2 <i>Visual or Remote Inspections</i>	3
1.3.3 <i>Reporting Requirements for Cooling Water Intake</i>	3
1.3.4 <i>Intake Screen Discharges and Removed Substances</i>	3
1.3.5 <i>Endangered Species Act</i>	4
<b>2 IN-PLANT REQUIREMENTS</b>	<b>5</b>
2.1 SAMPLING POINT(S)	5
2.2 MONITORING REQUIREMENTS AND LIMITATIONS	5
2.2.1 <i>Sampling Point 110 - Mercury Field Blank</i>	5
<b>3 SURFACE WATER REQUIREMENTS</b>	<b>6</b>
3.1 SAMPLING POINT(S)	6
3.2 MONITORING REQUIREMENTS AND EFFLUENT LIMITATIONS	6
3.2.1 <i>Sampling Point (Outfall) 003 - Cooling Water (Turb. 6 &amp; 7)</i>	6
3.2.2 <i>Sampling Point (Outfall) 009 - Emergency Generator NCCW</i>	8
<b>4 SCHEDULES</b>	<b>9</b>
4.1 ANNUAL CERTIFICATION STATEMENTS AND REPORTS FOR INTAKE STRUCTURE	9
4.2 IMPINGEMENT MORTALITY BTA SCHEDULE	9
4.3 OPTIMIZATION STUDY	9
4.4 PFOS/PFOA MINIMIZATION PLAN DETERMINATION OF NEED	10
4.5 PFOS AND PFOA MINIMIZATION PLAN	10
<b>5 STANDARD REQUIREMENTS</b>	<b>12</b>
5.1 REPORTING AND MONITORING REQUIREMENTS	12
5.1.1 <i>Monitoring Results</i>	12
5.1.2 <i>Sampling and Testing Procedures</i>	12
5.1.3 <i>Recording of Results</i>	12
5.1.4 <i>Reporting of Monitoring Results</i>	13
5.1.5 <i>Records Retention</i>	13
5.1.6 <i>Other Information</i>	13
5.1.7 <i>Reporting Requirements – Alterations or Additions</i>	13
5.2 SYSTEM OPERATING REQUIREMENTS	13
5.2.1 <i>Noncompliance Reporting</i>	14
5.2.2 <i>Bypass</i>	14
5.2.3 <i>Scheduled Bypass</i>	14
5.2.4 <i>Controlled Diversions</i>	15
5.2.5 <i>Proper Operation and Maintenance</i>	15
5.2.6 <i>Operator Certification</i>	15
5.2.7 <i>Spill Reporting</i>	15
5.2.8 <i>Planned Changes</i>	15
5.2.9 <i>Duty to Halt or Reduce Activity</i>	16
5.3 SURFACE WATER REQUIREMENTS	16
5.3.1 <i>Permittee-Determined Limit of Quantitation Incorporated into this Permit</i>	16
5.3.2 <i>Appropriate Formulas for Effluent Calculations</i>	16
5.3.3 <i>Effluent Temperature Requirements</i>	16

<i>5.3.4 Energy Emergency Events</i>	<i>17</i>
<i>5.3.5 Visible Foam or Floating Solids</i>	<i>17</i>
<i>5.3.6 Surface Water Uses and Criteria</i>	<i>17</i>
<i>5.3.7 Additives</i>	<i>17</i>

<b>6 SUMMARY OF REPORTS DUE</b>	<b>18</b>
---------------------------------	-----------

# 1 Influent Requirements - Cooling Water Intake Structure (CWIS)

## 1.1 Sampling Point(s)

Sampling Point Designation	
Sampling Point Number	Sampling Point Location, WasteType/Sample Contents and Treatment Description (as applicable)
702	INTAKE: Blount St. Intake Water Temperature for Condenser Cooling Water without additives discharged Thru Outfall 002.
703	INTAKE: Livingston St. Intake Water Temperature for Condenser Cooling Water without additives discharged Thru Outfall 003. Samples are taken under hatch next to the traveling screens.

## 1.2 Monitoring Requirements and BTA Determinations

The permittee shall comply with the following monitoring requirements.

The intake(s) has been reviewed for compliance with BTA (Best Technology Available) standards and the BTA determination(s) is listed below.

### 1.2.1 Sampling Point 702 - Blount St. Emergency Intake

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Temperature Maximum		deg F	Daily	Continuous	

#### 1.2.1.1 Intake Activation and Sampling

This intake is currently on standby. In order to utilize the intake, the permittee must notify the department of its intent in writing, and the permit must be modified to include a BTA determination as required under section 1.2.1.2. The sampling in the above table only needs to occur if the intake is active.

#### 1.2.1.2 Cooling Water Intake BTA (Best Technology Available Determination)

If the intake structure is to be activated the permittee must submit the required information from 40 CFR 122.21(r) for the final BTA determination to be made. The BTA determination must be received by the facility in writing before the intake can be used.

#### 1.2.1.3 Intake Screen Discharges

Floating debris and accumulated trash shall be removed from the condenser water intake screen backwash discharge and shall be stored and disposed of in a manner to prevent any pollutant from the materials from entering the waters of the State pursuant to s. NR 205.07(03), Wis. Adm. Code.

## 1.2.2 Sampling Point 703 - Livingston Intake

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Temperature Maximum		deg F	Daily	Continuous	
Flow Rate		MGD	Daily	Calculated	
Copper, Total Recoverable		µg/L	Annual	Grab	
Hardness, Total as CaCO <sub>3</sub>		mg/L	Annual	Grab	
Mercury, Total Recoverable		ng/L	Annual	Grab	See Mercury Monitoring section for more details.

### 1.2.2.1 Mercury Monitoring

The permittee shall collect and analyze all mercury samples according to the data quality requirements of ss. NR 106.145(9) and (10), Wisconsin Administrative Code. The limit of quantitation (LOQ) used for the effluent and field blank shall be less than 1.3 ng/L, unless the samples are quantified at levels above 1.3 ng/L. The permittee shall collect at least one mercury field blank for each set of mercury samples (a set of samples may include combinations of intake, influent, effluent or other samples all collected on the same day). The permittee shall report results of samples and field blanks to the Department on Discharge Monitoring Reports.

### 1.2.2.2 Intake Screen Discharges

Floating debris and accumulated trash shall be removed from the condenser water intake screen backwash discharge and shall be stored and disposed of in a manner to prevent any pollutant from the materials from entering the waters of the State pursuant to s. NR 205.07(03), Wis. Adm. Code.

### 1.2.2.3 CWIS - Authority to Operate and Description

The permittee shall at all times properly operate and maintain all water intake facilities. The permittee shall give advance notice to the Department of any planned changes in the location, design, operation, or capacity of the intake structure. The permittee is authorized to use the cooling water intake system which consists of the following:

- Location: In Lake Monona off of Livingston Street approximately 350 feet from shore at 43°04'35.1"N, 89°22'10.3"W.
- General Description: The CWIS withdraws water through a velocity cap made of a 14 feet 8-inch x 14 feet 8-inch x 4-inch solid wood plate connected to the intake by 1-inch diameter steel rods, which are spaced to create 7-inch-wide openings. The water then passes through a bell mouth elbow with a 9-foot diameter opening that converges into an 84-inch pipe that connects to a conduit that runs under Livingston Street. The conduit discharges to an intake well where the water then passes through two 3/8-inch mesh traveling screens.
- Maximum Design Intake Flow (DIF): 68 MGD
- Maximum Design Intake Velocity: 2.7 feet/second

### 1.2.2.4 Cooling Water Intake BTA (Best Technology Available) Determination

The Department believes that the Livingston Intake, as described above in subsection 1.2.1.3, represents BTA for minimizing entrainment but is not BTA for minimizing impingement mortality in accordance with the requirements in

section s. 283.31(6), Wis. Stats. and section 316(b) of the Clean Water Act. See the Impingement Mortality BTA schedule for more details.

### 1.3 Cooling Water Intake Structure Standard Requirements

The following requirements and provisions apply to all water intake structures identified as sampling points in subsection 1.1.

#### 1.3.1 Future BTA for Cooling Water Intake Structure

BTA determinations for entrainment and impingement mortality at cooling water intake structures will be made in each permit reissuance, in accordance with ch. NR 111, Wis. Adm. Code. **In subsequent permit reissuance applications, the permittee shall provide all the information required in ss. NR 111.41(1) through (7) and (13), Wis. Adm. Code.**

**Also include an alternatives analysis report for compliance with the entrainment BTA requirements with the permit application.** This alternatives analysis for entrainment BTA shall examine the options for compliance with the entrainment BTA requirement and propose a candidate entrainment BTA to the Department for consideration during its next BTA determination. The analysis must, at least narratively, address and consider the factors listed in s. NR 111.41(13)(a), Wis. Adm. Code, and may consider the factors listed in s. NR 111.41(13)(b), Wis. Adm. Code. The analysis must evaluate, at a minimum, closed-cycle recirculating systems, fine mesh screens with a mesh size of 2mm or smaller, variable speed pumps, water reuse or alternate sources of cooling water, and any additional technology identified by the department at a later date.

Exemptions from some permit application requirements are possible in accordance with s. NR 111.42(1), Wis. Adm. Code, where information already submitted is sufficient. If an exemption is desired, a request for reduced application material requirements must be submitted at least 2 years and 6 months prior to permit expiration. Past submittals and previously conducted studies may satisfy some or all of the application material requirements.

#### 1.3.2 Visual or Remote Inspections

The permittee shall conduct a weekly visual inspection or employ a remote monitoring device during periods when the cooling water intake is in operation. The inspection frequency shall be weekly to ensure the intakes are maintained and operated to function as designed.

#### 1.3.3 Reporting Requirements for Cooling Water Intake

The permittee shall adhere to the reporting requirements listed below:

##### 1.3.3.1 Annual Certification Statement and Report

Submit an annual certification statement signed by the authorized representative with information on the following, no later than January 31<sup>st</sup> for the previous year:

- Certification that water intake structure technologies are being maintained and operated as set forth in this permit, or a justification to allow a modification of the practices. Include a summary of the required Visual or Remote Inspections.
- If there are substantial modifications to the operation of any unit that impacts the cooling water withdrawals or operation of the water intake structure, provide a summary of those changes.
- If the information contained in the previous year's annual certification is still applicable, the certification may simply state as such.

#### 1.3.4 Intake Screen Discharges and Removed Substances

Floating debris and accumulated trash collected on the cooling water intake trash rack shall be removed and disposed of in a manner to prevent any pollutant from the material from entering the waters of the State pursuant to s. NR 205.07 (3) (a), Wis. Adm. Code, except that backwashes may contain fine materials that originated from the intake water source such as sand, silt, small vegetation or aquatic life.

### **1.3.5 Endangered Species Act**

Nothing in this permit authorizes take for the purpose of a facility's compliance with the Endangered Species Act. Refer to 40 CFR §125.98 (b) (1) and (2).

## 2 In-Plant Requirements

### 2.1 Sampling Point(s)

Sampling Point Designation	
Sampling Point Number	Sampling Point Location, Waste Type/Sample Contents and Treatment Description (as applicable)
110	BLANK: Field blank sample to confirm good quality mercury sample collection procedures.

### 2.2 Monitoring Requirements and Limitations

The permittee shall comply with the following monitoring requirements and limitations.

#### 2.2.1 Sampling Point 110 - Mercury Field Blank

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Mercury, Total Recoverable		ng/L	Annual	Blank	See Mercury Monitoring section below for details.

##### 2.2.1.1 Mercury Monitoring

The permittee shall collect and analyze all mercury samples according to the data quality requirements of ss. NR 106.145(9) and (10), Wisconsin Administrative Code. The limit of quantitation (LOQ) used for the effluent and field blank shall be less than 1.3 ng/L, unless the samples are quantified at levels above 1.3 ng/L. The permittee shall collect at least one mercury field blank for each set of mercury samples (a set of samples may include combinations of intake, influent, effluent or other samples all collected on the same day). The permittee shall report results of samples and field blanks to the Department on Discharge Monitoring Reports.

### 3 Surface Water Requirements

#### 3.1 Sampling Point(s)

The discharge(s) shall be limited to the waste type(s) designated for the listed sampling point(s).

Sampling Point Designation	
Sampling Point Number	Sampling Point Location, WasteType/Sample Contents and Treatment Description (as applicable)
003	EFFLUENT: Condenser cooling water and turbine sump discharge (Turbines 6 & 7), roof drains, city water when the fire suppression system is tested, and auxiliary equipment cooling water discharged to Lake Monona (Livingston Street). Samples taken in screen house prior to comingling with roof drain water and water from when the fire suppression system is tested.
009	EFFLUENT: Emergency generator noncontact cooling water discharged infrequently to the City storm sewer on Main Street. Samples taken from spigot near the bottom of the emergency generator.

#### 3.2 Monitoring Requirements and Effluent Limitations

The permittee shall comply with the following monitoring requirements and limitations.

##### 3.2.1 Sampling Point (Outfall) 003 - Cooling Water (Turb. 6 & 7)

Monitoring Requirements and Effluent Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Daily	Continuous	
Temperature Maximum	Daily Max	120 deg F	Daily	Continuous	
Copper, Total Recoverable		µg/L	Annual	Grab	
Mercury, Total Recoverable		ng/L	Annual	Grab	See Mercury Monitoring section below for details.
Hardness, Total as CaCO <sub>3</sub>		mg/L	Annual	Grab	
PFOS		ng/L	Monthly	Grab	Monitoring only. See the PFOS and PFOA Minimization Plan Requirements section and the PFOS and PFOA Minimization Plan Schedule.

<b>Monitoring Requirements and Effluent Limitations</b>					
<b>Parameter</b>	<b>Limit Type</b>	<b>Limit and Units</b>	<b>Sample Frequency</b>	<b>Sample Type</b>	<b>Notes</b>
PFOA		ng/L	Monthly	Grab	Monitoring only. See the PFOS and PFOA Minimization Plan Requirements section and the PFOS and PFOA Minimization Plan Schedule.

**3.2.1.1 Mercury Monitoring**

The permittee shall collect and analyze all mercury samples according to the data quality requirements of ss. NR 106.145(9) and (10), Wis. Adm. Code. The limit of quantitation (LOQ) used for the effluent and field blank shall be less than 1.3 ng/L, unless the samples are quantified at levels above 1.3 ng/L. The permittee shall collect at least one mercury field blank for each set of mercury samples (a set of samples may include combinations of intake, influent, effluent or other samples all collected on the same day). The permittee shall report results of samples and field blanks to the Department on Discharge Monitoring Reports.

**3.2.1.2 Effluent Temperature Monitoring**

For monitoring temperature continuously, collect measurements in accordance with s. NR 218.04(13). This means that discrete measurements shall be recorded at intervals of not more than 15 minutes during the 24-hour period. Report the maximum temperature measured during the day on the DMR. For seasonal discharges collect measurements continuously during the period of operation and report the daily maximum effluent temperature on the DMR.

**3.2.1.3 PFOS/PFOA Sampling and Reporting Requirements**

For grab samples, as defined per s. NR 218.04(10), Wis. Adm. Code, a single sample at a location as defined by the sample point description shall be taken during the time of the day most representative to capture all potential discharges. If extra equipment besides the sample bottle is used to collect the sample, it is recommended that a one-time equipment blank is collected with the first sample. An equipment blank would be collected by passing laboratory-verified PFAS-free water over or through field sampling equipment before the collection of a grab sample to evaluate potential contamination from the equipment used during sample.

If any equipment blanks are performed, these results shall be reported in the comments section of the eDMR and shall also be documented in the reports submitted as part of the PFOS/PFOA Minimization Plan Determination of Need schedule of the permit.

**3.2.1.4 PFOS/PFOA Minimization Plan Determination of Need**

The permittee shall monitor PFOS and PFOA as specified in the table above and report on the effluent concentrations including trends in monthly and annual average PFOS and PFOA concentrations as specified in the PFOS/PFOA Minimization Plan Determination of Need Schedule.

If, after reviewing the data, the Department determines that a minimization plan for PFOS and PFOA is necessary based on the procedures in s. NR 106.98(4), Wis. Adm. Code, the Department will notify the permittee in writing that a PFOS and PFOA minimization plan that satisfies the requirements in s. NR 106.99, Wis. Adm. Code, is required. The permittee shall submit an initial plan for Department approval no later than 90 days after written notification was sent from the Department in accordance with s. NR 106.985(2)(a), Wis. Adm. Code. Pursuant to s. NR 106.985(2)(b), Wis. Adm. Code, as soon as possible after Department approval of the PFOS and PFOA minimization plan, the Department will modify or revoke and reissue the permit in accordance with public notice procedures under ch. 283,

Wis. Stats., and ch. NR 203, Wis. Adm. Code, to include the PFOS and PFOA minimization plan and other related terms and condition.

If, however, the Department determines that a PFOS and PFOA minimization plan is unnecessary based on the procedures in s. NR 106.98(4), Wis. Adm. Code, the Department shall notify the permittee that no further action is required. Per s. NR 106.98(3)(a), Wis. Adm. Code, the Department may reduce monitoring frequency to once every 3 months (quarterly) on a case-by-case basis, but only after at least 12 representative results have been generated. If the permittee requests a reduction in monitoring and the Department agrees a reduction would be appropriate, the permit may be modified in accordance with public notice procedures under ch. 283, Wis. Stats., and ch. NR 203, Wis. Adm. Code, to incorporate this change.

**3.2.1.5 PFOS and PFOA Minimization Plan Requirements**

The permittee is required to implement the approved PFOS and PFOA Minimization Plan in accordance with s. NR 106.99, Wis. Adm. Code. The permittee shall (a) maintain effluent quality at or below the current effluent PFOS and PFOA concentrations, (b) implement the pollutant minimization plan dated January 16, 2026 (received 01/19/2026) as approved by the Department, and (c) perform the actions listed in the compliance schedule. (See the Schedules section herein.)

**3.2.1.6 Polychlorinated Biphenyls**

There shall be no discharge of polychlorinated biphenyl compounds such as those commonly used for transformer fluid.

**3.2.1.7 Zebra Mussel Control**

If the facility requires treatment for zebra mussels the temperature limit may be exceeded for a short period of time or the facility may propose a chemical treatment to the department. The department must be notified in advance of the intended method and timing for zebra mussel control. If a chemical treatment is proposed as the zebra mussel control method, the permit may be modified to include appropriate monitoring requirements and limitations and an additive review may be required before the chemical treatment can begin. If the thermal treatment is used the effluent may not be discharged in a manner that will cause a potential for scalding of humans

**3.2.1.8 Additives**

The permittee shall maintain a record of the dosage rate of all additives used on a monthly basis. The additives may be changed during the term of the permit following procedures in the ‘Additives’ subsection of the Standard Requirements.

**3.2.2 Sampling Point (Outfall) 009 - Emergency Generator NCCW**

Monitoring Requirements and Effluent Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		gpd	Daily	Total Daily	
Oil & Grease (Hexane)		mg/L	Quarterly	Grab	Sampling only required when discharges occur.

**3.2.2.1 Polychlorinated Biphenyls**

There shall be no discharge of polychlorinated biphenyl compounds such as those commonly used for transformer fluid.

## 4 Schedules

### 4.1 Annual Certification Statements and Reports for Intake Structure

Submit Annual Reports by January 31st of each year in accordance with the Annual Reports subsection in Standard Requirements.

Required Action	Due Date
<b>Submit Annual Certification Statement and Report #1:</b>	01/31/2024
<b>Submit Annual Certification Statement and Report #2:</b>	01/31/2025
<b>Submit Annual Certification Statement and Report #3:</b>	01/31/2026
<b>Submit Annual Certification Statement and Report #4:</b>	01/31/2027
<b>Submit Annual Certification Statement and Report #5:</b>	01/31/2028
<b>Ongoing Annual Certification Statements and Reports:</b> Continue to submit Annual Certification Statements and Reports until permit reissuance has been completed.	

### 4.2 Impingement Mortality BTA Schedule

Required Action	Due Date
<b>Compliance Option:</b> If the permittee has chosen to move forward with a different option of compliance with the impingement mortality BTA standards than the system of technologies option the permittee must inform the department by this date.	01/01/2026
<b>Plans and Specifications:</b> If the chosen compliance option involves a modification to the existing CWIS the permittee must submit plans and specification for the chosen option of compliance with the impingement mortality BTA standards by this date.	01/01/2027
<b>Construction:</b> If construction was deemed necessary in order to comply with the BTA determination, complete construction. This is also the date when compliance with the BTA standards must start being met.	01/01/2028

### 4.3 Optimization Study

The permittee shall complete an optimization study if either a system of technologies or a modified travelling screen is selected as the option for complying with the impingement mortality BTA standards.

Required Action	Due Date
<b>Progress Report:</b> The permittee shall submit a progress report that includes the data collected so far as part of the study, the methodology of the study, and an outline of the future stages of the study.	01/01/2027
<b>Optimization Study:</b> The permittee shall submit a report which meets the requirements under s. NR 111.41(5)b, Wis. Adm. Code, if the permittee has chosen to move forward with a system of technologies as the selected option for complying with impingement mortality BTA standards. If the permittee has chosen to change the selected option for complying with impingement mortality BTA standards and has instead chosen a modified traveling screen as their compliance option the permittee shall submit a report that meets the requirements under s. NR 111.41(5)a, Wis. Adm. Code.	01/01/2028

#### 4.4 PFOS/PFOA Minimization Plan Determination of Need

Required Action	Due Date
<p><b>Report on Effluent Discharge:</b> Submit a report on effluent PFOS and PFOA concentrations and include an analysis of trends in monthly and annual average PFOS and PFOA concentrations. This analysis should also include a comparison to the applicable narrative standard in s. NR 102.04(8)(d), Wis. Adm. Code.</p> <p>This report shall include all additional PFOS and PFOA data that may be collected including any influent, intake, in-plant, collection system sampling, and blank sample results.</p>	10/01/2024
<p><b>Report on Effluent Discharge and Evaluation of Need:</b> Submit a final report on effluent PFOS and PFOA concentrations and include an analysis of trends in monthly and annual average PFOS and PFOA concentrations of data collected over the last 24 months. The report shall also provide a comparison on the likelihood of the facility needing to develop a PFOS/PFOA minimization plan.</p> <p>This report shall include all additional PFOS and PFOA data that may be collected including any influent, intake, in-plant, collection system sampling, and blank sample results.</p> <p>The permittee shall also submit a request to the department to evaluate the need for a PFOS/PFOA minimization plan.</p> <p>If the Department determines a PFOS/PFOA minimization plan is needed based on a reasonable potential evaluation, the permittee will be required to develop a minimization plan for Department approval no later than 90 days after written notification was sent from the Department. The Department will modify or revoke and reissue the permit to include PFOS/PFOA minimization plan reporting requirements along with a schedule of compliance to meet WQBELs. Effluent monitoring of PFOS and PFOA shall continue as specified in the permit until the modified permit is issued.</p> <p>If, however, the Department determines there is no reasonable potential for the facility to discharge PFOS or PFOA above the narrative standard in s. NR 102.04(8)(d), Wis. Adm. Code, no further action is required and effluent monitoring of PFOS and PFOA shall continue as specified in the permit.</p>	10/01/2025

#### 4.5 PFOS and PFOA Minimization Plan

This compliance schedule requires the permittee to achieve compliance by the Due Date.

Required Action	Due Date
<p><b>Submit Progress Report #1:</b> Submit an annual progress report. The annual progress report shall:</p> <p>Indicate which source reduction measures or activities in the approved PFOS and PFOA minimization plan have been implemented;</p> <p>Identify which suspected sources have been monitored;</p> <p>Include an analysis of trends in weekly, monthly and annual average PFOS and/or PFOA concentrations; and</p> <p>Include an analysis of how influent and effluent concentrations vary with time and with significant loadings of PFAS such as loads from industries or other sources into the collection system.</p>	06/30/2027
<p><b>Submit Progress Report #2:</b> Submit the PFOS and PFOA minimization progress report as defined above.</p>	11/30/2027
<p><b>Submit Progress Report #3 and Re-evaluation:</b> Submit a progress report on the success in the implementation of the PFAS minimization plan. The report shall include a summary of all actions</p>	03/31/2028

<p>taken and analysis of trends in weekly, monthly, and annual average PFOA and/or PFOS effluent concentrations.</p> <p>If initial PMP actions were not successful enough to result in PFOA and/or PFOS reductions below the values in s. NR 102.04(8)(d)1., Wis. Adm. Code, the permittee shall submit an updated PMP with the permit application for reissuance. Based on facility and PMP specifics the permittee may be allowed up to 53 additional months after the permit expiration date to implement additional PMP actions before being required to install PFAS treatment technologies. This schedule may be modified to adjust compliance schedule dates to incorporate any changes in minimization plan goals and actions or as new information is made available to the department.</p>	
<p><b>Submit Progress Report #4:</b> Submit the PFOS and PFOA minimization progress report as defined above.</p>	09/30/2029
<p><b>Submit Progress Report #5:</b> Submit the PFOS and PFOA minimization progress report as defined above.</p>	09/30/2030
<p><b>Submit Progress Report #6:</b> Submit the PFOS and PFOA minimization progress report as defined above.</p>	09/30/2031
<p><b>Submit Progress Report #7:</b> Submit the PFOS and PFOA minimization progress report as defined above.</p>	09/30/2032
<p><b>Submit Final Progress Report and Re-evaluation:</b> Submit a progress report on the success in the implementation of the PFOS and PFOA minimization plan. The report shall include a summary of all actions taken and analysis of trends in weekly, monthly, and annual average PFOS and/or PFOA effluent concentrations.</p> <p>If initial PMP actions were not successful enough to result in PFOS and/or PFOA reductions below the values in s. NR 102.04(8)(d)1., Wis. Adm. Code, the permittee shall be required to install PFAS treatment technologies to meet the calculated WQBELs.</p>	03/31/2033
<p><b>Submit Preliminary Engineering Report:</b> The permittee shall submit a report outlining the various options for compliance with the applicable PFOS and/or PFOA WQBELs to the Department for review.</p>	03/31/2034
<p><b>Plan and Specification Submittal:</b> The permittee shall submit final construction plans and specifications to the Department for approval pursuant to ch. NR 108, Wis. Adm. Code, specifying treatment plant upgrades that must be constructed to achieve compliance with the applicable PFOS and/or PFOA WQBELs, and a schedule for completing construction of the upgrades by the complete construction date specified below.</p>	03/31/2035
<p><b>Treatment Plant Upgrade to Meet Limitations:</b> The permittee shall initiate bidding, procurement, and/or construction of the project. The permittee shall obtain approval of final constructions plans and schedule from the Department pursuant to s. 281.41, Stats., prior to initiating activities defined as construction under ch. NR 108, Wis. Adm. Code. Upon approval of the final construction plans/specifications and schedule by the Department, the permittee shall construct the treatment plant upgrades in accordance with the approved plans and specifications.</p>	03/31/2036
<p><b>Complete Construction:</b> The permittee shall complete construction of the wastewater treatment plant upgrades.</p>	03/31/2037
<p><b>Achieve Compliance:</b> The permittee shall achieve compliance with the PFOS water quality-based effluent limit of 8 ng/L as a monthly average.</p>	04/30/2037

## 5 Standard Requirements

**NR 205, Wisconsin Administrative Code (Conditions for Industrial Dischargers):** The conditions in ss. NR 205.07(1) and NR 205.07(3), Wis. Adm. Code, are included by reference in this permit. The permittee shall comply with all of these requirements. Some of these requirements are outlined in the Standard Requirements section of this permit. Requirements not specifically outlined in the Standard Requirement section of this permit can be found in ss. NR 205.07(1) and NR 205.07(3).

### 5.1 Reporting and Monitoring Requirements

#### 5.1.1 Monitoring Results

Monitoring results obtained during the previous month shall be summarized and reported on a Department Wastewater Discharge Monitoring Report. The report may require reporting of any or all of the information specified below under 'Recording of Results'. This report is to be returned to the Department no later than the date indicated on the form. A copy of the Wastewater Discharge Monitoring Report Form or an electronic file of the report shall be retained by the permittee.

Monitoring results shall be reported on an electronic discharge monitoring report (eDMR). The eDMR shall be certified electronically by a responsible executive or officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The 'eReport Certify' page certifies that the electronic report form is true, accurate and complete.

If the permittee monitors any pollutant more frequently than required by this permit, the results of such monitoring shall be included on the Wastewater Discharge Monitoring Report.

The permittee shall comply with all limits for each parameter regardless of monitoring frequency. For example, monthly, weekly, and/or daily limits shall be met even with monthly monitoring. The permittee may monitor more frequently than required for any parameter.

#### 5.1.2 Sampling and Testing Procedures

Sampling and laboratory testing procedures shall be performed in accordance with Chapters NR 218 and NR 219, Wis. Adm. Code and shall be performed by a laboratory certified or registered in accordance with the requirements of ch. NR 149, Wis. Adm. Code. Groundwater sample collection and analysis shall be performed in accordance with ch. NR 140, Wis. Adm. Code. The analytical methodologies used shall enable the laboratory to quantitate all substances for which monitoring is required at levels below the effluent limitation. If the required level cannot be met by any of the methods available in NR 219, Wis. Adm. Code, then the method with the lowest limit of detection shall be selected. Additional test procedures may be specified in this permit.

#### 5.1.3 Recording of Results

The permittee shall maintain records which provide the following information for each effluent measurement or sample taken:

- the date, exact place, method and time of sampling or measurements;
- the individual who performed the sampling or measurements;
- the date the analysis was performed;
- the individual who performed the analysis;
- the analytical techniques or methods used; and
- the results of the analysis.

#### **5.1.4 Reporting of Monitoring Results**

The permittee shall use the following conventions when reporting effluent monitoring results:

- Pollutant concentrations less than the limit of detection shall be reported as < (less than) the value of the limit of detection. For example, if a substance is not detected at a detection limit of 0.1 mg/L, report the pollutant concentration as < 0.1 mg/L.
- Pollutant concentrations equal to or greater than the limit of detection, but less than the limit of quantitation, shall be reported and the limit of quantitation shall be specified.
- For purposes of calculating NR 101 fees, the 2 mg/l lower reporting limits for BOD5 and Total Suspended Solids shall be considered to be limits of quantitation
- For the purposes of reporting a calculated result, average or a mass discharge value, the permittee may substitute a “0” (zero) for any pollutant concentration that is less than the limit of detection. However, if the effluent limitation is less than the limit of detection, the department may substitute a value other than zero for results less than the limit of detection, after considering the number of monitoring results that are greater than the limit of detection and if warranted when applying appropriate statistical techniques.
- If no discharge occurs through an outfall, flow related parameters (e.g. flow rate, hydraulic application rate, volume, etc.) should be reported as “0” (zero) at the required sample frequency specified for the outfall. For example: if the sample frequency is daily, “0” would be reported for any day during the month that no discharge occurred.

#### **5.1.5 Records Retention**

The permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings or electronic data records for continuous monitoring instrumentation, copies of all reports required by the permit, and records of all data used to complete the application for the permit for a period of at least 3 years from the date of the sample, measurement, report or application, except for sludge management forms and records, which shall be kept for a period of at least 5 years.

#### **5.1.6 Other Information**

Where the permittee becomes aware that it failed to submit any relevant facts in a permit application or submitted incorrect information in a permit application or in any report to the Department, it shall promptly submit such facts or correct information to the Department.

#### **5.1.7 Reporting Requirements – Alterations or Additions**

The permittee shall give notice to the Department as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is only required when:

- The alteration or addition to the permitted facility may meet one of the criteria for determining whether a facility is a new source.
- The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification requirement applies to pollutants which are not subject to effluent limitations in the existing permit.
- The alteration or addition results in a significant change in the permittee’s sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use of disposal sites not reported during the permit application process nor reported pursuant to an approved land application plan. Additional sites may not be used for the land application of sludge until department approval is received.

### **5.2 System Operating Requirements**

### 5.2.1 Noncompliance Reporting

The permittee shall report the following types of noncompliance by a telephone call to the Department's regional office within 24 hours after becoming aware of the noncompliance:

- any noncompliance which may endanger health or the environment;
- any violation of an effluent limitation resulting from a bypass;
- any violation of an effluent limitation resulting from an upset; and
- any violation of a maximum discharge limitation for any of the pollutants listed by the Department in the permit, either for effluent or sludge.

A written report describing the noncompliance shall also be submitted to the Department as directed at the end of this permit within 5 days after the permittee becomes aware of the noncompliance. On a case-by-case basis, the Department may waive the requirement for submittal of a written report within 5 days and instruct the permittee to submit the written report with the next regularly scheduled monitoring report. In either case, the written report shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times; the steps taken or planned to reduce, eliminate and prevent reoccurrence of the noncompliance; and if the noncompliance has not been corrected, the length of time it is expected to continue.

A scheduled bypass approved by the Department under the 'Scheduled Bypass' section of this permit shall not be subject to the reporting required under this section.

**NOTE:** Section 292.11(2)(a), Wisconsin Statutes, requires any person who possesses or controls a hazardous substance or who causes the discharge of a hazardous substance to notify the Department of Natural Resources **immediately** of any discharge not authorized by the permit. **The discharge of a hazardous substance that is not authorized by this permit or that violates this permit may be a hazardous substance spill. To report a hazardous substance spill, call DNR's 24-hour HOTLINE at 1-800-943-0003.**

### 5.2.2 Bypass

Except for a controlled diversion as provided in the 'Controlled Diversions' section of this permit, any bypass is prohibited and the Department may take enforcement action against a permittee for such occurrences under s. 283.89, Wis. Stats. The Department may approve a bypass if the permittee demonstrates all the following conditions apply:

- The bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
- There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities or adequate back-up equipment, retention of untreated wastes, reduction of inflow and infiltration, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventative maintenance. When evaluating feasibility of alternatives, the department may consider factors such as technical achievability, costs and affordability of implementation and risks to public health, the environment and, where the permittee is a municipality, the welfare of the community served; and
- The bypass was reported in accordance with the 'Noncompliance Reporting' section of this permit.

### 5.2.3 Scheduled Bypass

Whenever the permittee anticipates the need to bypass for purposes of efficient operations and maintenance and the permittee may not meet the conditions for controlled diversions in the 'Controlled Diversions' section of this permit, the permittee shall obtain prior written approval from the Department for the scheduled bypass. A permittee's written request for Department approval of a scheduled bypass shall demonstrate that the conditions for unscheduled bypassing are met and include the proposed date and reason for the bypass, estimated volume and duration of the bypass, alternatives to bypassing and measures to mitigate environmental harm caused by the bypass. The department may require the permittee to provide public notification for a scheduled bypass if it is determined there is significant public interest in the proposed action and may recommend mitigation measures to minimize the impact of such bypass.

### **5.2.4 Controlled Diversions**

Controlled diversions are allowed only when necessary for essential maintenance to assure efficient operation provided the following requirements are met:

- Effluent from the wastewater treatment facility shall meet the effluent limitations established in the permit. Wastewater that is diverted around a treatment unit or treatment process during a controlled diversion shall be recombined with wastewater that is not diverted prior to the effluent sampling location and prior to effluent discharge;
- A controlled diversion may not occur during periods of excessive flow or other abnormal wastewater characteristics;
- A controlled diversion may not result in a wastewater treatment facility overflow; and
- All instances of controlled diversions shall be documented in wastewater treatment facility records and such records shall be available to the department on request.

### **5.2.5 Proper Operation and Maintenance**

The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance includes effective performance, adequate funding, adequate operator staffing and training as required in ch. NR 114, Wis. Adm. Code, and adequate laboratory and process controls, including appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems only when necessary to achieve compliance with the conditions of the permit.

### **5.2.6 Operator Certification**

The wastewater treatment facility shall be under the direct supervision of a state certified operator. In accordance with s. NR 114.53, Wis. Adm. Code, every WPDES permitted treatment plant shall have a designated operator-in-charge holding a current and valid certificate. The designated operator-in-charge shall be certified at the level and in all subclasses of the treatment plant, except laboratory. Treatment plant owners shall notify the department of any changes in the operator-in-charge within 30 days. Note that s. NR 114.52(22), Wis. Adm. Code, lists types of facilities that are excluded from operator certification requirements (i.e. private sewage systems, pretreatment facilities discharging to public sewers, industrial wastewater treatment that consists solely of land disposal, agricultural digesters and concentrated aquatic production facilities with no biological treatment).

### **5.2.7 Spill Reporting**

The permittee shall notify the Department in accordance with ch. NR 706 (formerly NR 158), Wis. Adm. Code, in the event that a spill or accidental release of any material or substance results in the discharge of pollutants to the waters of the state at a rate or concentration greater than the effluent limitations established in this permit, or the spill or accidental release of the material is unregulated in this permit, unless the spill or release of pollutants has been reported to the Department in accordance with s. NR 205.07 (1)(s), Wis. Adm. Code.

### **5.2.8 Planned Changes**

In accordance with ss. 283.31(4)(b) and 283.59, Stats., the permittee shall report to the Department any facility expansion, production increase or process modifications which will result in new, different or increased discharges of pollutants. The report shall either be a new permit application, or if the new discharge will not violate the effluent limitations of this permit, a written notice of the new, different or increased discharge. The notice shall contain a description of the new activities, an estimate of the new, different or increased discharge of pollutants and a description of the effect of the new or increased discharge on existing waste treatment facilities. Following receipt of this report, the Department may modify this permit to specify and limit any pollutants not previously regulated in the permit.

### 5.2.9 Duty to Halt or Reduce Activity

Upon failure or impairment of treatment facility operation, the permittee shall, to the extent necessary to maintain compliance with its permit, curtail production or wastewater discharges or both until the treatment facility operations are restored or an alternative method of treatment is provided.

## 5.3 Surface Water Requirements

### 5.3.1 Permittee-Determined Limit of Quantitation Incorporated into this Permit

For pollutants with water quality-based effluent limits below the Limit of Quantitation (LOQ) in this permit, the LOQ calculated by the permittee and reported on the Discharge Monitoring Reports (DMRs) is incorporated by reference into this permit. The LOQ shall be reported on the DMRs, shall be the lowest quantifiable level practicable, and shall be no greater than the minimum level (ML) specified in or approved under 40 CFR Part 136 for the pollutant at the time this permit was issued, unless this permit specifies a higher LOQ.

### 5.3.2 Appropriate Formulas for Effluent Calculations

The permittee shall use the following formulas for calculating effluent results to determine compliance with average concentration limits and mass limits and total load limits:

**Weekly/Monthly/Six-Month/Annual Average Concentration** = the sum of all daily results for that week/month/six-month/year, divided by the number of results during that time period. [Note: When a six-month average effluent limit is specified for Total Phosphorus the applicable periods are May through October and November through April.]

**Weekly Average Mass Discharge (lbs/day):** Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the week.

**Monthly Average Mass Discharge (lbs/day):** Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the month.

**Six-Month Average Mass Discharge (lbs/day):** Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the six-month period. [Note: When a six-month average effluent limit is specified for Total Phosphorus the applicable periods are May through October and November through April.]

**Annual Average Mass Discharge (lbs/day):** Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the entire year.

**Total Monthly Discharge:** = monthly average concentration (mg/L) x total flow for the month (MG/month) x 8.34.

**Total Annual Discharge:** = sum of total monthly discharges for the calendar year.

**12-Month Rolling Sum of Total Monthly Discharge:** = the sum of the most recent 12 consecutive months of Total Monthly Discharges.

### 5.3.3 Effluent Temperature Requirements

**Weekly Average Temperature** – If temperature limits are included in this permit, Weekly Average Temperature shall be calculated as the sum of all daily maximum results for that week divided by the number of daily maximum results during that time period.

**Cold Shock Standard** – Water temperatures of the discharge shall be controlled in a manner as to protect fish and aquatic life uses from the deleterious effects of cold shock pursuant to Wis. Adm. Code, s. NR 102.28. ‘Cold Shock’ means exposure of aquatic organisms to a rapid decrease in temperature and a sustained exposure to low temperature that induces abnormal behavior or physiological performance and may lead to death.

**Rate of Temperature Change Standard** – Temperature of a water of the state or discharge to a water of the state may not be artificially raised or lowered at such a rate that it causes detrimental health or reproductive effects to fish or aquatic life of the water of the state pursuant to Wis. Adm. Code, s. NR 102.29.

### **5.3.4 Energy Emergency Events**

The Department will use enforcement discretion whenever there are exceedances of effluent temperature limitations for the electric generating facility during an energy emergency warning or when an energy emergency event has been declared under a Federal Energy Regulatory Commission order (Standard EOP-002, North American Electric Reliability Corporation).

### **5.3.5 Visible Foam or Floating Solids**

There shall be no discharge of floating solids or visible foam in other than trace amounts.

### **5.3.6 Surface Water Uses and Criteria**

In accordance with NR 102.04, Wis. Adm. Code, surface water uses and criteria are established to govern water management decisions. Practices attributable to municipal, industrial, commercial, domestic, agricultural, land development or other activities shall be controlled so that all surface waters including the mixing zone meet the following conditions at all times and under all flow and water level conditions:

- a) Substances that will cause objectionable deposits on the shore or in the bed of a body of water, shall not be present in such amounts as to interfere with public rights in waters of the state.
- b) Floating or submerged debris, oil, scum or other material shall not be present in such amounts as to interfere with public rights in waters of the state.
- c) Materials producing color, odor, taste or unsightliness shall not be present in such amounts as to interfere with public rights in waters of the state.
- d) Substances in concentrations or in combinations which are toxic or harmful to humans shall not be present in amounts found to be of public health significance, nor shall substances be present in amounts which are acutely harmful to animal, plant or aquatic life.

### **5.3.7 Additives**

In the event that the permittee wishes to commence use of a water treatment additive, or increase the usage of the additives greater than indicated in the permit application, the permittee must get a written approval from the Department prior to initiating such changes. This written approval shall provide authority to utilize the additives at the specific rates until the permit can be either reissued or modified in accordance with s. 283.53, Stats. Restrictions on the use of the additives may be included in the authorization letter.

## 6 Summary of Reports Due

FOR INFORMATIONAL PURPOSES ONLY

Description	Date	Page
Annual Certification Statements and Reports for Intake Structure -Submit Annual Certification Statement and Report #1	January 31, 2024	9
Annual Certification Statements and Reports for Intake Structure -Submit Annual Certification Statement and Report #2	January 31, 2025	9
Annual Certification Statements and Reports for Intake Structure -Submit Annual Certification Statement and Report #3	January 31, 2026	9
Annual Certification Statements and Reports for Intake Structure -Submit Annual Certification Statement and Report #4	January 31, 2027	9
Annual Certification Statements and Reports for Intake Structure -Submit Annual Certification Statement and Report #5	January 31, 2028	9
Annual Certification Statements and Reports for Intake Structure -Ongoing Annual Certification Statements and Reports	See Permit	9
Impingement Mortality BTA Schedule -Compliance Option	January 1, 2026	9
Impingement Mortality BTA Schedule -Plans and Specifications	January 1, 2027	9
Impingement Mortality BTA Schedule -Construction	January 1, 2028	9
Optimization Study -Progress Report	January 1, 2027	9
Optimization Study -Optimization Study	January 1, 2028	9
PFOS/PFOA Minimization Plan Determination of Need -Report on Effluent Discharge	October 1, 2024	10
PFOS/PFOA Minimization Plan Determination of Need -Report on Effluent Discharge and Evaluation of Need	October 1, 2025	10
PFOS and PFOA Minimization Plan -Submit Progress Report #1	June 30, 2027	10
PFOS and PFOA Minimization Plan -Submit Progress Report #2	November 30, 2027	10
PFOS and PFOA Minimization Plan -Submit Progress Report #3 and Re-evaluation	March 31, 2028	11
PFOS and PFOA Minimization Plan -Submit Progress Report #4	September 30, 2029	11
PFOS and PFOA Minimization Plan -Submit Progress Report #5	September 30, 2030	11
PFOS and PFOA Minimization Plan -Submit Progress Report #6	September 30, 2031	11
PFOS and PFOA Minimization Plan -Submit Progress Report #7	September 30, 2032	11
PFOS and PFOA Minimization Plan -Submit Final Progress Report and Re-evaluation	March 31, 2033	11
PFOS and PFOA Minimization Plan -Submit Preliminary Engineering Report	March 31, 2034	11
PFOS and PFOA Minimization Plan -Plan and Specification Submittal	March 31, 2035	11
PFOS and PFOA Minimization Plan -Treatment Plant Upgrade to Meet	March 31, 2036	11

WPDES Permit No. WI-0001961-10-2  
Madison Gas and Electric Company

Limitations		
PFOS and PFOA Minimization Plan -Complete Construction	March 31, 2037	11
PFOS and PFOA Minimization Plan -Achieve Compliance	April 30, 2037	11
Wastewater Discharge Monitoring Report	no later than the date indicated on the form	12

Report forms shall be submitted electronically in accordance with the reporting requirements herein. Any facility plans or plans and specifications for municipal, industrial, industrial pretreatment and non industrial wastewater systems shall be submitted to the Bureau of Water Quality, P.O. Box 7921, Madison, WI 53707-7921. All other submittals required by this permit shall be submitted to:

Central Office, 101 S Webster St, P.O. Box 7921, Madison, WI 53707-7921