



WPDES PERMIT

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
**PERMIT TO DISCHARGE UNDER THE WISCONSIN POLLUTANT DISCHARGE
ELIMINATION SYSTEM**

Organic Valley Chaseburg

is permitted, under the authority of Chapter 283, Wisconsin Statutes, to discharge from a facility
located at
203 S Main St Chaseburg WI 54521
to
groundwaters of the Bad Axe River and Coon Creek Watershed Basin located in Vernon County

in accordance with the effluent limitations, monitoring requirements and other conditions set
forth in this permit.

The permittee shall not discharge after the date of expiration. If the permittee wishes to continue to discharge after this expiration date an application shall be filed for reissuance of this permit, according to Chapter NR 200, Wis. Adm. Code, at least 180 days prior to the expiration date given below.

State of Wisconsin Department of Natural Resources
For the Secretary

By _____
Geisa Bittencourt
Wastewater Field Supervisor

Date Permit Signed/Issued

PERMIT TERM: EFFECTIVE DATE - July 01, 2024

EXPIRATION DATE - June 30, 2029

TABLE OF CONTENTS

1 LAND APPLICATION REQUIREMENTS	1
1.1 SAMPLING POINT(S)	1
1.2 MONITORING REQUIREMENTS AND LIMITATIONS	1
1.2.1 <i>Sampling Point (Outfall) 001 - BUTTERMILK and 003- MILK PRODUCTS</i>	1
1.2.2 <i>Sampling Point (Outfall) 002 - DAF SLUDGE</i>	3
2 SCHEDULES	5
2.1 LAND APPLICATION MANAGEMENT PLAN	5
3 STANDARD REQUIREMENTS	6
3.1 REPORTING AND MONITORING REQUIREMENTS	6
3.1.1 <i>Sampling and Testing Procedures</i>	6
3.1.2 <i>Recording of Results</i>	6
3.1.3 <i>Records Retention</i>	6
3.1.4 <i>Other Information</i>	6
3.1.5 <i>Reporting Requirements – Alterations or Additions</i>	6
3.2 SYSTEM OPERATING REQUIREMENTS	7
3.2.1 <i>Noncompliance Reporting</i>	7
3.2.2 <i>Bypass</i>	7
3.2.3 <i>Scheduled Bypass</i>	8
3.2.4 <i>Controlled Diversions</i>	8
3.2.5 <i>Proper Operation and Maintenance</i>	8
3.2.6 <i>Operator Certification</i>	8
3.2.7 <i>Spill Reporting</i>	8
3.2.8 <i>Planned Changes</i>	9
3.2.9 <i>Duty to Halt or Reduce Activity</i>	9
3.3 LAND APPLICATION REQUIREMENTS	9
3.3.1 <i>General Sludge Management Information</i>	9
3.3.2 <i>Land Application Characteristic Report</i>	9
3.3.3 <i>Annual Land Application Report</i>	9
3.3.4 <i>Other Methods of Disposal or Distribution Report</i>	10
3.3.5 <i>Land Application Site Approval</i>	10
3.3.6 <i>Operating Requirements/Management Plan</i>	10
3.3.7 <i>Chloride Requirements for Liquid Wastes and By-Product Solids</i>	10
3.3.8 <i>Nitrogen Requirements for Liquid Wastes and By-Product Solids and Sludges</i>	10
3.3.9 <i>Ponding</i>	11
3.3.10 <i>Runoff</i>	11
3.3.11 <i>Soil Incorporation Requirements</i>	11
3.3.12 <i>Field Stockpiles</i>	11
3.3.13 <i>By-Product Storage Sites</i>	11
3.3.14 <i>Annual Inspections-Stacking Pads and Leachate Containment</i>	12
3.3.15 <i>Additional Requirements from ch. NR 214, Wis. Adm. Code</i>	12
4 SUMMARY OF REPORTS DUE	13

1 Land Application Requirements

1.1 Sampling Point(s)

The discharge(s) shall be limited to land application of the waste type(s) designated for the listed sampling point(s) on Department approved land spreading sites or by hauling to another facility.

Sampling Point Designation	
Sampling Point Number	Sampling Point Location, Waste Type/Sample Contents and Treatment Description (as applicable)
001	Representative liquid waste samples shall be either collected from the septic tanker truck discharge line or the buttermilk tank before discharged to the truck.
002	Representative sludge samples shall be collected from the sludge tank as it is discharged to the A-1 Septic hauling truck or from the discharge line of the septic truck.
003	Representative liquid waste samples shall be collected from the milk tankers.

1.2 Monitoring Requirements and Limitations

The permittee shall comply with the following monitoring requirements and limitations.

1.2.1 Sampling Point (Outfall) 001 - BUTTERMILK and 003- MILK PRODUCTS

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Chloride		mg/L	Monthly	Grab	
Nitrogen, Total Kjeldahl		mg/L	Monthly	Grab	
Solids, Total		Percent	Quarterly	Grab	
Phosphorus, Total		mg/L	Quarterly	Grab	
Phosphorus, Water Extractable		% of Tot P	Quarterly	Grab	
Potassium, Total Recoverable		Percent	Quarterly	Grab	

Daily Log – Monitoring Requirements and Limitations All discharge and monitoring activity shall be documented on log sheets to comply with pars.NR 214.17(5)(a) and/or NR 214.18(5), Wis. Adm. Code Originals of the log sheets shall be kept by the permittee as described under “Records Retention” in the Standard Requirements section, and if requested, made available to the Department.				
Parameters	Limit	Units	Sample Frequency	Sample Type
Landspreading Rate	-	Date	Daily	Log
Landspreading Start Time	-	Time	Daily	Log
DNR Site Number(s)	-	Number	Daily	Log
Amount Applied	-	Unit*	Daily	Log
Application Rate	-	Unit*/Acre/Day	Daily	Calculated
Volume to Manure Pits	See NR 214.17(1)	Gallons/Day	Daily	Log
Manure Pit ID Number	-	Number		Log
Incorporation Time (if applicable)	-	Time	Daily	Log
Incorporation Date (if applicable)	-	Date	Daily	Log

*gallons, cubic yards, dry US tons, or dry metric tons

Annual Report – Summary of Monitoring Requirements and Limitations The Annual Report is due by January 31 st of each year for the previous calendar year. See the ‘Annual Land Application Report’ subsection in Standard Requirements.				
Parameters	Limit	Units	Reporting Frequency	Sample Type
DNR Site Number(s)	-	Number	-	-
Acres Land Applied	-	Acres	Annual	-
Total Volume Per Site	-	Gallons	Annual	Total Annual
Total Kjeldahl Nitrogen per Site	165, or alternate approved in writing	Pounds/Acre/Year	Annual	Calculated
Total Chloride per Site	340	Pounds/Acre per 2 Years	Annual	Calculated
Total Volume to Manure Pits	-	Gallons	Annual	Total Annual

1.2.1.1 Annual Site Nitrogen Loading

For details on nitrogen loading requirements, including approval of an alternate nitrogen pounds/acre/year site loading, see the “Nitrogen Requirements for Liquid Wastes, By-Product Solids and Sludges” paragraph in the Standard Requirements section of this permit.

1.2.1.2 Biennial Site Chloride Loading

For details on chloride requirements see the “Chloride Requirements for Liquid Wastes and By-Product Solids” paragraph in the Standard Requirements section of this permit.

1.2.1.3 Discharge to Manure Pit(s)

Pursuant to s. NR 214.17(1), Wisconsin Administrative Code, an exemption may be granted in writing to certain provisions of NR 214 for discharges to manure pits, provided industrial wastes are less than 10 % of the mixture contained in the manure pit at the time it is landspread.

1.2.2 Sampling Point (Outfall) 002 - DAF SLUDGE

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Sludge Hauled		tons/day	Daily	Total Daily	
Solids, Total		Percent	Quarterly	Grab	
Nitrogen, Total Kjeldahl		Percent	Quarterly	Grab	
Nitrogen, Ammonia (NH ₃ -N) Total		Percent	Quarterly	Grab	
Nitrogen, Organic Total		Percent	Quarterly	Grab	
Chloride		Percent	Quarterly	Grab	
Potassium, Total Recoverable		Percent	Quarterly	Grab	
Phosphorus, Total		Percent	Quarterly	Grab	
Phosphorus, Water Extractable		% of Tot P	Quarterly	Grab	
pH Field		su	Quarterly	Grab	
Lead Dry Wt		mg/kg	Once	Grab	
Zinc Dry Wt		mg/kg	Once	Grab	
Copper Dry Wt		mg/kg	Once	Grab	
Nickel Dry Wt		mg/kg	Once	Grab	
Cadmium Dry Wt		mg/kg	Once	Grab	
PCB Total Dry Wt		mg/kg	Once	Grab	

Daily Log – Monitoring Requirements and Limitations All discharge and monitoring activity shall be documented on log sheets. Originals of the log sheets shall be kept by the permittee as described under “Records Retention” in the Standard Requirements section, and if requested, made available to the Department.				
Parameters	Limit	Units	Sample Frequency	Sample Type
DNR Site Number(s)	-	Number	Daily	Log
Acres Applied	-	Acres	Daily	Log
Application Rate	-	Gal/Acre/Day	Daily	Calculated
Volume to Manure Pits	See NR 214.17(1)	Gallons/Day	Daily	Log
Manure Pit ID Number	-	Number		Log

Annual Report – Summary of Monitoring Requirements and Limitations The Annual Report is due by January 31 st of each year for the previous calendar year. See the ‘Annual Land Application Report’ subsection in Standard Requirements.				
Parameters	Limit	Units	Reporting Frequency	Sample Type
DNR Site Number(s)	-	Number	-	-
Acres Land Applied	-	Acres	Annual	-
Total Volume Per Site	-	Gallons	Annual	Total Annual
Total Kjeldahl Nitrogen per Site	165, or alternate approved in writing	Pounds/Acre/Year	Annual	Calculated
Total Chloride per Site	340	Pounds/Acre per 2 Years	Annual	Calculated
Total Volume to Manure Pits	-	Gallons	Annual	Total Annual

1.2.2.1 Annual Site Nitrogen Loading

For details on nitrogen loading requirements, including approval of an alternate nitrogen pounds/acre/year site loading, see the “Nitrogen Requirements for Liquid Wastes, By-Product Solids and Sludges” paragraph in the Standard Requirements section of this permit.

1.2.2.2 Biennial Site Chloride Loading

For details on chloride requirements see the “Chloride Requirements for Liquid Wastes and By-Product Solids” paragraph in the Standard Requirements section of this permit.

1.2.2.3 Discharge to Manure Pit(s)

Pursuant to s. NR 214.17(1), Wisconsin Administrative Code, an exemption may be granted in writing to certain provisions of NR 214 for discharges to manure pits, provided industrial wastes are less than 10 % of the mixture contained in the manure pit at the time it is landspread.

2 Schedules

2.1 Land Application Management Plan

A management plan is required for the land application system.

Required Action	Due Date
Land Application Management Plan: Submit a management plan to optimize the land application system performance and demonstrate compliance with Wisconsin Administrative Code NR 214.	09/30/2025

3 Standard Requirements

Chapter NR 205, Wisconsin Administrative Code (Conditions for Industrial Dischargers): The conditions in ss. NR 205.07(1) and NR 205.07(3), Wis. Adm. Code, are included by reference in this permit. The permittee shall comply with all of these requirements. Some of these requirements are outlined in the Standard Requirements section of this permit. Requirements not specifically outlined in the Standard Requirement section of this permit can be found in ss. NR 205.07(1) and NR 205.07(3), Wis. Adm. Code.

3.1 Reporting and Monitoring Requirements

3.1.1 Sampling and Testing Procedures

Sampling and laboratory testing procedures shall be performed in accordance with Chapters NR 218 and NR 219, Wis. Adm. Code, and completed by a laboratory certified or registered in accordance with the requirements of ch. NR 149, Wis. Adm. Code. Groundwater sampling shall be performed in accordance with procedures contained in s. NR 140.16, Wis. Adm. Code, and the WDNr publications, Groundwater Sampling Desk Reference (PUBL-DG-037-96) and Groundwater Sampling Field Manual (PUBL-DG-038-96). The analytical methodologies used shall enable the laboratory to quantitate all substances for which monitoring is required at levels below the effluent limitation and/or groundwater standard. If the required level cannot be met by any of the methods available in ch. NR 219, Wis. Adm. Code, then the method with the lowest limit of detection shall be selected. Additional test procedures may be specified in this permit.

3.1.2 Recording of Results

The permittee shall maintain records which provide the following information for each effluent measurement or sample taken:

- the date, exact place, method and time of sampling or measurements;
- the individual who performed the sampling or measurements;
- the date the analysis was performed;
- the individual who performed the analysis;
- the analytical techniques or methods used; and
- the results of the analysis.

3.1.3 Records Retention

The permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings or electronic data records for continuous monitoring instrumentation, copies of all reports required by the permit, and records of all data used to complete the application for the permit for a period of at least 3 years from the date of the sample, measurement, report or application, except for sludge management forms and records, which shall be kept for a period of at least 5 years.

3.1.4 Other Information

Where the permittee becomes aware that it failed to submit any relevant facts in a permit application or submitted incorrect information in a permit application or in any report to the Department, it shall promptly submit such facts or correct information to the Department.

3.1.5 Reporting Requirements – Alterations or Additions

The permittee shall give notice to the Department as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is only required when:

- The alteration or addition to the permitted facility may meet one of the criteria for determining whether a facility is a new source.
- The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification requirement applies to pollutants which are not subject to effluent limitations in the existing permit.
- The alteration or addition results in a significant change in the permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use of disposal sites not reported during the permit application process nor reported pursuant to an approved land application plan. Additional sites may not be used for the land application of sludge until department approval is received.

3.2 System Operating Requirements

3.2.1 Noncompliance Reporting

The permittee shall report the following types of noncompliance by a telephone call to the Department's regional office within 24 hours after becoming aware of the noncompliance:

- any noncompliance which may endanger health or the environment;
- any violation of an effluent limitation resulting from a bypass;
- any violation of an effluent limitation resulting from an upset; and
- any violation of a maximum discharge limitation for any of the pollutants listed by the Department in the permit, either for effluent or sludge.

A written report describing the noncompliance shall also be submitted to the Department as directed at the end of this permit within 5 days after the permittee becomes aware of the noncompliance. On a case-by-case basis, the Department may waive the requirement for submittal of a written report within 5 days and instruct the permittee to submit the written report with the next regularly scheduled monitoring report. In either case, the written report shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times; the steps taken or planned to reduce, eliminate and prevent reoccurrence of the noncompliance; and if the noncompliance has not been corrected, the length of time it is expected to continue.

A scheduled bypass approved by the Department under the 'Scheduled Bypass' section of this permit shall not be subject to the reporting required under this section.

NOTE: Section 292.11(2)(a), Wisconsin Statutes, requires any person who possesses or controls a hazardous substance or who causes the discharge of a hazardous substance to notify the Department of Natural Resources **immediately** of any discharge not authorized by the permit. **The discharge of a hazardous substance that is not authorized by this permit or that violates this permit may be a hazardous substance spill. To report a hazardous substance spill, call DNR's 24-hour HOTLINE at 1-800-943-0003.**

3.2.2 Bypass

Except for a controlled diversion as provided in the 'Controlled Diversions' section of this permit, any bypass is prohibited and the Department may take enforcement action against a permittee for such occurrences under s. 283.89, Wis. Stats. The Department may approve a bypass if the permittee demonstrates all the following conditions apply:

- The bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
- There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities or adequate back-up equipment, retention of untreated wastes, reduction of inflow and infiltration, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance. When evaluating feasibility of

alternatives, the department may consider factors such as technical achievability, costs and affordability of implementation and risks to public health, the environment and, where the permittee is a municipality, the welfare of the community served; and

- The bypass was reported in accordance with the ‘Noncompliance Reporting’ section of this permit.

3.2.3 Scheduled Bypass

Whenever the permittee anticipates the need to bypass for purposes of efficient operations and maintenance and the permittee may not meet the conditions for controlled diversions in the ‘Controlled Diversions’ section of this permit, the permittee shall obtain prior written approval from the Department for the scheduled bypass. A permittee’s written request for Department approval of a scheduled bypass shall demonstrate that the conditions for unscheduled bypassing are met and include the proposed date and reason for the bypass, estimated volume and duration of the bypass, alternatives to bypassing and measures to mitigate environmental harm caused by the bypass. The department may require the permittee to provide public notification for a scheduled bypass if it is determined there is significant public interest in the proposed action and may recommend mitigation measures to minimize the impact of such bypass.

3.2.4 Controlled Diversions

Controlled diversions are allowed only when necessary for essential maintenance to assure efficient operation provided the following requirements are met:

- Effluent from the wastewater treatment facility shall meet the effluent limitations established in the permit. Wastewater that is diverted around a treatment unit or treatment process during a controlled diversion shall be recombined with wastewater that is not diverted prior to the effluent sampling location and prior to effluent discharge;
- A controlled diversion may not occur during periods of excessive flow or other abnormal wastewater characteristics;
- A controlled diversion may not result in a wastewater treatment facility overflow; and
- All instances of controlled diversions shall be documented in wastewater treatment facility records and such records shall be available to the department on request.

3.2.5 Proper Operation and Maintenance

The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance includes effective performance, adequate funding, adequate operator staffing and training as required in ch. NR 114, Wis. Adm. Code, and adequate laboratory and process controls, including appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems only when necessary to achieve compliance with the conditions of the permit.

3.2.6 Operator Certification

The wastewater treatment facility shall be under the direct supervision of a state certified operator. In accordance with s. NR 114.53, Wis. Adm. Code, every WPDES permitted treatment plant shall have a designated operator-in-charge holding a current and valid certificate. The designated operator-in-charge shall be certified at the level and in all subclasses of the treatment plant, except laboratory. Treatment plant owners shall notify the department of any changes in the operator-in-charge within 30 days. Note that s. NR 114.52(22), Wis. Adm. Code, lists types of facilities that are excluded from operator certification requirements (i.e. private sewage systems, pretreatment facilities discharging to public sewers, industrial wastewater treatment that consists solely of land disposal, agricultural digesters and concentrated aquatic production facilities with no biological treatment).

3.2.7 Spill Reporting

The permittee shall notify the Department in accordance with ch. NR 706 (formerly NR 158), Wis. Adm. Code, in the event that a spill or accidental release of any material or substance results in the discharge of pollutants to the waters of the state at a rate or concentration greater than the effluent limitations established in this permit, or the spill or accidental release of the material is unregulated in this permit, unless the spill or release of pollutants has been reported to the Department in accordance with s. NR 205.07 (1)(s), Wis. Adm. Code.

3.2.8 Planned Changes

In accordance with ss. 283.31(4)(b) and 283.59, Stats., the permittee shall report to the Department any facility expansion, production increase or process modifications which will result in new, different or increased discharges of pollutants. The report shall either be a new permit application, or if the new discharge will not violate the effluent limitations of this permit, a written notice of the new, different or increased discharge. The notice shall contain a description of the new activities, an estimate of the new, different or increased discharge of pollutants and a description of the effect of the new or increased discharge on existing waste treatment facilities. Following receipt of this report, the Department may modify this permit to specify and limit any pollutants not previously regulated in the permit.

3.2.9 Duty to Halt or Reduce Activity

Upon failure or impairment of treatment facility operation, the permittee shall, to the extent necessary to maintain compliance with its permit, curtail production or wastewater discharges or both until the treatment facility operations are restored or an alternative method of treatment is provided.

3.3 Land Application Requirements

3.3.1 General Sludge Management Information

The General Sludge Management Form 3400-48 shall be completed and submitted prior to any significant sludge management changes.

3.3.2 Land Application Characteristic Report

The analytical results from testing of liquid wastes, by-product solids and sludges that are land applied shall be reported annually on the Characteristic Report Form 3400-49. The report form shall be submitted electronically no later than the date indicated on the form. Following submittal of the electronic Characteristic Report Form 3400-49, this form shall be certified electronically via the 'eReport Certify' page by a responsible executive officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The 'eReport Certify' page certifies that the electronic report form is true, accurate and complete.

The permittee shall use the following convention when reporting sludge monitoring results: Pollutant concentrations less than the limit of detection shall be reported as < (less than) the value of the limit of detection. For example, if a substance is not detected at a detection limit of 1.0 mg/kg, report the pollutant concentration as < 1.0 mg/kg.

All sludge results shall be reported on a dry weight basis.

3.3.3 Annual Land Application Report

The annual totals for the land application loadings of liquid wastes, by-product solids and sludges to field spreading sites shall be submitted electronically on the Annual Land Application Report Form 3400-55 by January 31, each year whether or not waste is land applied. Following submittal of the electronic Annual Land Application Report Form 3400-55, this form shall be certified electronically via the 'eReport Certify' page by a responsible executive officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The 'eReport Certify' page certifies that the electronic report form is true, accurate and complete.

3.3.4 Other Methods of Disposal or Distribution Report

The permittee shall submit electronically the Other Methods of Disposal or Distribution Report Form 3400-52 by January 31, each year whether or not waste is hauled to another facility, landfilled, incinerated, or stored in a manure pit. Following submittal of the electronic Report Form 3400-52, this form shall be certified electronically via the 'eReport Certify' page by a responsible executive officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The 'eReport Certify' page certifies that the electronic report form is true, accurate and complete.

3.3.5 Land Application Site Approval

The permittee is authorized to landspread permitted liquid wastes, by-product solids and sludges on sites approved in writing by the Department in accordance with ss. NR 214.17(2) and 214.18(2), Wis. Adm. Code. Any site use restrictions or granting of case-by-case exceptions shall be identified in the approval letter. If the permittee wishes to have approval for additional sites, application shall be made using Land Application Site Request Form 3400-053. Complete information shall be submitted about each site, including location maps and soil maps, any soil analyses results and other information showing that the site complies with all application requirements and permit conditions. Spreading on a site may commence upon receipt of Department approval. If an existing spreading site is found by the Department to be environmentally unacceptable, a written notice will be issued to withdraw approval of that site.

3.3.6 Operating Requirements/Management Plan

All land application sites used for treatment of liquid wastes, by-product solids and sludges shall be operated in accordance with a Department approved management plan. The management plan shall be consistent with the requirements of this permit, ss. NR 214.17 (3) and (6), and NR 214.18 (3) and (6), Wis. Adm. Code. If operational changes are needed, the land application management plan shall be amended by submitting a written request to the Department for approval. A land application management plan shall be submitted for approval at least 60 days prior to land application.

3.3.7 Chloride Requirements for Liquid Wastes and By-Product Solids

The total pounds of chloride applied shall be limited to 340 pounds per acre per 2 year period. Calculate the chloride loading as follows:

$$\text{Wet Weight Solids: } \frac{\text{lbs of solids} \times \% \text{solids} \times \% \text{chloride}}{\text{acres land applied} \times 100 \times 100} = \text{lbs chloride/acre}$$

$$\text{Liquid: } \frac{\text{mg/L chloride} \times (\text{millions of gallons}) \times 8.34}{\text{acres land applied}} = \text{lbs chloride/acre}$$

3.3.8 Nitrogen Requirements for Liquid Wastes and By-Product Solids and Sludges

NR 214.17(4) and NR 214.18(4) Wis. Adm. Code specify that the total pounds of nitrogen land applied per acre per year shall be limited to the nitrogen needs of the cover crop minus any other nitrogen added to the land application site, including fertilizer or manure. Nitrogen applied can be calculated on the basis of plant available nitrogen, as long as the release of nitrogen from the organic material is credited to future years. This permit requires that the Total Kjeldahl Nitrogen calendar year application amount shall not exceed 165 pounds per acre per year, except when alternate numerical nitrogen loading limits (consistent with the above sections of NR 214) are approved in writing via the Department's land application management plan approval. Calculate nitrogen loading as follows ("TKN" represents "Total Kjeldahl Nitrogen"):

Wet Weight Solids and Sludges: $\frac{\text{lbs of solids} \times \% \text{solids} \times \% \text{TKN}}{\text{acres land applied} \times 100 \times 100} = \text{lbs TKN/acre}$

Liquid: $\frac{\text{mg/L TKN} \times (\text{millions of gallons}) \times 8.34}{\text{acres land applied}} = \text{lbs TKN/acre}$

3.3.9 Ponding

The volume of liquid wastes land applied shall be limited to prevent ponding, except for temporary conditions following rainfall events. If ponding occurs all land application shall cease immediately. The permittee shall land apply only the liquid wastes that are permitted.

3.3.10 Runoff

The volume of liquid wastes land applied shall be limited to prevent runoff. If runoff occurs all land application shall cease immediately. The permittee shall land apply only the liquid wastes that are permitted.

3.3.11 Soil Incorporation Requirements

- **Liquid Sludge Requirements:** The Department may require that liquid sludge be incorporated into the soil on specific land application sites when necessary to prevent surface runoff or objectionable odors. Requirements and procedures for incorporation of liquid sludge, when such incorporation may be necessary, shall be specified in the management plan or in specific site applications, subject to Department approval. The permittee shall comply with the requirements in the Department approved management plan, specific site-approval requirements and the terms and conditions of this permit.
- **Cake Sludge Requirements:** After land application, cake sludge shall be incorporated into the soil. The timing of such incorporation and other related requirements and procedures shall be specified in the management plan or in specific site applications, subject to Department approval. The permittee shall comply with the requirements in the Department approved management plan, specific site-approval requirements and the terms and conditions of this permit.
- **Liquid Wastewater Requirements:** The Department may require that liquid wastewater be incorporated or injected into the soil on specific land application sites when necessary to prevent surface runoff or objectionable odors. Requirements and procedures for injection or incorporation of liquid wastewater, when such injection or incorporation is necessary, shall be specified in the management plan or in specific site applications, subject to Department approval. The permittee shall comply with the requirements in the Department approved management plan, specific site-approval requirements and the terms and conditions of this permit.
- **By-Product Solids Requirements:** The Department may limit the volume of by-products solids that are landspread on a specific site when necessary to prevent surface runoff or leaching of contaminants to groundwater and objectionable odors. By-product solids shall, after application, be plowed, disced, or otherwise incorporated into the soil. Requirements and procedures for the incorporation of byproduct solids into the soil shall be specified in the management plan or in specific site applications, subject to Department approval. The permittee shall comply with the requirements in the Department approved management plan, specific site-approval requirements and the terms and conditions of this permit.

3.3.12 Field Stockpiles

The permittee is encouraged to landspread the by-product solids or sludges as they are transported to the fields; but if it becomes necessary to stockpile solids in the fields, the stockpiles shall be spread within 72 hours or as specified in the approved management plan.

3.3.13 By-Product Storage Sites

All sites used for storage of by-product solids shall be located such that surface water or groundwater pollution does not occur. Written Department approval is required prior to storage of more than 150 tons of by-product solids on a site at any one time.

3.3.14 Annual Inspections-Stacking Pads and Leachate Containment

Stacking pads for more than 1200 tons of silage and all leachate containment facilities shall be inspected annually for cracks and shall be repaired as necessary to prevent leakage from the containment system. The inspection reports shall be available for inspection by Department personnel for a period of three years, and shall include at a minimum the following information:

- date and name of person(s) performing the inspection
- description of what the inspection consisted of
- details of what was discovered during the inspection
- recommendations for repair or maintenance
- details of repair completed

3.3.15 Additional Requirements from ch. NR 214, Wis. Adm. Code

The requirements of s. NR 214.17 (4)(c) [pathogen prohibition for human consumption crop fields], (4)(d)1 [no adverse soil effects], (4)(d)10 [allowable whey spreading rates], and (4)(e)1-3 [by-product solids spreading within agricultural practices and not cause contamination] for landspreading of liquid wastes and by product solids and s. NR 214.18 (4)(b),(d)-(h) [application, nutrient, pH, metals, and PCB limitations] for sludge spreading systems are included by reference in this permit. The permittee shall comply with these requirements.

4 Summary of Reports Due

FOR INFORMATIONAL PURPOSES ONLY

Description	Date	Page
Land Application Management Plan -Land Application Management Plan	September 30, 2025	6
General Sludge Management Form 3400-48	prior to any significant sludge management changes	9
Characteristic Report Form 3400-49	no later than the date indicated on the form	9
Land Application Report Form 3400-55	January 31, each year whether or not waste is land applied	9
Other Methods of Disposal or Distribution Report Form 3400-52	by January 31, each year whether or not waste is hauled to another facility, landfilled, incinerated, or stored in a manure pit	10

Report forms shall be submitted electronically in accordance with the reporting requirements herein. Any facility plans or plans and specifications for municipal, industrial, industrial pretreatment and non industrial wastewater systems shall be submitted to the Bureau of Water Quality, P.O. Box 7921, Madison, WI 53707-7921. All other submittals required by this permit shall be submitted to:

West Central Region, 1300 W. Clairemont Ave, Eau Claire, WI 54701