



WPDES PERMIT

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
**PERMIT TO DISCHARGE UNDER THE WISCONSIN POLLUTANT DISCHARGE
ELIMINATION SYSTEM**

Payne and Dolan, Inc. - Capitol Sand & Gravel Site# 80328

is permitted, under the authority of Chapter 283, Wisconsin Statutes, to discharge from a facility
located at
8355 Stagecoach Rd, Cross Plains, Wisconsin
to

**Black Earth Creek, located in the Black Earth Creek Watershed
in the Lower Wisconsin River Basin (LW 17) in Dane County**

in accordance with the effluent limitations, monitoring requirements and other conditions set
forth in this permit.

The permittee shall not discharge after the date of expiration. If the permittee wishes to continue to discharge after this expiration date an application shall be filed for reissuance of this permit, according to Chapter NR 200, Wis. Adm. Code, at least 180 days prior to the expiration date given below.

State of Wisconsin Department of Natural Resources
For the Secretary

By _____
Tim Ryan
Field Operations Director

Date Permit Signed/Issued

PERMIT TERM: EFFECTIVE DATE - January 01, 2024
Modification Effective Date – April 1, 2025

EXPIRATION DATE - December 31, 2028

TABLE OF CONTENTS

1 SURFACE WATER REQUIREMENTS	1
1.1 SAMPLING POINT(S)	1
1.2 MONITORING REQUIREMENTS AND EFFLUENT LIMITATIONS	1
1.2.1 <i>Sampling Point (Outfall) 001 - Gravel Pit Effluent</i>	1
2 SCHEDULES	4
2.1 TEMPERATURE LIMITS (INDUSTRIAL FACILITIES)	4
2.2 PERMIT APPLICATION PHOSPHORUS MONITORING	4
2.3 PERMIT APPLICATION SUBMITTAL	4
3 STANDARD REQUIREMENTS	5
3.1 REPORTING AND MONITORING REQUIREMENTS	5
3.1.1 <i>Monitoring Results</i>	5
3.1.2 <i>Sampling and Testing Procedures</i>	5
3.1.3 <i>Recording of Results</i>	5
3.1.4 <i>Reporting of Monitoring Results</i>	6
3.1.5 <i>Records Retention</i>	6
3.1.6 <i>Other Information</i>	6
3.1.7 <i>Reporting Requirements – Alterations or Additions</i>	6
3.2 SYSTEM OPERATING REQUIREMENTS	6
3.2.1 <i>Noncompliance Reporting</i>	7
3.2.2 <i>Bypass</i>	7
3.2.3 <i>Scheduled Bypass</i>	7
3.2.4 <i>Controlled Diversions</i>	8
3.2.5 <i>Proper Operation and Maintenance</i>	8
3.2.6 <i>Operator Certification</i>	8
3.2.7 <i>Spill Reporting</i>	8
3.2.8 <i>Planned Changes</i>	8
3.2.9 <i>Duty to Halt or Reduce Activity</i>	9
3.3 SURFACE WATER REQUIREMENTS	9
3.3.1 <i>Permittee-Determined Limit of Quantitation Incorporated into this Permit</i>	9
3.3.2 <i>Appropriate Formulas for Effluent Calculations</i>	9
3.3.3 <i>Effluent Temperature Requirements</i>	9
3.3.4 <i>Visible Foam or Floating Solids</i>	10
3.3.5 <i>Surface Water Uses and Criteria</i>	10
4 SUMMARY OF REPORTS DUE	11

1 Surface Water Requirements

1.1 Sampling Point(s)

The discharge(s) shall be limited to the waste type(s) designated for the listed sampling point(s).

Sampling Point Designation	
Sampling Point Number	Sampling Point Location, WasteType/Sample Contents and Treatment Description (as applicable)
001	Representative samples of untreated gravel pit effluent shall be collected at Outfall 001 which is located 100 feet south of Stagecoach Road bridge on Black Earth Creek. Monitoring requirements and limitations specified below are in effect whenever discharge occurs.

1.2 Monitoring Requirements and Effluent Limitations

The permittee shall comply with the following monitoring requirements and limitations.

1.2.1 Sampling Point (Outfall) 001 - Gravel Pit Effluent

Monitoring Requirements and Effluent Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Daily	Calculated	
Dissolved Oxygen	Daily Min	6.0 mg/L	1/6 Months	Grab	Limit effective April 1 to October 31. Two samples annually with one sample taken April – October and one sample taken November – March.
Dissolved Oxygen	Daily Min	7.0 mg/L	1/6 Months	Grab	Limit effective November 1 to March 31. Two samples annually with one sample taken April – October and one sample taken November – March.
pH Field	Daily Min	6.0 su	1/6 Months	Grab	Two samples annually with one sample taken April – October and one sample taken November – March.
pH Field	Daily Max	9.0 su	1/6 Months	Grab	Two samples annually with one sample taken April – October and one sample taken November – March.
Temperature Maximum	Daily Max	72 deg F	Daily	Continuous	Limit effective in June per the Temperature Limits compliance schedule.

Monitoring Requirements and Effluent Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Temperature Maximum	Daily Max	73 deg F	Daily	Continuous	Limit effective July and August per the Temperature Limits compliance schedule.
Temperature Maximum	Weekly Avg	57 deg F	Daily	Continuous	Limit effective in April per the Temperature Limits compliance schedule.
Temperature Maximum	Weekly Avg	67 deg F	Daily	Continuous	Limit effective in June and July per the Temperature Limits compliance schedule.
Temperature Maximum	Weekly Avg	65 deg F	Daily	Continuous	Limit effective in August per the Temperature Limits compliance schedule.
Temperature Maximum	Weekly Avg	53 deg F	Daily	Continuous	Limit effective in October upon permit reissuance.
Temperature Maximum	Weekly Avg	48 deg F	Daily	Continuous	Limit effective in November upon permit reissuance.
Suspended Solids, Total		mg/L	1/6 Months	Grab	Two samples annually with one sample taken April – October and one sample taken November – March.
Phosphorus, Total		mg/L	Monthly	Grab	Monitoring required in 2027 only.

1.2.1.1 Effluent Temperature Monitoring

For manually measuring effluent temperature, grab samples should be collected at 6 evenly spaced intervals during the 24-hour period. Alternative sampling intervals may be approved if the permittee can show that the maximum effluent temperature is captured during the sampling interval. For monitoring temperature continuously, collect measurements in accordance with s. NR 218.04(13), Wis. Adm. Code. This means that discrete measurements shall be recorded at intervals of not more than 15 minutes during the 24-hour period. In either case, report the maximum temperature measured during the day on the DMR. For seasonal discharges collect measurements either manually or continuously during the period of operation and report the daily maximum effluent temperature on the DMR.

1.2.1.2 Effluent Temperature Limitations

Determination of Need for Effluent Limits: The effluent limitations for “Temperature, Maximum” added this permit reissuance become effective on December 31, 2028 as specified in the Schedules section. Monitoring is required continuously upon permit reissuance. Daily maximum temperatures shall be reported so that applicable daily maximum limits can be compared to the reported daily maximum temperatures and applicable weekly average limits can be compared to the weekly averages of the reported daily maximum temperatures. After completion of at least one year of temperature data collection the permittee may request that the Department make a determination of the need for limits under s. NR 106.56, Wis. Adm. Code. Within 60 days of such request the Department will make that determination. If the Department determines that effluent limitations are unnecessary based on the procedures in NR 106.56, the Department shall notify the permittee that the limitations are unnecessary pursuant to NR106.56. A permit modification will be required to remove the temperature limits and schedule from this permit. If, after reviewing the

data, the Department determines that effluent limitations for “Temperature, Maximum” are necessary based on the procedures in NR 106.56, the requirement to meet the effluent limitations according to the Schedules section will not be removed nor will the monitoring frequency be reduced. Permittees may then wish to pursue a re-evaluation of the limits based on NR 106 – ‘Subchapters V and VI Effluent Limitations for Temperature’ or NR 102.26 – Site Specific Ambient Temperature. If the re-calculation of limits results in revisions to the temperature limits, a permit modification will be required to include the revised limits in the permit.

Table 2: Effluent Limitations for 'Temperature Maximum'
(Effective per the Schedules section):

Month	Weekly Average Effluent Limitation (°F)	Daily Maximum Effluent Limitation (°F)
April	57	
June	67	72
July	67	73
August	65	73
October	53*	
November	48*	

*Carried over limits effective with permit reissuance.

1.2.1.3 Sampling Frequency for Dissolved Oxygen, pH and Suspended Solids

Permit Modification 01: The monitoring frequency for DO, pH and TSS are changed to 1/6 Months or 2/Year with one sample taken April – October and one sample taken November – March.

Determination of Need for Quarterly Monitoring: The minimum quarterly monitoring requirements for dissolved oxygen, pH and suspended solids (TSS) included with this permit reissuance become effective upon permit reissuance. Monitoring may be performed more frequently than quarterly but no closer than 10 days apart. All sample collection occurrences shall be reported so that monitoring data can be compared to the permit limitations and parameter Limits of Detection. After completion of one year of data collection and at least 12 datapoints for each parameter, the permittee may request the Department make a determination of the need for less frequent monitoring. Within 60 days of such request, the Department will make that determination. If the Department determines reduced monitoring frequencies are appropriate, the Department shall notify the permittee the monitoring frequencies may be reduced from the current permit issuance. A permit modification will be required to revise the monitoring frequencies in this permit. If, after reviewing the data, the Department determines the current monitoring frequencies are necessary based on the data collected, the monitoring frequencies will not be reduced.

2 Schedules

2.1 Temperature Limits (Industrial Facilities)

Required Action	Due Date
Report on Effluent Discharges: Submit a report on effluent temperature with conclusions regarding compliance. If the Department determines that because of data variability, 24 months of monitoring data is required to determine the need for temperature limits, the Department will so notify the permittee in writing and all dates in the permit schedule will be extended by 12 months. Informational Note - Refer to the Surface Water subsection regarding 'Determination of Need for Effluent Limits' for information concerning a Department determination on the need for limits and pursuing re-evaluation of limits per NR 106 Subchapters V & VI or NR 102.26, Wis. Adm. Code.	01/01/2025
Action Plan: Submit a study plan for approval for collecting data for site specific ambient temperature data or other study as proposed. The plan should include information on proposed sample locations, frequency of data collection, and methods used to record and collect data.	07/01/2025
Implement Plan: Start collecting data for site specific ambient temperature or other approved study per the approved study plan.	12/31/2025
Progress Report: Submit a progress report on the implementation of the temperature study plan. The progress report shall include sample locations, sample dates and times, recorded results, along with a summary of any challenges encountered and proposed modifications to the study plan, if applicable.	12/31/2026
Report on Temperature Study: Site-Specific Temperature Evaluation Report: Submit a report with at least 2 years of data and other requirements of s. NR 102.26(1), Wis. Adm. Code or other means of compliance if applicable.	12/31/2027
Complete Actions and Achieve Compliance: Complete actions necessary to achieve compliance with effluent temperature limitations at sample points 001 and 002.	12/31/2028

2.2 Permit Application Phosphorus Monitoring

Required Action	Due Date
Phosphorus Monitoring: The permittee shall collect 12 samples for phosphorus in 2027 to provide data for the reissuance application. If monthly monitoring will not provide at least 12 samples due to months without discharge, the permittee may sample more frequently than monthly but no closer than 10 days apart.	12/31/2027

2.3 Permit Application Submittal

Required Action	Due Date
Permit Application Submittal: Submit a complete permit application to the Department no later than 180 days prior to permit expiration.	07/04/2028

3 Standard Requirements

NR 205, Wisconsin Administrative Code (Conditions for Industrial Dischargers): The conditions in ss. NR 205.07(1) and NR 205.07(3), Wis. Adm. Code, are included by reference in this permit. The permittee shall comply with all of these requirements. Some of these requirements are outlined in the Standard Requirements section of this permit. Requirements not specifically outlined in the Standard Requirement section of this permit can be found in ss. NR 205.07(1) and NR 205.07(3).

3.1 Reporting and Monitoring Requirements

3.1.1 Monitoring Results

Monitoring results obtained during the previous month shall be summarized and reported on a Department Wastewater Discharge Monitoring Report. The report may require reporting of any or all of the information specified below under 'Recording of Results'. This report is to be returned to the Department no later than the date indicated on the form. A copy of the Wastewater Discharge Monitoring Report Form or an electronic file of the report shall be retained by the permittee.

Monitoring results shall be reported on an electronic discharge monitoring report (eDMR). The eDMR shall be certified electronically by a responsible executive or officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The 'eReport Certify' page certifies that the electronic report form is true, accurate and complete.

If the permittee monitors any pollutant more frequently than required by this permit, the results of such monitoring shall be included on the Wastewater Discharge Monitoring Report.

The permittee shall comply with all limits for each parameter regardless of monitoring frequency. For example, monthly, weekly, and/or daily limits shall be met even with monthly monitoring. The permittee may monitor more frequently than required for any parameter.

3.1.2 Sampling and Testing Procedures

Sampling and laboratory testing procedures shall be performed in accordance with Chapters NR 218 and NR 219, Wis. Adm. Code and shall be performed by a laboratory certified or registered in accordance with the requirements of ch. NR 149, Wis. Adm. Code. Groundwater sample collection and analysis shall be performed in accordance with ch. NR 140, Wis. Adm. Code. The analytical methodologies used shall enable the laboratory to quantitate all substances for which monitoring is required at levels below the effluent limitation. If the required level cannot be met by any of the methods available in NR 219, Wis. Adm. Code, then the method with the lowest limit of detection shall be selected. Additional test procedures may be specified in this permit.

3.1.3 Recording of Results

The permittee shall maintain records which provide the following information for each effluent measurement or sample taken:

- the date, exact place, method and time of sampling or measurements;
- the individual who performed the sampling or measurements;
- the date the analysis was performed;
- the individual who performed the analysis;
- the analytical techniques or methods used; and
- the results of the analysis.

3.1.4 Reporting of Monitoring Results

The permittee shall use the following conventions when reporting effluent monitoring results:

- Pollutant concentrations less than the limit of detection shall be reported as < (less than) the value of the limit of detection. For example, if a substance is not detected at a detection limit of 0.1 mg/L, report the pollutant concentration as < 0.1 mg/L.
- Pollutant concentrations equal to or greater than the limit of detection, but less than the limit of quantitation, shall be reported and the limit of quantitation shall be specified.
- For purposes of calculating NR 101 fees, the 2 mg/l lower reporting limits for BOD5 and Total Suspended Solids shall be considered to be limits of quantitation
- For the purposes of reporting a calculated result, average or a mass discharge value, the permittee may substitute a “0” (zero) for any pollutant concentration that is less than the limit of detection. However, if the effluent limitation is less than the limit of detection, the department may substitute a value other than zero for results less than the limit of detection, after considering the number of monitoring results that are greater than the limit of detection and if warranted when applying appropriate statistical techniques.
- If no discharge occurs through an outfall, flow related parameters (e.g. flow rate, hydraulic application rate, volume, etc.) should be reported as “0” (zero) at the required sample frequency specified for the outfall. For example: if the sample frequency is daily, “0” would be reported for any day during the month that no discharge occurred.

3.1.5 Records Retention

The permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings or electronic data records for continuous monitoring instrumentation, copies of all reports required by the permit, and records of all data used to complete the application for the permit for a period of at least 3 years from the date of the sample, measurement, report or application, except for sludge management forms and records, which shall be kept for a period of at least 5 years.

3.1.6 Other Information

Where the permittee becomes aware that it failed to submit any relevant facts in a permit application or submitted incorrect information in a permit application or in any report to the Department, it shall promptly submit such facts or correct information to the Department.

3.1.7 Reporting Requirements – Alterations or Additions

The permittee shall give notice to the Department as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is only required when:

- The alteration or addition to the permitted facility may meet one of the criteria for determining whether a facility is a new source.
- The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification requirement applies to pollutants which are not subject to effluent limitations in the existing permit.
- The alteration or addition results in a significant change in the permittee’s sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use of disposal sites not reported during the permit application process nor reported pursuant to an approved land application plan. Additional sites may not be used for the land application of sludge until department approval is received.

3.2 System Operating Requirements

3.2.1 Noncompliance Reporting

The permittee shall report the following types of noncompliance by a telephone call to the Department's regional office within 24 hours after becoming aware of the noncompliance:

- any noncompliance which may endanger health or the environment;
- any violation of an effluent limitation resulting from a bypass;
- any violation of an effluent limitation resulting from an upset; and
- any violation of a maximum discharge limitation for any of the pollutants listed by the Department in the permit, either for effluent or sludge.

A written report describing the noncompliance shall also be submitted to the Department as directed at the end of this permit within 5 days after the permittee becomes aware of the noncompliance. On a case-by-case basis, the Department may waive the requirement for submittal of a written report within 5 days and instruct the permittee to submit the written report with the next regularly scheduled monitoring report. In either case, the written report shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times; the steps taken or planned to reduce, eliminate and prevent reoccurrence of the noncompliance; and if the noncompliance has not been corrected, the length of time it is expected to continue.

A scheduled bypass approved by the Department under the 'Scheduled Bypass' section of this permit shall not be subject to the reporting required under this section.

NOTE: Section 292.11(2)(a), Wisconsin Statutes, requires any person who possesses or controls a hazardous substance or who causes the discharge of a hazardous substance to notify the Department of Natural Resources **immediately** of any discharge not authorized by the permit. **The discharge of a hazardous substance that is not authorized by this permit or that violates this permit may be a hazardous substance spill. To report a hazardous substance spill, call DNR's 24-hour HOTLINE at 1-800-943-0003.**

3.2.2 Bypass

Except for a controlled diversion as provided in the 'Controlled Diversions' section of this permit, any bypass is prohibited and the Department may take enforcement action against a permittee for such occurrences under s. 283.89, Wis. Stats. The Department may approve a bypass if the permittee demonstrates all the following conditions apply:

- The bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
- There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities or adequate back-up equipment, retention of untreated wastes, reduction of inflow and infiltration, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventative maintenance. When evaluating feasibility of alternatives, the department may consider factors such as technical achievability, costs and affordability of implementation and risks to public health, the environment and, where the permittee is a municipality, the welfare of the community served; and
- The bypass was reported in accordance with the 'Noncompliance Reporting' section of this permit.

3.2.3 Scheduled Bypass

Whenever the permittee anticipates the need to bypass for purposes of efficient operations and maintenance and the permittee may not meet the conditions for controlled diversions in the 'Controlled Diversions' section of this permit, the permittee shall obtain prior written approval from the Department for the scheduled bypass. A permittee's written request for Department approval of a scheduled bypass shall demonstrate that the conditions for unscheduled bypassing are met and include the proposed date and reason for the bypass, estimated volume and duration of the bypass, alternatives to bypassing and measures to mitigate environmental harm caused by the bypass. The department may require the permittee to provide public notification for a scheduled bypass if it is determined there is significant public interest in the proposed action and may recommend mitigation measures to minimize the impact of such bypass.

3.2.4 Controlled Diversions

Controlled diversions are allowed only when necessary for essential maintenance to assure efficient operation provided the following requirements are met:

- Effluent from the wastewater treatment facility shall meet the effluent limitations established in the permit. Wastewater that is diverted around a treatment unit or treatment process during a controlled diversion shall be recombined with wastewater that is not diverted prior to the effluent sampling location and prior to effluent discharge;
- A controlled diversion may not occur during periods of excessive flow or other abnormal wastewater characteristics;
- A controlled diversion may not result in a wastewater treatment facility overflow; and
- All instances of controlled diversions shall be documented in wastewater treatment facility records and such records shall be available to the department on request.

3.2.5 Proper Operation and Maintenance

The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance includes effective performance, adequate funding, adequate operator staffing and training as required in ch. NR 114, Wis. Adm. Code, and adequate laboratory and process controls, including appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems only when necessary to achieve compliance with the conditions of the permit.

3.2.6 Operator Certification

The wastewater treatment facility shall be under the direct supervision of a state certified operator. In accordance with s. NR 114.53, Wis. Adm. Code, every WPDES permitted treatment plant shall have a designated operator-in-charge holding a current and valid certificate. The designated operator-in-charge shall be certified at the level and in all subclasses of the treatment plant, except laboratory. Treatment plant owners shall notify the department of any changes in the operator-in-charge within 30 days. Note that s. NR 114.52(22), Wis. Adm. Code, lists types of facilities that are excluded from operator certification requirements (i.e. private sewage systems, pretreatment facilities discharging to public sewers, industrial wastewater treatment that consists solely of land disposal, agricultural digesters and concentrated aquatic production facilities with no biological treatment).

3.2.7 Spill Reporting

The permittee shall notify the Department in accordance with ch. NR 706 (formerly NR 158), Wis. Adm. Code, in the event that a spill or accidental release of any material or substance results in the discharge of pollutants to the waters of the state at a rate or concentration greater than the effluent limitations established in this permit, or the spill or accidental release of the material is unregulated in this permit, unless the spill or release of pollutants has been reported to the Department in accordance with s. NR 205.07 (1)(s), Wis. Adm. Code.

3.2.8 Planned Changes

In accordance with ss. 283.31(4)(b) and 283.59, Stats., the permittee shall report to the Department any facility expansion, production increase or process modifications which will result in new, different or increased discharges of pollutants. The report shall either be a new permit application, or if the new discharge will not violate the effluent limitations of this permit, a written notice of the new, different or increased discharge. The notice shall contain a description of the new activities, an estimate of the new, different or increased discharge of pollutants and a description of the effect of the new or increased discharge on existing waste treatment facilities. Following receipt of this report, the Department may modify this permit to specify and limit any pollutants not previously regulated in the permit.

3.2.9 Duty to Halt or Reduce Activity

Upon failure or impairment of treatment facility operation, the permittee shall, to the extent necessary to maintain compliance with its permit, curtail production or wastewater discharges or both until the treatment facility operations are restored or an alternative method of treatment is provided.

3.3 Surface Water Requirements

3.3.1 Permittee-Determined Limit of Quantitation Incorporated into this Permit

For pollutants with water quality-based effluent limits below the Limit of Quantitation (LOQ) in this permit, the LOQ calculated by the permittee and reported on the Discharge Monitoring Reports (DMRs) is incorporated by reference into this permit. The LOQ shall be reported on the DMRs, shall be the lowest quantifiable level practicable, and shall be no greater than the minimum level (ML) specified in or approved under 40 CFR Part 136 for the pollutant at the time this permit was issued, unless this permit specifies a higher LOQ.

3.3.2 Appropriate Formulas for Effluent Calculations

The permittee shall use the following formulas for calculating effluent results to determine compliance with average concentration limits and mass limits and total load limits:

Weekly/Monthly/Six-Month/Annual Average Concentration = the sum of all daily results for that week/month/six-month/year, divided by the number of results during that time period. [Note: When a six-month average effluent limit is specified for Total Phosphorus the applicable periods are May through October and November through April.]

Weekly Average Mass Discharge (lbs/day): Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the week.

Monthly Average Mass Discharge (lbs/day): Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the month.

Six-Month Average Mass Discharge (lbs/day): Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the six-month period. [Note: When a six-month average effluent limit is specified for Total Phosphorus the applicable periods are May through October and November through April.]

Annual Average Mass Discharge (lbs/day): Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the entire year.

Total Monthly Discharge: = monthly average concentration (mg/L) x total flow for the month (MG/month) x 8.34.

Total Annual Discharge: = sum of total monthly discharges for the calendar year.

12-Month Rolling Sum of Total Monthly Discharge: = the sum of the most recent 12 consecutive months of Total Monthly Discharges.

3.3.3 Effluent Temperature Requirements

Weekly Average Temperature – If temperature limits are included in this permit, Weekly Average Temperature shall be calculated as the sum of all daily maximum results for that week divided by the number of daily maximum results during that time period.

Cold Shock Standard – Water temperatures of the discharge shall be controlled in a manner as to protect fish and aquatic life uses from the deleterious effects of cold shock pursuant to Wis. Adm. Code, s. NR 102.28. ‘Cold Shock’ means exposure of aquatic organisms to a rapid decrease in temperature and a sustained exposure to low temperature that induces abnormal behavior or physiological performance and may lead to death.

Rate of Temperature Change Standard – Temperature of a water of the state or discharge to a water of the state may not be artificially raised or lowered at such a rate that it causes detrimental health or reproductive effects to fish or aquatic life of the water of the state pursuant to Wis. Adm. Code, s. NR 102.29.

3.3.4 Visible Foam or Floating Solids

There shall be no discharge of floating solids or visible foam in other than trace amounts.

3.3.5 Surface Water Uses and Criteria

In accordance with NR 102.04, Wis. Adm. Code, surface water uses and criteria are established to govern water management decisions. Practices attributable to municipal, industrial, commercial, domestic, agricultural, land development or other activities shall be controlled so that all surface waters including the mixing zone meet the following conditions at all times and under all flow and water level conditions:

- a) Substances that will cause objectionable deposits on the shore or in the bed of a body of water, shall not be present in such amounts as to interfere with public rights in waters of the state.
- b) Floating or submerged debris, oil, scum or other material shall not be present in such amounts as to interfere with public rights in waters of the state.
- c) Materials producing color, odor, taste or unsightliness shall not be present in such amounts as to interfere with public rights in waters of the state.
- d) Substances in concentrations or in combinations which are toxic or harmful to humans shall not be present in amounts found to be of public health significance, nor shall substances be present in amounts which are acutely harmful to animal, plant or aquatic life.

4 Summary of Reports Due

FOR INFORMATIONAL PURPOSES ONLY

Description	Date	Page
Temperature Limits (Industrial Facilities) -Report on Effluent Discharges	January 1, 2025	4
Temperature Limits (Industrial Facilities) -Action Plan	July 1, 2025	4
Temperature Limits (Industrial Facilities) -Implement Plan	December 31, 2025	4
Temperature Limits (Industrial Facilities) -Progress Report	December 31, 2026	4
Temperature Limits (Industrial Facilities) -Report on Temperature Study	December 31, 2027	4
Temperature Limits (Industrial Facilities) -Complete Actions and Achieve Compliance	December 31, 2028	4
Permit Application Phosphorus Monitoring -Phosphorus Monitoring	December 31, 2027	4
Permit Application Submittal -Permit Application Submittal	July 4, 2028	4
Wastewater Discharge Monitoring Report	no later than the date indicated on the form	5

Report forms shall be submitted electronically in accordance with the reporting requirements herein. Any facility plans or plans and specifications for municipal, industrial, industrial pretreatment and non industrial wastewater systems shall be submitted to the Bureau of Water Quality, P.O. Box 7921, Madison, WI 53707-7921. All other submittals required by this permit shall be submitted to:
 South Central Region, 3911 Fish Hatchery Rd, Fitchburg, WI 53711-5397