

# WPDES PERMIT

# STATE OF WISCONSIN DEPARTMENT OF NATURAL RESOURCES ERMIT TO DISCHARGE UNDER THE WISCONSIN POLILITANT DISCHARGE

# PERMIT TO DISCHARGE UNDER THE WISCONSIN POLLUTANT DISCHARGE ELIMINATION SYSTEM

#### **Seneca Foods Corporation - Berlin**

is permitted, under the authority of Chapter 283, Wisconsin Statutes, to discharge from a facility located at

NEQ NEQ SEC 34 T19N R13E

to

Willow Creek and the groundwater of the Pine and Willow Rivers Watershed (WR02), Wolf River Basin via Spray irrigation in Waushara County

in accordance with the effluent limitations, monitoring requirements and other conditions set forth in this permit.

The permittee shall not discharge after the date of expiration. If the permittee wishes to continue to discharge after this expiration date an application shall be filed for reissuance of this permit, according to Chapter NR 200, Wis. Adm. Code, at least 180 days prior to the expiration date given below.

	of Wisconsin Department of Natural Resources he Secretary	
Ву	Heidi Schmitt Marquez Wastewater Field Supervisor	
	Date Permit Signed/Issued	
PERI	MIT TERM: EFFECTIVE DATE - January 01, 2026	<b>EXPIRATION DATE - December 31, 2030</b>

# TABLE OF CONTENTS

I IN-PLANT REQUIREMENTS	1
1.1 SAMPLING POINT(S)	1
1.2 MONITORING REQUIREMENTS AND LIMITATIONS	1
1.2.1 Sampling Point 101 - HOLDING LAGOON	1
1.2.2 Sampling Point 104 - FIELD TILE SUMP COLLECT SYSTEM	1
2 SURFACE WATER REQUIREMENTS	2
2.1 SAMPLING POINT(S)	2
2.2 MONITORING REQUIREMENTS AND EFFLUENT LIMITATIONS	2
2.2.1 Sampling Point (Outfall) 005 – FREEZER DEFROST WATER	2
3 LAND TREATMENT REQUIREMENTS	5
3.1 SAMPLING POINT(S)	5
3.2 Monitoring Requirements and Limitations	5
3.2.1 Sampling Point (Outfall) 002 - SPRAY IRRIGATION, Spray Irrigation	5
4 LAND APPLICATION REQUIREMENTS	7
4.1 SAMPLING POINT(S)	7
4.2 Monitoring Requirements and Limitations	7
4.2.1 Sampling Point (Outfall) 003 - BY-PRODUCT SOLIDS	7
4.2.2 Sampling Point (Outfall) 004 - LAGOON SLUDGE	9
5 SCHEDULES	11
5.1 PHOSPHORUS - TMDL LIMITS FOR TOTAL PHOSPHORUS	11
5.2 GROUNDWATER MONITORING WELL - INSTALLATION	12
5.3 LAND TREATMENT MANAGEMENT PLAN	12
5.4 LAND APPLICATION MANAGEMENT PLAN	13
6 STANDARD REQUIREMENTS	14
6.1 REPORTING AND MONITORING REQUIREMENTS	14
6.1.1 Monitoring Results	14
6.1.2 Sampling and Testing Procedures	14
6.1.3 Recording of Results	14
6.1.4 Reporting of Monitoring Results	15
6.1.5 Records Retention	15
6.1.6 Other Information	15
6.1.7 Reporting Requirements – Alterations or Additions	15
6.2 SYSTEM OPERATING REQUIREMENTS	16
6.2.1 Noncompliance Reporting	16
6.2.2 Bypass 6.2.3 Scheduled Bypass	16 16
6.2.4 Controlled Diversions	17
6.2.5 Proper Operation and Maintenance	17
6.2.6 Operator Certification	17
6.2.7 Spill Reporting	17
6.2.8 Planned Changes	17
6.2.9 Duty to Halt or Reduce Activity	18
6.3 SURFACE WATER REQUIREMENTS	18
6.3.1 Permittee-Determined Limit of Quantitation Incorporated into this Permit	18
6.3.2 Appropriate Formulas for Effluent Calculations	18
6.3.3 Effluent Temperature Requirements	18
6.3.4 Visible Foam or Floating Solids	19
6.3.5 Surface Water Uses and Criteria	19

# WPDES Permit No. WI-0052809-11-0 Seneca Foods Corporation

7 SUMMARY OF REPORTS DUE	26
6.5.15 Additional Requirements from ch. NR 214, Wis. Adm. Code	25
6.5.14 Annual Inspections-Stacking Pads and Leachate Containment	24
6.5.13 By-Product Storage Sites	24
6.5.12 Field Stockpiles	24
6.5.11 Soil Incorporation Requirements	24
6.5.10 Runoff	24
6.5.9 Ponding	23
6.5.8 Nitrogen Requirements for Liquid Wastes and By-Product Solids and Sludges	23
6.5.7 Chloride Requirements for Liquid Wastes and By-Product Solids	23
6.5.6 Operating Requirements/Management Plan	23
6.5.5 Land Application Site Approval	23
6.5.4 Other Methods of Disposal or Distribution Report	22
6.5.3 Annual Land Application Report	22
6.5.2 Land Application Characteristic Report	22
6.5.1 General Sludge Management Information	22
6.5 LAND APPLICATION REQUIREMENTS	22
6.4.7 Irrigation Management Plan	22
6.4.6 Seasonal Irrigation Restriction	22
6.4.5 Runoff	21
6.4.4 Ponding	21
6.4.3 Nitrogen Loading Requirements for Spray Irrigation	21
6.4.2 Chloride Requirements for Land Treatment Systems	21
6.4.1 Formulas for Land Treatment Calculations	21
6.4 LAND TREATMENT REQUIREMENTS FOR INDUSTRIAL DISCHARGES	21
6.3.8 Additives	20
6.3.7 Compliance with Phosphorus Limitation	20
6.3.6 Total Residual Chlorine Requirements	19

# 1 In-Plant Requirements

# 1.1 Sampling Point(s)

	Sampling Point Designation						
Sampling	Sampling Point Location, Waste Type/Sample Contents and Treatment Description (as						
Point	Point applicable)						
Number							
101	In-Plant: Process wastewater grab sample collected from the sump prior to discharge to lagoon prior to						
	spray irrigation. Flow is measured with a mag meter just after the pump to the lagoon.						
104	In-Plant: Field tile sump collection system grab sample collected prior to lagoon prior to spray irrigation						

# 1.2 Monitoring Requirements and Limitations

The permittee shall comply with the following monitoring requirements and limitations.

# 1.2.1 Sampling Point 101 - HOLDING LAGOON

Monitoring Requirements and Limitations						
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes	
Flow Rate		MGD	Annual	Total Annual		
BOD <sub>5</sub> , Total		mg/L	Annual	8-Hr Comp		
Nitrogen, Total Kjeldahl		mg/L	Annual	8-Hr Comp		

# 1.2.2 Sampling Point 104 - FIELD TILE SUMP COLLECT SYSTEM

Monitoring Requirements and Limitations							
Parameter Limit Type Limit and Sample Sample Notes							
		Units	Frequency	Type			
BOD <sub>5</sub> , Total		mg/L	Annual	Grab			
Nitrogen, Total Kjeldahl		mg/L	Annual	Grab			
Nitrogen, Nitrate		mg/L	Annual	Grab			

# **2 Surface Water Requirements**

# 2.1 Sampling Point(s)

The discharge(s) shall be limited to the waste type(s) designated for the listed sampling point(s).

	Sampling Point Designation							
Sampling Point								
	applicable)							
Number								
005	Effluent: Freezer defrost water discharged to Willow Creek. Grab sample is taken from the end of the							
	pipe that runs under the driveway. Flow is estimated based off water used for defrost event.							

# 2.2 Monitoring Requirements and Effluent Limitations

The permittee shall comply with the following monitoring requirements and limitations.

# 2.2.1 Sampling Point (Outfall) 005 - FREEZER DEFROST WATER

	Monitoring Requirements and Effluent Limitations						
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes		
Flow Rate		MGD	Daily	Estimated			
BOD <sub>5</sub> , Total		mg/L	Monthly	Grab			
BOD <sub>5</sub> , Total	Daily Max	188 lbs/day	Monthly	Calculated			
BOD <sub>5</sub> , Total	Monthly Avg	109 lbs/day	Monthly	Calculated			
BOD <sub>5</sub> , Total	Annual Avg	74 lbs/day	Monthly	Calculated			
Suspended Solids, Total	Daily Max	40 mg/L	Monthly	Grab			
Suspended Solids, Total	Daily Max	333 lbs/day	Monthly	Calculated			
Suspended Solids, Total	Monthly Avg	226 lbs/day	Monthly	Calculated			
Suspended Solids, Total	Annual Avg	134 lbs/day	Monthly	Calculated			
Suspended Solids, Total		lbs/month	Monthly	Calculated	Calculate the Total Monthly Discharge of TSS and report on the last day of the month on the DMR. See TMDL Calculations section.		
Suspended Solids, Total	Annual Total	1219 lbs/yr	Monthly	Calculated	Calculate the 12-month rolling sum of total monthly mass of TSS discharged and report on the last day of the month on the DMR. See TMDL Calculations section.		

	Monitoring Requirements and Effluent Limitations						
Parameter	Limit Type	Limit and	Sample	Sample	Notes		
		Units	Frequency	Type			
Chlorine, Total	Daily Max	38 μg/L	5/Week	Grab			
Residual		. 0					
Oil & Grease	Daily Max	15 mg/L	Monthly	Grab			
(Hexane)							
Oil & Grease	Monthly Avg	15 mg/L	Monthly	Grab			
(Hexane)							
pH Field	Daily Max	9.0 su	5/Week	Grab			
pH Field	Daily Min	6.0 su	5/Week	Grab			
Nitrogen, Ammonia (NH <sub>3</sub> -N) Total		mg/L	Monthly	Grab			
Phosphorus, Total	Monthly Avg	1.2 mg/L	Monthly	Grab	Interim limit effective from permit issuance until final mass limits are effective on 10/1/30.		
Phosphorus, Total		lbs/day	Monthly	Calculated			
Phosphorus, Total		lbs/month	Monthly	Calculated	Calculate the Total Monthly Discharge of phosphorus and report on the last day of the month on the DMR. See TMDL Calculations section.		
Phosphorus, Total	Annual Total	5.0 lbs/yr	Monthly	Calculated	Limit effective 10/1/30 following compliance schedule. Calculate the 12-month rolling sum of total monthly mass of phosphorus discharged and report on the last day of the month on the DMR. See TMDL Calculations section.		
Temperature		deg F	Monthly	Grab			

#### 2.2.1.1 Effluent Temperature Monitoring

For manually measuring effluent temperature, grab samples should be collected at 6 evenly spaced intervals during the 24-hour period. Alternative sampling intervals may be approved if the permittee can show that the maximum effluent temperature is captured during the sampling interval. Report the maximum temperature measured during the day on the DMR. For seasonal discharges collect measurements either manually or continuously during the period of operation and report the daily maximum effluent temperature on the DMR.

#### 2.2.1.2 Upper Fox Wolf Total Maximum Daily Load (TMDL) Calculations

**Approved TMDL:** The Upper Fox Wolf River Basin TMDL Waste Load Allocation (WLA) for total phosphorus and total suspended solids was approved by the U.S. Environmental Protection Agency on February 27, 2020. TMDL total lbs/month and lbs/yr effluent results shall be calculated as follows:

**Total Monthly Discharge (lbs/month):** = monthly average concentration (mg/L) x total flow for the month (MG/month) x 8.34.

**12-Month Rolling Sum of Total Monthly Discharge (lbs/yr):** = the sum of the most recent 12 consecutive months of Total Monthly Discharges.

## 2.2.1.3 TMDL Limitations for Total Phosphorus

The plant shall be operated such that the amount of phosphorus being discharged an on annual basis does not increase over the permit term, and that the phosphorus reductions will occur over time through optimization. The approved TMDL phosphorus WLA for this permittee is 5.0 lbs/year which will go into effect following a compliance schedule.

# 2.2.1.4 TMDL Limitations for Total Suspended Solids

The approved TMDL TSS WLA for this permittee is 1219 lbs/year. The 12-month rolling sum of total monthly TSS (lbs/yr) shall be reported each month for direct comparison to the facility's WLA.

# **3 Land Treatment Requirements**

# 3.1 Sampling Point(s)

The discharge(s) shall be limited to the waste type(s) designated for the listed sampling point(s).

	Sampling Point Designation						
Sampling	Sampling Point Location, Waste Description/Sample Contents and Treatment Description (as						
Point	Point applicable)						
Number							
002	Land Treatment: Process wastewater grab sample collected prior to spray irrigation during the spray						
	irrigation season. Grab sample collected from the sample port on the piping that is connected to the						
	sprayer. Flow meter located at spray irrigation pump.						

# 3.2 Monitoring Requirements and Limitations

The permittee shall comply with the following monitoring requirements and limitations.

# 3.2.1 Sampling Point (Outfall) 002 - SPRAY IRRIGATION, Spray Irrigation

	Monitoring Requirements and Limitations						
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes		
Flow Rate		MGD	Daily	Continuous			
Hydraulic Application Rate	Monthly Avg	0 gal/ac/day	Monthly	Calculated	Effective December - April.		
Hydraulic Application Rate	Monthly Avg	6,800 gal/ac/day	Monthly	Calculated	Effective May - November.		
Nitrogen, Total Kjeldahl		mg/L	Annual	Grab			
BOD <sub>5</sub> , Total		mg/L	Annual	Grab			
Nitrogen, Total		mg/L	Annual	Grab			
Nitrogen, Max Applied On Any Zone	Annual Total	165 lbs/ac/yr	Annual	Calculated	Use the total nitrogen concentration when calculating the annual total. See the Maximum Applied Nitrogen On Any Zone section.		
Soil - Nitrogen, Available		mg/kg	Annual	Grab			
Soil - Phosphorus, Available		mg/kg	Annual	Grab			

Monitoring Requirements and Limitations						
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes	
Soil - Potassium, Available		mg/kg	Annual	Grab		
Soil - pH Lab		su	Annual	Grab		
Other Sources of Nitrogen		lbs/ac/yr	Annual	Measure		

#### Daily Log – Monitoring Requirements and Limitations

All discharge and monitoring activity shall be documented on log sheets. Originals of the log sheets shall be kept by the permittee as described under "Records Retention" in the Standard Requirements section, and if requested, made available to the Department.

Parameters	Limit	Units Sample Frequency		Sample Type
Zone or Location Being Sprayed	-	Number	Daily	Log
Volume per Zone	-	Gallons	Daily	Log
Acres Being Sprayed	-	Acres	Daily	Log
Start to End Time	-	Date, Hour	Daily	Log
Maximum Applied Volume	-	Inches/Load Cycle	Daily	Calculated

## 3.2.1.1 Maximum Applied Chloride/Nitrogen on Any Zone

Calculate the mass applied annually to each zone\* utilized during the calendar year using the equation below. Record the highest total mass applied to any zone within the treatment system each year on the eDMR with a sample date of December 31.

(annual avg. concentration in mg/L) (tot. annual flow in million gallons per zone) (8.34) = lbs/ac/yr acreage of zone

#### 3.2.1.2 Spray Irrigation Site(s) - Soil Analysis

The soil at each spray irrigation sample point (outfall) shall be tested annually for available nitrogen, available phosphorus, available potassium and pH. The soil tests shall be conducted by an approved testing facility. The permittee shall report sample results on an annual eDMR. If multiple soil tests are taken at this outfall, report all data on the eDMR and identify the zones sampled in the General Comments section of the report.

<sup>\*</sup>A zone can be an entire field, or a portion as defined in the approved Land Treatment Management Plan.

# **4 Land Application Requirements**

# 4.1 Sampling Point(s)

The discharge(s) shall be limited to land application of the waste type(s) designated for the listed sampling point(s) on Department approved land spreading sites or by hauling to another facility.

	Sampling Point Designation				
Sampling	Sampling   Sampling Point Location, Waste Type/Sample Contents and Treatment Description (as				
Point	Point applicable)				
Number	<b>Jumber</b>				
003	Land Application: By-product solids landspread on Department approved sites				
004	Land Application: Lagoon sludge and sediment from the inlet to the wastewater lagoon.				

# 4.2 Monitoring Requirements and Limitations

The permittee shall comply with the following monitoring requirements and limitations.

# 4.2.1 Sampling Point (Outfall) 003 - BY-PRODUCT SOLIDS

	Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes	
Solids, Total		Percent	Monthly	Grab Comp		
Nitrogen, Total Kjeldahl		Percent	Monthly	Grab Comp		
Chloride		Percent	Monthly	Grab Comp		
Phosphorus, Total		Percent	Monthly	Grab Comp		
Phosphorus, Water Extractable		% of Tot P	Monthly	Grab Comp		
Potassium, Total Recoverable		Percent	Monthly	Grab Comp		

#### Daily Log – Monitoring Requirements and Limitations

All discharge and monitoring activity shall be documented on log sheets. Originals of the log sheets shall be kept by the permittee as described under "Records Retention" in the Standard Requirements section, and if requested, made available to the Department.

Parameters	Limit	Units	Sample Frequency	Sample Type
DNR Site Number(s)	-	Number	Daily	Log
Acres Applied	-	Acres	Daily	Log
Application Rate	-	Tons/Acre/Day	Daily	Calculated

#### **Annual Report – Summary of Monitoring Requirements and Limitations**

The Annual Report is due by January 31<sup>st</sup> of each year for the previous calendar year. See the 'Annual Land Application Report' subsection in Standard Requirements.

Application Report subsection in Standard Requirements.					
Parameters	Limit	Units	Reporting Frequency	Sample Type	
DNR Site Number(s)	-	Number	-	-	
Acres Land Applied	-	Acres	Annual	-	
Total Amount Per Site	-	Tons	Annual	Total Annual	
Total Kjeldahl Nitrogen per Site	165, or alternate approved in writing	Pounds/Acre/Year	Annual	Calculated	
Total Chloride per Site	340	Pounds/Acre per 2 Years	Annual	Calculated	

#### 4.2.1.1 Annual Site Nitrogen Loading

For details on nitrogen loading requirements, including approval of an alternate nitrogen pounds/acre/year site loading, see the "Nitrogen Requirements for Liquid Wastes, By-Product Solids and Sludges" paragraph in the Standard Requirements section of this permit.

#### 4.2.1.2 Biennial Site Chloride Loading

For details on chloride requirements see the "Chloride Requirements for Liquid Wastes and By-Product Solids" paragraph in the Standard Requirements section of this permit.

#### **4.2.1.3 Sampling**

Representative samples shall be collected of the byproduct solids to be land applied. When the byproduct solids are large pieces, a large sample should be collected and ground to a homogenous slurry for analysis.

# 4.2.2 Sampling Point (Outfall) 004 - LAGOON SLUDGE

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Solids, Total		Percent	Once	Composite	
Nitrogen, Total Kjeldahl		Percent	Once	Composite	
Chloride		Percent	Once	Composite	
Phosphorus, Total		Percent	Once	Composite	
Phosphorus, Water Extractable		% of Tot P	Once	Composite	
Potassium, Total Recoverable		Percent	Once	Composite	
Arsenic Dry Wt	Ceiling	75 mg/kg	Once	Composite	
Arsenic Dry Wt	High Quality	41 mg/kg	Once	Composite	
Cadmium Dry Wt	Ceiling	85 mg/kg	Once	Composite	
Cadmium Dry Wt	High Quality	39 mg/kg	Once	Composite	
Copper Dry Wt	Ceiling	4,300 mg/kg	Once	Composite	
Copper Dry Wt	High Quality	1,500 mg/kg	Once	Composite	
Lead Dry Wt	Ceiling	840 mg/kg	Once	Composite	
Lead Dry Wt	High Quality	300 mg/kg	Once	Composite	
Mercury Dry Wt	Ceiling	57 mg/kg	Once	Composite	
Mercury Dry Wt	High Quality	17 mg/kg	Once	Composite	
Molybdenum Dry Wt	Ceiling	75 mg/kg	Once	Composite	
Nickel Dry Wt	Ceiling	420 mg/kg	Once	Composite	
Nickel Dry Wt	High Quality	420 mg/kg	Once	Composite	
Selenium Dry Wt	Ceiling	100 mg/kg	Once	Composite	
Selenium Dry Wt	High Quality	100 mg/kg	Once	Composite	
Zinc Dry Wt	Ceiling	7,500 Percent	Once	Composite	
Zinc Dry Wt	High Quality	2,800 Percent	Once	Composite	

#### Daily Log – Monitoring Requirements and Limitations

All discharge and monitoring activity shall be documented on log sheets. Originals of the log sheets shall be kept by the permittee as described under "Records Retention" in the Standard Requirements section, and if requested, made available to the Department.

Parameters	Limit	Units	Sample Frequency	Sample Type
DNR Site Number(s)	-	Number	Daily	Log
Acres Applied	-	Acres	Daily	Log
Application Rate	-	Tons/Acre/Day	Daily	Calculated

#### **Annual Report – Summary of Monitoring Requirements and Limitations**

The Annual Report is due by January 31<sup>st</sup> of each year for the previous calendar year. See the 'Annual Land Application Report' subsection in Standard Requirements.

	Application Report Subsection in Standard Requirements.					
Parameters	Limit	Units	Reporting Frequency	Sample Type		
DNR Site Number(s)	-	Number	-	-		
Acres Land Applied	-	Acres	Annual	-		
Total Amount Per Site	-	Tons	Annual	Total Annual		
Total Kjeldahl Nitrogen per Site	165, or alternate approved in writing	Pounds/Acre/Year	Annual	Calculated		
Total Chloride per Site	340	Pounds/Acre per 2 Years	Annual	Calculated		

#### 4.2.2.1 Annual Site Nitrogen Loading

For details on nitrogen loading requirements, including approval of an alternate nitrogen pounds/acre/year site loading, see the "Nitrogen Requirements for Liquid Wastes, By-Product Solids and Sludges" paragraph in the Standard Requirements section of this permit.

#### 4.2.2.2 Biennial Site Chloride Loading

For details on chloride requirements see the "Chloride Requirements for Liquid Wastes and By-Product Solids" paragraph in the Standard Requirements section of this permit.

# 5 Schedules

# **5.1 Phosphorus - TMDL Limits for Total Phosphorus**

No later than 30 days following each compliance date, the permittee shall notify the Department in writing of its compliance or noncompliance with the required action. If a submittal is part of the required action then a timely submittal fulfills the written notification requirement.

Required Action	Due Date
Operational Evaluation Report: The permittee shall prepare an operational evaluation report and submit it for Department approval. The report shall include an evaluation of collected effluent data, possible source reduction measures, operational improvements or other minor modifications that would enable compliance with the final phosphorus WQBEL (water quality based effluent limit) or some improved level of effluent quality using the existing wastewater treatment system. If the operational evaluation report concludes that the facility can achieve the final phosphorus WQBELs using the existing treatment system with only source reduction measures, operational improvements or minor facility modifications, the report shall contain a schedule for implementation of the improvements or other report recommendations necessary to meet final phosphorus WQBELs. The implementation schedule shall be based on providing compliance with the final phosphorus WQBEL as soon as reasonably possible. Once the report is approved by the Department, the permittee shall take the steps called for in the operational evaluation report and follow the schedule of implementation as approved. If the Department approved report concludes that the facility cannot achieve the phosphorus limit with source reduction measures, operational improvements or other minor facility modifications, the permittee shall initiate a Facility Planning Study and comply with the remaining schedule of compliance. Regardless of the conclusion of the operational evaluation report, the report shall also include a plan and implementation schedule for optimizing the treatment plant's removal of phosphorus during the period prior to complying with the WQBELs. Once the operational evaluation report is approved by the Department, the permittee shall proceed with implementation of the optimization plan and follow the schedule of implementation as approved.	07/01/2026
Compliance Alternatives, Source Reduction, Improvements and Modifications Status: The permittee shall submit a 'Compliance Alternatives, Source Reduction, Operational Improvements and Minor Facility Modification' status report to the Department. The report shall provide an update on the permittee's: (1) progress implementing source reduction measures, operational improvements, and minor facility modifications to optimize reductions in phosphorus discharges and, to the extent that such measures, improvements, and modifications will not enable compliance with the WQBELs, (2) status evaluating feasible alternatives for meeting phosphorus TMDL limits.	01/01/2027
<b>Preliminary Compliance Alternatives Plan:</b> The permittee shall submit a preliminary compliance alternatives plan to the Department.	04/01/2027
If the plan concludes upgrading of the permittee's wastewater treatment facility is necessary to achieve final phosphorus TMDL limits, the submittal shall include a preliminary engineering design report.	
If the plan concludes Adaptive Management will be used, the submittal shall include a completed Watershed Adaptive Management Request Form 3200-139 without the Adaptive Management Plan.	
If water quality trading will be undertaken, the plan must state that trading will be pursued.	
<b>Final Compliance Alternatives Plan:</b> The permittee shall submit a final compliance alternatives plan to the Department.	10/01/2027
If the plan concludes upgrading of the permittee's wastewater treatment is necessary to meet final	

<b>Complete Construction:</b> Complete construction of wastewater treatment system upgrades. Comply with the final phosphorus limits.	10/01/2030
<b>Construction Progress Report:</b> Submit a progress report on meeting the final WQBEL for phosphorus.	01/01/2029
<b>Final Plans and Specifications:</b> If the facility plan concluded that upgrading of the permittee's wastewater treatment system is necessary to meet final water quality based effluent limits, submit construction plans and specifications for Department approval.	01/01/2028
<b>Facility Plan:</b> The permittee shall submit a Facility Plan that evaluates feasible alternatives for meeting the phosphorus WQBELs. Alternatives may include: upgrading wastewater treatment facilities, selecting the Watershed Adaptive Management Option pursuant to s. NR 217.18, Wis. Adm. Code, using Water Quality Trading in conjunction with or in place of facility upgrading, sitespecific water quality criteria development, or a variance from water quality standards pursuant to s. 283.15, Stats.	07/01/2028
<b>Final Plans and Specifications:</b> Unless the permit has been modified, revoked and reissued, or reissued to include Adaptive Management or Water Quality Trading measures or to include a revised schedule based on factors in s. NR 217.17, Wis. Adm. Code, the permittee shall submit final construction plans to the Department for approval pursuant to s. 281.41, Stats., specifying treatment plant upgrades that must be constructed to achieve compliance with final phosphorus TMDL limits, and a schedule for completing construction of the upgrades by the complete construction date specified below. (Note: Permit modification, revocation and reissuance, and reissuance are subject to s. 283.53(2), Stats.)	04/01/2028
If the plan concludes water quality trading will be used, the submittal shall identify potential trading partners.	
If the plan concludes Adaptive Management will be implemented, the submittal shall include a completed Watershed Adaptive Management Request Form 3200-139 and an engineering report addressing any treatment system upgrades necessary to meet interim limits pursuant to s. NR 217.18, Wis. Adm. Code.	
phosphorus TMDL limits, the submittal shall include a final engineering design report addressing the treatment plant upgrades, and a facility plan if required pursuant to ch. NR 110, Wis. Adm. Code.	

# **5.2 Groundwater Monitoring Well - Installation**

Required Action	<b>Due Date</b>
<b>Plans and Specifications:</b> Submit plans and specifications for installation of monitoring wells. A minimum of three groundwater monitoring wells are required. Of these wells at least one should be up-gradient to determine background gound water quality and at least one should be down-gradient of the spray irrigation field.	04/01/2026
<b>Installation:</b> Complete well installation in accordance with ch NR 141, Wisconsin Administrative Code. (Note: Documentation of well construction must be submitted to the Department within 60 days of well installation.)	10/01/2026

# **5.3 Land Treatment Management Plan**

A management plan is required for the land treatment system.

Required Action		
Land Treatment Management Plan: Submit a management plan to optimize the land treatment	01/01/2027	
system performance and demonstrate compliance with Wisconsin Administrative Code NR 214.		

# **5.4 Land Application Management Plan**

A management plan is required for the land application system.

Required Action	Due Date
Land Application Management Plan: Submit a management plan to optimize the land application	01/01/2027
system performance and demonstrate compliance with Wisconsin Administrative Code NR 214.	

# **6 Standard Requirements**

Chapter NR 205, Wisconsin Administrative Code (Conditions for Industrial Dischargers): The conditions in ss. NR 205.07(1) and NR 205.07(3), Wis. Adm. Code, are included by reference in this permit. The permittee shall comply with all of these requirements. Some of these requirements are outlined in the Standard Requirements section of this permit. Requirements not specifically outlined in the Standard Requirement section of this permit can be found in ss. NR 205.07(1) and NR 205.07(3), Wis. Adm. Code.

# 6.1 Reporting and Monitoring Requirements

## 6.1.1 Monitoring Results

Monitoring results obtained during the previous month shall be summarized and reported on a Department Wastewater Discharge Monitoring Report. The report may require reporting of any or all of the information specified below under 'Recording of Results'. This report is to be returned to the Department no later than the date indicated on the form. A copy of the Wastewater Discharge Monitoring Report Form or an electronic file of the report shall be retained by the permittee.

Monitoring results shall be reported on an electronic discharge monitoring report (eDMR). The eDMR shall be certified electronically by a responsible executive or officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The 'eReport Certify' page certifies that the electronic report form is true, accurate and complete.

If the permittee monitors any pollutant more frequently than required by this permit, the results of such monitoring shall be included on the Wastewater Discharge Monitoring Report.

The permittee shall comply with all limits for each parameter regardless of monitoring frequency. For example, monthly, weekly, and/or daily limits shall be met even with monthly monitoring. The permittee may monitor more frequently than required for any parameter.

# 6.1.2 Sampling and Testing Procedures

Sampling and laboratory testing procedures shall be performed in accordance with Chapters NR 218 and NR 219, Wis. Adm. Code, and completed by a laboratory certified or registered in accordance with the requirements of ch. NR 149, Wis. Adm. Code. Groundwater sampling shall be performed in accordance with procedures contained in s. NR 140.16, Wis. Adm. Code, and the WDNR publications, Groundwater Sampling Desk Reference (PUBL-DG-037-96) and Groundwater Sampling Field Manual (PUBL-DG-038-96). The analytical methodologies used shall enable the laboratory to quantitate all substances for which monitoring is required at levels below the effluent limitation and/or groundwater standard. If the required level cannot be met by any of the methods available in ch. NR 219, Wis. Adm. Code, then the method with the lowest limit of detection shall be selected. Additional test procedures may be specified in this permit.

# 6.1.3 Recording of Results

The permittee shall maintain records which provide the following information for each effluent measurement or sample taken:

- The date, exact place, method and time of sampling or measurements;
- The individual who performed the sampling or measurements;
- The date the analysis was performed;
- The individual who performed the analysis;
- The analytical techniques or methods used; and

• The results of the analysis.

#### 6.1.4 Reporting of Monitoring Results

The permittee shall use the following conventions when reporting effluent monitoring results:

- Pollutant concentrations less than the limit of detection shall be reported as < (less than) the value of the limit of detection. For example, if a substance is not detected at a detection limit of 0.1 mg/L, report the pollutant concentration as < 0.1 mg/L.
- Pollutant concentrations equal to or greater than the limit of detection, but less than the limit of quantitation, shall be reported and the limit of quantitation shall be specified.
- For purposes of calculating fees under ch. NR 101, Wis. Adm. Code, a reporting limit of 2.0 mg/L for BOD<sub>5</sub> and 2.5 mg/L Total Suspended Solids shall be considered to be limits of quantitation.
- For the purposes of reporting a calculated result, average or a mass discharge value, the permittee may substitute a "0" (zero) for any pollutant concentration that is less than the limit of detection. However, if the effluent limitation is less than the limit of detection, the department may substitute a value other than zero for results less than the limit of detection, after considering the number of monitoring results that are greater than the limit of detection and if warranted when applying appropriate statistical techniques.
- If no discharge occurs through an outfall, flow related parameters (e.g. flow rate, hydraulic application rate, volume, etc.) should be reported as "0" (zero) at the required sample frequency specified for the outfall. For example: if the sample frequency is daily, "0" would be reported for any day during the month that no discharge occurred.

#### 6.1.5 Records Retention

The permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings or electronic data records for continuous monitoring instrumentation, copies of all reports required by the permit, and records of all data used to complete the application for the permit for a period of at least 3 years from the date of the sample, measurement, report or application, except for sludge management forms and records, which shall be kept for a period of at least 5 years.

#### 6.1.6 Other Information

Where the permittee becomes aware that it failed to submit any relevant facts in a permit application or submitted incorrect information in a permit application or in any report to the Department, it shall promptly submit such facts or correct information to the Department.

## 6.1.7 Reporting Requirements – Alterations or Additions

The permittee shall give notice to the Department as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is only required when:

- The alteration or addition to the permitted facility may meet one of the criteria for determining whether a facility is a new source.
- The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification requirement applies to pollutants which are not subject to effluent limitations in the existing permit.
- The alteration or addition results in a significant change in the permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use of disposal sites not reported during the permit application process nor reported pursuant to an approved land application plan. Additional sites may not be used for the land application of sludge until department approval is received.

# **6.2 System Operating Requirements**

#### **6.2.1 Noncompliance Reporting**

The permittee shall report the following types of noncompliance by a telephone call to the Department's regional office within 24 hours after becoming aware of the noncompliance:

- Any noncompliance which may endanger health or the environment;
- Any violation of an effluent limitation resulting from a bypass;
- Any violation of an effluent limitation resulting from an upset; and
- Any violation of a maximum discharge limitation for any of the pollutants listed by the Department in the permit, either for effluent or sludge.

A written report describing the noncompliance shall also be submitted to the Department as directed at the end of this permit within 5 days after the permittee becomes aware of the noncompliance. On a case-by-case basis, the Department may waive the requirement for submittal of a written report within 5 days and instruct the permittee to submit the written report with the next regularly scheduled monitoring report. In either case, the written report shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times; the steps taken or planned to reduce, eliminate and prevent reoccurrence of the noncompliance; and if the noncompliance has not been corrected, the length of time it is expected to continue.

A scheduled bypass approved by the Department under the 'Scheduled Bypass' section of this permit shall not be subject to the reporting required under this section.

NOTE: Section 292.11(2)(a), Wisconsin Statutes, requires any person who possesses or controls a hazardous substance or who causes the discharge of a hazardous substance to notify the Department of Natural Resources immediately of any discharge not authorized by the permit. The discharge of a hazardous substance that is not authorized by this permit or that violates this permit may be a hazardous substance spill. To report a hazardous substance spill, call DNR's 24-hour HOTLINE at 1-800-943-0003.

# 6.2.2 Bypass

Except for a controlled diversion as provided in the 'Controlled Diversions' section of this permit, any bypass is prohibited and the Department may take enforcement action against a permittee for such occurrences under s. 283.89, Wis. Stats. The Department may approve a bypass if the permittee demonstrates all the following conditions apply:

- The bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
- There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities or adequate back-up equipment, retention of untreated wastes, reduction of inflow and infiltration, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance. When evaluating feasibility of alternatives, the department may consider factors such as technical achievability, costs and affordability of implementation and risks to public health, the environment and, where the permittee is a municipality, the welfare of the community served; and
- The bypass was reported in accordance with the 'Noncompliance Reporting' section of this permit.

## 6.2.3 Scheduled Bypass

Whenever the permittee anticipates the need to bypass for purposes of efficient operations and maintenance and the permittee may not meet the conditions for controlled diversions in the 'Controlled Diversions' section of this permit, the permittee shall obtain prior written approval from the Department for the scheduled bypass. A permittee's written request for Department approval of a scheduled bypass shall demonstrate that the conditions for unscheduled bypassing are met and include the proposed date and reason for the bypass, estimated volume and duration of the

bypass, alternatives to bypassing and measures to mitigate environmental harm caused by the bypass. The department may require the permittee to provide public notification for a scheduled bypass if it is determined there is significant public interest in the proposed action and may recommend mitigation measures to minimize the impact of such bypass.

#### 6.2.4 Controlled Diversions

Controlled diversions are allowed only when necessary for essential maintenance to assure efficient operation provided the following requirements are met:

- Effluent from the wastewater treatment facility shall meet the effluent limitations established in the permit.
   Wastewater that is diverted around a treatment unit or treatment process during a controlled diversion shall be recombined with wastewater that is not diverted prior to the effluent sampling location and prior to effluent discharge;
- A controlled diversion may not occur during periods of excessive flow or other abnormal wastewater characteristics;
- A controlled diversion may not result in a wastewater treatment facility overflow; and
- All instances of controlled diversions shall be documented in wastewater treatment facility records and such records shall be available to the department on request.

#### 6.2.5 Proper Operation and Maintenance

The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance includes effective performance, adequate funding, adequate operator staffing and training as required in ch. NR 114, Wis. Adm. Code, and adequate laboratory and process controls, including appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems only when necessary to achieve compliance with the conditions of the permit.

#### **6.2.6 Operator Certification**

The wastewater treatment facility shall be under the direct supervision of a state certified operator. In accordance with s. NR 114.53, Wis. Adm. Code, every WPDES permitted treatment plant shall have a designated operator-incharge holding a current and valid certificate. The designated operator-in-charge shall be certified at the level and in all subclasses of the treatment plant, except laboratory. Treatment plant owners shall notify the department of any changes in the operator-in-charge within 30 days. Note that s. NR 114.52(22), Wis. Adm. Code, lists types of facilities that are excluded from operator certification requirements (i.e. private sewage systems, pretreatment facilities discharging to public sewers, industrial wastewater treatment that consists solely of land disposal, agricultural digesters and concentrated aquatic production facilities with no biological treatment).

# 6.2.7 Spill Reporting

The permittee shall notify the Department in accordance with ch. NR 706 (formerly NR 158), Wis. Adm. Code, in the event that a spill or accidental release of any material or substance results in the discharge of pollutants to the waters of the state at a rate or concentration greater than the effluent limitations established in this permit, or the spill or accidental release of the material is unregulated in this permit, unless the spill or release of pollutants has been reported to the Department in accordance with s. NR 205.07 (1)(s), Wis. Adm. Code.

# 6.2.8 Planned Changes

In accordance with ss. 283.31(4)(b) and 283.59, Stats., the permittee shall report to the Department any facility expansion, production increase or process modifications which will result in new, different or increased discharges of pollutants. The report shall either be a new permit application, or if the new discharge will not violate the effluent limitations of this permit, a written notice of the new, different or increased discharge. The notice shall contain a

description of the new activities, an estimate of the new, different or increased discharge of pollutants and a description of the effect of the new or increased discharge on existing waste treatment facilities. Following receipt of this report, the Department may modify this permit to specify and limit any pollutants not previously regulated in the permit.

#### 6.2.9 Duty to Halt or Reduce Activity

Upon failure or impairment of treatment facility operation, the permittee shall, to the extent necessary to maintain compliance with its permit, curtail production or wastewater discharges or both until the treatment facility operations are restored or an alternative method of treatment is provided.

## 6.3 Surface Water Requirements

#### 6.3.1 Permittee-Determined Limit of Quantitation Incorporated into this Permit

For pollutants with water quality-based effluent limits below the Limit of Quantitation (LOQ) in this permit, the LOQ calculated by the permittee and reported on the Discharge Monitoring Reports (DMRs) is incorporated by reference into this permit. The LOQ shall be reported on the DMRs, shall be the lowest quantifiable level practicable, and shall be no greater than the minimum level (ML) specified in or approved under 40 CFR Part 136 for the pollutant at the time this permit was issued, unless this permit specifies a higher LOQ.

#### 6.3.2 Appropriate Formulas for Effluent Calculations

The permittee shall use the following formulas for calculating effluent results to determine compliance with average concentration limits and mass limits and total load limits:

Weekly/Monthly/Six-Month/Annual Average Concentration = the sum of all daily results for that week/month/six-month/year, divided by the number of results during that time period. [Note: When a six-month average effluent limit is specified for Total Phosphorus the applicable periods are May through October and November through April, except in cases of Water Quality Trading, wherein the applicable periods are January through June and July through December.]

**Weekly Average Mass Discharge (lbs/day):** Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the week.

Monthly Average Mass Discharge (lbs/day): Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the month.

**Six-Month Average Mass Discharge (lbs/day):** Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the six-month period. [Note: When a six-month average effluent limit is specified for Total Phosphorus the applicable periods are May through October and November through April.]

**Annual Average Mass Discharge (lbs/day):** Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the entire year.

**Total Monthly Discharge:** = monthly average concentration (mg/L) x total flow for the month (MG/month) x 8.34.

**Total Annual Discharge:** = sum of total monthly discharges for the calendar year.

**12-Month Rolling Sum of Total Monthly Discharge:** = the sum of the most recent 12 consecutive months of Total Monthly Discharges.

### **6.3.3 Effluent Temperature Requirements**

**Weekly Average Temperature** – If temperature limits are included in this permit, Weekly Average Temperature shall be calculated as the sum of all daily maximum results for that week divided by the number of daily maximum results during that time period.

**Cold Shock Standard** – Water temperatures of the discharge shall be controlled in a manner as to protect fish and aquatic life uses from the deleterious effects of cold shock pursuant to Wis. Adm. Code, s. NR 102.28. 'Cold Shock' means exposure of aquatic organisms to a rapid decrease in temperature and a sustained exposure to low temperature that induces abnormal behavior or physiological performance and may lead to death.

**Rate of Temperature Change Standard** – Temperature of a water of the state or discharge to a water of the state may not be artificially raised or lowered at such a rate that it causes detrimental health or reproductive effects to fish or aquatic life of the water of the state pursuant to Wis. Adm. Code, s. NR 102.29.

#### 6.3.4 Visible Foam or Floating Solids

There shall be no discharge of floating solids or visible foam in other than trace amounts.

#### 6.3.5 Surface Water Uses and Criteria

In accordance with NR 102.04, Wis. Adm. Code, surface water uses and criteria are established to govern water management decisions. Practices attributable to municipal, industrial, commercial, domestic, agricultural, land development or other activities shall be controlled so that all surface waters including the mixing zone meet the following conditions at all times and under all flow and water level conditions:

- Substances that will cause objectionable deposits on the shore or in the bed of a body of water, shall not be present in such amounts as to interfere with public rights in waters of the state.
- Floating or submerged debris, oil, scum or other material shall not be present in such amounts as to interfere with public rights in waters of the state.
- Materials producing color, odor, taste or unsightliness shall not be present in such amounts as to interfere with public rights in waters of the state.
- Substances in concentrations or in combinations which are toxic or harmful to humans shall not be present in amounts found to be of public health significance, nor shall substances be present in amounts which are acutely harmful to animal, plant or aquatic life.

#### 6.3.6 Total Residual Chlorine Requirements

When total residual chlorine (TRC) limit(s) or monitoring are included in a permit, the permittee shall comply with the following conditions:

- The permittee shall perform TRC monitoring required in this permit using an approved method from ch. NR 219, Wis. Adm. Code, which produces a detection limit that is less than or equal to the permitted limit or produces the lowest economically feasible detection limit if the approved methods cannot meet the permit limit. If the facility cannot achieve a detection limit less than or equal to the permit limit using the approved methods, contact the laboratory accreditation program for guidance.
- The permittee shall determine the limit of detection (LOD) as specified in s. NR 149.48 (2)(b), Wis. Adm. Code, or the permittee shall contact the laboratory accreditation program for information on how to determine a verified detection limit allowed just for TRC. If the verified detection limit is determined using the special procedure, then the LOD and limit of quantitation (LOQ) shall be set to be equal to the verified detection limit determined from this special procedure.
- The permittee shall determine compliance with the TRC limit(s) as follows:
  - a) If the facility determines a statistical LOD as specified in s. NR 149.48 (2)(b), Wis. Adm. Code, and the measured TRC levels are less than the LOD, the permittee shall report the results as less than the LOD (<LOD). For this situation the LOQ shall be established at 3.33 times the LOD or at the concentration of the lowest standard in the calibration curve. TRC levels that are < LOD are in compliance with the TRC limit.</p>

- b) If the facility determines the verified detection limit using the laboratory accreditation program special procedure, this verified detection limit shall be reported as the LOD and LOQ. If the measured TRC levels are less than the LOD, the permittee shall report the results as < LOD. TRC levels that are < LOD are in compliance with the TRC limit.
- c) If the facility determines the statistical LOD as specified in s. NR 149.48 (2)(b), Wis. Adm. Code, and the measured TRC levels are greater than the statistical LOD but less than the LOQ, TRC levels are in compliance with the TRC limit except when the measured levels are consistently reported between the LOD and LOQ. When the measured TRC levels are consistently reported between the LOD and LOQ, the facility shall take action to determine the reliability of detected results (such as resampling and/or recalculating dosages) and shall adjust the chemical feed system if necessary to reduce the chances of detecting levels between the statistical LOD and LOQ.
- d) If the facility determines the statistical LOQ as specified in s. NR 149.48 (2)(b), Wis. Adm. Code, or determines the verified detection limit using the laboratory accreditation program special procedure, TRC measured levels that are greater than the statistical LOQ and the TRC limit, are not in compliance with the TRC limit. The permittee shall report the level as a limit exceedance.
- e) If the facility determines the statistical LOD as specified in s. NR 149.48 (2)(b), Wis. Adm. Code, and the measured level is < LOD, then a "0" (zero) value may be substituted for any test result less than the statistical LOD when calculating the average or mass discharge values. Calculated values shall then be compared directly to the average or mass limits to determine compliance.
- f) If the facility determines the verified detection limit using the laboratory accreditation program special procedure and the measured level is < LOD (set equal to the verified detection limit), then a "0" (zero) value may be substituted for any test result less than the LOD when calculating the average or mass discharge values. Calculated values shall then be compared directly to the average or mass limits to determine compliance.

# 6.3.7 Compliance with Phosphorus Limitation

Compliance with the concentration limitation for phosphorus shall be determined as a rolling twelve-month average and shall be calculated as follows:

First, determine the pounds of phosphorus for an individual month by multiplying the average of all the concentration values for phosphorus (in mg/L) for that month by the total flow for the month in Million Gallons times the conversion factor of 8.34.

Then, the monthly pounds of phosphorus determined in this manner shall be summed for the most recent 12 months and inserted into the numerator of the following equation.

Average concentration of P in mg/L = Total lbs of P discharged (most recent 12 months)

Total flow in MG (most recent 12 months) X 8.34

The compliance calculation shall be performed each month with a reported discharge volume after substituting data from the most recent month(s) for the oldest month(s). A calculated value in excess of the concentration limitation will be considered equivalent to a violation of a monthly average.

#### 6.3.8 Additives

In the event that the permittee wishes to commence use of a water treatment additive, or increase the usage of the additives greater than indicated in the permit application, the permittee must get a written approval from the Department prior to initiating such changes. This written approval shall provide authority to utilize the additives at the

specific rates until the permit can be either reissued or modified in accordance with s. 283.53, Stats. Restrictions on the use of the additives may be included in the authorization letter.

# 6.4 Land Treatment Requirements for Industrial Discharges

**NR 214, Wisconsin Administrative Code:** The requirements of this section are based on ss. NR 214.12-16, Wis. Adm. Code, and apply to wastewater discharges to designed and constructed absorption pond, ridge & furrow, spray irrigation, overland flow and subsurface absorption treatment systems.

### 6.4.1 Formulas for Land Treatment Calculations

The permittee shall use the following formulas for land treatment calculations, unless an alternate calculation method is approved by the Department in the Land Treatment Management Plan.

#### 6.4.1.1 Monthly Average Hydraulic Application Rate

Determine the monthly average hydraulic application rate (in gal/acre/day) for each outfall by calculating the total gallons of wastewater applied onto the site for the month, dividing that total by the number of wetted acres loaded during the month, and then dividing this resulting value by the number of days in the month. Enter this calculated monthly value on the Discharge Monitoring Report form in the box for the last day of the month, in the "Hydraulic Application Rate" column.

#### 6.4.1.2 Annual Total Nitrogen per Cell or per Zone

(annual ave. concentration in mg/L) (tot. annual flow in million gallons per cell or zone) (8.34) = lbs/ac/yr acreage of cell or zone

#### 6.4.1.3 Annual Total Chloride per Cell or per Zone

(annual ave. concentration in mg/L) (tot. annual flow in million gallons per cell or zone) (8.34) = lbs/ac/yr acreage of cell or zone

# 6.4.2 Chloride Requirements for Land Treatment Systems

Since chloride is not significantly treated by the soil, the chloride level of the wastewater treated on land shall be minimized to the extent that is technically and economically feasible. The goal is to protect groundwater quality and prevent exceedance of the 125 mg/L groundwater preventive action limit.

# 6.4.3 Nitrogen Loading Requirements for Spray Irrigation

The total annual nitrogen loading (pounds/acre/year) to the wastewater spray irrigation acreage shall not exceed the limitation contained in the monitoring requirements and limitations for that sampling point. Determination of the annual pounds of nitrogen applied to the land treatment system shall include the nitrogen supplied by the wastewater, organic nitrogen becoming available to plants and any supplemental fertilizers used. The Department may approve (in writing) an alternative nitrogen loading limit in a spray irrigation management plan based on the annual nitrogen needs of the cover crop and the permittee's demonstration of nitrogen losses for the site as specified in s. NR 214.14(3)(c), Wis. Adm. Code.

# 6.4.4 Ponding

The intensity of wastewater spray shall be limited to prevent ponding, except for temporary conditions following rainfall events.

#### 6.4.5 Runoff

The volume of wastewater sprayed shall be limited to prevent runoff of any wastewater mixed with rainwater as specified in s. NR 214.14(3)(f), Wis. Adm. Code. If wastewater runoff occurs, spray irrigation shall cease immediately.

## 6.4.6 Seasonal Irrigation Restriction

Discharge to the spray irrigation field shall occur only between April 1 and October 31 each year, unless otherwise specified in the approved Land Treatment Management Plan.

## 6.4.7 Irrigation Management Plan

The spray irrigation treatment system shall be operated and managed in accordance with a Department approved management plan. The management plan shall be consistent with the conditions listed in this permit and s. NR 214.14(5), Wis. Adm. Code, which requires a load/rest cycle, cover crop removal, annual soil testing, etc. If operational changes are needed, the management plan shall be amended and such plan shall be submitted to the Department for approval prior to implementing such changes.

# 6.5 Land Application Requirements

#### 6.5.1 General Sludge Management Information

The General Sludge Management Form 3400-48 shall be completed and submitted prior to any significant sludge management changes.

## 6.5.2 Land Application Characteristic Report

The analytical results from testing of liquid wastes, by-product solids and sludges that are land applied shall be reported annually on the Characteristic Report Form 3400-49. The report form shall be submitted electronically no later than the date indicated on the form. Following submittal of the electronic Characteristic Report Form 3400-49, this form shall be certified electronically via the 'eReport Certify' page by a responsible executive officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The 'eReport Certify' page certifies that the electronic report form is true, accurate and complete. The permittee shall use the following convention when reporting sludge monitoring results: Pollutant concentrations less than the limit of detection shall be reported as < (less than) the value of the limit of detection. For example, if a substance is not detected at a detection limit of 1.0 mg/kg, report the pollutant concentration as < 1.0 mg/kg. All sludge results shall be reported on a dry weight basis.

# 6.5.3 Annual Land Application Report

The annual totals for the land application loadings of liquid wastes, by-product solids and sludges to field spreading sites shall be submitted electronically on the Annual Land Application Report Form 3400-55 by January 31, each year whether or not waste is land applied. Following submittal of the electronic Annual Land Application Report Form 3400-55, this form shall be certified electronically via the 'eReport Certify' page by a responsible executive officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The 'eReport Certify' page certifies that the electronic report form is true, accurate and complete.

# 6.5.4 Other Methods of Disposal or Distribution Report

The permittee shall submit electronically the Other Methods of Disposal or Distribution Report Form 3400-52 by January 31, each year whether or not waste is hauled to another facility, landfilled, incinerated, or stored in a manure pit. Following submittal of the electronic Report Form 3400-52, this form shall be certified electronically via the 'eReport Certify' page by a responsible executive officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated

Seneca Foods Corporation

signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The 'eReport Certify' page certifies that the electronic report form is true, accurate and complete.

# 6.5.5 Land Application Site Approval

The permittee is authorized to landspread permitted liquid wastes, by-product solids and sludges on sites approved in writing by the Department in accordance with ss. NR 214.17(2) and 214.18(2), Wis. Adm. Code. Any site use restrictions or granting of case-by-case exceptions shall be identified in the approval letter. If the permittee wishes to have approval for additional sites, application shall be made using Land Application Site Request Form 3400-053. Complete information shall be submitted about each site, including location maps and soil maps, any soil analyses results and other information showing that the site complies with all application requirements and permit conditions. Spreading on a site may commence upon receipt of Department approval. If an existing spreading site is found by the Department to be environmentally unacceptable, a written notice will be issued to withdraw approval of that site.

## 6.5.6 Operating Requirements/Management Plan

All land application sites used for treatment of liquid wastes, by-product solids and sludges shall be operated in accordance with a Department approved management plan. The management plan shall be consistent with the requirements of this permit, ss. NR 214.17 (3) and (6), and NR 214.18 (3) and (6), Wis. Adm. Code. If operational changes are needed, the land application management plan shall be amended by submitting a written request to the Department for approval. A land application management plan shall be submitted for approval at least 60 days prior to land application.

## 6.5.7 Chloride Requirements for Liquid Wastes and By-Product Solids

The total pounds of chloride applied shall be limited to 340 pounds per acre per 2 year period. Calculate the chloride loading as follows:

Wet Weight Solids: <u>lbs of solids X %solids X %chloride</u> = lbs chloride/acre acres land applied X 100 X 100

Liquid:  $\frac{\text{mg/L chloride X (millions of gallons) X 8.34}}{\text{acres land applied}}$  = lbs chloride/acre

# 6.5.8 Nitrogen Requirements for Liquid Wastes and By-Product Solids and Sludges

NR 214.17(4) and NR 214.18(4) Wis. Adm. Code specify that the total pounds of nitrogen land applied per acre per year shall be limited to the nitrogen needs of the cover crop minus any other nitrogen added to the land application site, including fertilizer or manure. Nitrogen applied can be calculated on the basis of plant available nitrogen, as long as the release of nitrogen from the organic material is credited to future years. This permit requires that the Total Kjeldahl Nitrogen calendar year application amount shall not exceed 165 pounds per acre per year, except when alternate numerical nitrogen loading limits (consistent with the above sections of NR 214) are approved in writing via the Department's land application management plan approval. Calculate nitrogen loading as follows ("TKN" represents "Total Kjeldahl Nitrogen"):

Wet Weight Solids and Sludges: <u>lbs of solids X % solids X % TKN</u> = lbs TKN/acre acres land applied X 100 X 100

Liquid:  $\frac{\text{mg/L TKN X (millions of gallons) X 8.34}}{\text{acres land applied}} = \text{lbs TKN/acre}$ 

6.5.9 Ponding

The volume of liquid wastes land applied shall be limited to prevent ponding, except for temporary conditions following rainfall events. If ponding occurs all land application shall cease immediately. The permittee shall land apply only the liquid wastes that are permitted.

#### 6.5.10 Runoff

The volume of liquid wastes land applied shall be limited to prevent runoff. If runoff occurs all land application shall cease immediately. The permittee shall land apply only the liquid wastes that are permitted.

## 6.5.11 Soil Incorporation Requirements

- Liquid Sludge Requirements: The Department may require that liquid sludge be incorporated into the soil on
  specific land application sites when necessary to prevent surface runoff or objectionable odors. Requirements
  and procedures for incorporation of liquid sludge, when such incorporation may be necessary, shall be
  specified in the management plan or in specific site applications, subject to Department approval. The
  permittee shall comply with the requirements in the Department approved management plan, specific siteapproval requirements and the terms and conditions of this permit.
- Cake Sludge Requirements: After land application, cake sludge shall be incorporated into the soil. The timing of such incorporation and other related requirements and procedures shall be specified in the management plan or in specific site applications, subject to Department approval. The permittee shall comply with the requirements in the Department approved management plan, specific site-approval requirements and the terms and conditions of this permit.
- Liquid Wastewater Requirements: The Department may require that liquid wastewater be incorporated or injected into the soil on specific land application sites when necessary to prevent surface runoff or objectionable odors. Requirements and procedures for injection or incorporation of liquid wastewater, when such injection or incorporation is necessary, shall be specified in the management plan or in specific site applications, subject to Department approval. The permittee shall comply with the requirements in the Department approved management plan, specific site-approval requirements and the terms and conditions of this permit.
- By-Product Solids Requirements: The Department may limit the volume of by-products solids that are landspread on a specific site when necessary to prevent surface runoff or leaching of contaminants to groundwater and objectionable odors. By-product solids shall, after application, be plowed, disced, or otherwise incorporated into the soil. Requirements and procedures for the incorporation of byproduct solids into the soil shall be specified in the management plan or in specific site applications, subject to Department approval. The permittee shall comply with the requirements in the Department approved management plan, specific site-approval requirements and the terms and conditions of this permit.

# 6.5.12 Field Stockpiles

The permittee is encouraged to landspread the by-product solids or sludges as they are transported to the fields; but if it becomes necessary to stockpile solids in the fields, the stockpiles shall be spread within 72 hours or as specified in the approved management plan.

# 6.5.13 By-Product Storage Sites

All sites used for storage of by-product solids shall be located such that surface water or groundwater pollution does not occur. Written Department approval is required prior to storage of more than 150 tons of by-product solids on a site at any one time.

# 6.5.14 Annual Inspections-Stacking Pads and Leachate Containment

Stacking pads for more than 1200 tons of silage and all leachate containment facilities shall be inspected annually for cracks and shall be repaired as necessary to prevent leakage from the containment system. The inspection reports shall

be available for inspection by Department personnel for a period of three years, and shall include at a minimum the following information:

- Date and name of person(s) performing the inspection;
- Description of what the inspection consisted of;
- Details of what was discovered during the inspection;
- Recommendations for repair or maintenance; and
- Details or repair completed.

#### 6.5.15 Additional Requirements from ch. NR 214, Wis. Adm. Code

The requirements of s. NR 214.17 (4)(c) [pathogen prohibition for human consumption crop fields], (4)(d)1 [no adverse soil effects], (4)(d)10 [allowable whey spreading rates], and (4)(e)1-3 [by-product solids spreading within agricultural practices and not cause contamination] for landspreading of liquid wastes and by product solids and s. NR 214.18 (4)(b),(d)-(h) [application, nutrient, pH, metals, and PCB limitations] for sludge spreading systems are included by reference in this permit. The permittee shall comply with these requirements.

# 7 Summary of Reports Due

FOR INFORMATIONAL PURPOSES ONLY

Description	Date	Page
Phosphorus - TMDL Limits for Total Phosphorus - Operational Evaluation Report	July 1, 2026	11
Phosphorus - TMDL Limits for Total Phosphorus - Compliance Alternatives, Source Reduction, Improvements and Modifications Status	January 1, 2027	11
Phosphorus - TMDL Limits for Total Phosphorus - Preliminary Compliance Alternatives Plan	April 1, 2027	11
Phosphorus - TMDL Limits for Total Phosphorus -Final Compliance Alternatives Plan	October 1, 2027	11
Phosphorus - TMDL Limits for Total Phosphorus -Final Plans and Specifications	April 1, 2028	12
Phosphorus - TMDL Limits for Total Phosphorus -Facility Plan	July 1, 2028	12
Phosphorus - TMDL Limits for Total Phosphorus -Final Plans and Specifications	January 1, 2028	12
Phosphorus - TMDL Limits for Total Phosphorus - Construction Progress Report	January 1, 2029	12
Phosphorus - TMDL Limits for Total Phosphorus -Complete Construction	October 1, 2030	12
Groundwater Monitoring Well - Installation -Plans and Specifications	April 1, 2026	12
Groundwater Monitoring Well - Installation -Installation	October 1, 2026	12
Land Treatment Management Plan -Land Treatment Management Plan	January 1, 2027	13
Land Application Management Plan -Land Application Management Plan	January 1, 2027	13
General Sludge Management Form 3400-48	prior to any significant sludge management changes	22
Characteristic Report Form 3400-49	no later than the date indicated on the form	22
Land Application Report Form 3400-55	January 31, each year whether or not waste is land applied	22
Other Methods of Disposal or Distribution Report Form 3400-52	by January 31, each year whether or not waste is hauled to another facility, landfilled, incinerated, or stored in a manure pit	22
Wastewater Discharge Monitoring Report	no later than the date indicated on the form	14

Report forms shall be submitted electronically in accordance with the reporting requirements herein. Any facility plans or plans and specifications for municipal, industrial, industrial pretreatment and non industrial wastewater

WPDES Permit No. WI-0052809-11-0 Seneca Foods Corporation

systems shall be submitted to the Bureau of Water Quality, P.O. Box 7921, Madison, WI 53707-7921. All other submittals required by this permit shall be submitted to: Northeast Region, 2984 Shawano Ave, Green Bay, WI 54313-6727