



WPDES PERMIT

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
**PERMIT TO DISCHARGE UNDER THE WISCONSIN POLLUTANT DISCHARGE
ELIMINATION SYSTEM**

United States Geological Survey - Ecosystems Mission Area, UMESC

is permitted, under the authority of Chapter 283, Wisconsin Statutes, to discharge from a facility
located at
2630 Fanta Reed Rd, La Crosse, WI
to
the backwaters (wetlands) of the Black River, located in the Lower Black River Watershed
of the Black River Basin in La Crosse County

in accordance with the effluent limitations, monitoring requirements and other conditions set
forth in this permit.

The permittee shall not discharge after the date of expiration. If the permittee wishes to continue to discharge after this expiration date an application shall be filed for reissuance of this permit, according to Chapter NR 200, Wis. Adm. Code, at least 180 days prior to the expiration date given below.

State of Wisconsin Department of Natural Resources
For the Secretary

By _____
Geisa Thielen
Wastewater Field Supervisor

Date Permit Signed/Issued

PERMIT TERM: EFFECTIVE DATE - January 01, 2025

EXPIRATION DATE – December 31, 2029

TABLE OF CONTENTS

1 INFLUENT REQUIREMENTS	1
1.1 SAMPLING POINT(S)	1
1.2 MONITORING REQUIREMENTS	1
1.2.1 <i>Sampling Point 701 - INFLUENT</i>	1
2 IN-PLANT REQUIREMENTS	2
2.1 SAMPLING POINT(S)	2
2.2 MONITORING REQUIREMENTS AND LIMITATIONS	2
2.2.1 <i>Sampling Point 101 - EFFLUENT PRIOR TO SMALL POND</i>	2
2.2.2 <i>Sampling Point 103 - EFFLUENT TO LARGE POND</i>	2
3 SURFACE WATER REQUIREMENTS	3
3.1 SAMPLING POINT(S)	3
3.2 MONITORING REQUIREMENTS AND EFFLUENT LIMITATIONS	3
3.2.1 <i>Sampling Point (Outfall) 001 - EFFLUENT to BACKWATERS</i>	3
3.2.2 <i>Sampling Point (Outfall) 002 - STORM WTR, BYPASS, REARING WTR</i>	7
3.2.3 <i>Sampling Point (Outfall) 005 - COMBINED OUTFALL 001 + 002</i>	9
4 LAND APPLICATION REQUIREMENTS	11
4.1 SAMPLING POINT(S)	11
4.2 MONITORING REQUIREMENTS AND LIMITATIONS	11
4.2.1 <i>Sampling Point (Outfall) 003 - LARGE (STABILIZATION) POND</i>	11
4.2.2 <i>Sampling Point (Outfall) 004 - SMALL (QUIESCENT) POND</i>	12
5 SCHEDULES	17
5.1 TEMPERATURE COMPLIANCE SCHEDULE	17
5.2 PFOS/PFOA MINIMIZATION PLAN DETERMINATION OF NEED	17
5.3 LAND APPLICATION MANAGEMENT PLAN	18
6 STANDARD REQUIREMENTS	19
6.1 REPORTING AND MONITORING REQUIREMENTS	19
6.1.1 <i>Monitoring Results</i>	19
6.1.2 <i>Sampling and Testing Procedures</i>	19
6.1.3 <i>Recording of Results</i>	19
6.1.4 <i>Reporting of Monitoring Results</i>	20
6.1.5 <i>Records Retention</i>	20
6.1.6 <i>Other Information</i>	20
6.1.7 <i>Reporting Requirements – Alterations or Additions</i>	20
6.2 SYSTEM OPERATING REQUIREMENTS	20
6.2.1 <i>Noncompliance Reporting</i>	21
6.2.2 <i>Bypass</i>	21
6.2.3 <i>Scheduled Bypass</i>	21
6.2.4 <i>Controlled Diversions</i>	22
6.2.5 <i>Ammonia Limit Not Needed - Continue to Optimize Removal of Ammonia</i>	22
6.2.6 <i>Proper Operation and Maintenance</i>	22
6.2.7 <i>Operator Certification</i>	22
6.2.8 <i>Spill Reporting</i>	22
6.2.9 <i>Planned Changes</i>	22
6.2.10 <i>Duty to Halt or Reduce Activity</i>	23
6.3 SURFACE WATER REQUIREMENTS	23
6.3.1 <i>Permittee-Determined Limit of Quantitation Incorporated into this Permit</i>	23
6.3.2 <i>Appropriate Formulas for Effluent Calculations</i>	23
6.3.3 <i>Effluent Temperature Requirements</i>	23

6.3.4 <i>Visible Foam or Floating Solids</i>	24
6.3.5 <i>Surface Water Uses and Criteria</i>	24
6.3.6 <i>Compliance with Phosphorus Limitation</i>	24
6.3.7 <i>Additives</i>	25
6.3.8 <i>Whole Effluent Toxicity (WET) Monitoring Requirements</i>	25
6.3.9 <i>Whole Effluent Toxicity (WET) Identification and Reduction</i>	25
6.4 LAND APPLICATION REQUIREMENTS	25
6.4.1 <i>General Sludge Management Information</i>	25
6.4.2 <i>Land Application Characteristic Report</i>	26
6.4.3 <i>Annual Land Application Report</i>	26
6.4.4 <i>Other Methods of Disposal or Distribution Report</i>	26
6.4.5 <i>Land Application Site Approval</i>	26
6.4.6 <i>Operating Requirements/Management Plan</i>	26
6.4.7 <i>Chloride Requirements for Liquid Wastes and By-Product Solids</i>	27
6.4.8 <i>Nitrogen Requirements for Liquid Wastes and By-Product Solids and Sludges</i>	27
6.4.9 <i>Ponding</i>	27
6.4.10 <i>Runoff</i>	27
6.4.11 <i>Soil Incorporation Requirements</i>	27
6.4.12 <i>Field Stockpiles</i>	28
6.4.13 <i>Additional Requirements from ch. NR 214, Wis. Adm. Code</i>	28
7 SUMMARY OF REPORTS DUE	29

1 Influent Requirements

1.1 Sampling Point(s)

Sampling Point Designation	
Sampling Point Number	Sampling Point Location, WasteType/Sample Contents and Treatment Description (as applicable)
701	Representative samples of influent to the activated carbon filtration system shall be collected from the chem-wastewater wet well prior to that system.

1.2 Monitoring Requirements

The permittee shall comply with the following monitoring requirements.

1.2.1 Sampling Point 701 - INFLUENT

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Monthly	Total Daily	
BOD ₅ , Total		mg/L	Monthly	24-Hr Flow Prop Comp	
Suspended Solids, Total		mg/L	Monthly	24-Hr Flow Prop Comp	

2 In-Plant Requirements

2.1 Sampling Point(s)

Sampling Point Designation	
Sampling Point Number	Sampling Point Location, WasteType/Sample Contents and Treatment Description (as applicable)
101	Representative samples of treated effluent from the activated carbon filtration system shall be collected prior to discharge to the small (quiescent) pond.
103	Representative samples shall be collected from the nonchemical wet well prior to discharge into the large (stabilization) pond.

2.2 Monitoring Requirements and Limitations

The permittee shall comply with the following monitoring requirements and limitations.

2.2.1 Sampling Point 101 - EFFLUENT PRIOR TO SMALL POND

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Daily	Estimated	
BOD ₅ , Total		mg/L	Monthly	24-Hr Flow Prop Comp	
Suspended Solids, Total		mg/L	Monthly	24-Hr Flow Prop Comp	

2.2.2 Sampling Point 103 - EFFLUENT TO LARGE POND

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Daily	Estimated	
BOD ₅ , Total		mg/L	Monthly	24-Hr Flow Prop Comp	
Suspended Solids, Total		mg/L	Monthly	24-Hr Flow Prop Comp	

3 Surface Water Requirements

3.1 Sampling Point(s)

The discharge(s) shall be limited to the waste type(s) designated for the listed sampling point(s).

Sampling Point Designation	
Sampling Point Number	Sampling Point Location, Waste Type/Sample Contents and Treatment Description (as applicable)
001	Representative samples of effluent from the small (quiescent) pond shall be collected at the meter building prior to discharge to the backwaters (wetlands) of the Black River.
002	Representative flow and temperature samples shall be collected from the flow meter, and grab samples shall be collected from the concrete access pit and following combination of inflows and prior to discharge to the backwaters (wetlands) of the Black River. Discharge is limited to storm drain bypass of fish rearing pond, excess environmental chamber chillers and process water chamber chillers and parking lot/roof top storm water.
005	The permittee shall calculate the combined flow and phosphorus results from Outfall 001 and Outfall 002 and report it at Outfall 005.

3.2 Monitoring Requirements and Effluent Limitations

The permittee shall comply with the following monitoring requirements and limitations.

3.2.1 Sampling Point (Outfall) 001 - EFFLUENT to BACKWATERS

Monitoring Requirements and Effluent Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Continuous	Total Daily	
BOD ₅ , Total	Daily Max	40 mg/L	Monthly	24-Hr Flow Prop Comp	
BOD ₅ , Total	Monthly Avg	20 mg/L	Monthly	24-Hr Flow Prop Comp	
Suspended Solids, Total	Daily Max	40 mg/L	Weekly	24-Hr Flow Prop Comp	
Suspended Solids, Total	Monthly Avg	20 mg/L	Weekly	24-Hr Flow Prop Comp	
pH Field	Daily Min	6.0 su	5/Week	Grab	
pH Field	Daily Max	9.75 su	5/Week	Grab	
Dissolved Oxygen		mg/L	5/Week	Grab	
Nitrogen, Ammonia (NH ₃ -N) Total		mg/L	Monthly	24-Hr Flow Prop Comp	
Halogen, Total Residual as Cl ₂	Daily Max	19 µg/L	5/Week	Grab	See Total Halogens section below.
Halogen, Total Residual as Cl ₂	Monthly Avg	7.3 µg/L	5/Week	Grab	See Total Halogens section below.

Monitoring Requirements and Effluent Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Halogen, Total Residual as Cl ₂	Weekly Avg	7.3 µg/L	5/Week	Grab	See Total Halogens section below.
Arsenic, Total Recoverable		µg/L	Quarterly	24-Hr Flow Prop Comp	Sample concurrently with WET tests.
Temperature Maximum		deg F	Daily	Continuous	See Temperature footnote below and Compliance Schedule Section.
PFOS		ng/L	Monthly	Grab	Monitoring only. See PFOS/PFOA Minimization Plan Determination of Need schedule.
PFOA		ng/L	Monthly	Grab	Monitoring only. See PFOS/PFOA Minimization Plan Determination of Need schedule.
Phosphorus, Total		mg/L	Weekly	24-Hr Flow Prop Comp	Limits apply at Sample Point 005. See Phosphorus section below.
Acute WET		TU _a	See Listed Qtr(s)	24-Hr Flow Prop Comp	See WET footnote below.
Chronic WET	Monthly Avg	1.0 TU _c	See Listed Qtr(s)	24-Hr Flow Prop Comp	See WET footnote below.

3.2.1.1 Halogen, Total Residual as Chlorine

Acceptable test methods for determining Halogens, Total Residual as Cl₂ are the same as those for measuring Chlorine, Total Residual. These methods are listed for Chlorine, Total Residual in chapter NR 219, Table B, Wisconsin Administrative Code. The preferred test methods are the Spectrophotometric, DPD; the Electrode; and the Back Titration with amperometric endpoint.

3.2.1.2 Effluent Temperature Monitoring

For monitoring temperature continuously, collect measurements in accordance with s. NR 218.04(13). This means that discrete measurements shall be recorded at intervals of not more than 15 minutes during the 24-hour period. Report the maximum temperature measured during the day on the DMR.

3.2.1.3 Effluent Temperature Limitations

Limits for Temperature, Maximum: The effluent limitations for “Temperature, Maximum” become effective on 12/31/2029 as specified in the Schedules section. Monitoring is required Daily upon permit reissuance. Daily maximum temperatures shall be reported so that applicable daily maximum limits can be compared to the reported daily maximum temperatures and applicable weekly average limits can be compared to the weekly averages of the reported daily maximum temperatures.

After submitting the Site-Specific Temperature Evaluation Report of the compliance schedule (due 12/31/2027), the permittee may request a re-evaluation of the limits based on NR 106 – ‘Subchapters V and VI Effluent Limitations for Temperature’ or NR 102.26 – Site Specific Ambient Temperature. If the re-calculation of limits results in revisions to the temperature limits, a permit modification will be required to include the revised limits in the permit.

Effluent Limitations for 'Temperature Maximum' (Effective per the Schedules section) at 001:

Month	Weekly Avg. Effluent Limit (°F)
APR	57
MAY	66
JUN	76
SEP	74
OCT	62
NOV	51

3.2.1.4 PFOS/PFOA Sampling and Reporting Requirements

For grab samples, as defined per s. NR 218.04(10), Wis. Adm. Code, a single sample at a location as defined by the sample point description shall be taken during the time of the day most representative to capture all potential discharges. If extra equipment besides the sample bottle is used to collect the sample, it is recommended that a one-time equipment blank is collected with the first sample. An equipment blank would be collected by passing laboratory-verified PFAS-free water over or through field sampling equipment before the collection of a grab sample to evaluate potential contamination from the equipment used during sample.

If any equipment blanks are performed, these results shall be reported in the comments section of the eDMR and shall also be documented in the reports submitted as part of the PFOS/PFOA Minimization Plan Determination of Need schedule of the permit.

3.2.1.5 PFOS/PFOA Minimization Plan Determination of Need

The permittee shall monitor PFOS and PFOA as specified in the table above and report on the effluent concentrations including trends in monthly and annual average PFOS and PFOA concentrations as specified in the PFOS/PFOA Minimization Plan Determination of Need Schedule.

If, after reviewing the data, the Department determines that a minimization plan for PFOS and PFOA is necessary based on the procedures in s. NR 106.98(4), Wis. Adm. Code, the Department will notify the permittee in writing that a PFOS and PFOA minimization plan that satisfies the requirements in s. NR 106.99, Wis. Adm. Code, is required.

The permittee shall submit an initial plan for Department approval no later than 90 days after written notification was sent from the Department in accordance with s. NR 106.985(2)(a), Wis. Adm. Code. Pursuant to s. NR 106.985(2)(b), Wis. Adm. Code, as soon as possible after Department approval of the PFOS and PFOA minimization plan, the Department will modify or revoke and reissue the permit in accordance with public notice procedures under ch. 283, Wis. Stats., and ch. NR 203, Wis. Adm. Code, to include the PFOS and PFOA minimization plan and other related terms and condition.

If, however, the Department determines that a PFOS and PFOA minimization plan is unnecessary based on the procedures in s. NR 106.98(4), Wis. Adm. Code, the Department shall notify the permittee that no further action is required. Per s. NR 106.98(3)(a), Wis. Adm. Code, the Department may reduce monitoring frequency to once every 3 months (quarterly) on a case-by-case basis, but only after at least 12 representative results have been generated. If the permittee requests a reduction in monitoring and the Department agrees a reduction would be appropriate, the permit may be modified in accordance with public notice procedures under ch. 283, Wis. Stats., and ch. NR 203, Wis. Adm. Code, to incorporate this change.

3.2.1.6 Phosphorus Monitoring and Limitations

Phosphorus monitoring is required weekly. Results shall be reported at this sample point on the eDMRs. However, phosphorus limitations apply and compliance will be determined at the combined sample point 005, which includes contributions of phosphorus from sample points 001 and 002. See sample point 005 for more information.

3.2.1.7 Whole Effluent Toxicity (WET) Testing

Primary Control Water: backwaters of the Black River

Instream Waste Concentration (IWC): 100%

Acute Mixing Zone Concentration: N/A

Dilution series: At least five effluent concentrations and dual controls must be included in each test.

- **Acute:** 100, 50, 25, 12.5, 6.25% and any additional selected by the permittee.
- **Chronic:** 100, 75, 50, 25, 12.5% (if the IWC >30%) and any additional selected by the permittee.

WET Testing Frequency:

Acute tests are required during the following quarters:

January – March 2025

July - September 2027

April - June 2029

Acute WET testing shall continue after the permit expiration date (until the permit is reissued) in accordance with the WET requirements specified for the last full calendar year of this permit. For example, the next test would be required in **April – June 2030**.

Chronic tests are required during the following quarters:

January – March 2025

April – June 2026

July – September 2027

October – December 2028

April – June 2029

Chronic WET testing shall continue after the permit expiration date (until the permit is reissued) in accordance with the WET requirements specified for the last full calendar year of this permit. For example, the next test would be required in **April – June 2030**.

Testing: WET testing shall be performed during normal operating conditions. Permittees are not allowed to turn off or otherwise modify treatment systems, production processes, or change other operating or treatment conditions during WET tests.

Reporting: The permittee shall report test results on the Discharge Monitoring Report form, and also complete the "Whole Effluent Toxicity Test Report Form" (Section 6, "*State of Wisconsin Aquatic Life Toxicity Testing Methods Manual, 2nd Edition*"), for each test. The original, complete, signed version of the Whole Effluent Toxicity Test Report Form shall be sent to the Biomonitoring Coordinator, Bureau of Water Quality, 101 S. Webster St., P.O. Box 7921, Madison, WI 53707-7921, within 45 days of test completion. The Discharge Monitoring Report (DMR) form shall be submitted electronically by the required deadline.

Determination of Positive Results: An acute toxicity test shall be considered positive if the Toxic Unit - Acute (TU_a) is greater than **1.0** for either species (fathead minnow (*Pimephales promelas*) and waterflea (*Ceriodaphnia dubia*)). The TU_a shall be calculated as follows: $TU_a = 100 \div LC_{50}$. A chronic toxicity test shall be considered positive if the Toxic Unit - Chronic (TU_c) is greater than **1.0** for either species. The TU_c shall be calculated as follows: $TU_c = 100 \div IC_{25}$.

Additional Testing Requirements: Within 90 days of a test which showed positive results, the permittee shall submit the results of at least 2 retests to the Biomonitoring Coordinator on "Whole Effluent Toxicity Test Report Forms". The 90-day reporting period shall begin the day after the test which showed a positive result. The retests shall be completed using the same species and test methods specified for the original test (see the Standard Requirements section herein).

3.2.1.8 Additives

The permittee shall maintain an additives log that includes: additive name, date(s) used, amount used, location in the facility where additives are introduced and duration of the physical addition in hours each day. This log shall be maintained on site and available to the Department upon request. In its application for permit reissuance, the permittee shall identify and provide usage rates for each additive that may be discharged to waters of the State. In the event that the permittee wishes to commence use of an additive that may be discharged to waters of the State or increase the usage rate of an additive greater than that indicated in the permit application, the permittee must notify the Department prior to initiating such a change and follow the procedures in Standard Requirements Additives section. The Department may modify the permit in accordance with s. 283.53, Stats, to impose restrictions on the use of the additive.

3.2.2 Sampling Point (Outfall) 002 - STORM WTR, BYPASS, REARING WTR

Monitoring Requirements and Effluent Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Daily	Continuous	
BOD ₅ , Total	Daily Max	40 mg/L	Monthly	Grab	
BOD ₅ , Total	Monthly Avg	20 mg/L	Monthly	Grab	
Suspended Solids, Total	Daily Max	40 mg/L	Monthly	Grab	
Suspended Solids, Total	Monthly Avg	20 mg/L	Monthly	Grab	
pH Field		su	Weekly	Grab	
Dissolved Oxygen		mg/L	Weekly	Grab	
Nitrogen, Ammonia (NH ₃ -N) Total		mg/L	Weekly	Grab	
Arsenic, Total Recoverable		µg/L	Quarterly	Grab	
Temperature Maximum		deg F	Daily	Continuous	See Temperature footnote below and Compliance Schedule Section.

Monitoring Requirements and Effluent Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Phosphorus, Total		mg/L	Weekly	Grab	Limits apply at Sample Point 005. See Phosphorus footnote below.

3.2.2.1 Effluent Temperature Monitoring

For monitoring temperature continuously, collect measurements in accordance with s. NR 218.04(13). This means that discrete measurements shall be recorded at intervals of not more than 15 minutes during the 24-hour period. Report the maximum temperature measured during the day on the DMR. For seasonal discharges collect measurements either manually or continuously during the period of operation and report the daily maximum effluent temperature on the DMR.

3.2.2.2 Effluent Temperature Limitations

Limits for Temperature, Maximum: The effluent limitations for “Temperature, Maximum” become effective on 12/31/2029 as specified in the Schedules section. Monitoring is required Daily upon permit reissuance. Daily maximum temperatures shall be reported so that applicable daily maximum limits can be compared to the reported daily maximum temperatures and applicable weekly average limits can be compared to the weekly averages of the reported daily maximum temperatures.

After submitting the Site-Specific Temperature Evaluation Report of the compliance schedule (due 12/31/2027), the permittee may request a re-evaluation of the limits based on NR 106 – ‘Subchapters V and VI Effluent Limitations for Temperature’ or NR 102.26 – Site Specific Ambient Temperature. If the re-calculation of limits results in revisions to the temperature limits, a permit modification will be required to include the revised limits in the permit.

Effluent Limitations for 'Temperature Maximum' (Effective per the Schedules section) for 002:

Month	Calculated Effluent Limit	
	Weekly Avg. Effluent Limit (°F)	Daily Max. Effluent Limit (°F)
JAN	60	
MAR	62	
APR	60	
MAY	69	
JUN	78	
JUL	82	89
AUG	81	
SEP	78	
OCT	66	
NOV	57	
DEC	59	

3.2.2.3 Phosphorus Monitoring and Limitations

Phosphorus monitoring is required weekly. Results shall be reported at this sample point on the eDMRs. However, phosphorus limitations apply and compliance will be determined at the combined sample point 005, which includes contributions of phosphorus from sample points 001 and 002. See sample point 005 for more information.

3.2.2.4 Additives

The permittee shall maintain an additives log that includes additive name, date(s) used, amount used, location in the facility where additives are introduced and duration of the physical addition in hours each day. This log shall be maintained on site and available to the Department upon request. In its application for permit reissuance, the permittee shall identify and provide usage rates for each additive that may be discharged to waters of the State. In the event that the permittee wishes to commence use of an additive that may be discharged to waters of the State or increase the usage rate of an additive greater than that indicated in the permit application, the permittee must notify the Department prior to initiating such a change and follow the procedures in Standard Requirements Additives section. The Department may modify the permit in accordance with s. 283.53, Stats, to impose restrictions on the use of the additive.

3.2.3 Sampling Point (Outfall) 005 - COMBINED OUTFALL 001 + 002

Monitoring Requirements and Effluent Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Daily	Calculated	
Phosphorus, Total	6-Month Avg	0.1 mg/L	Weekly	Calculated	Phosphorus compliance shall be determined by combing phosphorus results from Sample Points 001 and 002, with the calculated results reported for this sample point. See Phosphorus section below.
Phosphorus, Total	Monthly Avg	0.3 mg/L	Weekly	Calculated	Phosphorus compliance shall be determined by combing phosphorus results from Sample Points 001 and 002, with the calculated results reported for this sample point. See Phosphorus section below.
Phosphorus, Total	6-Month Avg	1.0 lbs/day	Weekly	Calculated	Phosphorus compliance shall be determined by combing phosphorus results from Sample Points 001 and 002, with the calculated results reported for this sample point. See Phosphorus section below.

3.2.3.1 Combined Phosphorus Monitoring and Limitations

Compliance for phosphorus shall be determined at this Sample Point 005. The permittee shall use the daily flow and sample results collected as Sample Points 001 and 002 to calculate the weekly flow-proportional concentration of phosphorus according to the following equation:

$$\frac{(\text{daily TP value At 001 (mg/L)} \times \text{daily flow at 001 (MGD)}) + (\text{daily TP value at 002 (mg/L)} \times \text{daily flow at 002 (MGD)})}{(\text{daily flow at 001 (MGD)} + \text{daily flow at 002 (MGD)})}$$

4 Land Application Requirements

4.1 Sampling Point(s)

The discharge(s) shall be limited to land application of the waste type(s) designated for the listed sampling point(s) on Department approved land spreading sites or by hauling to another facility.

Sampling Point Designation	
Sampling Point Number	Sampling Point Location, Waste Type/Sample Contents and Treatment Description (as applicable)
003	In the event of pond sludge removal, representative samples of sludge shall be collected per application from the large (stabilization) pond per the list below. In the event of pond sludge removal, the analysis shall be conducted prior to land application of the sludge. The permittee is required to submit form 3400-52 'Other Methods of Disposal or Distribution Report' and 'Land Application Report Form' 3400-55 by January 31 following each year the sludge is hauled.
004	In the event of pond sludge removal, representative samples of sludge shall be collected per application from the small (quiescent) pond per the list below, except once in 2026 for PFAS. In the event of pond sludge removal, the analysis shall be conducted prior to land application of the sludge. The permittee is required to submit form 3400-52 'Other Methods of Disposal or Distribution Report' and 'Land Application Report Form' 3400-55 by January 31 following each year the sludge is hauled.

4.2 Monitoring Requirements and Limitations

The permittee shall comply with the following monitoring requirements and limitations.

4.2.1 Sampling Point (Outfall) 003 - LARGE (STABILIZATION) POND

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Solids, Total		Percent	Per Application	Grab	
Nitrogen, Total Kjeldahl		Percent	Per Application	Grab	
Chloride		Percent	Per Application	Grab	
pH Field		su	Per Application	Grab	
Nitrogen, Ammonium (NH ₄ -N) Total		Percent	Per Application	Grab	
Phosphorus, Total		Percent	Per Application	Grab	
Phosphorus, Water Extractable		% of Tot P	Per Application	Grab	
Potassium, Total Recoverable		Percent	Per Application	Grab	

Daily Log – Monitoring Requirements and Limitations				
All discharge and monitoring activity shall be documented on log sheets. Originals of the log sheets shall be kept by the permittee as described under “Records Retention” in the Standard Requirements section, and if requested, made available to the Department.				
Parameters	Limit	Units	Sample Frequency	Sample Type
DNR Site Number(s)	-	Number	Daily	Log
Acres Applied	-	Acres	Daily	Log
Application Rate	-	Gal/Acre/Day	Daily	Calculated

Annual Report – Summary of Monitoring Requirements and Limitations				
The Annual Report is due by January 31 st of each year for the previous calendar year. See the ‘Annual Land Application Report’ subsection in Standard Requirements.				
Parameters	Limit	Units	Reporting Frequency	Sample Type
DNR Site Number(s)	-	Number	-	-
Acres Land Applied	-	Acres	Annual	-
Total Volume Per Site	-	Gallons	Annual	Total Annual
Total Kjeldahl Nitrogen per Site	165, or alternate approved in writing	Pounds/Acre/Year	Annual	Calculated
Total Chloride per Site	340	Pounds/Acre per 2 Years	Annual	Calculated

4.2.1.1 Annual Site Nitrogen Loading

For details on nitrogen loading requirements, including approval of an alternate nitrogen pounds/acre/year site loading, see the “Nitrogen Requirements for Liquid Wastes, By-Product Solids and Sludges” paragraph in the Standard Requirements section of this permit.

4.2.1.2 Biennial Site Chloride Loading

For details on chloride requirements see the “Chloride Requirements for Liquid Wastes and By-Product Solids” paragraph in the Standard Requirements section of this permit.

4.2.2 Sampling Point (Outfall) 004 - SMALL (QUIESCENT) POND

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Solids, Total		Percent	Per Application	Grab	

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Nitrogen, Total Kjeldahl		Percent	Per Application	Grab	
Chloride		Percent	Per Application	Grab	
pH Field		su	Per Application	Grab	
Nitrogen, Ammonium (NH ₄ -N) Total		Percent	Per Application	Grab	
Phosphorus, Total		Percent	Per Application	Grab	
Phosphorus, Water Extractable		% of Tot P	Per Application	Grab	
Potassium, Total Recoverable		Percent	Per Application	Grab	
PFOA + PFOS		µg/kg	Once	Calculated	Report the sum of PFOA and PFOS. See PFAS Permit Sections for more information.
PFAS Dry Wt			Once	Grab	Perfluoroalkyl and Polyfluoroalkyl Substances based on updated DNR PFAS List. See PFAS Permit Sections for more information.

Daily Log – Monitoring Requirements and Limitations				
All discharge and monitoring activity shall be documented on log sheets. Originals of the log sheets shall be kept by the permittee as described under “Records Retention” in the Standard Requirements section, and if requested, made available to the Department.				
Parameters	Limit	Units	Sample Frequency	Sample Type
DNR Site Number(s)	-	Number	Daily	Log
Acres Applied	-	Acres	Daily	Log
Application Rate	-	Gal/Acre/Day	Daily	Calculated

Annual Report – Summary of Monitoring Requirements and Limitations				
The Annual Report is due by January 31 st of each year for the previous calendar year. See the ‘Annual Land Application Report’ subsection in Standard Requirements.				
Parameters	Limit	Units	Reporting Frequency	Sample Type
DNR Site Number(s)	-	Number	-	-
Acres Land Applied	-	Acres	Annual	-
Total Volume Per Site	-	Gallons	Annual	Total Annual
Total Kjeldahl Nitrogen per Site	165, or alternate approved in writing	Pounds/Acre/Year	Annual	Calculated
Total Chloride per Site	340	Pounds/Acre per 2 Years	Annual	Calculated

4.2.2.1 Annual Site Nitrogen Loading

For details on nitrogen loading requirements, including approval of an alternate nitrogen pounds/acre/year site loading, see the “Nitrogen Requirements for Liquid Wastes, By-Product Solids and Sludges” paragraph in the Standard Requirements section of this permit.

4.2.2.2 Biennial Site Chloride Loading

For details on chloride requirements see the “Chloride Requirements for Liquid Wastes and By-Product Solids” paragraph in the Standard Requirements section of this permit.

4.2.2.3 Sludge Monitoring for PFAS

Sampling shall occur for perfluoroalkyl and polyfluoroalkyl compounds (PFAS) listed in the table below and as indicated in sampling point sections above. Monitoring shall occur at each sample point when sludge is generated regardless of the end use (i.e. land applied, hauled to another facility, landfilled).

PERFLUOROALKYLCARBOXYLIC Acids (PFCAs)	
PFBA	Perfluorobutanoic acid
PFPeA	Perfluroropentanoic acid
PFHxA	Perfluorohexanoic acid
PFHpA	Perfluoroheptanoic acid
PFOA	Perfluorooctanoic acid
PFNA	Perfluorononanoic acid
PFDA	Perfluorodecanoic acid
PFUnA	Perfluroroundecanoic acid
PFDoA	Perfluorododecanoic acid
PFTriA	Perfluorotridecanoic acid
PFTeDA	Perfluorotetradecanoic acid
PERFLUOROALKYLSULFONIC Acids (PFSAs)	
PFBS	Perfluorobutane sulfonic acid
PFPeS	Perfluroropentane sulfonic acid

PFHxS	Perfluorohexane sulfonic acid
PFHpS	Perfluoroheptane sulfonic acid
PFOS	Perfluorooctane sulfonic acid
PFNS	Perfluorononane sulfonic acid
PFDS	Perfluorodecane sulfonic acid
PFDoS	Perfluorododecane sulfonic acid
TELOMER SULFONIC Acids	
4:2 FTSA	4:2 fluorotelomersulfonic acid
6:2 FTSA	6:2 fluorotelomersulfonic acid
8:2 FTSA	8:2 fluorotelomersulfonic acid
PERFLUOROOCETANESULFONAMIDES (FOSAs)	
PFOSA	Perfluorooctane sulfonamide
N-MeFOSA	N-Methyl perfluorooctane sulfonamide
N-EtFOSA	N-Ethyl perfluorooctane sulfonamide
PERFLUOROOCETANESULFONAMIDOACETIC Acids	
N-MeFOSAA	N-Methyl perfluorooctane sulfonamidoacetic acid
N-EtFOSAA	N-Ethyl perfluorooctane sulfonamidoacetic acid
NATIVE PERFLUOROOCETANESULFONAMIDOETHANOLS (FOSEs)	
N-MeFOSE	N-Methyl perfluorooctane sulfonamidoethanol
N-EtFOSE	N-Ethyl perfluorooctane sulfonamidoethanol
PERFLUOROALKYLETHERCARBOXYLIC Acids (PFECAs)	
HFPO-DA	Hexafluoropropylene oxide dimer acid
DONA	4,8-dioxa-3H-perfluorononanoic acid
CHLORO-PERFLUOROALKYLSULFONATE	
F-53B Major	9-chlorohexadecafluoro-3-oxanone-1-sulfonic acid
F-53B Minor	11-chloroelcosafluoro-3-oxaundecane-1-sulfonic acid

Note: If WDNR Lab Certification removes a particular compound from the reporting list above and upon receiving written communication from the department, reporting for that compound is no longer required.

4.2.2.4 Sampling and Reporting Sludge Samples for PFAS

Representative sludge samples shall be collected at each sample point as listed.

Note: If additional equipment is used for collecting sludge samples (i.e., shovels, compositing buckets, bottles, etc.), then a one-time equipment blank is recommended to be collected with the first sample. An equipment blank sample is collected by passing laboratory verified PFAS-free water over or through field sampling equipment before the collection of a representative sludge sample. The equipment blank result shall be reported on the annual Sludge Characteristics Form (3400-049) in the comment section when reporting PFAS concentrations in the sludge.

The permittee shall report each of the PFAS sludge monitoring results on the annual Sludge Characteristics and Monitoring Form (3400-049) as provided by the department. The permittee shall also report the summation of PFOS and PFOA on this same form. All results shall be reported in dry weight. The annual Sludge Characteristics and Monitoring Form (3400-049) are due January 31, of the year following the collection of the sludge samples.

The laboratory performing the analysis on any samples shall be certified for the applicable PFAS compounds in the solids matrix by the Wisconsin Laboratory Certification Program established under s. 299.11, Wis. Stats., and in accordance with s. NR 149.41, Wis. Adm. Code. If the EPA Office of Water publishes a 1600 series isotope dilution method for the analysis of PFAS in solids, the department recommends the use of the EPA method. The department

may reject any sample results if results are produced by a laboratory that is not in compliance with certification requirements under ch. NR 149, Wis. Adm. Code.

4.2.2.5 PFAS Land Application Requirements

The department recommends the landspreading and/or land application of sludge be done in a manner consistent with the most recent version of the “Interim Strategy for Land Application of Biosolids and Industrial Sludges containing PFAS”.

5 Schedules

5.1 Temperature Compliance Schedule

The compliance schedule applies to both sample points 001 and 002 temperature limitations.

Required Action	Due Date
Study Plan: Submit a study plan for approval for collecting data for site specific ambient temperature data. The plan should include information on proposed sample locations, frequency of data collection, and methods used to record and collect data.	06/30/2025
Implement Plan: Start collecting data for site specific ambient temperature per the approved study plan.	09/30/2025
Progress Report #1: Submit a progress report on the implementation of the temperature study plan. The progress report shall include sample locations, sample dates and times, recorded results, along with a summary of any challenges encountered and proposed modifications to the study plan, if applicable.	06/30/2026
Progress Report #2: Submit a progress report on the implementation of the temperature study plan. The progress report shall include sample locations, sample dates and times, recorded results, along with a summary of any challenges encountered and proposed modifications to the study plan, if applicable.	03/31/2027
Site-Specific Temperature Evaluation Report: Submit a report with at least 2 years of data and other requirements of s. NR 102.26(1) Wis. Adm. Code or other means of compliance if applicable.	12/31/2027
Action Plan: Submit an action plan for complying with the effluent limitations. If construction is required, include plans and specifications with submittal.	12/31/2028
Complete Actions and Achieve Compliance: Complete actions necessary to achieve compliance with effluent temperature limitations at sample points 001 and 002.	12/31/2029

5.2 PFOS/PFOA Minimization Plan Determination of Need

Required Action	Due Date
Report on Effluent Discharge: Submit a report on effluent PFOS and PFOA concentrations and include an analysis of trends in monthly and annual average PFOS and PFOA concentrations. This analysis should also include a comparison to the applicable narrative standard in s. NR 102.04(8)(d), Wis. Adm. Code. This report shall include all additional PFOS and PFOA data that may be collected including any influent, intake, in-plant, collection system sampling, and blank sample results. Please submit the laboratory analysis sheets with the report.	12/31/2025
Report on Effluent Discharge and Evaluation of Need: Submit a final report on effluent PFOS and PFOA concentrations and include an analysis of trends in monthly and annual average PFOS and PFOA concentrations of data collected over the last 24 months. Please submit the laboratory analysis sheets with the report. The report shall also provide a comparison on the likelihood of the facility needing to develop a PFOS/PFOA minimization plan.	12/31/2026

<p>This report shall include all additional PFOS and PFOA data that may be collected including any influent, intake, in-plant, collection system sampling, and blank sample results.</p> <p>The permittee shall also submit a request to the department to evaluate the need for a PFOS/PFOA minimization plan.</p> <p>If the Department determines a PFOS/PFOA minimization plan is needed based on a reasonable potential evaluation, the permittee will be required to develop a minimization plan for Department approval no later than 90 days after written notification was sent from the Department. The Department will modify or revoke and reissue the permit to include PFOS/PFOA minimization plan reporting requirements along with a schedule of compliance to meet WQBELs. Effluent monitoring of PFOS and PFOA shall continue as specified in the permit until the modified permit is issued.</p> <p>If, however, the Department determines there is no reasonable potential for the facility to discharge PFOS or PFOA above the narrative standard in s. NR 102.04(8)(d), Wis. Adm. Code, no further action is required and effluent monitoring of PFOS and PFOA shall continue as specified in the permit.</p>	
--	--

5.3 Land Application Management Plan

A management plan is required for the land application system.

Required Action	Due Date
<p>Land Application Management Plan Submittal: The permittee shall submit management plan for approval if removal of sludge will occur during this permit term. The plan shall demonstrate compliance with ch. NR 214 Wis. Adm. Code and at minimum address 1) How and where is sludge sampled; 2) Available sludge storage details and location(s); 3) How will the sludge be removed with details on volume, characterization and how will the treatment plant continue to function during the drawdown; 4) Describe the type of transportation and spreading vehicles and loading and unloading practices; 5) Identify approved land application sites, apply for needed sites, site limitations, total acres needed and vegetative cover management; 6) Specify record keeping procedures including site loading; 7) Address contingency plans for adverse weather and odor/nuisance abatement; and 8) Include any other pertinent information such as other disposal options that may be used or specifications of any pretreatment processes</p> <p>Once approved, all sludge management activities shall be conducted in accordance with the plan. Any changes to the plan must be approved by the Department prior to implementing the changes. No desludging may occur unless approval from the Department is obtained. Daily logs shall be kept that record where the sludge has been disposed.</p> <p>The plan is due at least 60 days prior to desludging.</p>	

6 Standard Requirements

Chapter NR 205, Wisconsin Administrative Code (Conditions for Industrial Dischargers): The conditions in ss. NR 205.07(1) and NR 205.07(3), Wis. Adm. Code, are included by reference in this permit. The permittee shall comply with all of these requirements. Some of these requirements are outlined in the Standard Requirements section of this permit. Requirements not specifically outlined in the Standard Requirement section of this permit can be found in ss. NR 205.07(1) and NR 205.07(3), Wis. Adm. Code.

6.1 Reporting and Monitoring Requirements

6.1.1 Monitoring Results

Monitoring results obtained during the previous month shall be summarized and reported on a Department Wastewater Discharge Monitoring Report. The report may require reporting of any or all of the information specified below under 'Recording of Results'. This report is to be returned to the Department no later than the date indicated on the form. A copy of the Wastewater Discharge Monitoring Report Form or an electronic file of the report shall be retained by the permittee.

Monitoring results shall be reported on an electronic discharge monitoring report (eDMR). The eDMR shall be certified electronically by a responsible executive or officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The 'eReport Certify' page certifies that the electronic report form is true, accurate and complete.

If the permittee monitors any pollutant more frequently than required by this permit, the results of such monitoring shall be included on the Wastewater Discharge Monitoring Report.

The permittee shall comply with all limits for each parameter regardless of monitoring frequency. For example, monthly, weekly, and/or daily limits shall be met even with monthly monitoring. The permittee may monitor more frequently than required for any parameter.

6.1.2 Sampling and Testing Procedures

Sampling and laboratory testing procedures shall be performed in accordance with Chapters NR 218 and NR 219, Wis. Adm. Code, and completed by a laboratory certified or registered in accordance with the requirements of ch. NR 149, Wis. Adm. Code. Groundwater sampling shall be performed in accordance with procedures contained in s. NR 140.16, Wis. Adm. Code, and the WDNR publications, Groundwater Sampling Desk Reference (PUBL-DG-037-96) and Groundwater Sampling Field Manual (PUBL-DG-038-96). The analytical methodologies used shall enable the laboratory to quantitate all substances for which monitoring is required at levels below the effluent limitation and/or groundwater standard. If the required level cannot be met by any of the methods available in ch. NR 219, Wis. Adm. Code, then the method with the lowest limit of detection shall be selected. Additional test procedures may be specified in this permit.

6.1.3 Recording of Results

The permittee shall maintain records which provide the following information for each effluent measurement or sample taken:

- the date, exact place, method and time of sampling or measurements;
- the individual who performed the sampling or measurements;
- the date the analysis was performed;
- the individual who performed the analysis;
- the analytical techniques or methods used; and
- the results of the analysis.

6.1.4 Reporting of Monitoring Results

The permittee shall use the following conventions when reporting effluent monitoring results:

- Pollutant concentrations less than the limit of detection shall be reported as < (less than) the value of the limit of detection. For example, if a substance is not detected at a detection limit of 0.1 mg/L, report the pollutant concentration as < 0.1 mg/L.
- Pollutant concentrations equal to or greater than the limit of detection, but less than the limit of quantitation, shall be reported and the limit of quantitation shall be specified.
- For purposes of calculating fees under ch. NR 101, Wis. Adm. Code, a reporting limit of 2.0 mg/L for BOD₅ and 2.5 mg/L Total Suspended Solids shall be considered to be limits of quantitation.
- For the purposes of reporting a calculated result, average or a mass discharge value, the permittee may substitute a “0” (zero) for any pollutant concentration that is less than the limit of detection. However, if the effluent limitation is less than the limit of detection, the department may substitute a value other than zero for results less than the limit of detection, after considering the number of monitoring results that are greater than the limit of detection and if warranted when applying appropriate statistical techniques.
- If no discharge occurs through an outfall, flow related parameters (e.g. flow rate, hydraulic application rate, volume, etc.) should be reported as “0” (zero) at the required sample frequency specified for the outfall. For example: if the sample frequency is daily, “0” would be reported for any day during the month that no discharge occurred.

6.1.5 Records Retention

The permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings or electronic data records for continuous monitoring instrumentation, copies of all reports required by the permit, and records of all data used to complete the application for the permit for a period of at least 3 years from the date of the sample, measurement, report or application, except for sludge management forms and records, which shall be kept for a period of at least 5 years.

6.1.6 Other Information

Where the permittee becomes aware that it failed to submit any relevant facts in a permit application or submitted incorrect information in a permit application or in any report to the Department, it shall promptly submit such facts or correct information to the Department.

6.1.7 Reporting Requirements – Alterations or Additions

The permittee shall give notice to the Department as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is only required when:

- The alteration or addition to the permitted facility may meet one of the criteria for determining whether a facility is a new source.
- The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification requirement applies to pollutants which are not subject to effluent limitations in the existing permit.
- The alteration or addition results in a significant change in the permittee’s sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use of disposal sites not reported during the permit application process nor reported pursuant to an approved land application plan. Additional sites may not be used for the land application of sludge until department approval is received.

6.2 System Operating Requirements

6.2.1 Noncompliance Reporting

The permittee shall report the following types of noncompliance by a telephone call to the Department's regional office within 24 hours after becoming aware of the noncompliance:

- any noncompliance which may endanger health or the environment;
- any violation of an effluent limitation resulting from a bypass;
- any violation of an effluent limitation resulting from an upset; and
- any violation of a maximum discharge limitation for any of the pollutants listed by the Department in the permit, either for effluent or sludge.

A written report describing the noncompliance shall also be submitted to the Department as directed at the end of this permit within 5 days after the permittee becomes aware of the noncompliance. On a case-by-case basis, the Department may waive the requirement for submittal of a written report within 5 days and instruct the permittee to submit the written report with the next regularly scheduled monitoring report. In either case, the written report shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times; the steps taken or planned to reduce, eliminate and prevent reoccurrence of the noncompliance; and if the noncompliance has not been corrected, the length of time it is expected to continue.

A scheduled bypass approved by the Department under the 'Scheduled Bypass' section of this permit shall not be subject to the reporting required under this section.

NOTE: Section 292.11(2)(a), Wisconsin Statutes, requires any person who possesses or controls a hazardous substance or who causes the discharge of a hazardous substance to notify the Department of Natural Resources **immediately** of any discharge not authorized by the permit. **The discharge of a hazardous substance that is not authorized by this permit or that violates this permit may be a hazardous substance spill. To report a hazardous substance spill, call DNR's 24-hour HOTLINE at 1-800-943-0003.**

6.2.2 Bypass

Except for a controlled diversion as provided in the 'Controlled Diversions' section of this permit, any bypass is prohibited and the Department may take enforcement action against a permittee for such occurrences under s. 283.89, Wis. Stats. The Department may approve a bypass if the permittee demonstrates all the following conditions apply:

- The bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
- There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities or adequate back-up equipment, retention of untreated wastes, reduction of inflow and infiltration, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance. When evaluating feasibility of alternatives, the department may consider factors such as technical achievability, costs and affordability of implementation and risks to public health, the environment and, where the permittee is a municipality, the welfare of the community served; and
- The bypass was reported in accordance with the 'Noncompliance Reporting' section of this permit.

6.2.3 Scheduled Bypass

Whenever the permittee anticipates the need to bypass for purposes of efficient operations and maintenance and the permittee may not meet the conditions for controlled diversions in the 'Controlled Diversions' section of this permit, the permittee shall obtain prior written approval from the Department for the scheduled bypass. A permittee's written request for Department approval of a scheduled bypass shall demonstrate that the conditions for unscheduled bypassing are met and include the proposed date and reason for the bypass, estimated volume and duration of the bypass, alternatives to bypassing and measures to mitigate environmental harm caused by the bypass. The department may require the permittee to provide public notification for a scheduled bypass if it is determined there is significant public interest in the proposed action and may recommend mitigation measures to minimize the impact of such bypass.

6.2.4 Controlled Diversions

Controlled diversions are allowed only when necessary for essential maintenance to assure efficient operation provided the following requirements are met:

- Effluent from the wastewater treatment facility shall meet the effluent limitations established in the permit. Wastewater that is diverted around a treatment unit or treatment process during a controlled diversion shall be recombined with wastewater that is not diverted prior to the effluent sampling location and prior to effluent discharge;
- A controlled diversion may not occur during periods of excessive flow or other abnormal wastewater characteristics;
- A controlled diversion may not result in a wastewater treatment facility overflow; and
- All instances of controlled diversions shall be documented in wastewater treatment facility records and such records shall be available to the department on request.

6.2.5 Ammonia Limit Not Needed - Continue to Optimize Removal of Ammonia

Applying the procedures in s. NR 106.05, Wis. Adm. Code, to ammonia data that is representative of the current operations of the wastewater treatment plant resulted in a determination that ammonia effluent limits are not necessary in this permit. Pursuant to NR 106.33, throughout the term of this permit, the wastewater treatment plant shall continue to be operated in a manner that optimizes the removal of ammonia within the design capabilities of the wastewater treatment plant.

6.2.6 Proper Operation and Maintenance

The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance includes effective performance, adequate funding, adequate operator staffing and training as required in ch. NR 114, Wis. Adm. Code, and adequate laboratory and process controls, including appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems only when necessary to achieve compliance with the conditions of the permit.

6.2.7 Operator Certification

The wastewater treatment facility shall be under the direct supervision of a state certified operator. In accordance with s. NR 114.53, Wis. Adm. Code, every WPDES permitted treatment plant shall have a designated operator-in-charge holding a current and valid certificate. The designated operator-in-charge shall be certified at the level and in all subclasses of the treatment plant, except laboratory. Treatment plant owners shall notify the department of any changes in the operator-in-charge within 30 days. Note that s. NR 114.52(22), Wis. Adm. Code, lists types of facilities that are excluded from operator certification requirements (i.e. private sewage systems, pretreatment facilities discharging to public sewers, industrial wastewater treatment that consists solely of land disposal, agricultural digesters and concentrated aquatic production facilities with no biological treatment).

6.2.8 Spill Reporting

The permittee shall notify the Department in accordance with ch. NR 706 (formerly NR 158), Wis. Adm. Code, in the event that a spill or accidental release of any material or substance results in the discharge of pollutants to the waters of the state at a rate or concentration greater than the effluent limitations established in this permit, or the spill or accidental release of the material is unregulated in this permit, unless the spill or release of pollutants has been reported to the Department in accordance with s. NR 205.07 (1)(s), Wis. Adm. Code.

6.2.9 Planned Changes

In accordance with ss. 283.31(4)(b) and 283.59, Stats., the permittee shall report to the Department any facility expansion, production increase or process modifications which will result in new, different or increased discharges of

pollutants. The report shall either be a new permit application, or if the new discharge will not violate the effluent limitations of this permit, a written notice of the new, different or increased discharge. The notice shall contain a description of the new activities, an estimate of the new, different or increased discharge of pollutants and a description of the effect of the new or increased discharge on existing waste treatment facilities. Following receipt of this report, the Department may modify this permit to specify and limit any pollutants not previously regulated in the permit.

6.2.10 Duty to Halt or Reduce Activity

Upon failure or impairment of treatment facility operation, the permittee shall, to the extent necessary to maintain compliance with its permit, curtail production or wastewater discharges or both until the treatment facility operations are restored or an alternative method of treatment is provided.

6.3 Surface Water Requirements

6.3.1 Permittee-Determined Limit of Quantitation Incorporated into this Permit

For pollutants with water quality-based effluent limits below the Limit of Quantitation (LOQ) in this permit, the LOQ calculated by the permittee and reported on the Discharge Monitoring Reports (DMRs) is incorporated by reference into this permit. The LOQ shall be reported on the DMRs, shall be the lowest quantifiable level practicable, and shall be no greater than the minimum level (ML) specified in or approved under 40 CFR Part 136 for the pollutant at the time this permit was issued, unless this permit specifies a higher LOQ.

6.3.2 Appropriate Formulas for Effluent Calculations

The permittee shall use the following formulas for calculating effluent results to determine compliance with average concentration limits and mass limits and total load limits:

Weekly/Monthly/Six-Month/Annual Average Concentration = the sum of all daily results for that week/month/six-month/year, divided by the number of results during that time period. [Note: When a six-month average effluent limit is specified for Total Phosphorus the applicable periods are May through October and November through April, except in cases of Water Quality Trading, wherein the applicable periods are January through June and July through December.]

Weekly Average Mass Discharge (lbs/day): Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the week.

Monthly Average Mass Discharge (lbs/day): Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the month.

Six-Month Average Mass Discharge (lbs/day): Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the six-month period. [Note: When a six-month average effluent limit is specified for Total Phosphorus the applicable periods are May through October and November through April.]

Annual Average Mass Discharge (lbs/day): Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the entire year.

Total Monthly Discharge: = monthly average concentration (mg/L) x total flow for the month (MG/month) x 8.34.

Total Annual Discharge: = sum of total monthly discharges for the calendar year.

12-Month Rolling Sum of Total Monthly Discharge: = the sum of the most recent 12 consecutive months of Total Monthly Discharges.

6.3.3 Effluent Temperature Requirements

Weekly Average Temperature – If temperature limits are included in this permit, Weekly Average Temperature shall be calculated as the sum of all daily maximum results for that week divided by the number of daily maximum results during that time period.

Cold Shock Standard – Water temperatures of the discharge shall be controlled in a manner as to protect fish and aquatic life uses from the deleterious effects of cold shock pursuant to Wis. Adm. Code, s. NR 102.28. ‘Cold Shock’ means exposure of aquatic organisms to a rapid decrease in temperature and a sustained exposure to low temperature that induces abnormal behavior or physiological performance and may lead to death.

Rate of Temperature Change Standard – Temperature of a water of the state or discharge to a water of the state may not be artificially raised or lowered at such a rate that it causes detrimental health or reproductive effects to fish or aquatic life of the water of the state pursuant to Wis. Adm. Code, s. NR 102.29.

6.3.4 Visible Foam or Floating Solids

There shall be no discharge of floating solids or visible foam in other than trace amounts.

6.3.5 Surface Water Uses and Criteria

In accordance with NR 102.04, Wis. Adm. Code, surface water uses and criteria are established to govern water management decisions. Practices attributable to municipal, industrial, commercial, domestic, agricultural, land development or other activities shall be controlled so that all surface waters including the mixing zone meet the following conditions at all times and under all flow and water level conditions:

- a) Substances that will cause objectionable deposits on the shore or in the bed of a body of water, shall not be present in such amounts as to interfere with public rights in waters of the state.
- b) Floating or submerged debris, oil, scum or other material shall not be present in such amounts as to interfere with public rights in waters of the state.
- c) Materials producing color, odor, taste or unsightliness shall not be present in such amounts as to interfere with public rights in waters of the state.
- d) Substances in concentrations or in combinations which are toxic or harmful to humans shall not be present in amounts found to be of public health significance, nor shall substances be present in amounts which are acutely harmful to animal, plant or aquatic life.

6.3.6 Compliance with Phosphorus Limitation

Compliance with the concentration limitation for phosphorus shall be determined as a rolling twelve-month average and shall be calculated as follows:

First, determine the pounds of phosphorus for an individual month by multiplying the average of all the concentration values for phosphorus (in mg/L) for that month by the total flow for the month in Million Gallons times the conversion factor of 8.34.

Then, the monthly pounds of phosphorus determined in this manner shall be summed for the most recent 12 months and inserted into the numerator of the following equation.

$$\text{Average concentration of P in mg/L} = \frac{\text{Total lbs of P discharged (most recent 12 months)}}{\text{Total flow in MG (most recent 12 months) X 8.34}}$$

The compliance calculation shall be performed each month with a reported discharge volume after substituting data from the most recent month(s) for the oldest month(s). A calculated value in excess of the concentration limitation will be considered equivalent to a violation of a monthly average.

6.3.7 Additives

In the event that the permittee wishes to commence use of a water treatment additive, or increase the usage of the additives greater than indicated in the permit application, the permittee must get a written approval from the Department prior to initiating such changes. This written approval shall provide authority to utilize the additives at the specific rates until the permit can be either reissued or modified in accordance with s. 283.53, Stats. Restrictions on the use of the additives may be included in the authorization letter.

6.3.8 Whole Effluent Toxicity (WET) Monitoring Requirements

In order to determine the potential impact of the discharge on aquatic organisms, static-renewal toxicity tests shall be performed on the effluent in accordance with the procedures specified in the *"State of Wisconsin Aquatic Life Toxicity Testing Methods Manual, 2nd Edition"* (PUB-WT-797, November 2004) as required by NR 219.04, Table A, Wis. Adm. Code). All of the WET tests required in this permit, including any required retests, shall be conducted on the *Ceriodaphnia dubia* and fathead minnow species. Receiving water samples shall not be collected from any point in contact with the permittee's mixing zone and every attempt shall be made to avoid contact with any other discharge's mixing zone.

6.3.9 Whole Effluent Toxicity (WET) Identification and Reduction

Within 60 days of a retest which showed positive results, the permittee shall submit a written report to the Biomonitoring Coordinator, Bureau of Water Quality, 101 S. Webster St., PO Box 7921, Madison, WI 53707-7921, which details the following:

- A description of actions the permittee has taken or will take to remove toxicity and to prevent the recurrence of toxicity;
- A description of toxicity reduction evaluation (TRE) investigations that have been or will be done to identify potential sources of toxicity, including the following actions:
 - a) Evaluate the performance of the treatment system to identify deficiencies contributing to effluent toxicity (e.g., operational problems, chemical additives, incomplete treatment)
 - b) Identify the compound(s) causing toxicity. Conduct toxicity screening tests on the effluent at a minimum of once per month for six months to determine if toxicity recurs. Screening tests are WET tests using fewer effluent concentrations conducted on the most sensitive species. If any of the screening tests contain toxicity, conduct a toxicity identification evaluation (TIE) to determine the cause. TIE methods are available from USEPA "Methods for Aquatic Toxicity Identification Evaluations: Phase I Toxicity Characterization Procedures (EPA/600/6-91/003) and "Toxicity Identification Evaluation: Characterization of Chronically Toxic Effluents, Phase I" (EPA/600/6-91/005F).
 - c) Trace the compound(s) causing toxicity to their sources (e.g., industrial, commercial, domestic)
 - d) Evaluate, select, and implement methods or technologies to control effluent toxicity (e.g., in-plant or pretreatment controls, source reduction or removal)
- Where corrective actions including a TRE have not been completed, an expeditious schedule under which corrective actions will be implemented;
- If no actions have been taken, the reason for not taking action.

The permittee may also request approval from the Department to postpone additional retests in order to investigate the source(s) of toxicity. Postponed retests must be completed after toxicity is believed to have been removed.

6.4 Land Application Requirements

6.4.1 General Sludge Management Information

The General Sludge Management Form 3400-48 shall be completed and submitted prior to any significant sludge management changes.

6.4.2 Land Application Characteristic Report

The analytical results from testing of liquid wastes, by-product solids and sludges that are land applied shall be reported annually on the Characteristic Report Form 3400-49. The report form shall be submitted electronically no later than the date indicated on the form. Following submittal of the electronic Characteristic Report Form 3400-49, this form shall be certified electronically via the 'eReport Certify' page by a responsible executive officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The 'eReport Certify' page certifies that the electronic report form is true, accurate and complete.

The permittee shall use the following convention when reporting sludge monitoring results: Pollutant concentrations less than the limit of detection shall be reported as < (less than) the value of the limit of detection. For example, if a substance is not detected at a detection limit of 1.0 mg/kg, report the pollutant concentration as < 1.0 mg/kg.

All sludge results shall be reported on a dry weight basis.

6.4.3 Annual Land Application Report

The annual totals for the land application loadings of liquid wastes, by-product solids and sludges to field spreading sites shall be submitted electronically on the Annual Land Application Report Form 3400-55 by January 31, each year whether or not waste is land applied. Following submittal of the electronic Annual Land Application Report Form 3400-55, this form shall be certified electronically via the 'eReport Certify' page by a responsible executive officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The 'eReport Certify' page certifies that the electronic report form is true, accurate and complete.

6.4.4 Other Methods of Disposal or Distribution Report

The permittee shall submit electronically the Other Methods of Disposal or Distribution Report Form 3400-52 by January 31, each year whether or not waste is hauled to another facility, landfilled, incinerated, or stored in a manure pit. Following submittal of the electronic Report Form 3400-52, this form shall be certified electronically via the 'eReport Certify' page by a responsible executive officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The 'eReport Certify' page certifies that the electronic report form is true, accurate and complete.

6.4.5 Land Application Site Approval

The permittee is authorized to landspread permitted liquid wastes, by-product solids and sludges on sites approved in writing by the Department in accordance with ss. NR 214.17(2) and 214.18(2), Wis. Adm. Code. Any site use restrictions or granting of case-by-case exceptions shall be identified in the approval letter. If the permittee wishes to have approval for additional sites, application shall be made using Land Application Site Request Form 3400-053. Complete information shall be submitted about each site, including location maps and soil maps, any soil analyses results and other information showing that the site complies with all application requirements and permit conditions. Spreading on a site may commence upon receipt of Department approval. If an existing spreading site is found by the Department to be environmentally unacceptable, a written notice will be issued to withdraw approval of that site.

6.4.6 Operating Requirements/Management Plan

All land application sites used for treatment of liquid wastes, by-product solids and sludges shall be operated in accordance with a Department approved management plan. The management plan shall be consistent with the requirements of this permit, ss. NR 214.17 (3) and (6), and NR 214.18 (3) and (6), Wis. Adm. Code. If operational changes are needed, the land application management plan shall be amended by submitting a written request to the

Department for approval. A land application management plan shall be submitted for approval at least 60 days prior to land application.

6.4.7 Chloride Requirements for Liquid Wastes and By-Product Solids

The total pounds of chloride applied shall be limited to 340 pounds per acre per 2 year period. Calculate the chloride loading as follows:

$$\text{Wet Weight Solids: } \frac{\text{lbs of solids} \times \% \text{solids} \times \% \text{chloride}}{\text{acres land applied} \times 100 \times 100} = \text{lbs chloride/acre}$$

$$\text{Liquid: } \frac{\text{mg/L chloride} \times (\text{millions of gallons}) \times 8.34}{\text{acres land applied}} = \text{lbs chloride/acre}$$

6.4.8 Nitrogen Requirements for Liquid Wastes and By-Product Solids and Sludges

NR 214.17(4) and NR 214.18(4) Wis. Adm. Code specify that the total pounds of nitrogen land applied per acre per year shall be limited to the nitrogen needs of the cover crop minus any other nitrogen added to the land application site, including fertilizer or manure. Nitrogen applied can be calculated on the basis of plant available nitrogen, as long as the release of nitrogen from the organic material is credited to future years. This permit requires that the Total Kjeldahl Nitrogen calendar year application amount shall not exceed 165 pounds per acre per year, except when alternate numerical nitrogen loading limits (consistent with the above sections of NR 214) are approved in writing via the Department's land application management plan approval. Calculate nitrogen loading as follows ("TKN" represents "Total Kjeldahl Nitrogen"):

$$\text{Wet Weight Solids and Sludges: } \frac{\text{lbs of solids} \times \% \text{solids} \times \% \text{TKN}}{\text{acres land applied} \times 100 \times 100} = \text{lbs TKN/acre}$$

$$\text{Liquid: } \frac{\text{mg/L TKN} \times (\text{millions of gallons}) \times 8.34}{\text{acres land applied}} = \text{lbs TKN/acre}$$

6.4.9 Ponding

The volume of liquid wastes land applied shall be limited to prevent ponding, except for temporary conditions following rainfall events. If ponding occurs all land application shall cease immediately. The permittee shall land apply only the liquid wastes that are permitted.

6.4.10 Runoff

The volume of liquid wastes land applied shall be limited to prevent runoff. If runoff occurs all land application shall cease immediately. The permittee shall land apply only the liquid wastes that are permitted.

6.4.11 Soil Incorporation Requirements

- **Liquid Sludge Requirements:** The Department may require that liquid sludge be incorporated into the soil on specific land application sites when necessary to prevent surface runoff or objectionable odors. Requirements and procedures for incorporation of liquid sludge, when such incorporation may be necessary, shall be specified in the management plan or in specific site applications, subject to Department approval. The permittee shall comply with the requirements in the Department approved management plan, specific site-approval requirements and the terms and conditions of this permit.
- **Cake Sludge Requirements:** After land application, cake sludge shall be incorporated into the soil. The timing of such incorporation and other related requirements and procedures shall be specified in the management plan or in specific site applications, subject to Department approval. The permittee shall comply with the

requirements in the Department approved management plan, specific site-approval requirements and the terms and conditions of this permit.

- **Liquid Wastewater Requirements:** The Department may require that liquid wastewater be incorporated or injected into the soil on specific land application sites when necessary to prevent surface runoff or objectionable odors. Requirements and procedures for injection or incorporation of liquid wastewater, when such injection or incorporation is necessary, shall be specified in the management plan or in specific site applications, subject to Department approval. The permittee shall comply with the requirements in the Department approved management plan, specific site-approval requirements and the terms and conditions of this permit.
- **By-Product Solids Requirements:** The Department may limit the volume of by-products solids that are landspread on a specific site when necessary to prevent surface runoff or leaching of contaminants to groundwater and objectionable odors. By-product solids shall, after application, be plowed, disced, or otherwise incorporated into the soil. Requirements and procedures for the incorporation of byproduct solids into the soil shall be specified in the management plan or in specific site applications, subject to Department approval. The permittee shall comply with the requirements in the Department approved management plan, specific site-approval requirements and the terms and conditions of this permit.

6.4.12 Field Stockpiles

The permittee is encouraged to landspread the by-product solids or sludges as they are transported to the fields; but if it becomes necessary to stockpile solids in the fields, the stockpiles shall be spread within 72 hours or as specified in the approved management plan.

6.4.13 Additional Requirements from ch. NR 214, Wis. Adm. Code

The requirements of s. NR 214.17 (4)(c) [pathogen prohibition for human consumption crop fields], (4)(d)1 [no adverse soil effects], (4)(d)10 [allowable whey spreading rates], and (4)(e)1-3 [by-product solids spreading within agricultural practices and not cause contamination] for landspreading of liquid wastes and by product solids and s. NR 214.18 (4)(b),(d)-(h) [application, nutrient, pH, metals, and PCB limitations] for sludge spreading systems are included by reference in this permit. The permittee shall comply with these requirements.

7 Summary of Reports Due

FOR INFORMATIONAL PURPOSES ONLY

Description	Date	Page
Temperature Compliance Schedule -Study Plan	June 30, 2025	16
Temperature Compliance Schedule -Implement Plan	September 30, 2025	16
Temperature Compliance Schedule -Progress Report #1	June 30, 2026	16
Temperature Compliance Schedule -Progress Report #2	March 31, 2027	16
Temperature Compliance Schedule -Site-Specific Temperature Evaluation Report	December 31, 2027	16
Temperature Compliance Schedule -Action Plan	December 31, 2028	16
Temperature Compliance Schedule -Complete Actions and Achieve Compliance	December 31, 2029	16
PFOS/PFOA Minimization Plan Determination of Need -Report on Effluent Discharge	December 31, 2025	16
PFOS/PFOA Minimization Plan Determination of Need -Report on Effluent Discharge and Evaluation of Need	December 31, 2026	16
Land Application Management Plan -Land Application Management Plan Submittal	See Permit	17
General Sludge Management Form 3400-48	prior to any significant sludge management changes	26
Characteristic Report Form 3400-49	no later than the date indicated on the form	26
Land Application Report Form 3400-55	January 31, each year whether or not waste is land applied	26
Other Methods of Disposal or Distribution Report Form 3400-52	by January 31, each year whether or not waste is hauled to another facility, landfilled, incinerated, or stored in a manure pit	26
Wastewater Discharge Monitoring Report	no later than the date indicated on the form	19

Report forms shall be submitted electronically in accordance with the reporting requirements herein. Any facility plans or plans and specifications for municipal, industrial, industrial pretreatment and non industrial wastewater systems shall be submitted to the Bureau of Water Quality, P.O. Box 7921, Madison, WI 53707-7921. All other submittals required by this permit shall be submitted to:

West Central Region, 1300 W. Clairemont Ave, Eau Claire, WI 54701