

De Soto Public Noticed Permit Fact Sheet

General Information

Permit Number	WI-0029793-12-0
Permittee	Village of De Soto, P.O. Box 65 10135 State Hwy 35, De Soto, WI 54624-0065
Permitted Facility	De Soto Wastewater Treatment Facility, STH 35, De Soto, Wisconsin
Permit Term	February 01, 2026 to December 31, 2030
Discharge Location	West Bank of the Mississippi River, 1/10 of a mile south of State Highway 82, Main Street NE1/4, NW1/4, T11N R07W, Section 22, Village of DeSoto, Crawford County
Receiving Water	Mississippi River in Rush Creek Watershed of Bad Axe - La Crosse River Basin in Crawford County
Stream Flow (Q _{7,10})	6940 cfs
Stream Classification	Warm Water Sport Fish, Non-public Water Supply
Discharge Type	Existing, continuous
Annual Average Design Flow	0.065 MGD
Industrial or Commercial Contributors	None
Plant Classification	A2 - Attached Growth Processes; B - Solids Separation; C - Biological Solids/Sludges; SS - Sanitary Sewage Collection System
Approved Pretreatment Program?	N/A

Facility Description

The De Soto Wastewater Treatment Facility treats domestic wastewater from the Village of De Soto. The treatment system consists of comminution, bar screening, a primary clarifier, rotating biological contactors (RBCs), a final clarifier, and chemical addition for phosphorus removal. Sludge is anaerobically digested prior to land application either as a liquid or as a cake after drying on sludge beds. Sludge beds have not been used in recent years. The annual average design flow is 0.065 million gallons per day (MGD) and had an annual average discharge of 0.025 MGD in 2024. The facility will be upgraded at the same site within this permit term. Effluent outfall will remain the same.

Substantial Compliance Determination

Enforcement During Last Permit:

The facility received a notice of noncompliance (NON) in 2021 for exceeding the high-quality limit for lead in their sludge. Another NON for exceeding the high-quality limit for zinc in their sludge was received in 2022. The facility has had two bypasses of their facility that have resulted in effluent limit exceedances. The facility is required to track metals loadings on fields due to the sludge limit exceedances and is required to notify the department of any bypass events. The facility has completed all previously required actions as part of the enforcement process.

Late submission of reports was an issue in all years of the permit term. This number of late reports have decreased over the permit term, but remain a problem. Minor underreporting has occurred. Besides the bypass event in August 2023, the facility has met their effluent limits consistently.

After a desk top review on December 10, 2025 of all discharge monitoring reports, CMARs, land app reports, compliance schedule items, and a site visit on October 30, 2024, this facility has been found to be in substantial compliance with their current permit.

Compliance determination entered by Katie Jo Jerzak, PE, Wastewater Engineer, on December 10, 2025.

Sample Point Descriptions

Sample Point Designation		
Sample Point Number	Discharge Flow, Units, and Averaging Period	Sample Point Location, Waste Type/Sample Contents and Treatment Description (as applicable)
701	Influent: flow not measured during the last permit term	Representative influent samples shall be collected downstream from the comminutor and prior to primary clarification.
001	Effluent to Mississippi River: 0.0249 MGD (2024)	Representative effluent composite samples shall be collected at the effluent trough of the final clarifier. Representative grab samples shall be collected at the V-notch weir in the former chlorine contact tank.
002	Land application, liquid sludge: 28,100 gallons (2022-2024 average)	Representative liquid sludge samples shall be collected from the sludge pump sample valve. See footnote 3.2.1.3 for additional information on monitoring frequency for multiple sludge sample points.
003	Land application, cake sludge: 0 dry US tons (2024)	Representative cake sludge samples shall be collected from the drying bed prior to removal and land application. See footnote 3.2.1.3 for additional information on monitoring frequency for multiple sludge sample points.

Permit Requirements

1 Influent – Monitoring Requirements

1.1 Sample Point Number: 701- INFLUENT to PLANT

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Daily	Continuous	See flow subsection in permit & associated compliance schedule
BOD5, Total		mg/L	3/Week	24-Hr Flow Prop Comp	

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Suspended Solids, Total		mg/L	3/Week	24-Hr Flow Prop Comp	

Changes from Previous Permit:

Influent limitations and monitoring requirements were evaluated for this permit term. Per the associated compliance schedule, by 12/31/2028 the permittee shall install a new sampler that will collect 24-hour flow proportional samples, provide for adequate sample refrigeration and will also collect continuous flow data. Influent flow reporting is required as of 01/01/2029. See the associated compliance schedule for more information.

Explanation of Limits and Monitoring Requirements

Monitoring of influent flow, BOD5 and total suspended solids is required by s. NR 210.04(2), Wis. Adm. Code, to assess wastewater strengths and volumes and to demonstrate the percent removal requirements in s. NR 210.05, Wis. Adm. Code, and in the Standard Requirements section of the permit.

2 Surface Water - Monitoring and Limitations

2.1 Sample Point Number: 001- EFFLUENT to MISSISSIPPI RIVER

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Daily	Continuous	
BOD5, Total	Weekly Avg	45 mg/L	3/Week	24-Hr Flow Prop Comp	
BOD5, Total	Monthly Avg	30 mg/L	3/Week	24-Hr Flow Prop Comp	
Suspended Solids, Total	Weekly Avg	45 mg/L	3/Discharge	24-Hr Flow Prop Comp	
Suspended Solids, Total	Monthly Avg	30 mg/L	3/Discharge	24-Hr Flow Prop Comp	
pH Field	Daily Min	6.0 su	Daily	Grab	
pH Field	Daily Max	9.0 su	Daily	Grab	
Nitrogen, Ammonia (NH3-N) Total		mg/L	Quarterly	24-Hr Flow Prop Comp	Quarterly monitoring required in 2027 & 2028.
Phosphorus, Total	Monthly Avg	0.6 mg/L	3/Week	24-Hr Flow Prop Comp	This is an interim MDV limit. See the MDV/Phosphorus sections and phosphorus schedules

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
					in the permit.
Phosphorus, Total		lbs/month	Monthly	Calculated	Report the total monthly phosphorus discharged in lbs/month on the last day of the month on the DMR. See Standard Requirements for 'Appropriate Formulas' in the permit to calculate the Total Monthly Discharge in lbs/month.
Phosphorus, Total		lbs/yr	Annual	Calculated	Report the sum of the total monthly discharges (for the months that the MDV is in effect) for the calendar year on the Annual Report form.
Nitrogen, Total Kjeldahl		mg/L	See Listed Qtr(s)	24-Hr Flow Prop Comp	See Nitrogen Series Monitoring section in permit for specific quarters that monitoring is required.
Nitrogen, Nitrite + Nitrate Total		mg/L	See Listed Qtr(s)	24-Hr Flow Prop Comp	See Nitrogen Series Monitoring section in permit for specific quarters that monitoring is required.
Nitrogen, Total		mg/L	See Listed Qtr(s)	Calculated	Monitoring required annually in specific quarters. See Nitrogen Series Monitoring section in permit Total Nitrogen shall be calculated as the sum of reported values for Total Kjeldahl Nitrogen and Total Nitrite + Nitrate Nitrogen.

Changes from Previous Permit

Effluent limitations and monitoring requirements were evaluated for this permit term and the following changes were made from the previous permit term:

- **Flow-** The sample frequency for flow has been changed from “continuous” to “daily” for eDMR reporting purposes.
- Per the associated compliance schedule, by 12/31/2028 the permittee shall install a new sampler that will collect 24-hour flow proportional samples and provide for adequate sample refrigeration.

Explanation of Limits and Monitoring Requirements

Limits were determined for De Soto's existing discharge to the Mississippi River using chs. NR 102, 104, 105, 106, 207, 210, 212 and 217 of the Wisconsin Administrative Code (where applicable). For additional information on any of the limits see the October 27, 2025 memo from Ben Hartenbower to Holly Heldstab titled "Water Quality-Based Effluent Limitations for the De Soto Area Wastewater Commission WPDES Permit No. WI-0029793".

Monitoring Frequencies- The Monitoring Frequencies for Individual Wastewater Permits guidance (April 12, 2021) recommends that standard monitoring frequencies be included in individual wastewater permits based on the size and type of the facility, in order to characterize effluent quality and variability, to detect events of noncompliance, and to ensure consistency in permits issued across the state. Guidance and requirements in administrative code were considered when determining the appropriate monitoring frequencies for pollutants that have final effluent limits in effect during this permit term. No monitoring frequency changes have been made.

Expression of Limits- In accordance with the federal regulation 40 CFR 122.45(d) and s. NR 205.065, Wis. Adm. Code, limits in this permit are to be expressed as weekly average and monthly average whenever practicable.

Phosphorus: Water quality based effluent limits of 0.300 mg/L (monthly average) and 0.100 lbs/day & 0.054 lbs/day (6-month averages) were set to become effective unless a variance was granted. The permittee applied for, and was granted, a multi-discharge variance (MDV) for phosphorus during the previous permit term and has re-applied for the MDV as provided for in s. 283.16, Wis. Stats., and approved by USEPA on September 3, 2025 for a 10-year duration. The permittee qualifies for the MDV because it is an existing source and a major facility upgrade is needed to comply with the applicable phosphorus WQBELs, thereby creating a financial burden. De Soto's MDV application was conditionally approved by the DNR on April 4, 2025. The interim effluent limit for total phosphorus is 1.0 mg/L as an average monthly limit through 12/31/2029. The interim limit drops to 0.6 mg/L on 01/01/2030. The limit was derived using DMR data from April 2020 to August 2025.

Conditions of the MDV require the permittee to optimize phosphorus removal throughout the permit term, comply with interim limits and make annual payments to participating county(s) by March 1 of each year based on the pounds of phosphorus discharged during the previous year in excess of the specified target value.

The "price per pound" value is \$50.00 adjusted for CPI annually during the first quarter as defined by s. 283.16(8)(a)2, Wis. Stats and takes effect for reissued permits with effective dates starting April 1. This may differ from the "price per pound" that is public noticed; however, the "price per pound" is set upon reissuance and is applicable for the entire permit term. The participating county(s) uses these payments to implement non-point source phosphorus control strategies at the watershed level.

PFOS and PFOA: NR 106 Subchapter VIII – Permit Requirements for PFOS and PFOA Dischargers became effective on August 1, 2022. Pursuant to s. NR 106.98(3)(b), Wis. Adm. Code, the department evaluated the need for PFOS and PFOA monitoring taking into consideration the presence of potential PFOS or PFOA industrial wastes, remediation sites and other potential sources of PFOS or PFOA. Based on information available at the time the permit was drafted, the department has determined the permittee does not need to sample for PFOS or PFOA as part of this permit reissuance. The department may re-evaluate the need for sampling at the next permit reissuance if new information becomes available that suggests PFOS or PFOA may be present in the discharge.

3 Land Application - Monitoring and Limitations

Municipal Sludge Description						
Sample Point	Sludge Class (A or B)	Sludge Type (Liquid or Cake)	Pathogen Reduction Method	Vector Attraction Method	Reuse Option	Amount Reused/Disposed
002	B	Liquid	Anaerobic digestion & fecal coliform	Volatile solids & incorporation	Land Application	28,100 gallons (2022-2024 average)
003	B	Cake				0
Does sludge management demonstrate compliance? Yes						
Is additional sludge storage required? No						
Is Radium-226 present in the water supply at a level greater than 2 pCi/liter? No						
Is a priority pollutant scan required? No						
Priority pollutant scans are required once every 10 years at facilities with design flows between 5 MGD and 40 MGD, and once every 5 years if design flow is greater than 40 MGD.						

3.1 Sample Point Number: 002- LIQUID SLUDGE and 003- CAKE SLUDGE

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Solids, Total		Percent	Annual	Composite	
Arsenic Dry Wt	Ceiling	75 mg/kg	Annual	Composite	
Arsenic Dry Wt	High Quality	41 mg/kg	Annual	Composite	
Cadmium Dry Wt	Ceiling	85 mg/kg	Annual	Composite	
Cadmium Dry Wt	High Quality	39 mg/kg	Annual	Composite	
Copper Dry Wt	Ceiling	4,300 mg/kg	Annual	Composite	
Copper Dry Wt	High Quality	1,500 mg/kg	Annual	Composite	
Lead Dry Wt	Ceiling	840 mg/kg	Annual	Composite	
Lead Dry Wt	High Quality	300 mg/kg	Annual	Composite	
Mercury Dry Wt	Ceiling	57 mg/kg	Annual	Composite	
Mercury Dry Wt	High Quality	17 mg/kg	Annual	Composite	
Molybdenum Dry Wt	Ceiling	75 mg/kg	Annual	Composite	
Nickel Dry Wt	Ceiling	420 mg/kg	Annual	Composite	
Nickel Dry Wt	High Quality	420 mg/kg	Annual	Composite	
Selenium Dry Wt	Ceiling	100 mg/kg	Annual	Composite	
Selenium Dry Wt	High Quality	100 mg/kg	Annual	Composite	

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Zinc Dry Wt	Ceiling	7,500 mg/kg	Annual	Composite	
Zinc Dry Wt	High Quality	2,800 mg/kg	Annual	Composite	
Nitrogen, Total Kjeldahl		Percent	Annual	Composite	
Nitrogen, Ammonium (NH4-N) Total		Percent	Annual	Composite	
Phosphorus, Total		Percent	Annual	Composite	
Phosphorus, Water Extractable		% of Tot P	Annual	Composite	
Potassium, Total Recoverable		Percent	Annual	Composite	
PCB Total Dry Wt	Ceiling	50 mg/kg	Once	Composite	Once in 2026
PCB Total Dry Wt	High Quality	10 mg/kg	Once	Composite	Once in 2026
PFOA + PFOS		ug/kg	Annual	Calculated	Report the sum of PFOA and PFOS. See PFAS Permit Sections for more information.
PFAS Dry Wt			Annual	Grab	Perfluoroalkyl and Polyfluoroalkyl Substances based on updated DNR PFAS List. See PFAS Permit Sections for more information.

Changes from Previous Permit:

Sludge limitations and monitoring requirements were evaluated for this permit term and the only change was the addition of PFAS monitoring annually. PFAS monitoring is required pursuant to s. NR 204.06(2)(b)9., Wis. Adm. Code.

Explanation of Limits and Monitoring Requirements

Requirements for disposal, including land application of municipal sludge, are determined in accordance with ch. NR 204, Wis. Adm. Code. Ceiling and high-quality limits for metals in sludge are specified in s. NR 204.07(5). Requirements for pathogens are specified in s. NR 204.07(6) and in s. NR 204.07 (7) for vector attraction requirements. Limitations for PCBs are addressed in s. NR 204.07(3)(k).

PFAS- The presence and fate of PFAS in municipal and industrial sludges is an emerging public health concern. EPA has developed a draft risk assessment to determine future land application rates and released this risk assessment in January of 2025. The department is evaluating this new information. Until a decision is made, the “Interim Strategy for Land Application of Biosolids and Industrial Sludges Containing PFAS” should be followed

Collecting sludge data on PFAS concentrations from a wide range of wastewater treatment facilities will help protect public health from exposure to elevated levels of PFAS and determine the department’s implementation of EPA’s

recommendations. To quantitate this risk, PFAS sampling has been included in this WPDES permit pursuant to ss. NR 214.18(5)(b) and NR 204.06(2)(b)9., Wis. Adm. Code.

4 Schedules

4.1 Phosphorus Schedule - Optimization and Compliance Planning

The permittee is required to optimize performance and undertake compliance planning to control phosphorus discharges per the following schedule.

Required Action	Due Date
Optimization and Compliance Alternatives: The permittee shall implement a phosphorus discharge optimization plan to control phosphorus discharges to the greatest extent practicable. Submit a progress report that summarizes the approach to phosphorus removal at the facility, the resulting concentration and mass loading for the last 12-month period, and any changes that were or are needed to optimize removal of phosphorus by the due date. The permittee shall also evaluate alternative phosphorus compliance options such as water quality trading and adaptive management. The progress report submitted on the date due shall also detail any outreach activities undertaken to evaluate these options, any communications with credit generators, brokers/clearinghouse, and any potential water quality trading or adaptive management projects that may lead to compliance with phosphorus WQBELs. Financial alternatives evaluation: If the permittee intends to seek a renewed variance at the end of this permit term, the permittee may complete a financial evaluation to support ongoing variance eligibility. The report must evaluate financial mechanisms that have the potential to make compliance with phosphorus WQBELs economically feasible. Include an assessment of the feasibility and financial outcomes of the following opportunities: variable rate structures, grants through USDA or other sources, and DNR's Clean Water Fund Program. The assessment of the DNR's Clean Water Fund program should take into account subsidized interest rate loans, principal forgiveness, and other options as outlined in EPA's March 2024 Financial Capabilities Assessment Guidance, Appendix C.	09/30/2026
Progress Report #2: Submit a progress report per the above for the prior calendar year.	09/30/2027
Progress Report #3: Submit a progress report per the above for the prior calendar year.	09/30/2028
Progress Report #4: Submit a progress report per the above for the prior calendar year.	09/30/2029
Final MDV Optimization and Compliance Alternatives Report: Submit a progress report per the above for the prior calendar year. If water quality trading or adaptive management will be used to comply with phosphorus limitations during the next permit term, submit a draft water quality trading plan, adaptive management plan, or executed clearinghouse credit purchase agreement. The financial alternatives evaluation as described above must be submitted by the date due if the facility chooses to seek renewal of the variance.	06/30/2030

Explanation of Schedule: Per s. 283.16(6)(a), Wis. Stats. the Department may include a requirement that the permittee optimize the performance of a point source in controlling phosphorus discharges, which may be necessary to achieve compliance with applicable effluent limits. This compliance schedule requires the permittee to prepare an optimization plan with a schedule for implementation and submit it for Department approval. The schedule also includes a compliance planning element focused on economically feasible solutions to low-level phosphorus effluent limits such as water quality trading or adaptive management. The permittee shall take the steps called for in the optimization plan and submit annual

progress reports on optimizing the removal of phosphorus and establishing a water quality trade or adaptive management project. Should the permittee intend to reapply for a subsequent term of variance coverage, a financial alternatives analysis will need to be completed. Report elements are listed in the schedule, and more information can be found in [EPA's March 2024 Financial Capabilities Assessment Guidance, Appendix C](#).

4.2 Phosphorus Payment per Pound to County

The permittee is required to make annual payments for phosphorus reductions to the participating county or counties in accordance with s. 283.16(8), Wis. Stats, and the following schedule. The price per pound will be set at the time of permit reissuance and will apply for the duration of the permit.

Required Action	Due Date
<p>Annual Verification of Phosphorus Payment to County: The permittee shall make a total payment to the participating county or counties approved by the Department by March 1 of each calendar year. The amount due is equal to the following: [(lbs of phosphorus discharged minus the permittee's target value) times (\$66.62 per pound)] or \$640,000, whichever is less. See the payment calculation steps in the Surface Water section.</p> <p>The permittee shall submit Form 3200-151 to the Department by March 1 of each calendar year indicating total amount remitted to the participating counties to verify that the correct payment was made. The first payment verification form is due by the specified Due Date.</p> <p>Note: The applicable Target Value is 0.2 mg/L as defined by s. 283.16(1)(h), Wis. Stats. The "per pound" value is \$50.00 adjusted for CPI.</p>	03/01/2026
Annual Verification of Payment #2: Submit Form 3200-151 to the Department indicating total amount remitted to the participating counties.	03/01/2027
Annual Verification of Payment #3: Submit Form 3200-151 to the Department indicating total amount remitted to the participating counties.	03/01/2028
Annual Verification of Payment #4: Submit Form 3200-151 to the Department indicating total amount remitted to the participating counties.	03/01/2029
Annual Verification of Payment #5: Submit Form 3200-151 to the Department indicating total amount remitted to the participating counties.	03/01/2030
Continued Coverage: If the permittee intends to seek a renewed variance, an application for the MDV (Multi Discharger Variance) shall be submitted as part of the application for permit reissuance in accordance with s. 283.16(4)(b), Wis. Stats.	
Annual Verification of Payment After Permit Expiration: In the event that this permit is not reissued prior to the expiration date, the permittee shall continue to submit Form 3200-151 to the Department indicating total amount remitted to the participating counties by March 1 each year.	

Explanation of Schedule: Subsection 283.16(6)(b), Wis. Stats., requires permittees that have received approval for the multi-discharger variance (MDV) to implement a watershed project that is designed to reduce nonpoint sources of phosphorus within the HUC 8 watershed in which the permittee is located. The permittee has selected the "Payment to Counties" watershed option described in s. 283.16(8), Wis. Stats. Under this option the permittee shall make annual payment(s) to participating county(s) that are calculated based on the amount of phosphorus actually discharged during a calendar year in pounds per year less the amount of phosphorus that would have been discharged had the permittee discharged phosphorus at a target value of 0.2 mg/L. The pounds of phosphorus discharged in excess of the target value is multiplied by a per pound phosphorus charge that will equal \$66.62 per pound. This schedule requires the permittee to submit Form 3200-151 to the Department indicating the total amount remitted to the participating county(s).

4.3 Installation of Influent (Sample Point 701) and Effluent Monitoring Equipment (Sample Point 001)

The permittee shall install influent and effluent monitoring equipment consistent with 24-hour, flow-proportional composite sampling and continuous flow monitoring, including proper sample refrigeration.

Required Action	Due Date
Plan Submittal: The permittee shall submit plans for influent and effluent monitoring equipment consistent with the 24-hour, flow-proportional composite sampling and continuous flow monitoring. Plans for the monitoring equipment shall comply with chs. NR 108 and NR 218, Wis. Adm. Code.	12/31/2026
Submit Progress Report: The permittee shall submit a progress report on the installation of the new influent and effluent samplers.	12/31/2027
Complete Installation: The permittee shall complete the installation of the influent and effluent flow and monitoring equipment in accordance with approved plans. As of 01/01/2029 measurement and reporting of influent flow shall be based off the newly installed influent flow meter.	12/31/2028

Explanation of Schedule: The 2024 inspection noted significant deficiencies with sampler refrigeration. The operator noted that external equipment affected the internal temperature of the samplers, and that ice needed to be added to keep samples preserved properly. Samples used for compliance reporting should be stored in a refrigerator and kept at 6° C or less, but not frozen.

4.4 Land Application Management Plan

A management plan is required for the land application system.

Required Action	Due Date
Land Application Management Plan Submittal: Submit a management plan to optimize the land application system performance and demonstrate compliance with ch. NR 204, Wis. Adm. Code, by the Due Date. This management plan shall 1) specify information on pretreatment processes (if any); 2) identify land application sites; 3) describe site limitations; 4) address vegetative cover management and removal; 5) specify availability of storage; 6) describe the type of transporting and spreading vehicle(s); 7) specify monitoring procedures; 8) track site loading; 9) address contingency plans for adverse weather and odor/nuisance abatement; and 10) include any other pertinent information. Once approved, all landspreading activities shall be conducted in accordance with the plan. Any changes to the plan must be approved by the Department prior to implementing the changes.	09/30/2030

Explanation of Schedule: This schedule requires the submittal of an updated Land Application Management Plan that documents how the permittee will manage the land application of biosolids consistent with ch. NR 204, Wis. Adm. Code.

Other Comments

Publishing Newspaper: Vernon County Times, 1407 St. Andrew St, La Crosse, WI 54603

Attachments

- Water Quality Based Effluent Limits: the October 27, 2025 memo from Ben Hartenbower to Holly Heldstab titled “Water Quality-Based Effluent Limitations for the De Soto Area Wastewater Commission WPDES Permit No. WI-0029793”
- MDV Evaluation Checklist, completed by Matt Claucherty, dated 04/04/2025
- MDV Conditional Approval Letter, completed by Matt Claucherty, dated 04/04/2025

Justification Of Any Waivers From Permit Application Requirements

No waivers requested or granted as part of this permit reissuance

Prepared By: Holly Heldstab, Wastewater Specialist **Date:** 12/29/2025

DATE: October 27, 2025

TO: Holly Heldstab – WCR/Eau Claire

FROM: Benjamin Hartenbower – WCR/Eau Claire

SUBJECT: Water Quality-Based Effluent Limitations for the De Soto Wastewater Treatment Facility
WPDES Permit No. WI-0029793

This is in response to your request for an evaluation of the need for water quality-based effluent limitations (WQBELs) using chapters NR 102, 104, 105, 106, 207, 210, 212, and 217 of the Wisconsin Administrative Code (where applicable) for the discharge from the De Soto Wastewater Treatment Facility in Crawford County. This municipal wastewater treatment facility (WWTF) discharges to the Mississippi River, located in the Rush Creek Watershed in the Bad Axe - La Crosse River Basin. The evaluation of the permit recommendations is discussed in more detail in the attached report.

Based on our review, the following recommendations are made on a chemical-specific basis at Outfall 001:

Parameter	Daily Maximum	Daily Minimum	Weekly Average	Monthly Average	Six-Month Average	Footnotes
Flow Rate						1, 2
BOD ₅			45 mg/L	30 mg/L		1, 3
TSS			45 mg/L	30 mg/L		1, 3
pH	9.0 s.u.	6.0 s.u.				1
Ammonia Nitrogen						2
Phosphorus HAC Interim Final WQBEL				0.6 mg/L 0.300 mg/L	0.100 mg/L, 0.054 lbs/day	4
TKN, Nitrate+Nitrite, and Total Nitrogen						5

Footnotes:

1. No changes from the current permit.
2. Monitoring only.
3. These limits are based on the Warm Water Sport Fish (WWSF) community of the immediate receiving water as described in s. NR 210.05(1), Wis. Adm. Code.
4. Under the phosphorus MDV, a highest attainable condition (HAC) limit of 0.6 mg/L should be effective upon permit reissuance. The final WQBELs remain at 0.300 mg/L as a monthly average and 0.100 mg/L as a six-month average, as well as a respective mass limit.
5. As recommended in the Department's October 1, 2019 *Guidance for Total Nitrogen Monitoring in Wastewater Permits*, annual total nitrogen monitoring is recommended for all minor municipal permittees. Sections 283.37(5) and 283.55(1)(e), Wis. Stats, and ss. NR 200.065(1)(g) and NR 200.065(1)(h), Wis. Adm. Codes, provide the authority to request this monitoring during the permit term. Total Nitrogen is the sum of nitrate (NO₃), nitrite (NO₂), and total Kjeldahl nitrogen (TKN) (all expressed as N).

Please consult the attached report for details regarding the above recommendations. If there are any questions or comments, please contact Benjamin Hartenbower at (715) 225-4705 or benjamin.hartenbower@wisconsin.gov or Diane Figiel at diane.figiel@wisconsin.gov.

Attachments (2) – Narrative & Map

PREPARED BY:



Benjamin Hartenbower, PE,
Water Resources Engineer

Date: 10/27/2025

E-cc: Katie Jo Jerzak, Wastewater Engineer – WCR/Eau Claire
Geisa Bittencourt, Regional Wastewater Supervisor – WCR/Eau Claire
Diane Figiel, Water Resources Engineer – WY/3
Nate Willis, Wastewater Engineer – WY/3
Shawn Giblin, Water Quality Biologist – WCR/La Crosse

**Water Quality-Based Effluent Limitations for
The De Soto Wastewater Treatment Facility**

WPDES Permit No. WI-0029793

Prepared by: Benjamin P. Hartenbower

PART 1 – BACKGROUND INFORMATION

Facility Description

The De Soto Wastewater Treatment Facility consists of comminution, bar screen, a primary clarifier, RBC unit, and final clarifier. The sludge is anaerobically digested and land spread. The effluent is discharged at the west bank of the Mississippi River 1/10 mile south of intersection of Highway 82 and Highway 35.

Attachment #2 is a map of the area showing the approximate location of Outfall 001.

Existing Permit Limitations

The current permit, which expired on March 31, 2025, includes the following effluent limitations and monitoring requirements.

Parameter	Daily Maximum	Daily Minimum	Weekly Average	Monthly Average	Six-Month Average	Footnotes
Flow Rate						1, 2
BOD ₅			45 mg/L	30 mg/L		1, 3
TSS			45 mg/L	30 mg/L		1, 3
pH	9.0 s.u.	6.0 s.u.				1
Ammonia Nitrogen						2
Phosphorus Interim MDV Interim Final WQBEL				5.4 mg/L 1.0 mg/L 0.300 mg/L	0.100 mg/L, 0.054 lbs/day	4
TKN, Nitrate+Nitrite, and Total Nitrogen						2

Footnotes:

1. These limitations are not being evaluated as part of this review. Because the water quality criteria (WQC), reference effluent flow rates, and receiving water characteristics have not changed, limitations for these water quality characteristics do not need to be re-evaluated at this time.
2. Monitoring only.
3. These limits are based on the Warm Water Sport Fish (WWSF) community of the immediate receiving water as described in s. NR 210.05(1), Wis. Adm. Code.
4. A compliance schedule is in the current permit to meet the MDV Interim Limit by April 1, 2024.

Receiving Water Information

- Name: Mississippi River
- Waterbody Identification Code (WBIC): 721000
- Classification used in accordance with chs. NR 102 and 104, Wis. Adm. Code: Warm Water Sport Fish (WWSF) community, non-public water supply.
- Low flows used in accordance with chs. NR 106 and 217, Wis. Adm. Code: The following 7-Q₁₀ and 7-Q₂ values are from USGS for Station 05383500 at La Crosse, in the Mississippi River , where Outfall 001 is located.

7-Q₁₀ = 6940 cubic feet per second (cfs)

7-Q₂ = 11200 cfs

Harmonic Mean Flow = 20960 cfs using a drainage area of 62,800 mi²

The Harmonic Mean has been estimated based on average flow and the 7-Q₁₀ using an equation from U.S. EPA's *Technical Support Document for Water Quality-Based Toxics Control* (March 1991, EPA/505/2-90-001, pgs. 88-89).

- Hardness = 159 mg/L as CaCO₃. This value represents the geometric mean of hardness from the Mississippi River from 10/04/1988 to 12/05/1990 (n = 40).
- % of low flow used to calculate limits in accordance with s. NR 106.06(4)(c)5., Wis. Adm. Code: 25%
- Source of background concentration data: Metals data from the Mississippi River at Alma are used in this evaluation because there is no data available for the Mississippi River . The Mississippi River is within the same ecological landscape so ambient water quality characteristics are expected to be similar. The numerical values are shown in the tables below. If no data is available, the background concentration is assumed to be negligible and a value of zero is used in the computations. Background data for calculating effluent limitations for ammonia nitrogen are described later.
- Multiple dischargers: There are several other dischargers to the Mississippi River, however they are not in the immediate vicinity and the mixing zones do not overlap. Therefore, the other dischargers do not impact this evaluation.
- Impaired water status: The Mississippi River is impaired for Mercury (multiple segments between miles 580.8 and 811.5), PCBs (multiple segments between miles 580.8 and 811.5), PFOS (miles 714.2 to 763.4 and 763.4 to 811.5), Sediment/Total Suspended Solids from mile 763.4 to 811.5, and Total Phosphorus (multiple segments between miles 580.8 and 811.5).

Effluent Information

- Flow Rate(s):

Annual Average = 0.065 MGD (Million Gallons per Day)

For reference, the actual average flow from April 2020 to August 2025 was 0.028 MGD.

- Hardness = 349 mg/L as CaCO₃. This value represents the geometric mean of data (n = 4) from September 2023 to September 2023.
- Acute dilution factor used in accordance with s. NR 106.06(3)(c), Wis. Adm. Code: Not applicable – this facility does not have an approved Zone of Initial Dilution (ZID).
- Wastewater source: Domestic wastewater.
- Water supply: Private Wells
- Additives: Ferric Chloride (Water Quality Conditioner)

Attachment #1

- Effluent characterization: This facility is categorized as a minor municipality, so the permit application required effluent sample analyses for a limited number of common pollutants, as specified in s. NR 200.065, Table 1, Wis. Adm. Code, primarily metal substances plus ammonia, chloride, and hardness. The permit-required monitoring for Phosphorus from April 2020 to August 2025 is used in this evaluation.
- Effluent data for substances for which a single sample was analyzed is shown in the tables in Part 2, in the column titled “MEAN EFFL. CONC.”. Otherwise, substances with multiple effluent data are shown in the tables below or in their respective parts in this evaluation.

Effluent Data for Outfall 001

Sample Date	Copper $\mu\text{g}/\text{L}$	Sample Date	Chloride mg/L
09/14/2023	<1.1	09/14/2023	230
09/18/2023	2.0	09/18/2023	300
09/21/2023	2.1	09/21/2023	340
09/23/2023	2.0	09/23/2023	310
09/27/2023	5.6		
10/03/2023	4.2		
10/07/2023	3.1		
10/11/2023	3.3		
11/19/2023	6.1		
11/22/2023	3.6		
09/18/2024	6.2		
mean	3.5	mean	295

“<” means that the pollutant was not detected at the indicated limit of detection. The mean concentration was calculated using zero in place of the non-detected results.

The following table presents the average concentrations and loadings at Outfall 001 from April 2020 to August 2025 for all parameters with limits in the current permit to meet the requirements of s. NR 201.03(6), Wis. Adm. Code:

Parameters with Effluent Limits

	Average Measurement
BOD ₅	7*
TSS	4*
pH	7.29
Phosphorus	0.29*

*Results below the limit of detection (LOD) were included as zeros in calculation of average.

** The average measurement for bacteria is calculated as a geometric mean. Values reported below the LOD are replaced with a value of 1 for the calculation of the geometric mean.

PART 2 – WATER QUALITY-BASED EFFLUENT LIMITATIONS FOR TOXIC SUBSTANCES – EXCEPT AMMONIA NITROGEN

Permit limits for toxic substances are required whenever any of the following occur:

1. The maximum effluent concentration exceeds the calculated limit (s. NR 106.05(3), Wis. Adm. Code)
2. If 11 or more detected results are available in the effluent, the upper 99th percentile (or P₉₉) value exceeds the comparable calculated limit (s. NR 106.05(4), Wis. Adm. Code)
3. If fewer than 11 detected results are available, the mean effluent concentration exceeds 1/5 of the calculated limit (s. NR 106.05(6), Wis. Adm. Code)

Acute Limits based on 1-Q₁₀

Daily maximum effluent limitations for toxic substances are based on the acute toxicity criteria (ATC), listed in ch. NR 105, Wis. Adm. Code. Previously daily maximum limits for toxic substances were calculated as two times the ATC. However, changes to ch. NR 106, Wis. Code, (September 1, 2016) require the Department to calculate acute limitations using the same mass balance equation as used for other limits along with the 1-Q₁₀ receiving water low flow to determine if more restrictive effluent limitations are needed to protect the receiving stream from discharges which may cause or contribute to an exceedance of the acute water quality standards. The mass balance equation is provided below.

$$\text{Limitation} = \frac{(\text{WQC})(\text{Q}_s + (1-f)\text{Q}_e) - (\text{Q}_s - f\text{Q}_e)(\text{C}_s)}{\text{Q}_e}$$

Where:

WQC = Acute toxicity criterion or secondary acute value according to ch. NR 105, Wis. Adm. Code.

Q_s = average minimum 1-day flow which occurs once in 10 years (1-day Q₁₀)
if the 1-day Q₁₀ flow data is not available = 80% of the average minimum 7-day flow
which occurs once in 10 years (7-day Q₁₀).

Q_e = Effluent flow (in units of volume per unit time) as specified in s. NR 106.06(4)(d), Wis. Adm. Code.

f = Fraction of the effluent flow that is withdrawn from the receiving water, and

C_s = Background concentration of the substance (in units of mass per unit volume) as specified in s. NR 106.06(4)(e), Wis. Adm. Code.

If the receiving water is effluent dominated under low stream flow conditions, the 1-Q₁₀ method of limit calculation produces the most stringent daily maximum limitations and should be used while making reasonable potential determinations. This is not the case for the De Soto Wastewater Treatment Facility, and the limits are set based on two times the acute toxicity criteria.

The following tables list the calculated WQBELs for this discharge along with the results of effluent sampling. All concentrations are expressed in terms of micrograms per Liter (µg/L), except for hardness and chloride (mg/L).

Attachment #1

Daily Maximum Limits based on Acute Toxicity Criteria (ATC)

RECEIVING WATER FLOW = 5552 cfs, (1-Q₁₀ (estimated as 80% of 7-Q₁₀)), as specified in s. NR 106.06(3)(bm), Wis. Adm. Code.

SUBSTANCE	REF. HARD.* mg/L	ATC	MEAN BACK-GRD.	MAX. EFFL. LIMIT**	1/5 OF EFFL. LIMIT	MEAN EFFL. CONC.	1-day P ₉₉	1-day MAX. CONC.
Arsenic		339.8		680	136	<1.1		
Cadmium	349	43.28	0.0331	87	17	<0.19		
Chromium (+3)	301	4445.84		8892	1778	<1.1		
Copper	349	50.51	1.86	101	20	3.5		6.2
Lead	349	358.09	0.841	716	143	<4.3		
Nickel	268	1080.28		2161	432	2.4		
Zinc	333	344.68	2.35	689	138	11		
Chloride (mg/L)		757	18	1514	303	295		340

* The indicated hardness may differ from the effluent hardness because the effluent hardness exceeded the maximum range in ch. NR 105, Wis. Adm. Code, over which the acute criteria are applicable. In that case, the maximum of the range is used to calculate the criterion.

**The 2 × ATC method of limit calculation yields a more restrictive limit than consideration of ambient concentrations and 1-Q₁₀ flow rates per the changes to s. NR 106.07(3), Wis. Adm. Code, effective 09/01/2016.

Weekly Average Limits based on Chronic Toxicity Criteria (CTC)

RECEIVING WATER FLOW = 1735 cfs, (1/4 of 7-Q₁₀), as specified in s. NR 106.06(4)(c), Wis. Adm. Code.

SUBSTANCE	REF. HARD. mg/L	CTC	MEAN BACK-GRD.	WEEKLY AVE. LIMIT**	1/5 OF EFFL. LIMIT	MEAN EFFL. CONC.	4-day P ₉₉
Arsenic		152.2		2625638	525128	<1.1	
Cadmium	159	3.55	0.0331	60671	12134	<0.19	
Chromium (+3)	159	193.43		3336907	667381	<1.1	
Copper	159	15.42	1.86	233929	46786	3.5	
Lead	159	43.91	0.841	742994	148599	<4.3	
Nickel	159	77.39		1335073	267015	2.4	
Zinc	159	180.87	2.35	3079693	615939	11	
Chloride (mg/L)		395	18	6503735	1300747	295	

Monthly Average Limits based on Wildlife Criteria (WC)

The effluent characterization did not include any effluent sampling results for substances for which Wildlife Criteria exist.

Monthly Average Limits based on Human Threshold Criteria (HTC)

RECEIVING WATER FLOW = 5240 cfs, (1/4 of Harmonic Mean), as specified in s. NR 106.06(4)(c), Wis. Adm. Code.

SUBSTANCE	HTC	MEAN BACK-GRD.	MO'L.Y AVE. LIMIT	1/5 OF EFFL. LIMIT	MEAN EFFL. CONC.	30-day P ₉₉
Cadmium	370	0.0331	19275848	3855170	<0.19	
Chromium (+3)	3818000		198923712186	39784742437	<1.1	
Lead	140	0.841	7250400	1450080	<4.3	
Nickel	43000		2240366586	448073317	2.4	

Attachment #1

Monthly Average Limits based on Human Cancer Criteria (HCC)

RECEIVING WATER FLOW = 5240 cfs, (1/4 of Harmonic Mean), as specified in s. NR 106.06(4)(c), Wis. Adm. Code.

SUBSTANCE	HCC	MEAN BACK-GRD.	MO'L Y AVE. LIMIT	1/5 OF EFFL. LIMIT	MEAN EFFL. CONC.	30-day P ₉₉
Arsenic	13.3		692950.6	138590.1	<1.1	

In addition to evaluating the need for limits for each individual substance for which HCC exist, s. NR 106.06(8), Wis. Adm. Code, requires the evaluation of the cumulative cancer risk. Because no effluent limits are needed based on HCC, determination of the cumulative cancer risk is not needed per s. NR 106.06(8), Wis. Adm. Code.

Conclusions and Recommendations

Based on a comparison of the calculated limitations and effluent data, effluent limitations are not required for toxic substances.

Mercury— The permit application did not require monitoring for mercury because the De Soto Wastewater Treatment Facility is categorized as a minor facility as defined in s. NR 200.02(8), Wis. Adm. Code. In accordance with s. NR 106.145(3)(a)3, Wis. Adm. Code, a minor municipal discharger shall monitor, and report results of influent and effluent mercury monitoring once every three months if, “there are two or more exceedances in the last five years of the high-quality sludge mercury concentration of 17 mg/kg specified in s. NR 204.07(5), Wis. Adm. Code.” A review of the past six years of sludge characteristics data reveals that all sample results are within expected analytical ranges and well below the 17 mg/kg level. The average concentration in the sludge from 2020 to 2024 was 0.102 mg/kg, with a maximum reported concentration of 0.329 mg/kg. **Therefore, no mercury monitoring is recommended at Outfall 001.**

PFOS and PFOA – The need for PFOS and PFOA monitoring is evaluated in accordance with s. NR 106.98(2), Wis. Adm. Code.

Based on the annual design flow and lack of nondomestic contributions, it is unlikely that the effluent will contain PFOS or PFOA. Therefore, **PFOS and PFOA monitoring is not recommended.**

**PART 3 – WATER QUALITY-BASED EFFLUENT LIMITATIONS
FOR AMMONIA NITROGEN**

The State of Wisconsin promulgated revised water quality standards for ammonia nitrogen in ch. NR 105, Wis. Adm. Code, effective March 1, 2004 which includes criteria based on both acute and chronic toxicity to aquatic life. Given the fact that the De Soto Wastewater Treatment Facility does not currently have ammonia nitrogen limits, the need for limits is evaluated at this time.

Daily Maximum Limits based on Acute Toxicity Criteria (ATC)

Daily maximum limitations are based on acute toxicity criteria in ch. NR 105, Wis. Adm. Code, which are a function of the effluent pH and the receiving water classification. The acute toxicity criterion (ATC) for ammonia is calculated using the following equation:

$$\text{ATC in mg/L} = [A \div (1 + 10^{(7.204 - \text{pH})})] + [B \div (1 + 10^{(\text{pH} - 7.204)})]$$

Where:

A = 0.411 and B = 58.4 for a Warm Water Sport Fishery, and

pH (s.u.) = that characteristic of the effluent.

The effluent pH data was examined as part of this evaluation. A total of 1979 samples were reported from April 2020 to August 2025. The maximum reported value was 7.99 s.u. (Standard pH Units). The effluent pH was 7.80 s.u. or less 99% of the time. The 1-day P₉₉, calculated in accordance with s. NR 106.05(5), Wis. Adm. Code, is 7.89 s.u. The mean plus the standard deviation multiplied by a factor of 2.33, an estimate of the upper ninety ninth percentile for a normally distributed dataset, is 7.87 s.u. Therefore, a value of 7.89 s.u. is believed to represent the maximum reasonably expected pH, and therefore most appropriate for determining daily maximum limitations for ammonia nitrogen. Substituting a value of 7.89 s.u. into the equation above yields an ATC = 10.32 mg/L.

Daily Maximum Ammonia Nitrogen Effluent Limitations Calculation Method

In accordance with s. NR 106.32(2), Wis. Adm. Code daily maximum ammonia limitations are calculated using the 1-Q₁₀ receiving water low flow if it is determined that the previous method of acute ammonia limit calculation (2×ATC) is not sufficiently protective of the fish and aquatic life. The more restrictive calculated limits shall apply.

The calculated daily maximum ammonia nitrogen effluent limits using the mass balance approach with the 1-Q₁₀ (estimated as 80 % of 7-Q₁₀) and the 2×ATC approach are shown below.

Daily Maximum Ammonia Nitrogen Determination

	Ammonia Nitrogen Limit mg/L
2×ATC	20.64
1-Q ₁₀	565757

The 2×ATC method yields the most stringent limits for the De Soto Wastewater Treatment Facility.

Presented below is a table of daily maximum limitations corresponding to various effluent pH values. Use of this table is not necessarily recommended in the permit, but it is presented herein for informational purposes.

Daily Maximum Ammonia Nitrogen Limits – WWSF

Effluent pH s.u.	Limit mg/L	Effluent pH s.u.	Limit mg/L	Effluent pH s.u.	Limit mg/L
6.0 ≤ pH ≤ 6.1	108	7.0 < pH ≤ 7.1	66	8.0 < pH ≤ 8.1	14
6.1 < pH ≤ 6.2	106	7.1 < pH ≤ 7.2	59	8.1 < pH ≤ 8.2	11
6.2 < pH ≤ 6.3	104	7.2 < pH ≤ 7.3	52	8.2 < pH ≤ 8.3	9.4
6.3 < pH ≤ 6.4	101	7.3 < pH ≤ 7.4	46	8.3 < pH ≤ 8.4	7.8
6.4 < pH ≤ 6.5	98	7.4 < pH ≤ 7.5	40	8.4 < pH ≤ 8.5	6.4
6.5 < pH ≤ 6.6	94	7.5 < pH ≤ 7.6	34	8.5 < pH ≤ 8.6	5.3
6.6 < pH ≤ 6.7	89	7.6 < pH ≤ 7.7	29	8.6 < pH ≤ 8.7	4.4
6.7 < pH ≤ 6.8	84	7.7 < pH ≤ 7.8	24	8.7 < pH ≤ 8.8	3.7
6.8 < pH ≤ 6.9	78	7.8 < pH ≤ 7.9	20	8.8 < pH ≤ 8.9	3.1
6.9 < pH ≤ 7.0	72	7.9 < pH ≤ 8.0	17	8.9 < pH ≤ 9.0	2.6

Weekly and Monthly Average Limits based on Chronic Toxicity Criteria (CTC)

The ammonia limit calculation also warrants evaluation of weekly and monthly average limits based on chronic toxicity criteria for ammonia, because those limits relate to the assimilative capacity of the receiving water.

Weekly average and monthly average limits for ammonia nitrogen are based on chronic toxicity criteria in ch. NR 105, Wis. Adm. Code.

The 30-day chronic toxicity criterion (CTC) for ammonia in waters classified as a Warm Water Sport Fish Community is calculated by the following equation, according to subchapter IV of NR 106, Wis. Adm. Code.

$$CTC = E \times \{[0.0676 \div (1 + 10^{(7.688 - pH)})] + [2.912 \div (1 + 10^{(pH - 7.688)})]\} \times C$$

Where:

pH = the pH (s.u.) of the receiving water,

E = 0.854,

C = the minimum of 2.85 or $1.45 \times 10^{(0.028 \times (25 - T))}$ – (Early Life Stages Present), or
C = $1.45 \times 10^{(0.028 \times (25 - T))}$ – (Early Life Stages Absent), and

T = the temperature (°C) of the receiving water – (Early Life Stages Present), or

T = the maximum of the actual temperature (°C) and 7 – (Early Life Stages Absent)

The 4-day criterion is equal to the 30-day criterion multiplied by 2.5. The 4-day criteria are used in a mass-balance equation with the 7-Q₁₀ (4-Q₃, if available) to derive weekly average limitations. And the 30-day criteria are used with the 30-Q₅ (estimated as 85% of the 7-Q₂ if the 30-Q₅ is not available) to derive monthly average limitations. The stream flow value is further adjusted to temperature; 100% of the flow is used if the Temperature ≥ 16 °C, 25% of the flow is used if the Temperature < 11°C, and 50% of the flow is used if the Temperature ≥ 11 °C but < 16 °C.

Attachment #1

The default basin assumed values are used for temperature, pH, and background ammonia. These values are shown in the table below, with the resulting criteria and effluent limitations.

Weekly and Monthly Average Ammonia Nitrogen Limits – WWSF

		January - March	April & May	June - September	October - December
Effluent Flow	Qe (MGD)	0.065	0.065	0.065	0.065
Background Information	7-Q ₁₀ (cfs)	6940	6940	6940	6940
	7-Q ₂ (cfs)	11200	11200	11200	11200
	Ammonia (mg/L)	0.07	0.05	0.04	0.03
	Average Temperature (°C)	0.9	12	23	5.7
	Maximum Temperature (°C)	2.2	16	24	12
	pH (s.u.)	7.85	8.35	8.09	8.04
	% of Flow used	25	50	100	25
	Reference Weekly Flow (cfs)	1735.00	3470.00	6940.00	1735.00
Criteria mg/L	Reference Monthly Flow (cfs)	2380.00	4760.00	9520.00	2380.00
	4-day Chronic				
	Early Life Stages Present	7.50	3.29	2.80	5.74
	Early Life Stages Absent	12.18	3.29	2.80	6.66
	30-day Chronic				
	Early Life Stages Present	3.00	1.31	1.12	2.30
Effluent Limitations mg/L	Early Life Stages Absent	4.87	1.31	1.12	2.66
	Weekly Average				
	Early Life Stages Present		111706	189968	
	Early Life Stages Absent	208893			114242
	Monthly Average				
	Early Life Stages Present		59891	101701	
	Early Life Stages Absent	113614			62187

Effluent Data

Twelve samples for ammonia nitrogen were taken November 2022 to April 2024.

Ammonia Nitrogen Effluent Data

Sample Date	Ammonia Nitrogen mg/L
11/02/2022	0.81
12/06/2022	1.29
01/03/2023	6.85
02/01/2023	4.64
03/07/2023	3.36
04/04/2023	4.2
11/07/2023	4.54
12/05/2023	1.32
01/23/2024	2.81
02/06/2024	15.81
03/05/2024	6.79
04/02/2024	3.71
1-day P ₉₉	19.99
4-day P ₉₉	11.19
30-day P ₉₉	6.64

Reasonable Potential

Based on this comparison, there is no reasonable potential for the discharge to exceed any of the calculated ammonia nitrogen limits. **Monitoring is recommended to continue in the reissued permit.**

PART 4 – WATER QUALITY-BASED EFFLUENT LIMITATIONS FOR BACTERIA

On May 1, 2020, revisions to chs. NR 102 and NR 210, Wis. Adm. Codes, became effective which replace fecal coliform limits with new *Escherichia coli* (*E. coli*) limits for protection of recreational uses. Section NR 210.06(2)(a)1, Wis. Adm. Code, includes two limits which must be included in permits for facilities which are required to disinfect:

1. The geometric mean of *E. coli* bacteria in effluent samples collected in any calendar month may not exceed 126 counts/100 mL.
2. No more than 10 percent of *E. coli* bacteria samples collected in any calendar month may exceed 410 counts/100 mL.

Dilution and mixing characteristics of the wastewater with the receiving water.

The effluent flow (annual average design flow) to receiving water flow (100% of 7Q₁₀) ratio is > 1 : 1,000 at the point of standards application and therefore disinfection isn't necessary to protect the recreational use, according to s. NR 210.06(3)(e), Wis. Adm. Code, and as discussed in the *Disinfection Requirements for Discharges to Surface Waters* guidance.

PART 5 – PHOSPHORUS

Technology-Based Effluent Limit

Subchapter II of Chapter NR 217, Wis. Adm. Code, requires municipal wastewater treatment facilities that discharge greater than 150 pounds of total phosphorus per month to comply with a monthly average limit of 1.0 mg/L, or an approved alternative concentration limit.

Since the De Soto Wastewater Treatment Facility has phosphorus limits in effect that are more stringent than 1.0 mg/L, the need for a TBEL will not be considered further.

In addition, the need for a WQBEL for phosphorus must be considered.

Water Quality-Based Effluent Limits (WQBEL)

Revisions to administrative rules regulating phosphorus took effect on December 1, 2010. These rule revisions include additions to s. NR 102.06, Wis. Adm. Code, which establish phosphorus standards for surface waters. Subchapter III of NR 217, Wis. Adm. Code, establishes procedures for determining WQBELs for phosphorus, based on the applicable standards in ch. NR 102, Wis. Adm. Code.

Section NR 102.06(3)(a), Wis. Adm. Code, specifically names river segments for which a phosphorus criterion of 0.100 mg/L applies. For other stream segments that are not specified in s. NR 102.06(3)(a), Wis. Adm. Code, s. NR 102.06(3)(b), Wis. Adm. Code, specifies a phosphorus criterion of 0.075 mg/L. The phosphorus criterion of 0.100 mg/L applies for the Mississippi River.

The conservation of mass equation is described in s. NR 217.13(2)(a), Wis. Adm. Code, for phosphorus WQBELs and includes variables of water quality criterion (WQC), receiving water flow rate (Q_s), effluent flow rate (Q_e), and upstream phosphorus concentrations (C_s) provided below.

$$\text{Limitation} = [(WQC)(Q_s + (1-f) Q_e) - (Q_s - f Q_e) (C_s)] / Q_e$$

Where:

WQC = 0.100 mg/L for the Mississippi River.

Q_s = 100% of the 7-Q₂ of 11200 cfs

C_s = background concentration of phosphorus in the receiving water pursuant to s. NR 217.13(2)(d), Wis. Adm. Code

Q_e = effluent flow rate = 0.065 MGD = 0.10 cfs

f = the fraction of effluent withdrawn from the receiving water = 0

Section NR 217.13(2)(d), Wis. Adm. Code, specifies that the background phosphorus concentration used in the limit calculation formula shall be calculated as a median using the procedures specified in s. NR 102.07(1)(b) to (c), Wis. Code. All representative data from the most recent 5 years shall be used, but data from the most recent 10 years may be used if representative of current conditions.

Attachment #1

The following data were considered in estimating the background phosphorus concentration:

In Stream Total Phosphorus Data					
Station Name	LD9	M701.1D	M752.9M	M764.3A	M786.2C
Waterbody	Mississippi River	Mississippi River	Mississippi River	Mississippi River	Mississippi River
Sample Count	60	105	105	105	105
First Sample	05/16/2008	05/13/2008	05/16/2008	05/16/2008	05/16/2008
Last Sample	10/04/2017	10/05/2017	10/04/2017	10/04/2017	10/04/2017
Mean	0.140 mg/L	0.130 mg/L	0.129 mg/L	0.130 mg/L	0.131 mg/L
Median	0.140 mg/L	0.126 mg/L	0.119 mg/L	0.122 mg/L	0.125 mg/L
NR 217 Median	0.138 mg/L	0.119 mg/L	0.115 mg/L	0.118 mg/L	0.127 mg/L
Lab Analysis	WI State Lab of Hygiene	USGS	USGS	USGS	USGS

Substituting a background concentration above criteria into the limit calculation equation above would result in a calculated limit that is less than the applicable criterion of 0.100 mg/L. However, s. NR 217.13(7), Wis. Adm. Code, specifies that “if the WQBEL calculated pursuant to the procedures in this section is less than the phosphorus criterion specified in s. NR 102.06, Wis. Adm. Code, for the water body, the effluent limit shall be set equal to the criterion.”

Effluent Data

The following table summarizes effluent total phosphorus monitoring data from April 2020 to August 2025.

Total Phosphorus Effluent Data

	Phosphorus mg/L
1-day P ₉₉	0.83
4-day P ₉₉	0.52
30-day P ₉₉	0.36
Mean	0.29
Std	0.16
Sample size	281
Range	<0.02 - 1.89

Reasonable Potential Determination

The discharge has reasonable potential to cause or contribute to an exceedance of the water quality criterion because the 30-day P₉₉ of reported effluent total phosphorus data is greater than the calculated WQBEL. Therefore, a WQBEL is required.

Limit Expression

According to s. NR 217.14(2), Wis. Adm. Code, because the calculated WQBEL is less than or equal to 0.3 mg/L, the effluent limit of 0.100 mg/L may be expressed as a six-month average. If a concentration limitation expressed as a six-month average is included in the permit, a monthly average concentration limitation of 0.300 mg/L, equal to three times the WQBEL calculated under s. NR 217.13, Wis. Adm. Code shall also be included in the permit. The six-month average should be averaged during the months of May – October and November – April.

Mass Limits

A mass limit is also required, pursuant to s. NR 217.14(1)(a), Wis. Adm. Code, because the discharge is to a surface water that is impaired for phosphorus. **This final mass limit shall be 0.100 mg/L × 8.34 × 0.065 MGD = 0.054 lbs/day expressed as a six-month average.**

Multi-Discharger Variance Interim Limit

With the permit application, the De Soto Wastewater Treatment Facility has applied for the phosphorus multi-discharger variance (MDV). Conditions of the phosphorus MDV require the facility to comply with an interim phosphorus limit in lieu of meeting the final WQBEL. The recommended interim limit during the 2nd permit under MDV approval, pursuant to s. 283.16(6)(a)1, Wis. Stats., is **0.6 mg/L as a monthly average.**

PART 6 – WATER QUALITY-BASED EFFLUENT LIMITATIONS FOR THERMAL

Surface water quality standards for temperature took effect on October 1, 2010. These regulations are detailed in chs. NR 102 (Subchapter II – Water Quality Standards for Temperature) and NR 106 (Subchapter V – Effluent Limitations for Temperature) of the Wisconsin Administrative Code. Daily maximum and weekly average temperature criteria are available for the 12 different months of the year depending on the receiving water classification.

Due to the amount of upstream flow available for dilution in the limit calculation ($Q_s:Q_e > 30:1$), the lowest calculated limitation is 120° F (s. NR 106.55(6)(a), Wis. Adm. Code). For treatment systems of domestic waste, there is no reasonable potential for the discharge to exceed this limit. **Therefore, no limits or monitoring are recommended.**

PART 7 – WHOLE EFFLUENT TOXICITY (WET)

WET testing is used to measure, predict, and control the discharge of toxic materials that may be harmful to aquatic life. In WET tests, organisms are exposed to a series of effluent concentrations for a given time and effects are recorded. Decisions below related to the selection of representative data and the need for WET limits were made according to ss. NR 106.08 and 106.09, Wis. Adm. Code. WET monitoring frequency and toxicity reduction evaluation (TRE) recommendations were made using the best professional judgment of staff familiar with the discharge after consideration of the guidance in the *Whole Effluent Toxicity (WET) Program Guidance Document* (2022).

Guidance in Chapter 1.11 of the WET Guidance Document (WET Testing of Minor Municipal Discharges) was consulted. This is a minor municipal discharge (< 1.0 MGD) comprised solely of domestic wastewater, with no history of WET failures and no toxic compounds detected at levels of concern. No WET testing is recommended at this time because of the low risk in effluent toxicity.

- Acute tests predict the concentration that causes lethality of aquatic organisms during a 48 to 96-hour exposure. To assure that a discharge is not acutely toxic to organisms in the receiving water, WET tests must produce a statistically valid LC50 (Lethal Concentration to 50% of the test organisms) greater than 100% effluent, according to s. NR 106.09(2)(b), Wis. Adm Code.
- Chronic testing is usually not recommended where the ratio of the 7-Q₁₀ to the effluent flow exceeds 100:1 and acute testing is not typically recommended if the ratio exceeds 1000:1. For the De Soto Wastewater Treatment Facility, that ratio is approximately 69,005:1. With this amount of dilution, there is believed to be little potential for acute or chronic toxicity effects in the Mississippi River associated with the discharge from the De Soto Wastewater Treatment Facility, so the need for acute and chronic WET testing will not be considered further.

De Soto WWTF



Legend: [some map layers may not be displayed]
▲ Surface Water Outfalls
Latest Leaf Off Imagery

3

► Surface Water Outfalls

Instant 10% OFF Images

Notes



Service Layer Credits:
Latest Leaf Off: DNR Basic Feature Vector Tile Layer WMTS - Permits & Determinations - WI DNR Bureau of
Map projection: NAD 1983 HARN Wisconsin TM

Date Printed: 10/13/2025 11:07 AM

תְּלִימָדָה וְעַמְּדָה

Page 15 of 15
De Soto Wastewater Treatment Facility

Page 15 of 15

An aerial photograph of a wastewater treatment facility (WWTF) in De Soto, Kansas. The facility is situated along a river, with a large green field and several buildings. A road runs alongside the facility, and a railway line is visible. A label "De Soto WWTF" is present on the right side.



4/4/2025

Timothy Gillespie
PO Box 37
De Soto, WI 54624

Subject: Conditional Approval of a Multi-Discharger Phosphorus Variance
Receiving Stream: Mississippi River in Crawford County
Permittee: Village of De Soto, WPDES WI-0029793

Dear Mr. Gillespie:

In accordance with s. 283.16 of the Wisconsin Statutes, you have requested coverage under Wisconsin's multi-discharger phosphorus variance for the DeSoto Wastewater Treatment Facility in an application dated 9/3/2024. Wisconsin's multi-discharger phosphorus variance was approved by EPA on February 6, 2017. Coverage under the multi-discharger phosphorus variance may only be granted to an existing source that demonstrates a major facility upgrade is necessary to achieve phosphorus compliance and the upgrade will result in economic hardship as defined in the federally approved variance. The water quality criterion for which you are seeking a variance is contained in s. NR 102.06, Wis. Adm. Code.

After review of the application materials, the Department is tentatively approving coverage under the phosphorus multi discharger variance because the applicant has demonstrated that a major facility upgrade would be required to comply with the phosphorus water quality based effluent limitation, and the applicant meets the economic hardship eligibility criteria delineated in the federally approved variance. In addition, the permitted facility has agreed to comply with the interim limitations that will be included in the WPDES permit, and has agreed to reduce the amount of phosphorus entering surface waters by making payments to the counties pursuant to s. 283.16(6)(b)1., Wis. Stats.

Public comment on this decision will be solicited at the time of permit reissuance after which a final decision will be made. The Department appreciates your attention and interest in Wisconsin's multi-discharger phosphorus variance. Should you have further questions regarding this matter, please contact me at (608) 400 – 5596 or by email at matthew.claucherty@wisconsin.gov.

Sincerely,

Matt Clawson

Matt Claucherty, MDV Point Source Coordinator
Bureau of Water Quality

e-cc Holly Heldstab, WDNR
Katie Jo Jerzak, WDNR
Tim Elkins, EPA Region 5
Michelle Woods, EPA Region 5

Notice: This checklist is meant to be a tool to help Department of Natural Resources (DNR) staff review municipal and industrial multi-discharger variance (MDV) applications (Forms 3200-149 and 3200-150). Personal information collected will be used for administrative purposes and may be provided to requesters to the extent required by Wisconsin's Open Records Law (ss. 19.31-19.39, Wis. Stats.).

Permittee Name

Village of De Soto

WPDES Permit Number	County		
WI- 0 0 2 9 7 9 3	Crawford		
1. Did the point source apply for the MDV at the appropriate time?	<input checked="" type="radio"/> Yes <input type="radio"/> No. <i>STOP- facility not eligible at this time.</i>		
2. This operation is (check one):	<input type="radio"/> New or relocated outfall. <i>STOP- facility not eligible.</i> <input checked="" type="radio"/> Existing outfall		
3. Is the point source is located in an MDV eligible area?	<input checked="" type="radio"/> Yes <input type="radio"/> No. <i>STOP- facility not eligible.</i>		
4. The secondary indicator score for the county (counties) the discharge is located is:	<u>6</u>		
5. Is a major facility upgrade required to comply with phosphorus limits?	<input checked="" type="radio"/> Yes <input type="radio"/> No. <i>STOP- facility not eligible.</i>		
6. List the months where phosphorus limits cannot be achieved during the permit term:	<input checked="" type="checkbox"/> All <input type="checkbox"/> Jan <input type="checkbox"/> Apr <input type="checkbox"/> Jul <input type="checkbox"/> Oct <input type="checkbox"/> Feb <input type="checkbox"/> May <input type="checkbox"/> Aug <input type="checkbox"/> Nov <input type="checkbox"/> Mar <input type="checkbox"/> Jun <input type="checkbox"/> Sep <input type="checkbox"/> Dec		
7. What is the current effluent level achievable?	Outfall Number(s) 001 Conc. (mg/L) 0.37 Method for calculation: <input checked="" type="radio"/> 30-day P99 <input type="radio"/> Other, specify: Does this concur with application? <input type="radio"/> Yes <input checked="" type="radio"/> No, why not: Application used smaller data subset		
8. What is the appropriate interim limitation(s) for the permit term?	0.5 mg/L as a monthly average, pursuant to s. 283.16(7), Wis. Stats. Target Value = 0.2 mg/L		

Provide Rationale:

The past three years' total phosphorus effluent results (10/1/2021 - 9/30/2024, n=148) yield a 30-day P99 value of 0.37 mg/L.

Note: See description in Section 2.02 of the MDV implementation guidance. Interim limitations should reflect the "highest attainable condition" for the permittee in question pursuant to s. 283.16(7), Wis. Stat.

9. For Industries Only- Where does the phosphorus in the effluent come from? (check all that apply)	<input type="checkbox"/> Process <input type="checkbox"/> Additive Usage <input type="checkbox"/> Water supply <i>Can intake credits be given or can the facility use an alternative water supply?</i> <input type="radio"/> Not feasible <input type="radio"/> Possibly, but further analysis needed <input type="radio"/> Not evaluated at this time	See Q14-15 & 19 on industrial form. If the answer is "possibly" or "not evaluated", the schedule section of the MDV permit should contain a requirement to perform this analysis.
10. Has this facility optimized?	<input checked="" type="radio"/> Yes <input type="radio"/> In progress <input type="radio"/> No	See Q14 on municipal form & Q16 & 20 on industrial form. Facility must optimize and operate at an optimize treatment level (s. 283.16(6)(a), Wis. Stat.) If no will need compliance schedule.
11. Has a facility plan/compliance alternative plan been completed for the facility?	<input checked="" type="radio"/> Yes <input type="radio"/> In progress <input type="radio"/> No	See Q15 on municipal form & Q17 on industrial form.
12. What is the projected cost for complying with phosphorus?	\$ <u>2,180,000.00</u> Source: Site specific cost estimate from Makepeace Engineering	Facility must submit site-specific compliance costs. If cost projections are used from EIA, the permittee must certify that these costs are reasonable for the facility in question. See "projected compliance costs" in Section 2.02 of the MDV Implementation Guidance for details.

Comments on planning efforts:

A Final Compliance Alternatives Plan (2019) was prepared by Makepeace Engineering and submitted on behalf of De Soto. The document provides planning information for meeting a WQBEL of 0.1 mg/L (six month) and 0.3 mg/L (monthly) phosphorus limit. De Soto has cited several factors that rule out WQT as a feasible alternative. As a Mississippi River Discharger, adaptive management would require too large of an offset. Other alternatives such as such as alternate discharge location and regionalization were investigated. Desoto installed and optimized phosphorus treatment during the prior permit term. Several tertiary treatment options for meeting the WQBEL are presented in the Plan. Reactive sand, cloth, and membrane filtration are given site specific cost estimates. These cost estimates were updated for the 2024 MDV application. The lowest cost option, cloth filtration, is used in the economic demonstration below.

13. Are adaptive management and water quality trading viable?	<input type="radio"/> Yes <input checked="" type="radio"/> Perhaps. Additional analysis required. <input type="radio"/> No	See Q18-21 on municipal form & Q22-25 on industrial form. If additional analyses required, the applicant may need to complete this analysis during the MDV permit term.
14. Has the point source met the appropriate primary screener?	<input checked="" type="radio"/> Yes <input type="radio"/> No. STOP- facility not eligible.	See Q4 of this form in addition to the "eligibility" guidance in Section 2.01 of the MDV Implementation Guidance.

Comments on economic demonstration:

Capital costs for cloth filtration were estimated at \$2,180,000. Additional O&M costs were estimated at \$20,700.00. Assuming a 20-year CWFP loan at 2.2% interest, annual debt service payments would be \$135,908.65. Total costs come to \$156,608.65 annually including O&M. 70% of this cost is borne by residential households, or \$109,626.06. The annual residential cost divided amongst 150 household users results in a per-user increase of \$730.84 annually. Current sewer rates are \$420/year, and future rates are expected to be \$1,150.84. This value is 1.32% of the community's \$86,996 MHI. In Crawford County with a secondary indicator score of 6, sewer rates at 1% of MHI meet the primary screener. The applicant meets the primary screener.

15. What watershed option was selected?

- County project option. *Complete Section 5.*
- Binding, written agreement with the DNR to construct a project or implement a watershed plan. *Complete Section 4.*
- Binding, written agreement with another person that is approved by the DNR to construct a project or implement a watershed plan. *Complete Section 4.*

Section 4. Watershed Plan Review

16. MDV Plan Number:

Note: This is for tracking purposes. Contact Statewide Phosphorus Implementation Coordinator for the plan number.

17. Did the point source complete Form 3200-148?

 Yes No

18. Is the project area in the same HUC 8 watershed as the point of discharge?

 Yes No. *STOP- Watershed plan must be updated.*

19. What is the annual offset required?

See Section 2.03 of the MDV implementation guidance. If this value is different from the offset target provided in form 3200-148, the watershed plan should be amended.

20. Does the plan ensure that the annual load is offset annually?

 Yes No. *STOP- Watershed plan must be updated.*

21. Are projects occurring on land owned/operated by a CAFO or within a permitted MS4 boundary?

- Yes. *Work with appropriate DNR staff to ensure projects are not working towards other permit compliance.*
- No.

22. Are other funding sources being used as part of the MDV watershed project?

- Yes. *Work with appropriate DNR staff to ensure that funding sources can be appropriately used in the plan area.*
- No.

23. Do you have any concerns about the watershed project?

Note: Coordinate with other DNR staff as appropriate.

 Yes. *STOP- Watershed plan must be updated.* No.

Comments:

Section 5. Payment to the County(ies)24. At this time, the appropriate per pound payment is: \$ 66.62

See "Payment Calculator" document at


\\central\water\WQWT_PROJECTS\WY_CW_Phosphorus\MDV.**Section 6. Determination**

Based on the available information, the MDV application is:

Approved
 Request for more information
 Denied

Additional Justification (if needed):

Certification

Preparer Name	Title
Matt Claucherty	Water Resources Management Specialist
Signature of Preparer	Date
	4/4/2025