

STATE OF WISCONSIN DEPARTMENT OF NATURAL RESOURCES

PUBLIC NOTICE OF INTENT TO REISSUE A WISCONSIN POLLUTANT DISCHARGE ELIMINATION SYSTEM (WPDES) PERMIT No.WI-0030937-11-0

Permittee: Village of Gilman, PO Box 156, Gilman, WI, 54433-0156

Facility Where Discharge Occurs: Village of Gilman, South Gilman Drive, Gilman, Wisconsin

Receiving Water And Location: A wetland tributary to the Yellow River in the Upper Yellow River Watershed in the Lower Chippewa River Drainage Basin in Taylor County

Brief Facility Description and Summary of Proposed Changes: The Village of Gilman wastewater treatment facility is designed to treat 125,000 gallons per day, currently treats an average of 73,000 gallons per day (June 2019 – June 2024). Wastewater (influent) generated from homes and businesses flows through a bar screen that removes large solids prior to flowing into two settling/septic tanks. Wastewater then travels to a dosing tank, and a filter bed that is divided into three zones. The filter bed is constructed of layers of fine and coarse sand where naturally occurring microorganisms living on the sand particles metabolize the remaining solids. After passing through the filter bed, some of the water is sent back to the dosing tank for recirculation through the filters. Wastewater is discharged to a wetland tributary of the Yellow River in Taylor County. The solids from the settling/septic tanks are pumped regularly to prevent the discharge of accumulated solids to the sand filters. These solids are considered septage and are regulated under NR 113, Wisconsin Administrative Code, for septage disposal.

It is the Department's intention to renew the permit for another term. The proposed new permit expiration date will be December 31, 2029. Limitations and conditions which the Department believes adequately protect the receiving water are included in the proposed permit. Additions to the effluent section of the permit include: [1] The effluent ammonia variable limits table was updated from the previous permit term. [2] An effluent E. coli schedule to comply with seasonal limits. At the end of the schedule seasonal monitoring and limits are required. [3] Phosphorus monitoring and schedule to comply with water quality-based limits (WQBEL). An interim limit, effective until the schedule is complete has been included. [4] PFOS + PFOA monitoring once every two months and minimization schedule. [5] Annual Total Nitrogen (TKN, N02+N03 and Total N) monitoring in rotating quarters. [6] Two Acute WET tests are required.

Permit Drafter's Name, Address, Phone and Email: Sheri A. Snowbank, DNR, 810 W Maple St, Spooner, WI, 54801, (715) 635-4131, Sheri.Snowbank@wisconsin.gov

Basin Engineer's Name, Address, Phone and Email: Arthur Ryzak, DNR, N4103 Highway 27, Ladysmith, WI 54848, (715) 403-2924, arthur.ryzak@wisconsin.gov

Persons wishing to comment on or object to the proposed permit action, or to request a public hearing, may write to the Department of Natural Resources at the above-named permit drafter's address. All comments or suggestions received no later than 30 days after the publication date of this public notice will be considered along with other information on file in making a final decision regarding the permit. Anyone providing comments in response to this public notice will receive a notification of the Department's final decision when the permit is issued. Where designated as a reviewable surface water discharge permit, the U.S. Environmental Protection Agency is allowed up to 90 days to submit comments or objections regarding this permit determination. If no comments are received on the proposed permit from anyone, including U.S. EPA, the permit will be issued as proposed.

The Department may schedule a public informational hearing if requested by any person and shall schedule a public informational hearing if a petition requesting a hearing is received from 5 or more persons or if response to this notice indicates significant public interest pursuant to s. 283.49, Wis. Stats. Requests for a public informational hearing shall state the following: the name and address of the person(s) requesting the hearing; the interest in the proposed permit of the person(s) requesting the hearing; the reasons for the request; and the issues proposed to be considered at the hearing.

Information on file for this permit action, including the draft permit, fact sheet and permit application, may be inspected and copied at either the above-named permit drafter's office or the above named basin engineer's office, Monday through Friday (except holidays), between 9:00 a.m. and 3:30 p.m. Please call the permit drafter or basin engineer for directions to their office location, if necessary. Information on this permit action may also be obtained by calling the permit drafter at (715) 635-4131 or by writing to the Department. Reasonable costs (15 cents per page for copies and 7 cents per page for scanning) will be charged for information in the file other than the public notice, permit and fact sheet. Permit information is also available on the internet at:

<http://dnr.wi.gov/topic/wastewater/PublicNotices.html>. Pursuant to the Americans with Disabilities Act, reasonable accommodation, including the provision of informational material in an alternative format, will be made to qualified individuals upon request.

NAME AND ADDRESS OF PUBLISHING NEWSPAPER: The Star News, PO Box 180, Medford, WI 54451-0180

Date Notice Issued: Thursday, October 24, 2024