



WPDES PERMIT

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
**PERMIT TO DISCHARGE UNDER THE WISCONSIN POLLUTANT DISCHARGE
ELIMINATION SYSTEM**

VILLAGE OF OREGON

is permitted, under the authority of Chapter 283, Wisconsin Statutes, to discharge from a facility
located at

101 NORTH PERRY PARKWAY, OREGON, WISCONSIN

SW ¼ of NE ¼ of Section 12, T5N, R9E

to

Oregon Branch (Badfish Creek Watershed, LR07 – Lower Rock River Basin) in Dane County

Outfall Location – Lat: 42.92469° N / Long: 89.37554° W

in accordance with the effluent limitations, monitoring requirements and other conditions set
forth in this permit.

The permittee shall not discharge after the date of expiration. If the permittee wishes to continue to discharge after this expiration date an application shall be filed for reissuance of this permit, according to Chapter NR 200, Wis. Adm. Code, at least 180 days prior to the expiration date given below.

State of Wisconsin Department of Natural Resources
For the Secretary

By

Lisa Creegan
Wastewater Field Supervisor

Date Permit Signed/Issued

PERMIT TERM: EFFECTIVE DATE - April 01, 2026

EXPIRATION DATE - March 31, 2031

TABLE OF CONTENTS

1 INFLUENT REQUIREMENTS	1
1.1 SAMPLING POINT(S)	1
1.2 MONITORING REQUIREMENTS	1
1.2.1 <i>Sampling Point 701 - INFLUENT</i>	1
2 IN-PLANT REQUIREMENTS	2
2.1 SAMPLING POINT(S)	2
2.2 MONITORING REQUIREMENTS AND LIMITATIONS	2
2.2.1 <i>Sampling Point 107 - GEN PLANT (Hg blank)</i>	2
3 SURFACE WATER REQUIREMENTS	3
3.1 SAMPLING POINT(S)	3
3.2 MONITORING REQUIREMENTS AND EFFLUENT LIMITATIONS	3
3.2.1 <i>Sampling Point (Outfall) 001 - EFFLUENT</i>	3
4 LAND APPLICATION REQUIREMENTS	11
4.1 SAMPLING POINT(S)	11
4.2 MONITORING REQUIREMENTS AND LIMITATIONS	11
4.2.1 <i>Sampling Point (Outfall) 004 - SLUDGE</i>	11
5 SCHEDULES	18
5.1 MERCURY EFFLUENT LIMITS	18
5.2 PFOS/PFOA MINIMIZATION PLAN DETERMINATION OF NEED	18
5.3 WATERSHED ADAPTIVE MANAGEMENT OPTION ANNUAL REPORT SUBMITTALS	19
5.4 DISINFECTION AND EFFLUENT LIMITATIONS FOR E. COLI	20
5.5 INSTALL CONTINUOUS FLOW RECORDING DEVICE	21
5.6 LAND APPLICATION MANAGEMENT PLAN	21
6 STANDARD REQUIREMENTS	22
6.1 REPORTING AND MONITORING REQUIREMENTS	22
6.1.1 <i>Monitoring Results</i>	22
6.1.2 <i>Sampling and Testing Procedures</i>	22
6.1.3 <i>Recording of Results</i>	22
6.1.4 <i>Reporting of Monitoring Results</i>	23
6.1.5 <i>Compliance Maintenance Annual Reports</i>	23
6.1.6 <i>Records Retention</i>	23
6.1.7 <i>Other Information</i>	23
6.1.8 <i>Reporting Requirements – Alterations or Additions</i>	24
6.2 SYSTEM OPERATING REQUIREMENTS	24
6.2.1 <i>Noncompliance Reporting</i>	24
6.2.2 <i>Flow Meters</i>	24
6.2.3 <i>Raw Grit and Screenings</i>	24
6.2.4 <i>Sludge Management</i>	25
6.2.5 <i>Prohibited Wastes</i>	25
6.2.6 <i>Bypass</i>	25
6.2.7 <i>Scheduled Bypass</i>	25
6.2.8 <i>Controlled Diversions</i>	26
6.2.9 <i>Proper Operation and Maintenance</i>	26
6.2.10 <i>Operator Certification</i>	26
6.3 SEWAGE COLLECTION SYSTEMS	26
6.3.1 <i>Sanitary Sewage Overflows and Sewage Treatment Facility Overflows</i>	26
6.3.2 <i>Capacity, Management, Operation and Maintenance (CMOM) Program</i>	28
6.3.3 <i>Sewer Cleaning Debris and Materials</i>	28

6.4 SURFACE WATER REQUIREMENTS	28
6.4.1 <i>Permittee-Determined Limit of Quantitation Incorporated into this Permit</i>	29
6.4.2 <i>Appropriate Formulas for Effluent Calculations</i>	29
6.4.3 <i>Effluent Temperature Requirements</i>	29
6.4.4 <i>Visible Foam or Floating Solids</i>	29
6.4.5 <i>Surface Water Uses and Criteria</i>	29
6.4.6 <i>Percent Removal</i>	30
6.4.7 <i>E. coli</i>	30
6.4.8 <i>Seasonal Disinfection</i>	30
6.4.9 <i>Whole Effluent Toxicity (WET) Monitoring Requirements</i>	30
6.4.10 <i>Whole Effluent Toxicity (WET) Identification and Reduction</i>	30
6.4.11 <i>PFOS and PFOA Requirements</i>	31
6.5 LAND APPLICATION REQUIREMENTS	31
6.5.1 <i>Sludge Management Program Standards And Requirements Based Upon Federally Promulgated Regulations</i>	31
6.5.2 <i>General Sludge Management Information</i>	31
6.5.3 <i>Sludge Samples</i>	31
6.5.4 <i>Land Application Characteristic Report</i>	31
6.5.5 <i>Calculation of Water Extractable Phosphorus</i>	32
6.5.6 <i>Monitoring and Calculating PCB Concentrations in Sludge</i>	32
6.5.7 <i>Annual Land Application Report</i>	32
6.5.8 <i>Other Methods of Disposal or Distribution Report</i>	33
6.5.9 <i>Approval to Land Apply</i>	33
6.5.10 <i>Soil Analysis Requirements</i>	33
6.5.11 <i>Land Application Site Evaluation</i>	33
6.5.12 <i>Class B Sludge: Fecal Coliform Limitation</i>	33
6.5.13 <i>Class B Sludge - Vector Control: Injection</i>	34
7 SUMMARY OF REPORTS DUE	35

1 Influent Requirements

1.1 Sampling Point(s)

Sampling Point Designation	
Sampling Point Number	Sampling Point Location, Waste Type/Sample Contents and Treatment Description (as applicable)
701	Influent: 24-Hr flow proportional composite samples collected prior to screening and grit removal.

1.2 Monitoring Requirements

The permittee shall comply with the following monitoring requirements.

1.2.1 Sampling Point 701 - INFLUENT

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Daily	Continuous	
BOD ₅ , Total		mg/L	3/Week	24-Hr Flow Prop Comp	
Suspended Solids, Total		mg/L	3/Week	24-Hr Flow Prop Comp	
Mercury, Total Recoverable		ng/L	Quarterly	24-Hr Flow Prop Comp	See the Mercury Monitoring section.

1.2.1.1 Mercury Monitoring

The permittee shall collect and analyze all mercury samples according to the data quality requirements of ss. NR 106.145(9) and (10), Wisconsin Administrative Code. The limit of quantitation (LOQ) used for the effluent and field blank shall be less than 1.3 ng/L, unless the samples are quantified at levels above 1.3 ng/L. The permittee shall collect at least one mercury field blank for each set of mercury samples (a set of samples may include combinations of intake, influent, effluent or other samples all collected on the same day). The permittee shall report results of samples and field blanks to the Department on Discharge Monitoring Reports.

2 In-Plant Requirements

2.1 Sampling Point(s)

Sampling Point Designation	
Sampling Point Number	Sampling Point Location, Waste Type/Sample Contents and Treatment Description (as applicable)
107	In-Plant: Mercury field blank collected using standard sample handling procedures.

2.2 Monitoring Requirements and Limitations

The permittee shall comply with the following monitoring requirements and limitations.

2.2.1 Sampling Point 107 - GEN PLANT (Hg blank)

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Mercury, Total Recoverable		ng/L	Quarterly	Blank	See the Mercury Monitoring section.

2.2.1.1 Mercury Monitoring

The permittee shall collect and analyze all mercury samples according to the data quality requirements of ss. NR 106.145(9) and (10), Wisconsin Administrative Code. The limit of quantitation (LOQ) used for the effluent and field blank shall be less than 1.3 ng/L, unless the samples are quantified at levels above 1.3 ng/L. The permittee shall collect at least one mercury field blank for each set of mercury samples (a set of samples may include combinations of intake, influent, effluent or other samples all collected on the same day). The permittee shall report results of samples and field blanks to the Department on Discharge Monitoring Reports.

3 Surface Water Requirements

3.1 Sampling Point(s)

Sampling Point Designation	
Sampling Point Number	Sampling Point Location, Waste Type/Sample Contents and Treatment Description (as applicable)
001	Effluent: 24-Hr Flow Proportional composite samples collected prior to step aerator and grab samples collected after step aerator prior to discharge to the Oregon Branch. A Parshall flume with ultrasonic meter is used to measure flow after the UV disinfection tank.

3.2 Monitoring Requirements and Effluent Limitations

The permittee shall comply with the following monitoring requirements and limitations.

3.2.1 Sampling Point (Outfall) 001 - EFFLUENT

Monitoring Requirements and Effluent Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Daily	Continuous	Monitoring begins April 1, 2027. See the Install Continuous Flow Recording Device Schedule.
BOD ₅ , Total	Weekly Avg	30 mg/L	3/Week	24-Hr Flow Prop Comp	
BOD ₅ , Total	Monthly Avg	20 mg/L	3/Week	24-Hr Flow Prop Comp	
Suspended Solids, Total	Weekly Avg	30 mg/L	3/Week	24-Hr Flow Prop Comp	
Suspended Solids, Total	Monthly Avg	20 mg/L	3/Week	24-Hr Flow Prop Comp	
Suspended Solids, Total	Weekly Avg	348 lbs/day	3/Week	Calculated	Limit effective in January.
Suspended Solids, Total	Weekly Avg	430 lbs/day	3/Week	Calculated	Limit effective in February.
Suspended Solids, Total	Weekly Avg	414 lbs/day	3/Week	Calculated	Limit effective in March, May and July.
Suspended Solids, Total	Weekly Avg	428 lbs/day	3/Week	Calculated	Limit effective in April, June and November.
Suspended Solids, Total	Weekly Avg	359 lbs/day	3/Week	Calculated	Limit effective in August.
Suspended Solids, Total	Weekly Avg	234 lbs/day	3/Week	Calculated	Limit effective in September.

Monitoring Requirements and Effluent Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Suspended Solids, Total	Weekly Avg	365 lbs/day	3/Week	Calculated	Limit effective in October.
Suspended Solids, Total	Weekly Avg	364 lbs/day	3/Week	Calculated	Limit effective in December.
Suspended Solids, Total	Monthly Avg	247 lbs/day	3/Week	Calculated	Limit effective in January.
Suspended Solids, Total	Monthly Avg	305 lbs/day	3/Week	Calculated	Limit effective in February.
Suspended Solids, Total	Monthly Avg	294 lbs/day	3/Week	Calculated	Limit effective in March, May and July.
Suspended Solids, Total	Monthly Avg	303 lbs/day	3/Week	Calculated	Limit effective in April, June and November.
Suspended Solids, Total	Monthly Avg	255 lbs/day	3/Week	Calculated	Limit effective in August.
Suspended Solids, Total	Monthly Avg	166 lbs/day	3/Week	Calculated	Limit effective in September.
Suspended Solids, Total	Monthly Avg	259 lbs/day	3/Week	Calculated	Limit effective in October.
Suspended Solids, Total	Monthly Avg	258 lbs/day	3/Week	Calculated	Limit effective in December.
pH Field	Daily Max	9.0 su	3/Week	Grab	
pH Field	Daily Min	6.0 su	3/Week	Grab	
Dissolved Oxygen	Daily Min	4.0 mg/L	3/Week	Grab	
Nitrogen, Ammonia (NH ₃ -N) Total	Daily Max	10 mg/L	3/Week	24-Hr Flow Prop Comp	Limit effective October through May.
Nitrogen, Ammonia (NH ₃ -N) Total	Weekly Avg	6.2 mg/L	3/Week	24-Hr Flow Prop Comp	Limit effective in April and May.
Nitrogen, Ammonia (NH ₃ -N) Total	Weekly Avg	6.3 mg/L	3/Week	24-Hr Flow Prop Comp	Limit effective June through September.
Nitrogen, Ammonia (NH ₃ -N) Total	Weekly Avg	10 mg/L	3/Week	24-Hr Flow Prop Comp	Limit effective October through March.
Nitrogen, Ammonia (NH ₃ -N) Total	Monthly Avg	2.5 mg/L	3/Week	24-Hr Flow Prop Comp	Limit effective in April and May.
Nitrogen, Ammonia (NH ₃ -N) Total	Monthly Avg	2.6 mg/L	3/Week	24-Hr Flow Prop Comp	Limit effective June through September.
Nitrogen, Ammonia (NH ₃ -N) Total	Monthly Avg	10 mg/L	3/Week	24-Hr Flow Prop Comp	Limit effective October through March.
E. coli	Geometric Mean - Monthly	126 #/100 ml	Weekly	Grab	Monitoring and limit effective March through November annually beginning April 1, 2027. See the Disinfection and Effluent Limitations for E. coli Schedule.

Monitoring Requirements and Effluent Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
E. coli	% Exceedance	10 Percent	Monthly	Calculated	Monitoring and limit effective March through November annually beginning April 1, 2027. See the Disinfection and Effluent Limitations for E. coli Schedule. See also the E. coli Percent Limit section. Enter the result in the eDMR on the last day of the month.
Chloride		mg/L	Monthly	24-Hr Flow Prop Comp	Monitoring only January through December 2029.
Mercury, Total Recoverable		ng/L	Quarterly	Grab	Monitoring only until the final limits become effective. See the Mercury Monitoring section and the Mercury Effluent Limits Schedule.
PFOS		ng/L	1/ 2 Months	Grab	Monitoring only. See PFOS/PFOA Minimization Plan Determination of Need Schedule.
PFOA		ng/L	1/ 2 Months	Grab	Monitoring only. See PFOS/PFOA Minimization Plan Determination of Need Schedule.
Phosphorus, Total	Monthly Avg	1.0 mg/L	3/Week	24-Hr Flow Prop Comp	
Phosphorus, Total	6-Month Avg	0.6 mg/L	3/Week	24-Hr Flow Prop Comp	This is an Adaptive Management interim limit effective upon permit issuance until April 30, 2026.
Phosphorus, Total	6-Month Avg	0.5 mg/L	3/Week	24-Hr Flow Prop Comp	This is an Adaptive Management interim limit that goes into effect May 1, 2026. See the Schedules section and effluent requirements below.
Phosphorus, Total		lbs/day	3/Week	Calculated	Calculate the daily mass discharge of phosphorus in lbs/day on the same days phosphorus sampling occurs. $\text{Mass (lbs/day)} = \text{Concentration (mg/L)} \times \text{Flow (MGD)} \times 8.34$

Monitoring Requirements and Effluent Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Nitrogen, Total Kjeldahl		mg/L	Quarterly	24-Hr Flow Prop Comp	
Nitrogen, Nitrite + Nitrate Total		mg/L	Quarterly	24-Hr Flow Prop Comp	
Nitrogen, Total		mg/L	Quarterly	Calculated	Total Nitrogen shall be calculated as the sum of reported values for Total Kjeldahl Nitrogen and Total Nitrite + Nitrate Nitrogen.
Acute WET		TU _a	See Listed Qtr(s)	24-Hr Flow Prop Comp	See the Whole Effluent Toxicity (WET) Testing section.
Chronic WET	Monthly Avg	1.0 TUC	See Listed Qtr(s)	24-Hr Flow Prop Comp	See the Whole Effluent Toxicity (WET) Testing section.

3.2.1.1 Annual Average Design Flow

The annual average design flow of the permittee's wastewater treatment facility is 1.8 MGD.

3.2.1.2 *E. coli* Percent Limit

No more than 10 percent of *E. coli* bacteria samples collected in any calendar month may exceed 410 #/100 ml. Bacteria samples may be collected more frequently than required. All samples shall be reported on the monthly discharge monitoring reports (DMRs). The following calculation should be used to calculate percent exceedances.

$$\frac{\text{\# of Samples greater than 410 \# / 100 mL}}{\text{Total \# of samples}} \times 100 = \% \text{ Exceedance}$$

3.2.1.3 Mercury Monitoring

The permittee shall collect and analyze all mercury samples according to the data quality requirements of ss. NR 106.145(9) and (10), Wis. Adm. Code. The limit of quantitation (LOQ) used for the effluent and field blank shall be less than 1.3 ng/L, unless the samples are quantified at levels above 1.3 ng/L. The permittee shall collect at least one mercury field blank for each set of mercury samples (a set of samples may include combinations of intake, influent, effluent or other samples all collected on the same day). The permittee shall report results of samples and field blanks to the Department on Discharge Monitoring Reports.

3.2.1.4 PFOS/PFOA Sampling and Reporting Requirements

For grab samples, as defined per s. NR 218.04(10), Wis. Adm. Code, a single sample at a location as defined by the sample point description shall be taken during the time of the day most representative to capture all potential discharges. If extra equipment besides the sample bottle is used to collect the sample, it is recommended that a one-time equipment blank is collected with the first sample. An equipment blank would be collected by passing laboratory-verified PFAS-free water over or through field sampling equipment before the collection of a grab sample to evaluate potential contamination from the equipment used during sample.

If any equipment blanks are performed, these results shall be reported in the comments section of the eDMR and shall also be documented in the reports submitted as part of the PFOS/PFOA Minimization Plan Determination of Need schedule of the permit.

3.2.1.5 PFOS/PFOA Minimization Plan Determination of Need

The permittee shall monitor PFOS and PFOA as specified in the table above and report on the effluent concentrations including trends in monthly and annual average PFOS and PFOA concentrations as specified in the PFOS/PFOA Minimization Plan Determination of Need Schedule.

If, after reviewing the data, the Department determines that a minimization plan for PFOS and PFOA is necessary based on the procedures in s. NR 106.98(4), Wis. Adm. Code, the Department will notify the permittee in writing that a PFOS and PFOA minimization plan that satisfies the requirements in s. NR 106.99, Wis. Adm. Code, is required. The permittee shall submit an initial plan for Department approval no later than 90 days after written notification was sent from the Department in accordance with s. NR 106.985(2)(a), Wis. Adm. Code. Pursuant to s. NR 106.985(2)(b), Wis. Adm. Code, as soon as possible after Department approval of the PFOS and PFOA minimization plan, the Department will modify or revoke and reissue the permit in accordance with public notice procedures under ch. 283, Wis. Stats., and ch. NR 203, Wis. Adm. Code, to include the PFOS and PFOA minimization plan and other related terms and condition.

If, however, the Department determines that a PFOS and PFOA minimization plan is unnecessary based on the procedures in s. NR 106.98(4), Wis. Adm. Code, the Department shall notify the permittee that no further action is required. Per s. NR 106.98(3)(a), Wis. Adm. Code, the Department may reduce monitoring frequency to once every 3 months (quarterly) on a case-by-case basis, but only after at least 12 representative results have been generated. If the permittee requests a reduction in monitoring and the Department agrees a reduction would be appropriate, the permit may be modified in accordance with public notice procedures under ch. 283, Wis. Stats., and ch. NR 203, Wis. Adm. Code, to incorporate this change.

3.2.1.6 Total Phosphorus Interim Limit, Averaging Periods and Compliance Determination

The adaptive management total phosphorus interim limit of 0.5 mg/L goes into effect May 1, 2026, beginning the averaging period from May 1, 2026, through October 31, 2026. The averaging periods are May through October and November through April. Compliance with the 6-month average limit is evaluated at the end of each 6-month period on April 30th and October 31st annually.

3.2.1.7 Phosphorus Limitation(s) and Adaptive Management Requirements

The Village of Oregon has requested and the Department has approved a plan to implement a watershed adaptive management approach under s. NR 217.18, Wis. Adm. Code, as a means for Oregon to achieve compliance with the phosphorus water quality standard in s. NR 102.06, Wis. Adm. Code. The phosphorus limitations and conditions in this permit reflect the approved adaptive management plan No. AM-2025-02 (September 2025). Failure to implement terms and conditions of this section is a violation of this permit. In cooperation with the other signatories of the Intergovernmental Agreement for an Adaptive Management Plan in the Yahara Watershed, the permittee shall design and implement the actions identified in section 3 of the AM Plan No. AM-2025-02 (September 2025) in accordance with the goals and measures identified in the approved plan.

The goal for phosphorus load reductions for Oregon for this permit term is equal to 60% of the total phosphorus load reduction goal from Oregon to the watershed, according to the approved adaptive management plan. This load reduction is identified as 22,817 pounds of phosphorus per year for Oregon. If Oregon does not achieve its load reduction goal by March 31, 2031, the watershed adaptive management option may not be available to the permittee upon permit reissuance, or alternatively, the Department may request appropriate modifications to the AM Plan as a condition of permit reissuance.

Pursuant to s. NR 217.18(3)(e)2, Wis. Adm. Code, the adaptive management interim limitation is 0.5 mg/L, expressed as a six-month average. Additionally, a 1.0 mg/L limitation expressed as a monthly average is required. The final

calculated water quality based effluent limitations for phosphorus are a six-month seasonal average limitation of 0.075 mg/L and a monthly average limitation of 0.225 mg/L based on current in-stream phosphorus data. These limitations may be recalculated based on changes in the in-stream data at the time of permit reissuance. There are also additional mass-based limits from the Rock River TMDL and they are listed in the table below. These limits will become effective at the end of three permit terms unless the adaptive management project is terminated per s. NR 217.18(3)(g), Wis. Adm. Code, in which case the limits may be imposed at an earlier date, or the phosphorus reductions specified in the adaptive management plan have been achieved.

Total Phosphorus Effluent Limitations

Month	Monthly Avg. (lbs./day)
Jan	2.18
Feb	2.43
March	2.11
April	2.16
May	2.04
June	2.20
July	2.02
Aug	1.95
Sept	1.95
Oct	1.99
Nov	2.17
Dec	2.16

3.2.1.8 Additional Watershed Adaptive Management Project Requirements

Adaptive Management Plan No. AM-2025-02 (September 2025) is a partnership between several WPDES permittees and a diverse group of entities that are not WPDES permit holders. The WPDES permittees include three publicly owned treatment works (POTWs) – Stoughton Utilities, Village of Oregon, and the Madison Metropolitan Sewerage District and WI DNR Nevin Fish Hatchery and various Municipal Separate Storm Sewer Systems (MS4s) that have signed an intergovernmental agreement to guide implementation of the plan. The adaptive management plan is a means to achieve compliance with the phosphorus water quality standard in s. NR 102.06, Wis. Adm. Code, and the Rock River TMDL. As the approved plan is written, Madison Metropolitan Sewerage District shall submit surface water samples as identified in AM Plan No. AM-2025-02 (September 2025) and shall submit the results as part of the annual reports on the implementation of AM Plan No. AM-2025-02 (September 2025).

The goal for phosphorus load reductions for this permit term within the Yahara River action area, as identified in AM-2025-02 (September 2025), shall be 60% of the total phosphorus load reduction from the combination of all four point sources (Stoughton Utilities, Village of Oregon, Madison Metropolitan Sewerage District and WI DNR Nevin Fish Hatchery). This load reduction goal is identified as 65,824 pounds of phosphorus per year from the contributing point sources in the adaptive management plan. If the load reduction goal is not met by March 31, 2031, the watershed adaptive management option may not be available to the participating permittees upon permit reissuance, or alternatively, the Department may request appropriate modifications to the AM Plan as a condition of permit reissuance.

3.2.1.9 Adaptive Management Reopener Clause

Per s. NR 217.18(3)(g), Wis. Adm. Code, the Department may terminate the adaptive management option for a permittee through permit modification or at permit reissuance and require compliance with a phosphorus effluent limitation calculated under s. NR 217.13, Wis. Adm. Code, or a US EPA approved TMDL based on any of the following reasons:

1. Failure to implement the adaptive management actions in accordance with the approved adaptive management plan and compliance schedule established in the permit.
2. New information becomes available that changes the Department's determinations made under s. NR 217.18(2), Wis. Adm. Code.
3. Circumstances beyond the permittee's control have made compliance with the applicable phosphorus criterion in s. NR 102.06, Wis. Adm. Code, pursuant to the plan's goals and measures infeasible.
4. A determination by the Department that sufficient reductions have not been achieved to timely reduce the amount of total phosphorus to meet the criteria in s. NR 102.06, Wis. Adm. Code.

3.2.1.10 Adaptive Management Requirements - Optimization

The permittee shall continue to optimize performance to control phosphorus discharges in accordance with s. NR 217.18(3)(c), Wis Adm. Code.

3.2.1.11 Whole Effluent Toxicity (WET) Testing

Primary Control Water for Acute Tests: A synthetic (standard) laboratory water may be used.

Primary Control Water for Chronic Tests: A grab sample collected from the Oregon Branch shall be used.

Instream Waste Concentration (IWC): 100%

Dilution Series: At least five effluent concentrations and dual controls must be included in each test.

- **Acute:** 100, 50, 25, 12.5, 6.25% and any additional selected by the permittee.
- **Chronic:** 100, 75, 50, 25, 12.5% and any additional selected by the permittee.

WET Testing Frequency:

Acute tests are required during the following quarters:

- **Acute:** October-December 2026; July-September 2027; April-June 2028; January-March 2029; and October-December 2030

Acute WET testing shall continue after the permit expiration date (until the permit is reissued) in accordance with the WET requirements specified for the last full calendar year of this permit. For example, the next test would be required in October-December 2031.

Chronic tests are required during the following quarters:

- **Chronic:** October-December 2026; July-September 2027; April-June 2028; January-March 2029; and October-December 2030

Chronic WET testing shall continue after the permit expiration date (until the permit is reissued) in accordance with the WET requirements specified for the last full calendar year of this permit. For example, the next test would be required in October-December 2031.

Testing: WET testing shall be performed during normal operating conditions. Permittees are not allowed to turn off or otherwise modify treatment systems, production processes, or change other operating or treatment conditions during WET tests.

Reporting: The permittee shall report test results on the Discharge Monitoring Report form, and also complete the "Whole Effluent Toxicity Test Report Form" (Section 6, "*State of Wisconsin Aquatic Life Toxicity Testing Methods Manual, 2nd Edition*"), for each test. The original, complete, signed version of the Whole Effluent Toxicity Test Report Form shall be sent to the Biomonitoring Coordinator, Bureau of Water Quality, 101 S. Webster St., P.O. Box 7921, Madison, WI 53707-7921, within 45 days of test completion. The Discharge Monitoring Report (DMR) form shall be submitted electronically by the required deadline.

Determination of Positive Results: An acute toxicity test shall be considered positive if the Toxic Unit - Acute (TU_a) is greater than 1.0 for either species (fathead minnow (*Pimephales promelas*) and waterflea (*Ceriodaphnia dubia*)). The TU_a shall be calculated as follows: $TU_a = 100 \div LC_{50}$. A chronic toxicity test shall be considered positive if the Toxic Unit - Chronic (TU_c) is greater than 1.0 for either species. The TU_c shall be calculated as follows: $TU_c = 100 \div IC_{25}$.

Additional Testing Requirements: Within 90 days of a test which showed positive results, the permittee shall submit the results of at least 2 retests to the Biomonitoring Coordinator on "Whole Effluent Toxicity Test Report Forms". The 90-day reporting period shall begin the day after the test which showed a positive result. The retests shall be completed using the same species and test methods specified for the original test (see the Standard Requirements section herein).

4 Land Application Requirements

4.1 Sampling Point(s)

The discharge(s) shall be limited to land application of the waste type(s) designated for the listed sampling point(s) on Department approved land spreading sites or by hauling to another facility.

Sampling Point Designation	
Sampling Point Number	Sampling Point Location, Waste Type/Sample Contents and Treatment Description (as applicable)
004	Sludge: Aerobically digested, thickened liquid, Class B. Representative sludge samples shall be collected after the gravity belt thickener.

4.2 Monitoring Requirements and Limitations

The permittee shall comply with the following monitoring requirements and limitations.

4.2.1 Sampling Point (Outfall) 004 - SLUDGE

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Solids, Total		Percent	Annual	Composite	
Arsenic Dry Wt	Ceiling	75 mg/kg	Annual	Composite	
Arsenic Dry Wt	High Quality	41 mg/kg	Annual	Composite	
Cadmium Dry Wt	Ceiling	85 mg/kg	Annual	Composite	
Cadmium Dry Wt	High Quality	39 mg/kg	Annual	Composite	
Copper Dry Wt	Ceiling	4,300 mg/kg	Annual	Composite	
Copper Dry Wt	High Quality	1,500 mg/kg	Annual	Composite	
Lead Dry Wt	Ceiling	840 mg/kg	Annual	Composite	
Lead Dry Wt	High Quality	300 mg/kg	Annual	Composite	
Mercury Dry Wt	Ceiling	57 mg/kg	Annual	Composite	
Mercury Dry Wt	High Quality	17 mg/kg	Annual	Composite	
Molybdenum Dry Wt	Ceiling	75 mg/kg	Annual	Composite	
Nickel Dry Wt	Ceiling	420 mg/kg	Annual	Composite	
Nickel Dry Wt	High Quality	420 mg/kg	Annual	Composite	
Selenium Dry Wt	Ceiling	100 mg/kg	Annual	Composite	

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Selenium Dry Wt	High Quality	100 mg/kg	Annual	Composite	
Zinc Dry Wt	Ceiling	7,500 mg/kg	Annual	Composite	
Zinc Dry Wt	High Quality	2,800 mg/kg	Annual	Composite	
Nitrogen, Total Kjeldahl		Percent	Annual	Composite	
Nitrogen, Ammonium (NH ₄ -N) Total		Percent	Annual	Composite	
Phosphorus, Total		Percent	Annual	Composite	
Phosphorus, Water Extractable		% of Tot P	Annual	Composite	
Potassium, Total Recoverable		Percent	Annual	Composite	
PCB Total Dry Wt	Ceiling	50 mg/kg	Once	Composite	Monitoring required in 2027. See Sludge Analysis for PCBs section and the Standard Requirements section for Monitoring and Calculating PCB Concentrations in Sludge.
PCB Total Dry Wt	High Quality	10 mg/kg	Once	Composite	Monitoring required in 2027. See Sludge Analysis for PCBs section and the Standard Requirements section for Monitoring and Calculating PCB Concentrations in Sludge.
PFOA + PFOS		µg/kg	Annual	Calculated	Report the sum of PFOA and PFOS. See PFAS Permit Sections for more information.
PFAS Dry Wt			Annual	Grab	Perfluoroalkyl and Polyfluoroalkyl Substances based on updated DNR PFAS List. See PFAS Permit Sections for more information.

Other Sludge Requirements	
Sludge Requirements	Sample Frequency
List 3 Requirements – Pathogen Control: The requirements in List 3 shall be met prior to land application of sludge.	Annual
List 4 Requirements – Vector Attraction Reduction: The vector attraction reduction shall be satisfied prior to, or at the time of land application as specified in List 4.	Annual

4.2.1.1 Changes in Feed Sludge Characteristics

If a change in feed sludge characteristics, treatment process, or operational procedures occurs which may result in a significant shift in sludge characteristics, the permittee shall reanalyze the sludge for List 1, 2, 3 and 4 parameters each time such change occurs.

4.2.1.2 Sludge Which Exceeds the High Quality Limit

Cumulative pollutant loading records shall be kept for all bulk land application of sludge which does not meet the high quality limit for any parameter. This requirement applies for the entire calendar year in which any exceedance of Table 3 of s. NR 204.07(5)(c), Wis. Adm. Code, is experienced. Such loading records shall be kept for all List 1 parameters for each site land applied in that calendar year. The formula to be used for calculating cumulative loading is as follows:

$[(\text{Pollutant concentration (mg/kg)} \times \text{dry tons applied/ac}) \div 500] + \text{previous loading (lbs/acre)} = \text{cumulative lbs pollutant per acre}$

When a site reaches 90% of the allowable cumulative loading for any metal established in Table 2 of s. NR 204.07(5)(b), Wis. Adm. Code, the Department shall be so notified through letter or in the comment section of the annual land application report (3400-55).

4.2.1.3 Sludge Analysis for PCBs

The permittee shall analyze the sludge for Total PCBs one time during **2027**. The results shall be reported as "PCB Total Dry Wt". Either congener-specific analysis or Aroclor analysis shall be used to determine the PCB concentration. The permittee may determine whether Aroclor or congener specific analysis is performed. Analyses shall be performed in accordance with Table EM in s. NR 219.04, Wis. Adm. Code and the conditions specified in Standard Requirements of this permit. PCB results shall be submitted by January 31, following the specified year of analysis.

4.2.1.4 Lists 1, 2, 3, and 4

List 1 TOTAL SOLIDS AND METALS	
See the Monitoring Requirements and Limitations table above for monitoring frequency and limitations for the List 1 parameters	
Solids, Total (percent)	
Arsenic, mg/kg (dry weight)	
Cadmium, mg/kg (dry weight)	
Copper, mg/kg (dry weight)	

List 1

TOTAL SOLIDS AND METALS

See the Monitoring Requirements and Limitations table above for monitoring frequency and limitations for the List 1 parameters

Lead, mg/kg (dry weight)
Mercury, mg/kg (dry weight)
Molybdenum, mg/kg (dry weight)
Nickel, mg/kg (dry weight)
Selenium, mg/kg (dry weight)
Zinc, mg/kg (dry weight)

List 2

NUTRIENTS

See the Monitoring Requirements and Limitations table above for monitoring frequency for the List 2 parameters

Solids, Total (percent)
Nitrogen Total Kjeldahl (percent)
Nitrogen Ammonium (NH ₄ -N) Total (percent)
Phosphorus Total as P (percent)
Phosphorus, Water Extractable (as percent of Total P)
Potassium Total Recoverable (percent)

List 3

PATHOGEN CONTROL FOR CLASS B SLUDGE

The permittee shall implement pathogen control as listed in List 3. The Department shall be notified of the pathogen control utilized and shall be notified when the permittee decides to utilize alternative pathogen control.

The following requirements shall be met prior to land application of sludge.

Parameter	Unit	Limit
Fecal Coliform*	MPN/gTS or CFU/gTS	2,000,000

OR, ONE OF THE FOLLOWING PROCESS OPTIONS

Aerobic Digestion	Air Drying
Anaerobic Digestion	Composting
Alkaline Stabilization	PSRP Equivalent Process

* The Fecal Coliform limit shall be reported as the geometric mean of 7 discrete samples on a dry weight basis.

List 4

VECTOR ATTRACTION REDUCTION

The permittee shall implement any one of the vector attraction reduction options specified in List 4. The Department shall be notified of the option utilized and shall be notified when the permittee decides to utilize an alternative option.

One of the following shall be satisfied prior to, or at the time of land application as specified in List 4.

Option	Limit	Where/When it Shall be Met
Volatile Solids Reduction	≥38%	Across the process
Specific Oxygen Uptake Rate	≤1.5 mg O ₂ /hr/g TS	On aerobic stabilized sludge
Anaerobic bench-scale test	<17 % VS reduction	On anaerobic digested sludge

List 4
VECTOR ATTRACTION REDUCTION

The permittee shall implement any one of the vector attraction reduction options specified in List 4. The Department shall be notified of the option utilized and shall be notified when the permittee decides to utilize an alternative option.

One of the following shall be satisfied prior to, or at the time of land application as specified in List 4.

Option	Limit	Where/When it Shall be Met
Aerobic bench-scale test	<15 % VS reduction	On aerobic digested sludge
Aerobic Process	>14 days, Temp >40°C and Avg. Temp > 45°C	On composted sludge
pH adjustment	>12 S.U. (for 2 hours) and >11.5 (for an additional 22 hours)	During the process
Drying without primary solids	>75 % TS	When applied or bagged
Drying with primary solids	>90 % TS	When applied or bagged
Equivalent Process	Approved by the Department	Varies with process
Injection	-	When applied
Incorporation	-	Within 6 hours of application

4.2.1.5 Daily Land Application Log

Daily Land Application Log		
Discharge Monitoring Requirements and Limitations		
The permittee shall maintain a daily land application log for biosolids land applied each day when land application occurs. The following minimum records must be kept, in addition to all analytical results for the biosolids land applied. The log book records shall form the basis for the annual land application report requirements.		
Parameters	Units	Sample Frequency
DNR Site Number(s)	Number	Daily as used
Outfall number applied	Number	Daily as used
Acres applied	Acres	Daily as used
Amount applied	As appropriate * /day	Daily as used
Application rate per acre	unit */acre	Daily as used
Nitrogen applied per acre	lb/acre	Daily as used
Method of Application	Injection, Incorporation, or surface applied	Daily as used

* gallons, cubic yards, dry US Tons or dry Metric Tons

4.2.1.6 Sludge Monitoring for PFAS

Sampling shall occur for perfluoroalkyl and polyfluoroalkyl compounds (PFAS) listed in the table below and as indicated in sampling point sections above. Monitoring shall occur at each sample point when sludge is generated regardless of the end use (i.e. land applied, hauled to another facility, landfilled).

PERFLUOROALKYLCARBOXYLIC Acids (PFCAs)	
PFBA	Perfluorobutanoic acid
PFPeA	Perfluroropentanoic acid
PFHxA	Perfluorohexanoic acid
PFHpA	Perfluoroheptanoic acid
PFOA	Perfluorooctanoic acid
PFNA	Perfluorononanoic acid
PFDA	Perfluorodecanoic acid
PFUnA	Perfluroroundecanoic acid
PFDoA	Perfluorododecanoic acid
PFTriDA	Perfluorotridecanoic acid
PFTeDA	Perfluorotetradecanoic acid
PERFLUOROALKYLSULFONIC Acids (PFSAs)	
PFBS	Perfluorobutane sulfonic acid
PFPeS	Perfluroropentane sulfonic acid
PFHxS	Perfluorohexane sulfonic acid
PFHpS	Perfluoroheptane sulfonic acid
PFOS	Perfluorooctane sulfonic acid
PFNS	Perfluorononane sulfonic acid
PFDS	Perfluorodecane sulfonic acid
PFDoS	Perfluorododecane sulfonic acid
TELOMER SULFONIC Acids	
4:2FTSA	<i>1H,1H,2H,2H</i> -Perfluorohexane sulfonic acid
6:2FTSA	<i>1H,1H,2H,2H</i> -Perfluorooctane sulfonic acid
8:2FTSA	<i>1H,1H,2H,2H</i> -Perfluorodecane sulfonic acid
PERFLUOROOCTANCESULFONAMIDES (FOSAs)	
PFOSA	Perflurorooctane sulfonamide
NMeFOSA	N-Methyl perfluorooctane sulfonamide
NEtFOSA	N-Ethyl perfluorooctane sulfonamide
PERFLUOROOCTANCESULFONAMIDOACETIC Acids	
NMeFOSAA	N-Methyl perfluorooctane sulfonamidoacetic acid
NEtFOSAA	N-Ethyl perfluorooctane sulfonamidoacetic acid
NATIVE PERFLUOROOCTANCESULFONAMIDOETHANOLS (FOSEs)	
NMeFOSE	N-Methyl perfluorooctane sulfonamideoethanol
NEtFOSE	N-Ethyl perfluorooctane sulfonamideoethanol
PERFLUOROALKYLETHERCARBOXYLIC Acids (PFECAs)	
HFPO-DA	Hexafluoropropylene oxide dimer acid
ADONA	4,8-dioxa-3 <i>H</i> -perfluorononanoic acid
PFMPA	Perfluoro-3-methoxypropanoic acid
PFMBA	Perfluoro-4-methoxybutanoic acid
NFDHA	Nonafluoro-3,6-dioxaheptaonic acid

CHLORO-PERFLUOROALKYLSULFONATE	
9Cl-PF3ONS	9-chlorohexadecafluoro-3-oxanone-1-sulfonic acid
11Cl-PF3OUdS	11-chloroelcosafafluoro-3-oxaundecane-1-sulfonic acid
PFEESA	Perfluro(2-ethoxyethane)sulfonic acid
TELOMER SULFONIC Acids	
3:3FTCA	3-Perfluoropropyl propanoic acid
5:3FTCA	2H,2H,3H,3H-Perfluorooctanoic acid
7:3FTCA	3-Perfluoroheptyl propanoic acid

Note: If WDNR Lab Certification removes a particular compound from the reporting list above and upon receiving written communication from the department, reporting for that compound is no longer required.

4.2.1.7 Sampling and Reporting Sludge Samples for PFAS

Representative sludge samples shall be collected at each sample point as listed. At minimum, liquid sludge storage/digesters should be thoroughly mixed prior to sampling. Cake sludge samples should consist of seven equal size discrete samples and be collected from different areas and depths then composited into one sample for laboratory analysis.

Note: If additional equipment is used for collecting sludge samples (i.e., shovels, compositing buckets, bottles, etc.), then a one-time equipment blank is recommended to be collected with the first sample. An equipment blank sample is collected by passing laboratory verified PFAS-free water over or through field sampling equipment before the collection of a representative sludge sample. The equipment blank result shall be reported on the annual Sludge Characteristics Form (3400-049) in the comment section when reporting PFAS concentrations in the sludge.

The permittee shall report each of the PFAS sludge monitoring results on the annual Sludge Characteristics and Monitoring Form (3400-049) as provided by the department. The permittee shall also report the summation of PFOS and PFOA on this same form. All results shall be reported in dry weight. The annual Sludge Characteristics and Monitoring Form (3400-049) are due January 31, of the year following the collection of the sludge samples.

The laboratory performing the analysis on any samples shall be certified for the applicable PFAS compounds in the solids matrix by the Wisconsin Laboratory Certification Program established under s. 299.11, Wis. Stats., and in accordance with s. NR 149.41, Wis. Adm. Code. The department may reject any sample results if results are produced by a laboratory that is not in compliance with certification requirements under ch. NR 149, Wis. Adm. Code.

4.2.1.8 PFAS Land Application Requirements

The department recommends the landspreading and/or land application of sludge be done in a manner consistent with the most recent version of the [“Interim Strategy for Land Application of Biosolids and Industrial Sludges containing PFAS”](#).

5 Schedules

5.1 Mercury Effluent Limits

This compliance schedule requires the permittee to achieve compliance by the specified date.

Required Action	Due Date
Report on Effluent Discharges: Submit a report on effluent discharges of mercury. The report shall include an evaluation of collected effluent data and the facility's ability to comply with the final mercury effluent limits. The report shall conclude whether current treatment, operational improvements, or a pollutant minimization program will result in compliance with the final mercury effluent limits.	03/31/2027
Action Plan: Submit an action plan for complying with the final mercury effluent limits.	09/30/2027
Initiate Actions: Initiate the actions identified in the plan.	03/31/2028
Progress Report: Submit a progress report detailing progress made toward meeting the final mercury effluent limits, including all available mercury sample results, a summary of actions taken and any mercury pollutant minimization activities conducted during the previous year.	03/31/2029
Final Evaluation Report: Submit a final evaluation report including all mercury sampling data and a conclusion on the likelihood that mercury effluent limits will still apply. The permittee shall submit a request to re-evaluate the need for mercury effluent limits. If the Department determines there is no reasonable potential to exceed the calculated mercury limits, permit modification would be required to remove the mercury effluent limits and remaining schedule actions.	03/31/2030
Complete Actions: Complete actions necessary to achieve compliance with the final mercury effluent limits.	03/31/2031

5.2 PFOS/PFOA Minimization Plan Determination of Need

Required Action	Due Date
Report on Effluent Discharge: Submit a report on effluent PFOS and PFOA concentrations and include an analysis of trends in monthly and annual average PFOS and PFOA concentrations. This analysis should also include a comparison to the applicable narrative standard in s. NR 102.04(8)(d), Wis. Adm. Code. This report shall include all additional PFOS and PFOA data that may be collected including any influent, intake, in-plant, collection system sampling, and blank sample results.	03/31/2027
Report on Effluent Discharge and Evaluation of Need: Submit a final report on effluent PFOS and PFOA concentrations and include an analysis of trends in monthly and annual average PFOS and PFOA concentrations of data collected over the last 24 months. The report shall also provide a comparison on the likelihood of the facility needing to develop a PFOS/PFOA minimization plan. This report shall include all additional PFOS and PFOA data that may be collected including any influent, intake, in-plant, collection system sampling, and blank sample results. The permittee shall also submit a request to the department to evaluate the need for a PFOS/PFOA minimization plan.	03/31/2028

<p>If the Department determines a PFOS/PFOA minimization plan is needed based on a reasonable potential evaluation, the permittee will be required to develop a minimization plan for Department approval no later than 90 days after written notification was sent from the Department. The Department will modify or revoke and reissue the permit to include PFOS/PFOA minimization plan reporting requirements along with a schedule of compliance to meet WQBELs. Effluent monitoring of PFOS and PFOA shall continue as specified in the permit until the modified permit is issued.</p> <p>If, however, the Department determines there is no reasonable potential for the facility to discharge PFOS or PFOA above the narrative standard in s. NR 102.04(8)(d), Wis. Adm. Code, no further action is required and effluent monitoring of PFOS and PFOA shall continue as specified in the permit.</p>	
--	--

5.3 Watershed Adaptive Management Option Annual Report Submittals

The permittee shall submit annual reports on the implementation of AM Plan No. AM-2025-02 (September 2025) as specified in Sections 3.2.1.7 and 3.2.1.8 and the following schedule.

Required Action	Due Date
<p>Annual Adaptive Management Report #6: Submit an annual adaptive management report. The annual adaptive management report shall:</p> <ul style="list-style-type: none"> o Confirm continued support of AM Plan No. AM-2025-02 (September 2025) with a narrative describing the permittee's support of the Plan and demonstrate fulfillment of the permittee's deliverables specified under the Yahara WINS intergovernmental agreement. 	07/31/2026
<p>Annual Adaptive Management Report #7: Submit an Adaptive Management report as defined above.</p>	07/31/2027
<p>Annual Adaptive Management Report #8: Submit an Adaptive Management report as defined above.</p>	07/31/2028
<p>Annual Adaptive Management Report #9: Submit an Adaptive Management report as defined above.</p>	07/31/2029
<p>Final Adaptive Management Report for 2nd Permit Term: Submit an Adaptive Management report as defined above. The report shall summarize continued support for AM Plan No. AM-2025-02 (September 2025) throughout the next permit term and indicate continued participation in the Yahara WINS intergovernmental agreement.</p>	07/31/2030
<p>Renewal of Adaptive Management Plan for Permit Reissuance: If the permittee intends to seek continued coverage under AM Plan No. AM-2025-02 (September 2025) per s. NR 217.18, Wis. Adm. Code, for the reissued permit term, this schedule may be modified to incorporate any changes in AM goals and actions, removed if the AM program is terminated per the Adaptive Management Reopener Clause section, or removed if the adaptive management plan has achieved water quality standards as determined by the Department within the AM action area.</p>	09/30/2030
<p>Annual Adaptive Management Report #10: Submit an Adaptive Management report as defined above.</p>	07/31/2031
<p>Annual Adaptive Management Report #11: Submit an Adaptive Management report as defined above.</p>	07/31/2032
<p>Annual Adaptive Management Report #12: Submit an Adaptive Management report as defined above.</p>	07/31/2033

Annual Adaptive Management Report #13: Submit an Adaptive Management report as defined above.	07/31/2034
Final Adaptive Management Report for 3rd Permit Term: Submit an Adaptive Management report as defined above. The report shall summarize continued support for AM Plan No. AM-2025-02 (September 2025) throughout the next permit term and indicate continued participation in the Yahara WINS intergovernmental agreement.	07/31/2035
Renewal of Adaptive Management Plan for Permit Reissuance: If the permittee intends to seek continued coverage under AM Plan No. AM-2025-02 (September 2025) per s. NR 217.18, Wis. Adm. Code, for the reissued permit term, this schedule may be modified to incorporate any changes in AM goals and actions, removed if the AM program is terminated per the Adaptive Management Reopener Clause section, or removed if the adaptive management plan has achieved water quality standards as determined by the Department within the AM action area.	09/30/2035
Annual Adaptive Management Report #14: Submit an Adaptive Management report as defined above.	07/31/2036
Annual Adaptive Management Report #15: Submit an Adaptive Management report as defined above.	07/31/2037
Annual Adaptive Management Report #16: Submit an Adaptive Management report as defined above.	07/31/2038
Annual Adaptive Management Report #17: Submit an Adaptive Management report as defined above.	07/31/2039
Final Adaptive Management Report: Submit an Adaptive Management report as defined above. The report shall summarize continued support for AM Plan No. AM-2025-02 (September 2025) throughout the next permit term and indicate continued participation in the Yahara WINS intergovernmental agreement.	07/31/2040
Achieve Water Quality Standards and Adaptive Management Plan Success: All the receiving waters identified within the AM Plan No. AM-2025-02 (September 2025) shall be measured for success in accordance with Section IV of the AM Plan. Compliance may be demonstrated using effluent data and watershed modeling that uses similar assumptions as the TMDL to demonstrate that the sum total of the allocations have been achieved for each reach. If some, but not all, reaches are complying with the allocations of the TMDL, only those point sources in the complying reaches will be considered in compliance at the end of the adaptive management period. The permittee shall continue to comply with applicable effluent limits (required under s. NR 217.18(3)(e)3, Wis. Adm. Code, expressed as a 6-month avg and 1.0 mg/L monthly avg) and continue support of monitoring per AM-2025-02 (September 2025) at a minimum of monthly May through October for total phosphorus. If the allocations in the TMDL have been achieved but the applicable phosphorus water quality criterion in s. NR 102.06, Wis. Adm. Code, has not been achieved for the facility's receiving water, consistent with s. 283.13(5), Wis. Stats., and Clean Water Act section 301(b)(1)(C), further evaluation and additional actions will be necessary in the next reissued permit as necessary to achieve phosphorus water quality criterion (e.g., DNR reevaluation of TMDL allocations, imposition of more stringent limits, etc.).	03/31/2041

5.4 Disinfection and Effluent Limitations for E. coli

This compliance schedule requires the permittee to achieve compliance by the specified date.

Required Action	Due Date
-----------------	----------

Construction Upgrade Progress Report: The permittee shall submit a progress report on construction upgrades.	09/30/2026
Complete Construction: The permittee shall complete construction of wastewater treatment system upgrades.	03/31/2027
Achieve Compliance: The permittee shall achieve compliance with final E. coli limitations.	04/01/2027

5.5 Install Continuous Flow Recording Device

The permittee shall install a continuous flow recording device at Sampling Point 001 (Effluent) in accordance with the following schedule.

Required Action	Due Date
Complete Install: The permittee shall complete installation of the continuous flow recording device at Sampling Point 001 (Effluent).	04/01/2027

5.6 Land Application Management Plan

A management plan is required for the land application system.

Required Action	Due Date
Land Application Management Plan Submittal: Submit an update to the management plan to optimize the land application system performance and demonstrate compliance with ch. NR 204, Wis. Adm. Code, by the Due Date. This management plan shall 1) specify information on pretreatment processes (if any); 2) identify land application sites; 3) describe site limitations; 4) address vegetative cover management and removal; 5) specify availability of storage; 6) describe the type of transporting and spreading vehicle(s); 7) specify monitoring procedures; 8) track site loading; 9) address contingency plans for adverse weather and odor/nuisance abatement; and 10) include any other pertinent information. Once approved, all landspreading activities shall be conducted in accordance with the plan. Any changes to the plan must be approved by the Department prior to implementing the changes.	03/31/2027

6 Standard Requirements

Chapter NR 205, Wisconsin Administrative Code: The conditions in ss. NR 205.07(1) and NR 205.07(2), Wis. Adm. Code, are included by reference in this permit. The permittee shall comply with all of these requirements. Some of these requirements are outlined in the Standard Requirements section of this permit. Requirements not specifically outlined in the Standard Requirement section of this permit can be found in ss. NR 205.07(1) and NR 205.07(2), Wis. Adm. Code.

6.1 Reporting and Monitoring Requirements

6.1.1 Monitoring Results

Monitoring results obtained during the previous month shall be summarized and reported on a Department Wastewater Discharge Monitoring Report. The report may require reporting of any or all of the information specified below under 'Recording of Results'. This report is to be returned to the Department no later than the date indicated on the form. A copy of the Wastewater Discharge Monitoring Report Form or an electronic file of the report shall be retained by the permittee.

Monitoring results shall be reported on an electronic discharge monitoring report (eDMR). The eDMR shall be certified electronically by a responsible executive or municipal officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The 'eReport Certify' page certifies that the electronic report form is true, accurate and complete.

If the permittee monitors any pollutant more frequently than required by this permit, the results of such monitoring shall be included on the Wastewater Discharge Monitoring Report.

The permittee shall comply with all limits for each parameter regardless of monitoring frequency. For example, monthly, weekly, and/or daily limits shall be met even with monthly monitoring. The permittee may monitor more frequently than required for any parameter.

6.1.2 Sampling and Testing Procedures

Sampling and laboratory testing procedures shall be performed in accordance with Chapters NR 218 and NR 219, Wis. Adm. Code, and completed by a laboratory certified or registered in accordance with the requirements of ch. NR 149, Wis. Adm. Code. Groundwater sampling shall be performed in accordance with procedures contained in s. NR 140.16, Wis. Adm. Code, and the WDNR publications, Groundwater Sampling Desk Reference (PUBL-DG-037-96) and Groundwater Sampling Field Manual (PUBL-DG-038-96). The analytical methodologies used shall enable the laboratory to quantitate all substances for which monitoring is required at levels below the effluent limitation and/or groundwater standard. If the required level cannot be met by any of the methods available in ch. NR 219, Wis. Adm. Code, then the method with the lowest limit of detection shall be selected. Additional test procedures may be specified in this permit.

6.1.3 Recording of Results

The permittee shall maintain records which provide the following information for each effluent measurement or sample taken:

- The date, exact place, method and time of sampling or measurements;
- The individual who performed the sampling or measurements;
- The date the analysis was performed;
- The individual who performed the analysis;
- The analytical techniques or methods used; and

- The results of the analysis.

6.1.4 Reporting of Monitoring Results

The permittee shall use the following conventions when reporting effluent monitoring results:

- Pollutant concentrations less than the limit of detection shall be reported as < (less than) the value of the limit of detection. For example, if a substance is not detected at a detection limit of 0.1 mg/L, report the pollutant concentration as < 0.1 mg/L.
- Pollutant concentrations equal to or greater than the limit of detection, but less than the limit of quantitation, shall be reported and the limit of quantitation shall be specified.
- For purposes of calculating fees under ch. NR 101, Wis. Adm. Code, a reporting limit of 2.0 mg/L for BOD₅ and 2.5 mg/L Total Suspended Solids shall be considered to be limits of quantitation.
- For the purposes of reporting a calculated result, average or a mass discharge value, the permittee may substitute a "0" (zero) for any pollutant concentration that is less than the limit of detection. However, if the effluent limitation is less than the limit of detection, the department may substitute a value other than zero for results less than the limit of detection, after considering the number of monitoring results that are greater than the limit of detection and if warranted when applying appropriate statistical techniques.
- If no discharge occurs through an outfall, flow related parameters (e.g. flow rate, hydraulic application rate, volume, etc.) should be reported as "0" (zero) at the required sample frequency specified for the outfall. For example: if the sample frequency is daily, "0" would be reported for any day during the month that no discharge occurred.

6.1.5 Compliance Maintenance Annual Reports

Compliance Maintenance Annual Reports (CMAR) shall be completed using information obtained over each calendar year regarding the wastewater conveyance and treatment system. The CMAR shall be submitted and certified by the permittee in accordance with ch. NR 208, Wis. Adm. Code, by June 30, each year on an electronic report form provided by the Department.

In the case of a publicly owned treatment works, a resolution shall be passed by the governing body and submitted as part of the CMAR, verifying its review of the report and providing responses as required. Private owners of wastewater treatment works are not required to pass a resolution; but they must provide an Owner Statement and responses as required, as part of the CMAR submittal.

The CMAR shall be certified electronically by a responsible executive or municipal officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The certification verifies that the electronic report is true, accurate and complete.

6.1.6 Records Retention

The permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings or electronic data records for continuous monitoring instrumentation, copies of all reports required by the permit, and records of all data used to complete the application for the permit for a period of at least 3 years from the date of the sample, measurement, report or application. All pertinent sludge information, including permit application information and other documents specified in this permit or s. NR 204.06(9), Wis. Adm. Code shall be retained for a minimum of 5 years.

6.1.7 Other Information

Where the permittee becomes aware that it failed to submit any relevant facts in a permit application or submitted incorrect information in a permit application or in any report to the Department, it shall promptly submit such facts or correct information to the Department.

6.1.8 Reporting Requirements – Alterations or Additions

The permittee shall give notice to the Department as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is only required when:

- The alteration or addition to the permitted facility may meet one of the criteria for determining whether a facility is a new source.
- The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification requirement applies to pollutants which are not subject to effluent limitations in the existing permit.
- The alteration or addition results in a significant change in the permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use of disposal sites not reported during the permit application process nor reported pursuant to an approved land application plan. Additional sites may not be used for the land application of sludge until department approval is received.

6.2 System Operating Requirements

6.2.1 Noncompliance Reporting

Sanitary sewer overflows and sewage treatment facility overflows shall be reported according to the 'Sanitary Sewer Overflows and Sewage Treatment Facility Overflows' section of this permit.

The permittee shall report the following types of noncompliance by a telephone call to the Department's regional office within 24 hours after becoming aware of the noncompliance:

- Any noncompliance which may endanger health or the environment;
- Any violation of an effluent limitation resulting from a bypass;
- Any violation of an effluent limitation resulting from an upset; and
- Any violation of a maximum discharge limitation for any of the pollutants listed by the Department in the permit, either for effluent or sludge.

A written report describing the noncompliance shall also be submitted to the Department's regional office within 5 days after the permittee becomes aware of the noncompliance. On a case-by-case basis, the Department may waive the requirement for submittal of a written report within 5 days and instruct the permittee to submit the written report with the next regularly scheduled monitoring report. In either case, the written report shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times; the steps taken or planned to reduce, eliminate and prevent reoccurrence of the noncompliance; and if the noncompliance has not been corrected, the length of time it is expected to continue.

A scheduled bypass approved by the Department under the 'Scheduled Bypass' section of this permit shall not be subject to the reporting required under this section.

NOTE: Section 292.11(2)(a), Wisconsin Statutes, requires any person who possesses or controls a hazardous substance or who causes the discharge of a hazardous substance to notify the Department of Natural Resources **immediately** of any discharge not authorized by the permit. **The discharge of a hazardous substance that is not authorized by this permit or that violates this permit may be a hazardous substance spill. To report a hazardous substance spill, call DNR's 24-hour HOTLINE at 1-800-943-0003.**

6.2.2 Flow Meters

Flow meters shall be calibrated annually, as per s. NR 218.06, Wis. Adm. Code.

6.2.3 Raw Grit and Screenings

All raw grit and screenings shall be disposed of at a properly licensed solid waste facility or picked up by a licensed waste hauler. If the facility or hauler are located in Wisconsin, then they shall be licensed under chs. NR 500-555, Wis. Adm. Code.

6.2.4 Sludge Management

All sludge management activities shall be conducted in compliance with ch. NR 204 "Domestic Sewage Sludge Management", Wis. Adm. Code.

6.2.5 Prohibited Wastes

Under no circumstances may the introduction of wastes prohibited by s. NR 211.10, Wis. Adm. Code, be allowed into the waste treatment system. Prohibited wastes include those:

- Which create a fire or explosion hazard in the treatment work;
- Which will cause corrosive structural damage to the treatment work;
- Solid or viscous substances in amounts which cause obstructions to the flow in sewers or interference with the proper operation of the treatment work;
- Wastewaters at a flow rate or pollutant loading which are excessive over relatively short time periods so as to cause a loss of treatment efficiency; and
- Changes in discharge volume or composition from contributing industries which overload the treatment works or cause a loss of treatment efficiency.

6.2.6 Bypass

This condition applies only to bypassing at a sewage treatment facility that is not a scheduled bypass, approved blending as a specific condition of this permit, a sewage treatment facility overflow or a controlled diversion as provided in the sections titled 'Scheduled Bypass', 'Blending' (if approved), 'SSO's and Sewage Treatment Facility Overflows' and 'Controlled Diversions' of this permit. Any other bypass at the sewage treatment facility is prohibited and the Department may take enforcement action against a permittee for such occurrences under s. 283.89, Wis. Stats. The Department may approve a bypass if the permittee demonstrates all the following conditions apply:

- The bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
- There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities or adequate back-up equipment, retention of untreated wastes, reduction of inflow and infiltration, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventative maintenance. When evaluating feasibility of alternatives, the department may consider factors such as technical achievability, costs and affordability of implementation and risks to public health, the environment and, where the permittee is a municipality, the welfare of the community served; and
- The bypass was reported in accordance with the Noncompliance Reporting section of this permit.

6.2.7 Scheduled Bypass

Whenever the permittee anticipates the need to bypass for purposes of efficient operations and maintenance and the permittee may not meet the conditions for controlled diversions in the 'Controlled Diversions' section of this permit, the permittee shall obtain prior written approval from the Department for the scheduled bypass. A permittee's written request for Department approval of a scheduled bypass shall demonstrate that the conditions for bypassing specified in the above section titled 'Bypass' are met and include the proposed date and reason for the bypass, estimated volume and duration of the bypass, alternatives to bypassing and measures to mitigate environmental harm caused by the bypass. The department may require the permittee to provide public notification for a scheduled bypass if it is

determined there is significant public interest in the proposed action and may recommend mitigation measures to minimize the impact of such bypass.

6.2.8 Controlled Diversions

Controlled diversions are allowed only when necessary for essential maintenance to assure efficient operation. Sewage treatment facilities that have multiple treatment units to treat variable or seasonal loading conditions may shut down redundant treatment units when necessary for efficient operation. The following requirements shall be met during controlled diversions:

- Effluent from the sewage treatment facility shall meet the effluent limitations established in the permit. Wastewater that is diverted around a treatment unit or treatment process during a controlled diversion shall be recombined with wastewater that is not diverted prior to the effluent sampling location and prior to effluent discharge;
- A controlled diversion does not include blending as defined in s. NR 210.03(2e), Wis. Adm. Code, and as may only be approved under s. NR 210.12. A controlled diversion may not occur during periods of excessive flow or other abnormal wastewater characteristics;
- A controlled diversion may not result in a wastewater treatment facility overflow; and
- All instances of controlled diversions shall be documented in sewage treatment facility records and such records shall be available to the department on request.

6.2.9 Proper Operation and Maintenance

The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance includes effective performance, adequate funding, adequate operator staffing and training as required in ch. NR 114, Wis. Adm. Code, and adequate laboratory and process controls, including appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems only when necessary to achieve compliance with the conditions of the permit.

6.2.10 Operator Certification

The wastewater treatment facility shall be under the direct supervision of a state certified operator. In accordance with s. NR 114.53, Wis. Adm. Code, every WPDES permitted treatment plant shall have a designated operator-in-charge holding a current and valid certificate. The designated operator-in-charge shall be certified at the level and in all subclasses of the treatment plant, except laboratory. Treatment plant owners shall notify the department of any changes in the operator-in-charge within 30 days. Note that s. NR 114.52(22), Wis. Adm. Code, lists types of facilities that are excluded from operator certification requirements (i.e. private sewage systems, pretreatment facilities discharging to public sewers, industrial wastewater treatment that consists solely of land disposal, agricultural digesters and concentrated aquatic production facilities with no biological treatment).

6.3 Sewage Collection Systems

6.3.1 Sanitary Sewage Overflows and Sewage Treatment Facility Overflows

6.3.1.1 Overflows Prohibited

Any overflow or discharge of wastewater from the sewage collection system or at the sewage treatment facility, other than from permitted outfalls, is prohibited. The permittee shall provide information on whether any of the following conditions existed when an overflow occurred:

- The sanitary sewer overflow or sewage treatment facility overflow was unavoidable to prevent loss of life, personal injury or severe property damage;

- There were no feasible alternatives to the sanitary sewer overflow or sewage treatment facility overflow such as the use of auxiliary treatment facilities or adequate back-up equipment, retention of untreated wastes, reduction of inflow and infiltration, or preventive maintenance activities;
- The sanitary sewer overflow or the sewage treatment facility overflow was caused by unusual or severe weather-related conditions such as large or successive precipitation events, snowmelt, saturated soil conditions, or severe weather occurring in the area served by the sewage collection system or sewage treatment facility; and
- The sanitary sewer overflow or the sewage treatment facility overflow was unintentional, temporary, and caused by an accident or other factors beyond the reasonable control of the permittee.

6.3.1.2 Permittee Response to Overflows

Whenever a sanitary sewer overflow or sewage treatment facility overflow occurs, the permittee shall take all feasible steps to control or limit the volume of untreated or partially treated wastewater discharged, and terminate the discharge as soon as practicable. Remedial actions, including those in s. NR 210.21 (3), Wis. Adm. Code, shall be implemented consistent with an emergency response plan developed under the CMOM program.

6.3.1.3 Permittee Reporting

Permittees shall report all sanitary sewer overflows and sewage treatment overflows as follows:

- The permittee shall notify the department by telephone, fax or email as soon as practicable, but no later than 24 hours from the time the permittee becomes aware of the overflow;
- The permittee shall, no later than five days from the time the permittee becomes aware of the overflow, provide to the department the information identified in this paragraph using department form number 3400-184. If an overflow lasts for more than five days, an initial report shall be submitted within 5 days as required in this paragraph and an updated report submitted following cessation of the overflow. At a minimum, the following information shall be included in the report:
 - a) The date and location of the overflow;
 - b) The surface water to which the discharge occurred, if any;
 - c) The duration of the overflow and an estimate of the volume of the overflow;
 - d) A description of the sewer system or treatment facility component from which the discharge occurred such as manhole, lift station, constructed overflow pipe, or crack or other opening in a pipe;
 - e) The estimated date and time when the overflow began and stopped or will be stopped;
 - f) The cause or suspected cause of the overflow including, if appropriate, precipitation, runoff conditions, areas of flooding, soil moisture and other relevant information;
 - g) Steps taken or planned to reduce, eliminate and prevent reoccurrence of the overflow and a schedule of major milestones for those steps;
 - h) A description of the actual or potential for human exposure and contact with the wastewater from the overflow;
 - i) Steps taken or planned to mitigate the impacts of the overflow and a schedule of major milestones for those steps;
 - j) To the extent known at the time of reporting, the number and location of building backups caused by excessive flow or other hydraulic constraints in the sewage collection system that occurred concurrently with the sanitary sewer overflow and that were within the same area of the sewage collection system as the sanitary sewer overflow; and
 - k) The reason the overflow occurred or explanation of other contributing circumstances that resulted in the overflow event. This includes any information available including whether the overflow was

unavoidable to prevent loss of life, personal injury, or severe property damage and whether there were feasible alternatives to the overflow.

NOTE: A copy of form 3400-184 for reporting sanitary sewer overflows and sewage treatment facility overflows may be obtained from the department or accessed on the department's web site at <http://dnr.wi.gov/topic/wastewater/SSOreport.html>. As indicated on the form, additional information may be submitted to supplement the information required by the form.

- The permittee shall identify each specific location and each day on which a sanitary sewer overflow or sewage treatment facility overflow occurs as a discrete sanitary sewer overflow or sewage treatment facility overflow occurrence. An occurrence may be more than one day if the circumstances causing the sanitary sewer overflow or sewage treatment facility overflow results in a discharge duration of greater than 24 hours. If there is a stop and restart of the overflow at the same location within 24 hours and the overflow is caused by the same circumstance, it may be reported as one occurrence. Sanitary sewer overflow occurrences at a specific location that are separated by more than 24 hours shall be reported as separate occurrences; and
- A permittee that is required to submit wastewater discharge monitoring reports under s. NR 205.07 (1) (r), Wis. Adm. Code, shall also report all sanitary sewer overflows and sewage treatment facility overflows on that report.

6.3.1.4 Public Notification

The permittee shall notify the public of any sanitary sewer and sewage treatment facility overflows consistent with its emergency response plan required under the CMOM (Capacity, Management, Operation and Maintenance) section of this permit and s. NR 210.23 (4) (f), Wis. Adm. Code. Such public notification shall occur promptly following any overflow event using the most effective and efficient communications available in the community. At minimum, a daily newspaper of general circulation in the county(s) and municipality whose waters may be affected by the overflow shall be notified by written or electronic communication.

6.3.2 Capacity, Management, Operation and Maintenance (CMOM) Program

- The permittee shall have written documentation of the Capacity, Management, Operation and Maintenance (CMOM) program components in accordance with s. NR 210.23(4), Wis. Adm. Code. Such documentation shall be available for Department review upon request. The Department may request that the permittee provide this documentation or prepare a summary of the permittee's CMOM program at the time of application for reissuance of the WPDES permit.
- The permittee shall implement a CMOM program in accordance with s. NR 210.23, Wis. Adm. Code.
- The permittee shall at least annually conduct a self-audit of activities conducted under the permittee's CMOM program to ensure CMOM components are being implemented as necessary to meet the general standards of s. NR 210.23(3), Wis. Adm. Code.

6.3.3 Sewer Cleaning Debris and Materials

All debris and material removed from cleaning sanitary sewers shall be managed to prevent nuisances, run-off, ground infiltration or prohibited discharges.

- Debris and solid waste shall be dewatered, dried and then disposed of at a licensed solid waste facility.
- Liquid waste from the cleaning and dewatering operations shall be collected and disposed of at a permitted wastewater treatment facility.
- Combination waste including liquid waste along with debris and solid waste may be disposed of at a licensed solid waste facility or wastewater treatment facility willing to accept the waste.

6.4 Surface Water Requirements

6.4.1 Permittee-Determined Limit of Quantitation Incorporated into this Permit

For pollutants with water quality-based effluent limits below the Limit of Quantitation (LOQ) in this permit, the LOQ calculated by the permittee and reported on the Discharge Monitoring Reports (DMRs) is incorporated by reference into this permit. The LOQ shall be reported on the DMRs, shall be the lowest quantifiable level practicable, and shall be no greater than the minimum level (ML) specified in or approved under 40 CFR Part 136 for the pollutant at the time this permit was issued, unless this permit specifies a higher LOQ.

6.4.2 Appropriate Formulas for Effluent Calculations

The permittee shall use the following formulas for calculating effluent results to determine compliance with average concentration limits and mass limits and total load limits:

Weekly/Monthly/Six-Month/Annual Average Concentration = the sum of all daily results for that week/month/six-month/year, divided by the number of results during that time period. [Note: When a six-month average effluent limit is specified for Total Phosphorus the applicable periods are May through October and November through April, except in cases of Water Quality Trading, wherein the applicable periods are January through June and July through December.]

Weekly Average Mass Discharge (lbs/day): Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the week.

Monthly Average Mass Discharge (lbs/day): Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the month.

Six-Month Average Mass Discharge (lbs/day): Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the six-month period. [Note: When a six-month average effluent limit is specified for Total Phosphorus the applicable periods are May through October and November through April.]

Annual Average Mass Discharge (lbs/day): Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the entire year.

Total Monthly Discharge: = monthly average concentration (mg/L) x total flow for the month (MG/month) x 8.34.

Total Annual Discharge: = sum of total monthly discharges for the calendar year.

12-Month Rolling Sum of Total Monthly Discharge: = the sum of the most recent 12 consecutive months of Total Monthly Discharges.

6.4.3 Effluent Temperature Requirements

Weekly Average Temperature – If temperature limits are included in this permit, Weekly Average Temperature shall be calculated as the sum of all daily maximum results for that week divided by the number of daily maximum results during that time period.

Cold Shock Standard – Water temperatures of the discharge shall be controlled in a manner as to protect fish and aquatic life uses from the deleterious effects of cold shock pursuant to Wis. Adm. Code, s. NR 102.28. ‘Cold Shock’ means exposure of aquatic organisms to a rapid decrease in temperature and a sustained exposure to low temperature that induces abnormal behavior or physiological performance and may lead to death.

Rate of Temperature Change Standard – Temperature of a water of the state or discharge to a water of the state may not be artificially raised or lowered at such a rate that it causes detrimental health or reproductive effects to fish or aquatic life of the water of the state pursuant to Wis. Adm. Code, s. NR 102.29.

6.4.4 Visible Foam or Floating Solids

There shall be no discharge of floating solids or visible foam in other than trace amounts.

6.4.5 Surface Water Uses and Criteria

In accordance with NR 102.04, Wis. Adm. Code, surface water uses and criteria are established to govern water management decisions. Practices attributable to municipal, industrial, commercial, domestic, agricultural, land development or other activities shall be controlled so that all surface waters including the mixing zone meet the following conditions at all times and under all flow and water level conditions:

- Substances that will cause objectionable deposits on the shore or in the bed of a body of water, shall not be present in such amounts as to interfere with public rights in waters of the state.
- Floating or submerged debris, oil, scum or other material shall not be present in such amounts as to interfere with public rights in waters of the state.
- Materials producing color, odor, taste or unsightliness shall not be present in such amounts as to interfere with public rights in waters of the state.
- Substances in concentrations or in combinations which are toxic or harmful to humans shall not be present in amounts found to be of public health significance, nor shall substances be present in amounts which are acutely harmful to animal, plant or aquatic life.

6.4.6 Percent Removal

During any 30 consecutive days, the average effluent concentrations of BOD₅ and of total suspended solids shall not exceed 15% of the average influent concentrations, respectively. This requirement does not apply to removal of total suspended solids if the permittee operates a lagoon system and has received a variance for suspended solids granted under NR 210.07(2), Wis. Adm. Code.

6.4.7 *E. coli*

The monthly limit for *E. coli* shall be expressed as a geometric mean. In calculating the geometric mean, a value of 1 is used for any result of 0.

6.4.8 Seasonal Disinfection

Disinfection shall be provided from March 1 through November 30 of each year. Monitoring requirements and the limitations for *E. coli* apply only during the period in which disinfection is required. Whenever chlorine is used for disinfection or other uses, the limitations and monitoring requirements for residual chlorine shall apply. A dechlorination process shall be in operation whenever chlorine is used.

6.4.9 Whole Effluent Toxicity (WET) Monitoring Requirements

In order to determine the potential impact of the discharge on aquatic organisms, static-renewal toxicity tests shall be performed on the effluent in accordance with the procedures specified in the "*State of Wisconsin Aquatic Life Toxicity Testing Methods Manual, 2nd Edition*" (PUB-WT-797, November 2004) as required by NR 219.04, Table A, Wis. Adm. Code). All of the WET tests required in this permit, including any required retests, shall be conducted on the *Ceriodaphnia dubia* and fathead minnow species. Receiving water samples shall not be collected from any point in contact with the permittee's mixing zone and every attempt shall be made to avoid contact with any other discharge's mixing zone.

6.4.10 Whole Effluent Toxicity (WET) Identification and Reduction

Within 60 days of a retest which showed positive results, the permittee shall submit a written report to the Biomonitoring Coordinator, Bureau of Water Quality, 101 S. Webster St., PO Box 7921, Madison, WI 53707-7921, which details the following:

- A description of actions the permittee has taken or will take to remove toxicity and to prevent the recurrence of toxicity;

- A description of toxicity reduction evaluation (TRE) investigations that have been or will be done to identify potential sources of toxicity, including the following actions:
 - a) Evaluate the performance of the treatment system to identify deficiencies contributing to effluent toxicity (e.g., operational problems, chemical additives, incomplete treatment)
 - b) Identify the compound(s) causing toxicity. Conduct toxicity screening tests on the effluent at a minimum of once per month for six months to determine if toxicity recurs. Screening tests are WET tests using fewer effluent concentrations conducted on the most sensitive species. If any of the screening tests contain toxicity, conduct a toxicity identification evaluation (TIE) to determine the cause. TIE methods are available from USEPA “Methods for Aquatic Toxicity Identification Evaluations: Phase I Toxicity Characterization Procedures (EPA/600/6-91/003) and “Toxicity Identification Evaluation: Characterization of Chronically Toxic Effluents, Phase I” (EPA/600/6-91/005F).
 - c) Trace the compound(s) causing toxicity to their sources (e.g., industrial, commercial, domestic)
 - d) Evaluate, select, and implement methods or technologies to control effluent toxicity (e.g., in-plant or pretreatment controls, source reduction or removal)
- Where corrective actions including a TRE have not been completed, an expeditious schedule under which corrective actions will be implemented;
- If no actions have been taken, the reason for not taking action.

The permittee may also request approval from the Department to postpone additional retests in order to investigate the source(s) of toxicity. Postponed retests must be completed after toxicity is believed to have been removed.

6.4.11 PFOS and PFOA Requirements

The laboratory performing the analysis on any samples shall be certified for the applicable PFAS compounds in the aqueous matrix by the Wisconsin Laboratory Certification Program established under s. 299.11, Wis. Stats., in accordance with s. NR 149.41, Wis. Adm. Code. All laboratories are required to utilize EPA Method 1633A for sampling PFAS in sludge.

The Department may reject any sample results if results are produced by a laboratory that is not in compliance with certification requirements under ch. NR 149, Wis. Adm. Code.

6.5 Land Application Requirements

6.5.1 Sludge Management Program Standards And Requirements Based Upon Federally Promulgated Regulations

In the event that new federal sewage sludge standards or regulations are promulgated, the permittee shall comply with the new sewage sludge requirements by the dates established in the regulations, if required by federal law, even if the permit has not yet been modified to incorporate the new federal regulations.

6.5.2 General Sludge Management Information

The General Sludge Management Form 3400-48 shall be completed and submitted prior to any significant sludge management changes.

6.5.3 Sludge Samples

All sludge samples shall be collected at a point and in a manner which will yield sample results which are representative of the sludge being tested, and collected at the time which is appropriate for the specific test.

6.5.4 Land Application Characteristic Report

Each report shall consist of a Characteristic Form 3400-49 and Lab Report. The Characteristic Report Form 3400-49 shall be submitted electronically by January 31 following each year whether or not samples are analyzed. In years in which monitoring does not occur, the report shall be completed by checking on the form that monitoring/land application did not occur.

Following submittal of the electronic Characteristic Report Form 3400-49, this form shall be certified electronically via the 'eReport Certify' page by a responsible executive or municipal officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The 'eReport Certify' page certifies that the electronic report is true, accurate and complete. The Lab Report must be sent directly to the facility's DNR sludge representative or basin engineer unless approval for not submitting the lab reports has been given.

The permittee shall use the following convention when reporting sludge monitoring results: Pollutant concentrations less than the limit of detection shall be reported as < (less than) the value of the limit of detection. For example, if a substance is not detected at a detection limit of 1.0 mg/kg, report the pollutant concentration as < 1.0 mg/kg .

All results shall be reported on a dry weight basis.

6.5.5 Calculation of Water Extractable Phosphorus

When sludge analysis for Water Extractable Phosphorus is required by this permit, the permittee shall use the following formula to calculate and report Water Extractable Phosphorus:

Water Extractable Phosphorus (% of Total P) =

$$[\text{Water Extractable Phosphorus (mg/kg, dry wt)} \div \text{Total Phosphorus (mg/kg, dry wt)}] \times 100$$

6.5.6 Monitoring and Calculating PCB Concentrations in Sludge

When sludge analysis for "PCB, Total Dry Wt" is required by this permit, the PCB concentration in the sludge shall be determined using either congener-specific analysis or Aroclor analysis. The permittee may decide which of these analyses is performed. Analyses shall be performed in accordance with the following provisions and Table EM in s. NR 219.04, Wis. Adm. Code:

- If congener-specific analysis is employed: All PCB congeners shall be delineated. Non-detects shall be treated as zero. The values that are between the limit of detection (LOD) and the limit of quantitation shall be used when calculating the total value of all congeners. All results shall be added together and the total PCB concentration by dry weight reported.
- If Aroclor analysis is employed, reporting protocols, consistent with s. NR 106.07(6)(e), should be as follows: If all Aroclors are less than the LOD, then the Total PCB Dry Wt result should be reported as less than the highest LOD. If a single Aroclor is detected, then that is what should be reported for the Total PCB result. If multiple Aroclors are detected, they should be summed and reported as Total PCBs. If the LOD cannot be achieved after using the appropriate clean up techniques, a reporting limit that is achievable for the Aroclors or each congener for the sample shall be determined. This reporting limit shall be reported and qualified indicating the presence of an interference.

6.5.7 Annual Land Application Report

Land Application Report Form 3400-55 shall be submitted electronically by January 31, each year whether or not non-exceptional quality sludge is land applied. Non-exceptional quality sludge is defined in s. NR 204.07(4), Wis. Adm. Code. Following submittal of the electronic Annual Land Application Report Form 3400-55, this form shall be certified electronically via the 'eReport Certify' page by a responsible executive or municipal officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The 'eReport Certify' page certifies that the electronic report form is true, accurate and complete.

6.5.8 Other Methods of Disposal or Distribution Report

The permittee shall submit electronically the Other Methods of Disposal or Distribution Report Form 3400-52 by January 31, each year whether or not sludge is hauled, landfilled, incinerated, or exceptional quality sludge is distributed or land applied. Following submittal of the electronic Report Form 3400-52, this form shall be certified electronically via the 'eReport Certify' page by a responsible executive or municipal officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The 'eReport Certify' page certifies that the electronic report form is true, accurate and complete.

6.5.9 Approval to Land Apply

Bulk non-exceptional quality sludge as defined in s. NR 204.07(4), Wis. Adm. Code, may not be applied to land without a written approval letter or Form 3400-122 from the Department unless the Permittee has obtained permission from the Department to self-approve sites in accordance with s. NR 204.06(6), Wis. Adm. Code. Analysis of sludge characteristics is required prior to land application. Application on frozen or snow-covered ground is restricted to the extent specified in s. NR 204.07(3)(l), Wis. Adm. Code.

6.5.10 Soil Analysis Requirements

Each site requested for approval for land application must have the soil tested prior to use. Each approved site used for land application must subsequently be soil tested such that there is at least one valid soil test in the four years prior to land application. All soil sampling and submittal of information to the testing laboratory shall be done in accordance with UW Extension Bulletin A-2100. The testing shall be done by the UW Soils Lab in Madison or Marshfield, WI or at a lab approved by UW. The test results including the crop recommendations shall be submitted to the DNR contact listed for this permit, as they are available. Application rates shall be determined based on the crop nitrogen recommendations and with consideration for other sources of nitrogen applied to the site.

6.5.11 Land Application Site Evaluation

For non-exceptional quality sludge, as defined in s. NR 204.07(4), Wis. Adm. Code, a Land Application Site Request Form 3400-053 shall be submitted to the Department for the proposed land application site. The Department will evaluate the proposed site for acceptability and will either approve or deny use of the proposed site. The permittee may obtain permission to approve their own sites in accordance with s. NR 204.06(6), Wis. Adm. Code.

6.5.12 Class B Sludge: Fecal Coliform Limitation

Compliance with the fecal coliform limitation for Class B sludge shall be demonstrated by calculating the geometric mean of at least 7 separate samples. (Note that a Total Solids analysis must be done on each sample). The geometric mean shall be less than 2,000,000 MPN or CFU/g TS. Calculation of the geometric mean can be done using one of the following 2 methods.

Method 1:

$$\text{Geometric Mean} = (X_1 \times X_2 \times X_3 \dots \times X_n)^{1/n}$$

Where X = Coliform Density value of the sludge sample, and where n = number of samples (at least 7)

Method 2:

$$\text{Geometric Mean} = \text{antilog}[(X_1 + X_2 + X_3 \dots + X_n) \div n]$$

Where X = \log_{10} of Coliform Density value of the sludge sample, and where n = number of samples (at least 7)

Example for Method 2

Sample Number	Coliform Density of Sludge Sample	\log_{10}
1	6.0×10^5	5.78
2	4.2×10^6	6.62
3	1.6×10^6	6.20
4	9.0×10^5	5.95
5	4.0×10^5	5.60

6	1.0×10^6	6.00
7	5.1×10^5	5.71

The geometric mean for the seven samples is determined by averaging the \log_{10} values of the coliform density and taking the antilog of that value.

$$(5.78 + 6.62 + 6.20 + 5.95 + 5.60 + 6.00 + 5.71) \div 7 = 5.98$$

$$\text{The antilog of } 5.98 = 9.5 \times 10^5$$

6.5.13 Class B Sludge - Vector Control: Injection

No significant amount of the sewage sludge shall be present on the land surface within one hour after the sludge is injected.

7 Summary of Reports Due

FOR INFORMATIONAL PURPOSES ONLY

Description	Date	Page
Mercury Effluent Limits -Report on Effluent Discharges	March 31, 2027	18
Mercury Effluent Limits -Action Plan	September 30, 2027	18
Mercury Effluent Limits -Initiate Actions	March 31, 2028	18
Mercury Effluent Limits -Progress Report	March 31, 2029	18
Mercury Effluent Limits -Final Evaluation Report	March 31, 2030	18
Mercury Effluent Limits -Complete Actions	March 31, 2031	18
PFOS/PFOA Minimization Plan Determination of Need -Report on Effluent Discharge	March 31, 2027	18
PFOS/PFOA Minimization Plan Determination of Need -Report on Effluent Discharge and Evaluation of Need	March 31, 2028	18
Watershed Adaptive Management Option Annual Report Submittals - Annual Adaptive Management Report #6	July 31, 2026	19
Watershed Adaptive Management Option Annual Report Submittals - Annual Adaptive Management Report #7	July 31, 2027	19
Watershed Adaptive Management Option Annual Report Submittals - Annual Adaptive Management Report #8	July 31, 2028	19
Watershed Adaptive Management Option Annual Report Submittals - Annual Adaptive Management Report #9	July 31, 2029	19
Watershed Adaptive Management Option Annual Report Submittals -Final Adaptive Management Report for 2nd Permit Term	July 31, 2030	19
Watershed Adaptive Management Option Annual Report Submittals - Renewal of Adaptive Management Plan for Permit Reissuance	September 30, 2030	19
Watershed Adaptive Management Option Annual Report Submittals - Annual Adaptive Management Report #10	July 31, 2031	19
Watershed Adaptive Management Option Annual Report Submittals - Annual Adaptive Management Report #11	July 31, 2032	19
Watershed Adaptive Management Option Annual Report Submittals - Annual Adaptive Management Report #12	July 31, 2033	19
Watershed Adaptive Management Option Annual Report Submittals - Annual Adaptive Management Report #13	July 31, 2034	20
Watershed Adaptive Management Option Annual Report Submittals -Final Adaptive Management Report for 3rd Permit Term	July 31, 2035	20
Watershed Adaptive Management Option Annual Report Submittals - Renewal of Adaptive Management Plan for Permit Reissuance	September 30, 2035	20
Watershed Adaptive Management Option Annual Report Submittals - Annual Adaptive Management Report #14	July 31, 2036	20

Watershed Adaptive Management Option Annual Report Submittals - Annual Adaptive Management Report #15	July 31, 2037	20
Watershed Adaptive Management Option Annual Report Submittals - Annual Adaptive Management Report #16	July 31, 2038	20
Watershed Adaptive Management Option Annual Report Submittals - Annual Adaptive Management Report #17	July 31, 2039	20
Watershed Adaptive Management Option Annual Report Submittals -Final Adaptive Management Report	July 31, 2040	20
Watershed Adaptive Management Option Annual Report Submittals - Achieve Water Quality Standards and Adaptive Management Plan Success	March 31, 2041	20
Disinfection and Effluent Limitations for E. coli -Construction Upgrade Progress Report	September 30, 2026	21
Disinfection and Effluent Limitations for E. coli -Complete Construction	March 31, 2027	21
Disinfection and Effluent Limitations for E. coli -Achieve Compliance	April 1, 2027	21
Install Continuous Flow Recording Device -Complete Install	April 1, 2027	21
Land Application Management Plan -Land Application Management Plan Submittal	March 31, 2027	21
Compliance Maintenance Annual Reports (CMAR)	by June 30, each year	23
General Sludge Management Form 3400-48	prior to any significant sludge management changes	31
Characteristic Form 3400-49 and Lab Report	by January 31 following each year whether or not samples are analyzed	32
Land Application Report Form 3400-55	by January 31, each year whether or not non-exceptional quality sludge is land applied	32
Other Methods of Disposal or Distribution Report Form 3400-52	by January 31, each year whether or not sludge is hauled, landfilled, incinerated, or exceptional quality sludge is distributed or land applied	33
Wastewater Discharge Monitoring Report	no later than the date indicated on the form	22

Report forms shall be submitted electronically in accordance with the reporting requirements herein. Any facility plans or plans and specifications for municipal, industrial, industrial pretreatment and non industrial wastewater systems shall be submitted to the Bureau of Water Quality, P.O. Box 7921, Madison, WI 53707-7921. All other submittals required by this permit shall be submitted to:

South Central Region, 3911 Fish Hatchery Rd, Fitchburg, WI 53711-5397