

Permit Fact Sheet

General Information

Permit Number	WI-0021555-11-0
Permittee Name and Address	Village of Saukville Sewer Utility 1600 Cottontail Drive, Saukville, WI 53080
Permitted Facility Name and Address	Saukville Village Sewer Utility 1600 Cottontail Drive
Permit Term	October 01, 2025 to September 30, 2030
Discharge Location	East bank of the Milwaukee River (South), ¼ mile south of the Hwy 33 bridge and approximately 300 feet west of the WWTP UV disinfection building at 1600 Cottontail Drive (Lat: 43.37514° Long: -87.94204°W)
Receiving Water	Milwaukee River South (Milwaukee River South Watershed of Milwaukee River Basin) in Ozaukee County
Stream Flow (Q _{7,10})	24 cfs
Stream Classification	Warm water sport fish community; non-public water supply. The Milwaukee River South is on the 303(d) impaired waters list for low dissolved oxygen, elevated temperature, pathogens, and PCBs.
Discharge Type	Existing and Continuous
Annual Average Design Flow (MGD)	1.61 MGD
Industrial or Commercial Contributors	Yes, Jeniel Biotechnology (food processes, flavors and preservatives). Charter Rolling steel mill (produces steel coils) contributes significant hydraulic loading. Arkema plastics and resin manufacturing.
Plant Classification	A1 - Suspended Growth Processes; B - Solids Separation; C - Biological Solids/Sludges; P - Total Phosphorus; D - Disinfection; L - Laboratory; SS - Sanitary Sewage Collection System
Approved Pretreatment Program?	N/A

Facility Description

The Village of Saukville Sewer Utility operates a 1.61 MGD wastewater treatment facility that serves a population of approximately 4,400 residents with one categorical industrial user that contributes nearly 20% of the facility's daily flow. The facility is an extended aeration activated sludge wastewater treatment facility (WWTF) and underwent major plant upgrades in 2002 and 2023. Waste stream processes include mechanical fine screening with a compactor, grit removal, biological treatment in a three-ring Orbal oxidation ditch and settling in two final clarifiers. PAC is added prior to the Aqua aerobic filters for phosphorus removal. Disinfection is achieved through an ultraviolet system. Waste sludge from clarifiers is aerobically digested and sent to a belt press. Cake sludge is stored onsite and land applied onto agricultural sites by a contract hauler. The Department has found the facility to be in substantial compliance with the current permit.

Substantial Compliance Determination

After a desk top review of all discharge monitoring reports, CMARs, land app reports, compliance schedule items, and a site visit on **October 16, 2024**, this facility has been found to be in substantial compliance with their current permit.

Compliance determination made by Curt Nickels, Wastewater Engineer on November 27, 2024.

Sample Point Descriptions

Sample Point Designation		
Sample Point Number	Discharge Flow, Units, and Averaging Period	Sample Point Location, Waste Type/Sample Contents and Treatment Description (as applicable)
701	1.1 MGD (2024)	INFLUENT WITH RECYCLED FLOWS: 24-hr flow proportional composite samples shall be collected at the discharge manifold in the sludge pump room. Flow monitoring shall be conducted via mag meter just prior to the grit chamber. Includes recycled flows.
702	1.0 MGD (2024)	INFLUENT WITHOUT RECYCLED FLOWS: Flow monitoring shall be conducted via 10" Palmer Bowlus flume upstream of the bar screen. Sample point does not include recycled flows.
001	1.2 MGD (2024)	Effluent: 24-hr flow proportional composite sampler located in the last channel of the UV system prior to UV treatment. Grab samples taken at the bottom of the cascade aeration steps.
003	130 dry US tons (per 2025 application)	Class B, aerobically digested, belt press thickened, cake sludge. Representative samples shall be taken from the belt press during the pressing process.
110	N/A	IN PLANT: Collect the field blank using standard sample handling procedures.

Permit Requirements

1 Influent – Monitoring Requirements

1.1 Sample Point Number: 701- INFLUENT With Recycled Flows

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Daily	Continuous	
BOD5, Total		mg/L	3/Week	24-Hr Flow Prop Comp	
Suspended Solids, Total		mg/L	3/Week	24-Hr Flow Prop Comp	
Mercury, Total Recoverable		ng/L	Annual	24-Hr Flow Prop Comp	See "Mercury Monitoring" section in permit

1.1.1 Changes from Previous Permit:

Influent limitations and monitoring requirements were evaluated for this permit term and no changes were required in this permit section.

1.1.2 Explanation of Limits and Monitoring Requirements

Monitoring of influent flow, BOD5 and total suspended solids is required by s. NR 210.04(2), Wis. Adm. Code, to assess wastewater strengths and volumes and to demonstrate the percent removal requirements in s. NR 210.05, Wis. Adm. Code, and in the Standard Requirements section of the permit.

1.2 Sample Point Number: 702- INFLUENT W/O Recycled Flows

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Daily	Measure	

1.2.1 Changes from Previous Permit:

Influent limitations and monitoring requirements were evaluated for this permit term and no changes were required in this permit section.

2 Inplant - Monitoring and Limitations

2.1 Sample Point Number: 110- MERCURY FIELD BLANK

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Mercury, Total Recoverable		ng/L	Annual	Blank	See "Mercury Monitoring" in permit.

2.1.1 Changes from Previous Permit:

In-plant limitations and monitoring requirements were evaluated for this permit term and no changes were required in this permit section.

2.1.2 Explanation of Limits and Monitoring Requirements

Mercury Field Blank- Monitoring is included in the permit pursuant to s. NR 106.145, Wis. Adm. Code. Field blanks must meet the requirements under s. NR 106.145(9) and (10), Wis. Adm. Code. The permittee shall collect a mercury field blank for each set of mercury samples (a set of samples may include a combination of influent, effluent or other samples all collected on the same day). Field blanks are required to verify a sample has not been contaminated during collection, transportation or analysis.

Precipitation – This is an operational parameter, not a permit requirement and is not listed within the permit but is available on the eDMR. Measuring wet weather events is a tool that assists the facility in maintaining a healthy treatment system.

3 Surface Water - Monitoring and Limitations

3.1 Sample Point Number: 001- EFFLUENT

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Daily	Continuous	
BOD5, Total	Weekly Avg	45 mg/L	3/Week	24-Hr Flow Prop Comp	November – April
BOD5, Total	Weekly Avg	35 mg/L	3/Week	24-Hr Flow Prop Comp	May – October
BOD5, Total	Monthly Avg	30 mg/L	3/Week	24-Hr Flow Prop Comp	
BOD5, Total	Weekly Avg	470 lbs/day	3/Week	Calculated	
Suspended Solids, Total	Weekly Avg	45 mg/L	3/Week	24-Hr Flow Prop Comp	November
Suspended Solids, Total	Weekly Avg	12 mg/L	3/Week	24-Hr Flow Prop Comp	December – October
Suspended Solids, Total	Monthly Avg	12 mg/L	3/Week	24-Hr Flow Prop Comp	
Suspended Solids, Total	Weekly Avg	222.24 lbs/day	3/Week	Calculated	November
pH Field	Daily Max	9.0 su	Daily	Grab	
pH Field	Daily Min	6.0 su	Daily	Grab	
Dissolved Oxygen	Daily Max	5.0 mg/L	5/Week	Grab	
Nitrogen, Ammonia (NH3-N) Total	Daily Max	9.6 mg/L	3/Week	24-Hr Flow Prop Comp	
Nitrogen, Ammonia (NH3-N) Total	Monthly Avg	6.5 mg/L	3/Week	24-Hr Flow Prop Comp	
Nitrogen, Ammonia (NH3-N) Total	Monthly Avg	9.6 mg/L	3/Week	24-Hr Flow Prop Comp	
Nitrogen, Ammonia (NH3-N) Total	Weekly Avg	9.6 mg/L	3/Week	24-Hr Flow Prop Comp	
E. coli	Geometric Mean - Monthly	126 #/100 ml	Weekly	Grab	May - September
E. coli	% Exceedance	10 Percent	Monthly	Calculated	May - September. No more than 10% of E.coli bacteria samples collected in any

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
					calendar month may exceed 410 count/100 mL.
Phosphorus, Total	Monthly Avg	1.0 mg/L	3/Week	24-Hr Flow Prop Comp	Technology based effluent limit.
Phosphorus, Total	Monthly Avg	2.83 lbs/day	3/Week	Calculated	January
Phosphorus, Total	Monthly Avg	3.11 lbs/day	3/Week	Calculated	February
Phosphorus, Total	Monthly Avg	2.40 lbs/day	3/Week	Calculated	March
Phosphorus, Total	Monthly Avg	2.76 lbs/day	3/Week	Calculated	April
Phosphorus, Total	Monthly Avg	2.35 lbs/day	3/Week	Calculated	May
Phosphorus, Total	Monthly Avg	3.04 lbs/day	3/Week	Calculated	June
Phosphorus, Total	Monthly Avg	2.55 lbs/day	3/Week	Calculated	July
Phosphorus, Total	Monthly Avg	2.50 lbs/day	3/Week	Calculated	August
Phosphorus, Total	Monthly Avg	2.53 lbs/day	3/Week	Calculated	September
Phosphorus, Total	Monthly Avg	2.05 lbs/day	3/Week	Calculated	October
Phosphorus, Total	Monthly Avg	2.82 lbs/day	3/Week	Calculated	November
Phosphorus, Total	Monthly Avg	2.52 lbs/day	3/Week	Calculated	December
Mercury, Total Recoverable		ng/L	Annual	Grab	See 'Mercury Monitoring' section in permit.
PFOS		ng/L	1/ 2 Months	Grab	Monitoring only. See PFOS/PFOA Minimization Plan Determination of Need schedule in permit.
PFOA		ng/L	1/ 2 Months	Grab	Monitoring only. See PFOS/PFOA Minimization Plan Determination of Need schedule in permit.
Nitrogen, Total Kjeldahl		mg/L	Quarterly	24-Hr Flow Prop Comp	
Nitrogen, Nitrite + Nitrate Total		mg/L	Quarterly	24-Hr Flow Prop Comp	
Nitrogen, Total		mg/L	Quarterly	Calculated	Total Nitrogen shall be calculated as the sum of reported values for Total Kjeldahl Nitrogen and Total Nitrite + Nitrate Nitrogen.

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Acute WET		TUa	See Listed Qtr(s)	24-Hr Flow Prop Comp	See 'Wet Testing' Section in permit.
Chronic WET	Monthly Avg	3.4 TUc	See Listed Qtr(s)	24-Hr Flow Prop Comp	See "Wet Testing' Section in permit.
Chloride		mg/L	Monthly	24-Hr Flow Prop Comp	Monitoring only in 2029.

3.1.1 Changes from Previous Permit

Effluent limitations and monitoring requirements were evaluated for this permit term and the following changes were made from the previous permit. See additional explanation of limits under “Explanation of Limits and Monitoring Requirements” below.

DO-monitoring frequency increased.

Ammonia Nitrogen-monitoring frequency increased.

Phosphorus-all limits became final in last permit. The 1 mg/L remains as a technology-based effluent limit.

PFOS and PFOA monitoring was added at a frequency of once every two months in accordance with s. NR 106.98(2) Wis. Adm. Code.

Chloride monitoring was changed to 2029.

3.1.2 Explanation of Limits and Monitoring Requirements

Detailed discussions of limits and monitoring requirements can be found in the attached water quality-based effluent limits (WQBEL) memo dated March 28, 2025.

Monitoring Frequencies- The Monitoring Frequencies for Individual Wastewater Permits guidance (April 12, 2021) recommends that standard monitoring frequencies be included in individual wastewater permits based on the size and type of the facility, in order to characterize effluent quality and variability, to detect events of noncompliance, and to ensure consistency in permits issued across the state. Guidance and requirements in administrative code were considered when determining the appropriate monitoring frequencies for pollutants that have final effluent limits in effect during this permit term. DO and Ammonia Nitrogen monitoring frequency was increased to meet the minimum frequencies listed in the guidance.

Expression of Limits- In accordance with the federal regulation 40 CFR 122.45(d) and s. NR 205.065, Wis. Adm. Code, limits in this permit are to be expressed as weekly and monthly average limits whenever practicable.

TSS-The Milwaukee River Basin TMDL was approved by the EPA on March 9, 2018 and has wasteload allocations (WLAs) for total suspended solids (TSS). Consistent with Section 6.4.1 of the Milwaukee River TMDL Report, in cases where the equivalent TSS concentration limit is < 12 mg/L, the effluent limit will be expressed as a concentration of 12 mg/L monthly average. November has an equivalent weekly average TSS concentration limit greater than 12 mg/L, so the weekly mass TMDL limit for November is continued along with the current weekly concentration limit of 45 mg/L. The 45 mg/L limit must be retained to meet antibacksliding requirements in ch. NR 207, Wis. Adm. Code.

Phosphorus-Technology-Based Effluent Limit

Subchapter II of Chapter NR 217, Wis. Adm. Code, requires municipal wastewater treatment facilities that discharge greater than 150 pounds of total phosphorus per month to comply with a monthly average limit of 1.0 mg/L, or an

approved alternative concentration limit.

Phosphorus-The Milwaukee River Basin TMDL is an integrated watershed management planning approach that sets Waste Load Allocations (WLAs) for all permitted point sources and Load Allocations (LAs) for all contributing nonpoint sources to impaired waterbodies as required through Section 303(d) of the Clean Water Act. Calculated monthly average mass-based effluent limits replace the former s. NR 217.13 Wis. Adm. Code limits for phosphorus and are consistent with how the mass-based limits are calculated for other dischargers in the Milwaukee River Basin. These limits are already effective, and no changes are recommended in the reissued permit.

Subchapter II of Chapter NR 217, Wis. Adm. Code, requires municipal wastewater treatment facilities that discharge greater than 150 pounds of total phosphorus per month to comply with a monthly average limit of 1.0 mg/L, or an approved alternative concentration limit.

PFOS and PFOA – NR 106 Subchapter VIII – Permit Requirements for PFOS and PFOA Dischargers became effective on August 1, 2022. At the first reissuance of a WPDES permit after August 1, 2022, the new rule requires WPDES permits for major municipal dischargers with an average flow rate greater than 1 MGD but less than 5 MGD, at a minimum sample effluent once every two-months for PFOS and PFOA pursuant s. NR 106.98(2)(b), Wis. Adm. Code.

A sample frequency of 1/2 months means one sample is taken during any two-month period. Examples of 1/2 month sample would be every other month (Jan, March, May, etc.) or back-to-back months with a break in between (February & March, May & June, Aug & Sept, etc.). DMR Short Forms will be generated for the following time periods: January-February, March-April, May-June, July-August, September-October, and November-December. At a minimum one sample result will be present on each form.

The initial determination of the need for sampling shall be conducted for up to two years in order to determine if the permitted discharge has the reasonable potential to cause or contribute to an exceedance of the PFOS or PFOA standards under s. NR 102.04(8)(d)1, Wis. Adm. Code.

4 Land Application - Monitoring and Limitations

Municipal Sludge Description						
Sample Point	Sludge Class (A or B)	Sludge Type (Liquid or Cake)	Pathogen Reduction Method	Vector Attraction Method	Reuse Option	Amount Reused/Disposed (Dry Tons/Year)
003	Class B	Cake	Fecal Coliform	Incorporation	Land Application	130 dry US tons (per 2025 application)
Does sludge management demonstrate compliance? Yes						
Is additional sludge storage required? No						
Is Radium-226 present in the water supply at a level greater than 2 pCi/liter? No						
If yes, special monitoring and recycling conditions will be included in the permit to track any potential problems in land applying sludge from this facility						
Is a priority pollutant scan required? No, design flow is less than 5 MGD						

Municipal Sludge Description						
Sample Point	Sludge Class (A or B)	Sludge Type (Liquid or Cake)	Pathogen Reduction Method	Vector Attraction Method	Reuse Option	Amount Reused/Disposed (Dry Tons/Year)
Priority pollutant scans are required once every 10 years at facilities with design flows between 5 MGD and 40 MGD, and once every 5 years if design flow is greater than 40 MGD.						

4.1 Sample Point Number: 003- CAKE SLUDGE

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Solids, Total		Percent	Annual	Composite	
Arsenic Dry Wt	Ceiling	75 mg/kg	Annual	Composite	
Arsenic Dry Wt	High Quality	41 mg/kg	Annual	Composite	
Cadmium Dry Wt	Ceiling	85 mg/kg	Annual	Composite	
Cadmium Dry Wt	High Quality	39 mg/kg	Annual	Composite	
Copper Dry Wt	Ceiling	4,300 mg/kg	Annual	Composite	
Copper Dry Wt	High Quality	1,500 mg/kg	Annual	Composite	
Lead Dry Wt	Ceiling	840 mg/kg	Annual	Composite	
Lead Dry Wt	High Quality	300 mg/kg	Annual	Composite	
Mercury Dry Wt	Ceiling	57 mg/kg	Annual	Composite	
Mercury Dry Wt	High Quality	17 mg/kg	Annual	Composite	
Molybdenum Dry Wt	Ceiling	75 mg/kg	Annual	Composite	
Nickel Dry Wt	Ceiling	420 mg/kg	Annual	Composite	
Nickel Dry Wt	High Quality	420 mg/kg	Annual	Composite	
Selenium Dry Wt	Ceiling	100 mg/kg	Annual	Composite	
Selenium Dry Wt	High Quality	100 mg/kg	Annual	Composite	
Zinc Dry Wt	Ceiling	7,500 mg/kg	Annual	Composite	
Zinc Dry Wt	High Quality	2,800 mg/kg	Annual	Composite	
Nitrogen, Total Kjeldahl		Percent	Annual	Composite	
Nitrogen, Ammonium (NH ₄ -N) Total		Percent	Annual	Composite	
Phosphorus, Total		Percent	Annual	Composite	
Phosphorus, Water		% of Tot P	Annual	Composite	

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Extractable					
Potassium, Total Recoverable		Percent	Annual	Composite	
PCB Total Dry Wt	Ceiling	50 mg/kg	Once	Composite	Sample once during 2026
PCB Total Dry Wt	High Quality	10 mg/kg	Once	Composite	Sample once during 2026
PFOA + PFOS		ug/kg	Once	Calculated	
PFAS Dry Wt			Once	Grab	Perfluoroalkyl and Polyfluoroalkyl Substances based on updated DNR PFAS List. See PFAS Permit Sections for more information.

4.1.1 Changes from Previous Permit:

PCB -Monitoring once in 2026.

PFAS –Monitoring is required **annually** pursuant to s. NR 204.06(2)(b)9, Wis. Adm. Code.

4.1.2 Explanation of Limits and Monitoring Requirements

Requirements for disposal, including land application of municipal sludge, are determined in accordance with ch. NR 204, Wis. Adm. Code. Ceiling and high-quality limits for metals in sludge are specified in s. NR 204.07(5), Wis. Adm. Code. Requirements for pathogens are specified in s. NR 204.07(6) and in s. NR 204.07 (7), Wis. Adm. Code for vector attraction requirements. Limitations for PCBs are addressed in s. NR 204.07(3)(k), Wis. Adm. Code.

PFAS- The presence and fate of PFAS in municipal and industrial sludges is an emerging public health concern. EPA is currently developing a risk assessment to determine future land application rates and expects to release this risk assessment by the end of 2024. In the interim, the department has developed the “Interim Strategy for Land Application of Biosolids and Industrial Sludges Containing PFAS.”

Collecting sludge data on PFAS concentrations from a wide range of wastewater treatment facilities will help protect public health from exposure to elevated levels of PFAS and determine the department’s implementation of EPA’s recommendations. To quantitate this risk, PFAS sampling has been included in this WPDES permit pursuant to ss. NR 214.18(5)(b) and NR 204.06(2)(b)9, Wis. Adm. Code.

5 Compliance Schedule

5.1 PFOS and PFOA Minimization Plan

Required Action	Due Date
Report on Effluent Discharge: Submit a report on effluent PFOS and PFOA concentrations and include an analysis of trends in monthly and annual average PFOS and PFOA concentrations. This analysis should also include a comparison to the applicable narrative standard in s. NR 102.04(8)(d),	09/30/2026

Wis. Adm. Code. This report shall include all additional PFOS and PFOA data that may be collected including any influent, intake, in-plant, collection system sampling, and blank sample results.	
<p>Report on Effluent Discharge and Evaluation of Need: Submit a final report on effluent PFOS and PFOA concentrations and include an analysis of trends in monthly and annual average PFOS and PFOA concentrations of data collected over the last 24 months. The report shall also provide a comparison on the likelihood of the facility needing to develop a PFOS/PFOA minimization plan.</p> <p>This report shall include all additional PFOS and PFOA data that may be collected including any influent, intake, in-plant, collection system sampling, and blank sample results.</p> <p>The permittee shall also submit a request to the department to evaluate the need for a PFOS/PFOA minimization plan.</p> <p>If the Department determines a PFOS/PFOA minimization plan is needed based on a reasonable potential evaluation, the permittee will be required to develop a minimization plan for Department approval no later than 90 days after written notification was sent from the Department. The Department will modify or revoke and reissue the permit to include PFOS/PFOA minimization plan reporting requirements along with a schedule of compliance to meet WQBELs. Effluent monitoring of PFOS and PFOA shall continue as specified in the permit until the modified permit is issued.</p> <p>If, however, the Department determines there is no reasonable potential for the facility to discharge PFOS or PFOA above the narrative standard in s. NR 102.04(8)(d), Wis. Adm. Code, no further action is required and effluent monitoring of PFOS and PFOA shall continue as specified in the permit.</p>	09/30/2027

5.2 Land Application Management Plan

A management plan is required for the land application system.

Required Action	Due Date
<p>Land Application Management Plan Submittal: Submit an update to the management plan to optimize the land application system performance and demonstrate compliance with ch. NR 204, Wis. Adm. Code, by the Due Date. This management plan shall 1) specify information on pretreatment processes (if any); 2) identify land application sites; 3) describe site limitations; 4) address vegetative cover management and removal; 5) specify availability of storage; 6) describe the type of transporting and spreading vehicle(s); 7) specify monitoring procedures; 8) track site loading; 9) address contingency plans for adverse weather and odor/nuisance abatement; and 10) include any other pertinent information. Once approved, all landspreading activities shall be conducted in accordance with the plan. Any changes to the plan must be approved by the Department prior to implementing the changes.</p>	09/30/2026

Attachments

Water Quality Based Effluent Limits Memo -March 28, 2025

Justification Of Any Waivers From Permit Application Requirements

No waivers requested or granted as part of this permit reissuance

Prepared By: Susan Eichelkraut

Wastewater Specialist

Date: July 30, 2025

CORRESPONDENCE/MEMORANDUM

State of Wisconsin

DATE: 03/28/2025

TO: Bryan Hartsook - SER

FROM: Nicole Krueger – SER *Nicole Krueger*

SUBJECT: Water Quality-Based Effluent Limitations for Saukville Village Sewer Utility
WPDES Permit No. WI-0021555-11

This is in response to your request for an evaluation of the need for water quality-based effluent limitations (WQBELs) using Chapters NR 102, 104, 105, 106, 207, 210, 212, and 217 of the Wisconsin Administrative Code (where applicable), for the discharge from Saukville Sewer Utility in Ozaukee County. This municipal wastewater treatment facility (WWTF) discharges to the Milwaukee River, located in the Lower Milwaukee River Watershed in the Milwaukee River Basin. This discharge is included in the Milwaukee River Basin TMDL as approved by EPA on 03/09/2018. The evaluation of the permit recommendations is discussed in more detail in the attached report.

Based on our review, the following recommendations are made on a chemical-specific basis at Outfall 001:

Parameter	Daily Maximum	Daily Minimum	Weekly Average	Monthly Average	Footnotes
Flow Rate					1,2
BOD ₅ November – April May – October			45 mg/L 35 mg/L 470 lbs/day	30 mg/L 30 mg/L	1
TSS November Dec – Oct			45 mg/L See Table	See Table See Table	3
pH	9.0 s.u.	6.0 s.u.			1
Dissolved Oxygen		5.0 mg/L			1
Ammonia Nitrogen April – May June – September October – March	9.6 mg/L 9.6 mg/L 9.6 mg/L		9.6 mg/L 9.6 mg/L 9.6 mg/L	9.6 mg/L 9.6 mg/L 6.5 mg/L	4
<i>E. coli</i> May – September				126 #/100 mL geometric mean	5
Phosphorus TBEL TMDL				1.0 mg/L See Table	1,3
Mercury					1,2
PFOS & PFOA					6
TKN, Nitrate+Nitrite, and Total Nitrogen					1,7
Acute WET					8,9
Chronic WET				3.4 TUc	8,9
Chloride					10

Footnotes:

1. No changes from the current permit.

2. Monitoring only.
3. The TSS and phosphorus limits below are based on the Total Maximum Daily Load (TMDL) for the Milwaukee River Basin to address phosphorus water quality impairments within the TMDL area.

Month	Monthly Average TP Effluent Limit (lbs/day)	Weekly Average TSS Effluent Limit (mg/L)	Weekly Average TSS Effluent Limit (lbs/day)	Monthly Average TSS Effluent Limit (mg/L)
Jan	2.83	12	-	12
Feb	3.11	12	-	12
Mar	2.40	12	-	12
Apr	2.76	12	-	12
May	2.35	12	-	12
Jun	3.04	12	-	12
Jul	2.55	12	-	12
Aug	2.50	12	-	12
Sep	2.53	12	-	12
Oct	2.05	12	-	12
Nov	2.82		222.24	12
Dec	2.52	12	-	12

4. Additional limits to comply with the expression of limits requirements in ss. NR 106.07 and NR 205.065(7), Wis. Adm. Codes, are included in bold.
5. Additional bacteria limit: No more than 10 percent of *E. coli* bacteria samples collected in any calendar month may exceed 410 count/100 mL.
6. PFOS and PFOA monitoring is recommended at a frequency of once every two months in accordance with s. NR 106.98(2), Wis. Adm. Code.
7. As recommended in the Department's October 1, 2019 Guidance for Total Nitrogen Monitoring in Wastewater Permits, quarterly total nitrogen monitoring is recommended for all municipal major permittees. Sections 283.37(5) and 283.55(1)(e), Wis. Stats, and ss. NR 200.065(1)(g) and NR 200.065(1)(h), Wis. Adm. Codes, provide the authority to request this monitoring during the permit term. Total Nitrogen is the sum of nitrate (NO₃), nitrite (NO₂), and total Kjeldahl nitrogen (TKN) (all expressed as N).
8. Annual acute and chronic WET testing is recommended. The Instream Waste Concentration (IWC) to assess chronic test results is 29%. According to the *State of Wisconsin Aquatic Life Toxicity Testing Methods Manual* (s. NR 219.04, Table A, Wis. Adm. Code), chronic testing shall be performed using a dilution series of 100%, 30%, 10%, 3% & 1%. The primary control water used in chronic WET tests conducted on Outfall 001 shall be a grab sample collected from the Milwaukee River.
9. Sampling WET concurrently with any chemical-specific toxic substances is recommended. Tests should be done in rotating quarters, to collect seasonal information about this discharge. Testing should continue after the permit expiration date (until the permit is reissued).
10. Monitoring at a frequency to ensure that at least 11 samples are available at the next permit issuance.

Please consult the attached report for details regarding the above recommendations. If there are any questions or comments, please contact Nicole Krueger at Nicole.Krueger@wisconsin.gov or Diane Figiel at Diane.Figiel@wisconsin.gov.

Attachments (4) – Narrative, Outfall Map, 2020 Ammonia Limits Calculations, & Thermal Table

PREPARED BY: Nicole Krueger, Water Resources Engineer – SER

E-cc: Curt Nickels, Wastewater Engineer – SER
Bryan Hartsook, Regional Wastewater Supervisor – SER
Diane Figiel, Water Resources Engineer – WY/3
Nate Willis, Wastewater Engineer – WY/3

Attachment #1
**Water Quality-Based Effluent Limitations for
Saukville Village Sewer Utility**

WPDES Permit No. WI-0021555-11

Prepared by: Nicole Krueger

PART 1 – BACKGROUND INFORMATION

Facility Description

The Village of Saukville Sewer Utility serves a population of approximately 4400 with one categorical industrial user that contributes about 25% of the facility's daily flow. The facility is an extended aeration activated sludge wastewater treatment facility (WWTF) and underwent a major plant upgrade in 2002. Waste stream processes include mechanical fine screening, grit removal, biological treatment in a three-ring Orbal oxidation ditch and settling in two final clarifiers. Ferrous chloride is added prior to the clarifier for phosphorus removal. Disinfection is achieved through an ultraviolet system.

Attachment #2 is a map of the area showing the approximate location of Outfall 001.

Existing Permit Limitations

The current permit, expiring on 09/30/2025, includes the following effluent limitations and monitoring requirements.

Parameter	Daily Maximum	Daily Minimum	Weekly Average	Monthly Average	Footnotes
Flow Rate					1
BOD ₅ November – April May – October			45 mg/L 35 mg/L 470 lbs/day	30 mg/L 30 mg/L	2,3
TSS November Dec – Oct			45 mg/L Table	Table Table	4
pH	9.0 s.u.	6.0 s.u.			2
Dissolved Oxygen		5.0 mg/L			2
Ammonia Nitrogen April – May June – September October – March	9.6 mg/L 9.6 mg/L 9.6 mg/L		9.6 mg/L 9.6 mg/L 9.6 mg/L	9.6 mg/L 9.6 mg/L 6.5 mg/L	5
<i>E. coli</i>				126 #/100 mL geometric mean	2,6
Mercury					1
Phosphorus TBEL TMDL				1.0 mg/L Table	4
TKN, Nitrate+Nitrite, and Total Nitrogen					1
Acute WET					7

Attachment #1

Parameter	Daily Maximum	Daily Minimum	Weekly Average	Monthly Average	Footnotes
Chronic WET				3.4 TU _c	7

Footnotes:

1. Monitoring only.
2. These limitations are not being evaluated as part of this review. Because the water quality criteria (WQC), reference effluent flow rates, and receiving water characteristics have not changed, limitations for these water quality characteristics do not need to be re-evaluated at this time.
3. These limits are based on the Warm Water Sport Fish (WWSF) community of the immediate receiving water as described in s. NR 210.05(1), Wis. Adm. Code.
4. The TSS and phosphorus limits in the table below are based on the Total Maximum Daily Load (TMDL) for the Milwaukee River Basin to address phosphorus water quality impairments within the TMDL area.

Month	Monthly Average TP Effluent Limit (lbs/day)	Weekly Average TSS Effluent Limit (mg/L)	Weekly Average TSS Effluent Limit (lbs/day)	Monthly Average TSS Effluent Limit (mg/L)
Jan	2.83	12	-	12
Feb	3.11	12	-	12
Mar	2.40	12	-	12
Apr	2.76	12	-	12
May	2.35	12	-	12
Jun	3.04	12	-	12
Jul	2.55	12	-	12
Aug	2.50	12	-	12
Sep	2.53	12	-	12
Oct	2.05	12	-	12
Nov	2.82		222.24	12
Dec	2.52	12	-	12

5. Additional limits to comply with the expression of limits requirements in ss. NR 106.07 and NR 205.065(7), Wis. Adm. Codes, are included in bold.
6. Additional bacteria limit: No more than 10 percent of *E. coli* bacteria samples collected in any calendar month may exceed 410 count/100 mL.
7. Annual acute and chronic WET testing is required in the current permit. The IWC for chronic WET was 29%.

Receiving Water Information

- Name: Milwaukee River
- Waterbody Identification Code (WBIC): 15000
- Classification used in accordance with chs. NR 102 and 104, Wis. Adm. Code: Warm Water Sport Fish (WWSF) community, non-public water supply. Note: Cold Water and Public Water Supply criteria are used for bioaccumulating compounds of concern, because the discharge is within the Great Lakes basin.
- Low flows used in accordance with chs. NR 106 and 217, Wis. Adm. Code: The following 7-Q₁₀ and 7-Q₂ values are from USGS for Station M19, where Outfall 001 is located.
7-Q₁₀ = 24 cubic feet per second (cfs)

$$7-Q_2 = 52 \text{ cfs}$$

$$90-Q_{10} = 44.2 \text{ cfs}$$

Harmonic Mean Flow = 105 cfs using a drainage area of 457 mi²

- Hardness = 301 mg/L as CaCO₃. This value represents the geometric mean of data from chronic WET (n=4) testing from 12/01/2020 – 03/07/2023.
- % of low flow used to calculate limits in accordance with s. NR 106.06(4)(c)5., Wis. Adm. Code: 25%. A mixing zone is not allowed for discharges of bioaccumulating compounds of concern (BCCs) in the Great Lakes system as described in s. NR 106.06(2)(br), Wis. Adm. Code.
- Source of background concentration data: Metals data from the Milwaukee River at Batavia is used for this evaluation. This data is from the ‘*DNR Water Quality Rules Implementation Plan*’, Chapter 4, January 1998; *Background of the Milwaukee River at Batavia*. Background chloride data from the Milwaukee River at Hwy 33 in Saukville. The numerical values are shown in the tables below. If no data is available, the background concentration is assumed to be negligible and a value of zero is used in the computations. Background data for calculating effluent limitations for ammonia nitrogen are described later.
- Multiple dischargers: There are several other dischargers to the Milwaukee River, however they are not in the immediate vicinity and the mixing zones do not overlap. Therefore, the other dischargers do not impact this evaluation.
- Impaired water status: The Milwaukee River at the outfall is 303(d) listed as impaired for PCBs and total phosphorus.

Effluent Information

- Design flow rate(s):
 Annual average = 1.61 million gallons per day (MGD)
 Peak daily = 3.41 MGD
 Peak weekly = 2.97 MGD
 Peak monthly = 2.51 MGD
 For reference, the actual average flow from 01/01/2020 – 02/28/2025 was 1.02 MGD.
- Hardness = 580 mg/L as CaCO₃. This value represents the geometric mean of four samples collected in August 2024 which were reported on the permit application.
- Acute dilution factor used in accordance with s. NR 106.06(3)(c), Wis. Adm. Code: Not applicable – this facility does not have an approved Zone of Initial Dilution (ZID).
- Wastewater source: Domestic wastewater with 2 industrial contributors (Charter Rolling and Jeniel Biotech).
- Water supply: Municipality waterworks and private wells.
- Effluent characterization: This facility is categorized as a major municipal, so the permit application required effluent sample analyses for all the “priority pollutants” except for the Dioxins and Furans as specified in s. NR 200.065, Table 1, Wis. Adm. Code. The permit-required monitoring for mercury, phosphorus, and ammonia is used in this evaluation.
- Effluent data for substances for which a single sample was analyzed is shown in the tables in Part 2, in the column titled “MEAN EFFL. CONC.”. Otherwise, substances with multiple effluent data are shown in the tables below or in their respective parts in this evaluation.

Chloride Effluent Data

	Chloride (mg/L)
1-day P ₉₉	997
4-day P ₉₉	786

Attachment #1

	Chloride (mg/L)
30-day P ₉₉	670
Mean	610
Std	137
Sample size	52
Range	362 – 960
Dates	01/13/2019 – 02/21/2025

Mercury Effluent Data

Sample Date	Mercury (ng/L)
05/27/2020	<0.20
08/12/2021	<0.20
06/01/2022	<0.20
03/08/2023	<0.50
02/22/2024	<0.20
Average*	0

*Results below the limit of detection (LOD) were included as zeroes in calculation of average.

The following table presents the average concentrations and loadings at Outfall 001 from 01/01/2020 – 02/28/2025 for all parameters with limits in the current permit to meet the requirements of s. NR 201.03(6), Wis. Adm. Code:

Parameters with Effluent Limits

	Average Measurement	Average Mass Discharged
BOD ₅	2.62 mg/L*	18 lbs/day
TSS	2.68 mg/L*	20 lbs/day
pH field	7.68 s.u.	
Dissolved Oxygen	8.91 mg/L	
Ammonia Nitrogen	0.02 mg/L*	
<i>E. coli</i>	1.6 #/100 mL**	
Phosphorus	0.34 mg/L*	1.41 lbs/day

*Results below the limit of detection (LOD) were included as zeroes in calculation of average.

** The average measurement for bacteria is calculated as a geometric mean. Values reported below the LOD are replaced with a value of 1 for the calculation of the geometric mean.

**PART 2 – WATER QUALITY-BASED EFFLUENT LIMITATIONS
FOR TOXIC SUBSTANCES – EXCEPT AMMONIA NITROGEN**

Permit limits for toxic substances are required whenever any of the following occur:

1. The maximum effluent concentration exceeds the calculated limit (s. NR 106.05(3), Wis. Adm. Code)
2. If 11 or more detected results are available in the effluent, the upper 99th percentile (or P₉₉) value exceeds the comparable calculated limit (s. NR 106.05(4), Wis. Adm. Code)
3. If fewer than 11 detected results are available, the mean effluent concentration exceeds 1/5 of the calculated limit (s. NR 106.05(6), Wis. Adm. Code)

Acute Limits based on 1-Q₁₀

Daily maximum effluent limitations for toxic substances are based on the acute toxicity criteria (ATC), listed in ch. NR 105, Wis. Adm. Code. Previously daily maximum limits for toxic substances were calculated as two times the ATC. However, changes to ch. NR 106, Wis. Code, (September 1, 2016) require the Department to calculate acute limitations using the same mass balance equation as used for other limits along with the 1-Q₁₀ receiving water low flow to determine if more restrictive effluent limitations are needed to protect the receiving stream from discharges which may cause or contribute to an exceedance of the acute water quality standards. The mass balance equation is provided below.

$$\text{Limitation} = \frac{(\text{WQC}) (Q_s + (1-f) Q_e) - (Q_s - f Q_e) (C_s)}{Q_e}$$

Where:

WQC = Acute toxicity criterion or secondary acute value according to ch. NR 105, Wis. Adm. Code.

Q_s = average minimum 1-day flow which occurs once in 10 years (1-day Q₁₀)
if the 1-day Q₁₀ flow data is not available = 80% of the average minimum 7-day flow which occurs once in 10 years (7-day Q₁₀).

Q_e = Effluent flow (in units of volume per unit time) as specified in s. NR 106.06(4)(d), Wis. Adm. Code.

f = Fraction of the effluent flow that is withdrawn from the receiving water, and

C_s = Background concentration of the substance (in units of mass per unit volume) as specified in s. NR 106.06(4)(e), Wis. Adm. Code.

If the receiving water is effluent dominated under low stream flow conditions, the 1-Q₁₀ method of limit calculation produces the most stringent daily maximum limitations and should be used while making reasonable potential determinations. This is not the case for Saukville, and the limits are set based on two times the acute toxicity criteria.

The following tables list the calculated WQBELs for this discharge along with the results of effluent sampling for all the detected substances. All concentrations are expressed in terms of micrograms per Liter (µg/L), except for hardness and chloride (mg/L) and mercury (ng/L).

Daily Maximum Limits based on Acute Toxicity Criteria (ATC)

RECEIVING WATER FLOW = 19.2 cfs, (1-Q₁₀ (estimated as 80% of 7-Q₁₀)), as specified in s. NR 106.06(3)(bm), Wis. Adm. Code.

SUBSTANCE	REF. HARD.* mg/L	ATC	MEAN BACK- GRD.	MAX. EFFL. LIMIT**	1/5 OF EFFL. LIMIT	MEAN EFFL. CONC.	1-day P ₉₉	1-day MAX. CONC.
Arsenic		340		680	136	2.1		
Cadmium	457	58.9	0.02	118	23.6	<0.15		
Chromium	301	4446	0.5	8892	1778	<2.5		
Copper	495	70.2	1.26	140	28.1	<1.9		
Lead	356	365	0.65	729	146	<0.24		
Mercury (ng/L)		830	4.11	1660	332	<0.2		
Nickel	268	1080		2161	432	2.5		
Zinc	333	345	2.61	689	138	<10.3		

Attachment #1

SUBSTANCE	REF. HARD.* mg/L	ATC	MEAN BACK- GRD.	MAX. EFFL. LIMIT**	1/5 OF EFFL. LIMIT	MEAN EFFL. CONC.	1-day P ₉₉	1-day MAX. CONC.
Chloride (mg/L)		757	83.5	1514			997	960

* The indicated hardness may differ from the effluent hardness because the effluent hardness exceeded the maximum range in ch. NR 105, Wis. Adm. Code, over which the acute criteria are applicable. In that case, the maximum of the range is used to calculate the criterion.

** The 2 × ATC method of limit calculation yields a more restrictive limit than consideration of ambient concentrations and 1-Q₁₀ flow rates per the changes to s. NR 106.07(3), Wis. Adm. Code, effective 09/01/2016.

Weekly Average Limits based on Chronic Toxicity Criteria (CTC)

RECEIVING WATER FLOW = 6.0 cfs (¼ of the 7-Q₁₀), as specified in s. NR 106.06(4)(c), Wis. Adm. Code

SUBSTANCE	REF. HARD.* mg/L	CTC	MEAN BACK- GRD.	WEEKLY AVE. LIMIT	1/5 OF EFFL. LIMIT	MEAN EFFL. CONC.	4-day P ₉₉
Arsenic		152		519	104	2.1	
Cadmium	175	3.82	0.02	13.0	2.59	<0.15	
Chromium	301	326	0.5	1109	222	<2.5	
Copper	301	26.6	1.26	87.6	17.5	<1.9	
Lead	301	81.2	0.65	275	55.1	<0.24	
Mercury (ng/L)		440	4.11	1490	298	<0.2	
Nickel	268	120		410	81.9	2.5	
Zinc	301	316	2.61	1069	214	<10.3	
Chloride (mg/L)		395	83.5	1145			786

* The indicated hardness may differ from the receiving water hardness because the receiving water hardness exceeded the maximum range in ch. NR 105, Wis. Adm. Code, over which the chronic criteria are applicable. In that case, the maximum of the range is used to calculate the criterion.

Monthly Average Limits based on Wildlife Criteria (WC)

RECEIVING WATER FLOW = 11 cfs (¼ of the 90-Q₁₀), as specified in s. NR 106.06(4), Wis. Adm. Code

SUBSTANCE	WC	MEAN BACK- GRD.	MO'LY AVE. LIMIT	1/5 OF EFFL. LIMIT	MEAN EFFL. CONC.	30-day P ₉₉
Mercury (ng/L)	1.3	4.11	1.3	0.26	<0.2	

Monthly Average Limits based on Human Threshold Criteria (HTC)

RECEIVING WATER FLOW = 26 cfs (¼ of Harmonic Mean), as specified in s. NR 106.06(4), Wis. Adm. Code.

SUBSTANCE	HTC	MEAN BACK- GRD.	MO'LY AVE. LIMIT	1/5 OF EFFL. LIMIT	MEAN EFFL. CONC.
Cadmium	370	0.02	4274	854.8	<0.15
Chromium (+3)	3818000	0.5	44106226	8821245	<2.5
Lead	140	0.65	1610	322.1	<0.24
Mercury (ng/L)	1.5	4.11	1.5	0.30	<0.5
Nickel	43000		496744	99349	2.5

Monthly Average Limits based on Human Cancer Criteria (HCC)RECEIVING WATER FLOW = 26 cfs ($\frac{1}{4}$ of Harmonic Mean), as specified in s. NR 106.06(4), Wis. Adm. Code.

SUBSTANCE	HCC	MEAN BACK- GRD.	MO'LY AVE. LIMIT	1/5 OF EFFL. LIMIT	MEAN EFFL. CONC.
Arsenic	13.3		154	30.7	2.1

In addition to evaluating the need for limits for each individual substance for which HCC exist, s. NR 106.06(8), Wis. Adm. Code, requires the evaluation of the cumulative cancer risk. Because no effluent limits are needed based on HCC, determination of the cumulative cancer risk is not needed per s. NR 106.06(8), Wis. Adm. Code.

Conclusions and Recommendations

Based on a comparison of the effluent data and calculated effluent limitations, effluent limitations are not required for any toxic substances in this section. Limits and/or monitoring recommendations are made in the paragraphs below:

Chloride – Considering available effluent data from the current permit term (01/13/2019 – 02/21/2025), the 1-day P₉₉ chloride concentration is 997 mg/L, and the 4-day P₉₉ of effluent data is 786 mg/L.

These effluent concentrations are below the calculated WQBELs for chloride, therefore no effluent limits are needed. **Chloride monitoring is recommended to ensure that at least 11 sample results are available at the next permit issuance to meet the data requirements of s. NR 106.85, Wis. Adm. Code.**

Mercury – The WQBEL for total recoverable mercury is set equal to the most stringent criterion of 1.3 ng/L, according to s. NR 106.06(6), Wis. Adm. Code, because the background concentration in the receiving water and similar inland streams is known to exceed 1.3 ng/L.

The current permit requires annual monitoring of the influent and effluent for total recoverable mercury. A total of 5 effluent sampling results are available from 05/27/2020 – 02/22/2024 for total recoverable mercury. The average concentration was <0.2 ng/L. Because the average of available data is less than 1/5th the most stringent WQBEL of 1.3 ng/L, **no WQBEL for mercury is required for permit reissuance. A minimum of annual mercury monitoring is recommended for permit reissuance.**

PFOS and PFOA – The need for PFOS and PFOA monitoring is evaluated in accordance with s. NR 106.98(2), Wis. Adm. Code. Available monitoring sample data from Saukville Waterworks (PWS ID: 24601346) is provided in the table below:

Water Supply PFAS Data

Sample Date	Sample ID	Well #	PFOS (ng/L)	PFOA (ng/L)
02/11/2025	MW4	BG659	23	1.2
02/11/2025	MW1	BG656	4.5	2.9
02/11/2025	MW5	KW480	0	8.7
10/21/2024	MW4	BG659	28	1.5
10/08/2024	MW1	BG656	4.9	2.7

Attachment #1

Sample Date	Sample ID	Well #	PFOS (ng/L)	PFOA (ng/L)
07/10/2024	MW1	BG656	5.9	3.3
07/10/2024	MW4	BG659	23	1.3
04/24/2024	MW4	BG659	32	1.9
04/08/2024	MW1	BG656	6.5	4.3
02/12/2024	MW5	KW480	0	0.78
02/06/2024	MW1	BG656	5.8	3.8
02/06/2024	MW4	BG659	32	1.5
10/11/2023	MW4	BG659	27	1.3
10/11/2023	MW5	KW480	0	1.1
10/11/2023	MW1	BG656	5.4	2.6
08/02/2023	MW4	BG659	0	1.4
08/02/2023	MW1	BG656	28	1.5
08/02/2023	MW5	KW480	5.4	2.9
05/16/2023	MW1	BG656	5.7	3.2
05/16/2023	MW4	BG659	31	1.5
05/15/2023	MW5	KW480	0	9.2
05/15/2023	MW3	BG658	0	0
05/15/2023	MW6	YO930	0	0
07/21/2022	MW4	BG659	27.7	1.25
07/19/2022	MW1	BG656	4.64	1.91
06/27/2022	MW3	BG658	0	0
06/21/2022	MW4	BG659	25.2	0
06/21/2022	MW6	YO930	0	0
06/21/2022	MW1	BG656	6.29	2.22
06/21/2022	MW5	KW480	0	5.24
Average =			11	2.3

The limited data above shows the municipal water supply is above 1/5th of the applicable PFOS criteria. Previous monitoring produced a PFOS result of 2.60 ng/L and a PFOA result of 3.59 ng/L. The PFOS result is greater than one fifth of the respective criteria for each substance. Based on the effluent flow rate, the available PFOS/PFOA monitoring data, and known levels of PFOS/PFOA in the source water, **PFOS and PFOA monitoring is recommended at a once every two months frequency.**

PART 3 – WATER QUALITY-BASED EFFLUENT LIMITATIONS FOR AMMONIA NITROGEN

The State of Wisconsin promulgated revised water quality standards for ammonia nitrogen in ch. NR 105, Wis. Adm. Code, effective March 1, 2004 which includes criteria based on both acute and chronic toxicity to aquatic life. The current permit has daily maximum, weekly average and monthly average limits. These limits are re-evaluated at this time due to the following changes:

- Subchapter IV of ch. NR 106, Wis. Adm. Code allows limits based on available dilution instead of limits set to twice the acute criteria.
- The maximum expected effluent pH has changed

Daily Maximum Limits based on Acute Toxicity Criteria (ATC)

Daily maximum limitations are based on acute toxicity criteria in ch. NR 105, Wis. Adm. Code, which are a function of the effluent pH and the receiving water classification. The acute toxicity criterion (ATC) for ammonia is calculated using the following equation:

$$\text{ATC in mg/L} = [A \div (1 + 10^{(7.204 - \text{pH})})] + [B \div (1 + 10^{(\text{pH} - 7.204)})]$$

Where:

A = 0.411 and B = 58.4 for a Warm Water Sport fishery, and
pH (s.u.) = that characteristic of the effluent.

The effluent pH data was examined as part of this evaluation. A total of 1886 sample results were reported from 01/02/2020 – 02/28/2025. The maximum reported value was 8.90 s.u. (Standard pH Units). The effluent pH was 8.43 s.u. or less 99% of the time. The 1-day P₉₉, calculated in accordance with s. NR 106.05(5), Wis. Adm. Code, is 8.19 s.u. The mean plus the standard deviation multiplied by a factor of 2.33, an estimate of the upper ninety ninth percentile for a normally distributed dataset, is 8.18 s.u. Therefore, a value of 8.2 s.u. is believed to represent the maximum reasonably expected pH, and therefore most appropriate for determining daily maximum limitations for ammonia nitrogen. Substituting a value of 8.2 s.u. into the equation above yields an ATC = 5.7 mg/L.

Daily Maximum Ammonia Nitrogen Effluent Limitations Calculation Method

In accordance with s. NR 106.32(2), Wis. Adm. Code daily maximum ammonia limitations are calculated using the the 1-Q₁₀ receiving water low flow if it is determined that the previous method of acute ammonia limit calculation (2×ATC) is not sufficiently protective of the fish and aquatic life. The more restrictive calculated limits shall apply.

The calculated daily maximum ammonia nitrogen effluent limits using the mass balance approach with the 1-Q₁₀ (estimated as 80 % of 7-Q₁₀) and the 2×ATC approach are shown below.

Daily Maximum Ammonia Nitrogen Determination

	Ammonia Nitrogen Limit mg/L
2×ATC	11
1-Q ₁₀	50

The 2×ATC method yields the most stringent limits for Saukville.

This limit is greater than the current daily maximum limit of 9.6 mg/L. If Saukville would like to request an increase to the existing permit limits an assessment of their effluent data consistent with the requirements of ss. NR 207.04(1)(a) and (c), Wis. Adm. Code, must be provided. This evaluation is on a parameter by parameter basis and includes consideration of operations, maintenance and temporary upsets. Without a demonstration of need for a higher limit in accordance with s. NR 207.04, Wis. Adm. Code, the current limits must be continued in the reissued permit. The Department would be unable to increase the limit due to the lack of need as shown via the antidegradation rule (ch. NR 207, Wis. Adm. Code) because the highest reported concentration was 1.05 mg/L during the previous permit term. **No changes are recommended in any of the permit limits for ammonia.**

Weekly and Monthly Average Limits based on Chronic Toxicity Criteria (CTC)

The weekly and monthly average ammonia nitrogen limits calculation from the previous memo do not change because there have been no changes in the effluent and receiving water flow rates. The calculations from the previous WQBEL memo are shown in Attachment #3.

Effluent Data

The following table evaluates the statistics based upon ammonia data reported from 01/05/2020 – 02/24/2025.

Ammonia Nitrogen Effluent Data

Ammonia Nitrogen mg/L	April – September	October - March
1-day P ₉₉	0.27	0.12
4-day P ₉₉	0.16	0.06
30-day P ₉₉	0.07	0.03
Mean *	0.02	0.01
Std	0.09	0.04
Sample size	261	278
Range	<0.012 - 1.049	<0.012 - 0.3

*Values lower than the limit of detection were substituted with a zero

Reasonable Potential

The need to include ammonia limits in Saukville's permit is determined by calculating 99th upper percentile (or P₉₉) values for ammonia and comparing those to the calculated limits. Based on this comparison, there is no reasonable potential for the discharge to exceed any of the calculated ammonia nitrogen limits. However, since the permit currently has weekly and monthly average limits year-round, **the limits must be retained regardless of reasonable potential**, consistent with s. NR 106.33(1)(b), Wis. Adm. Code:

- (b) If a permittee is subject to an ammonia limitation in an existing permit, the limitation shall be included in any reissued permit. Ammonia limitations shall be included in the permit if the permitted facility will be providing treatment for ammonia discharges.

Conclusions and Recommendations

In summary, after rounding to two significant figures, the following ammonia nitrogen limitations are recommended. No mass limitations are recommended in accordance with s. NR 106.32(5), Wis. Adm. Code. Limits to meet the requirements in s. NR 106.07, Wis. Adm. Code, are denoted in bold text.

Final Ammonia Nitrogen Limits

	Daily Maximum mg/L	Weekly Average mg/L	Monthly Average mg/L
April – September	9.6	9.6	9.6
October – March	9.6	9.6	6.5

PART 5 – PHOSPHORUS**Technology-Based Effluent Limit**

Subchapter II of Chapter NR 217, Wis. Adm. Code, requires municipal wastewater treatment facilities

that discharge greater than 150 pounds of total phosphorus per month to comply with a monthly average limit of 1.0 mg/L, or an approved alternative concentration limit.

Because Saukville currently has a limit of 1.0 mg/L, this limit should be included in the reissued permit.

Milwaukee River TMDL

The Milwaukee River Basin TMDL report addresses phosphorus water quality impairments within the basin and provides waste load allocations (WLAs) required to meet water quality standards. Effluent limitations based on these WLAs must be included in WPDES permits according to s. NR 217.16, Wis. Adm. Code.

The monthly average total phosphorus (TP) effluent limits in lbs/day are calculated based on the maximum monthly phosphorus WLA given in pounds per month as suggested in the TMDL report and implementation guidance. The monthly maximum TP WLAs for this facility are found in Appendix A of the Milwaukee River Basin TMDL report. **The monthly average limits shown in the table below are recommended in place of the s. NR 217.13, Wis. Adm. Code, limit, and should be expressed in pounds per day.**

Total Phosphorus Wasteload Allocations and Effluent Limits

Month	Monthly Maximum TP WLA¹ (lbs/month)	Days Per Month	Monthly Average TP Effluent Limit² (lbs/day)
Jan	87.64	31	2.83
Feb	87.07	28	3.11
Mar	74.46	31	2.40
Apr	82.77	30	2.76
May	72.74	31	2.35
Jun	91.13	30	3.04
Jul	79.07	31	2.55
Aug	77.54	31	2.50
Sep	75.80	30	2.53
Oct	63.59	31	2.05
Nov	84.66	30	2.82
Dec	78.21	31	2.52

Footnotes:

1- Milwaukee River Basin TMDL Appendix A. Monthly Total Suspended Solids Wasteload Allocation by Permitted Point Source. Table A.17 for the Milwaukee River Watershed

2- Monthly Average Total P effluent limit (lbs/day) = monthly Total P WLA (lbs/month) ÷ days per month

These limits are already effective and no changes are recommended in the reissued permit.

Effluent Data

The following table summarizes effluent total phosphorus monitoring data from 01/05/2020 – 06/25/2024 for the concentration and 07/01/2024 – 02/25/2025 for the mass loading.

Total Phosphorus Effluent Data

	Concentration mg/L	Mass lbs/day
1-day P ₉₉	0.74	2.95
4-day P ₉₉	0.52	2.32
30-day P ₉₉	0.41	1.97
Mean	0.35	1.79
Std	0.13	0.41
Sample size	674	104
Range	0.148 - 0.734	1.05 - 2.95

PART 6 – TOTAL SUSPENDED SOLIDS

The Milwaukee River Basin TMDL also has wasteload allocations (WLAs) for total suspended solids (TSS). For a municipal facility, the limits for TSS must be expressed as weekly and monthly averages. The current permit includes a monthly average limit of 12 mg/L year-round and weekly average limits of 45 mg/L and 222.24 lbs/day for November and 12 mg/L for December – October.

The monthly TMDL WLAs according to the TMDL report is shown in the table below.

Total Suspended Solids Wasteload Allocations

Month	Monthly TSS WLA¹ (lbs/month)
Jan	3,494.38
Feb	2,433.93
Mar	2,377.64
Apr	2,495.66
May	2,872.92
Jun	3,508.78
Jul	2,922.71
Aug	2,479.73
Sep	3,209.79
Oct	3,332.90
Nov	5,128.58
Dec	3,593.46

Footnotes:

1- Milwaukee River Basin TMDL Appendix A. Monthly Total Suspended Solids Wasteload Allocation by Permitted Point Source. Table A.19 for the Milwaukee River Watershed

Consistent with Section 6.4.1 of the Milwaukee River TMDL Report, in cases where the equivalent TSS concentration limit is ≤ 12 mg/L, the effluent limit will be expressed as a concentration of 12 mg/L monthly average. November has an equivalent weekly average TSS concentration limit greater than 12 mg/L, so the weekly mass TMDL limit for November is continued along with the current weekly concentration limit of 45 mg/L. The 45 mg/L limit must be retained to meet antibacksliding requirements in ch. NR 207, Wis. Adm. Code.

The currently effective TMDL-based limits are shown below and no changes are recommended.

Total Suspended Solids Limits

Month	Weekly Average TSS Effluent Limit (mg/L)	Weekly Average TSS Effluent Limit (lbs/day)	Monthly Average TSS Effluent Limit (mg/L)
Jan	12	-	12
Feb	12	-	12
Mar	12	-	12
Apr	12	-	12
May	12	-	12
Jun	12	-	12
Jul	12	-	12
Aug	12	-	12
Sep	12	-	12
Oct	12	-	12
Nov	45	222.24	12
Dec	12	-	12

**PART 7 – WATER QUALITY-BASED EFFLUENT LIMITATIONS
FOR THERMAL**

Surface water quality standards for temperature took effect on October 1, 2010. These regulations are detailed in chs. NR 102 (Subchapter II – Water Quality Standards for Temperature) and NR 106 (Subchapter V – Effluent Limitations for Temperature) of the Wisconsin Administrative Code. Daily maximum and weekly average temperature criteria are available for the 12 different months of the year depending on the receiving water classification.

In accordance with s. NR 106.53(2)(b), Wis. Adm. Code, the highest daily maximum flow rate for a calendar month is used to determine the acute (daily maximum) effluent limitation. In accordance with s. NR 106.53(2)(c), Wis. Adm. Code, the highest 7-day rolling average flow rate for a calendar month is used to determine the sub-lethal (weekly average) effluent limitation. These values were based off actual flow reported from 01/01/2020 – 02/28/2025.

The table below summarizes the maximum temperatures reported during monitoring from 01/01/2019 – 12/31/2019.

Monthly Temperature Effluent Data & Limits

Month	Representative Highest Monthly Effluent Temperature		Calculated Effluent Limit	
	Weekly Maximum	Daily Maximum	Weekly Average Effluent Limitation	Daily Maximum Effluent Limitation
	(°F)	(°F)	(°F)	(°F)
JAN	52	52	93	120
FEB	52	52	91	120
MAR	50	51	82	120
APR	53	53	67	119
MAY	55	56	75	110
JUN	62	63	96	115
JUL	65	67	111	120
AUG	67	67	NA	120
SEP	66	66	116	120
OCT	62	65	101	120
NOV	58	58	80	120
DEC	53	53	98	120

Reasonable Potential

Permit limits for temperature are recommended based on the procedures in s. NR 106.56, Wis. Adm. Code.

- An acute limit for temperature is recommended for each month in which the representative daily maximum effluent temperature for that month exceeds the acute WQBEL. The representative daily maximum effluent temperature is the greater of the following:
 - (a) The highest recorded representative daily maximum effluent temperature
 - (b) The projected 99th percentile of all representative daily maximum effluent temperatures
- A sub-lethal limitation for temperature is recommended for each month in which the representative weekly average effluent temperature for that month exceeds the weekly average WQBEL. The representative weekly average effluent temperature is the greater of the following:
 - (a) The highest weekly average effluent temperature for the month.
 - (b) The projected 99th percentile of all representative weekly average effluent temperatures for the month

Based on the available effluent data, **no effluent limits or monitoring are recommended for temperature.** The complete thermal table used for the limit calculation is shown in Attachment #4.

PART 8 – WHOLE EFFLUENT TOXICITY (WET)

WET testing is used to measure, predict, and control the discharge of toxic materials that may be harmful to aquatic life. In WET tests, organisms are exposed to a series of effluent concentrations for a given time and effects are recorded. Decisions below related to the selection of representative data and the need for WET limits were made according to ss. NR 106.08 and 106.09, Wis. Adm. Code. WET monitoring frequency

Attachment #1

and toxicity reduction evaluation (TRE) recommendations were made using the best professional judgment of staff familiar with the discharge after consideration of the guidance in the *Whole Effluent Toxicity (WET) Program Guidance Document* (2022).

- Acute tests predict the concentration that causes lethality of aquatic organisms during a 48 to 96-hour exposure. To assure that a discharge is not acutely toxic to organisms in the receiving water, WET tests must produce a statistically valid LC₅₀ (Lethal Concentration to 50% of the test organisms) greater than 100% effluent, according to s. NR 106.09(2)(b), Wis. Adm Code.
- Chronic tests predict the concentration that interferes with the growth or reproduction of test organisms during a seven-day exposure. To assure that a discharge is not chronically toxic to organisms in the receiving water, WET tests must produce a statistically valid IC₂₅ (Inhibition Concentration) greater than the instream waste concentration (IWC), according to s. NR 106.09(3)(b), Wis. Adm Code. The IWC is an estimate of the proportion of effluent to total volume of water (receiving water + effluent). The **IWC of 29%** shown in the WET Checklist summary below, was calculated according to the following equation, as specified in s. NR 106.03(6), Wis. Adm Code:

$$\text{IWC (as \%)} = Q_e \div \{(1 - f) Q_e + Q_s\} \times 100$$

Where:

Q_e = annual average flow = 1.61 MGD = 2.491 cfs

f = fraction of the Q_e withdrawn from the receiving water = 0

Q_s = ¼ of the 7-Q₁₀ = 24 cfs ÷ 4 = 6 cfs

- According to the *State of Wisconsin Aquatic Life Toxicity Testing Methods Manual* (s. NR 219.04, Table A, Wis. Adm. Code), a synthetic (standard) laboratory water may be used as the dilution water and primary control in acute WET tests, unless the use of different dilution water is approved by the Department prior to use. The primary control water must be specified in the WPDES permit.
- According to the *State of Wisconsin Aquatic Life Toxicity Testing Methods Manual* (s. NR 219.04, Table A, Wis. Adm. Code), receiving water must be used as the dilution water and primary control in chronic WET tests, unless the use of different dilution water is approved by the Department prior to use. The dilution water used in WET tests conducted on Outfall 001 shall be a grab sample collected from the receiving water location, upstream and out of the influence of the mixing zone and any other known discharge. The specific receiving water location must be specified in the WPDES permit.
- Shown below is a tabulation of all available WET data for Outfall 001. Efforts are made to ensure that decisions about WET monitoring and limits are made based on representative data, as specified in s. NR 106.08(3), Wis. Adm Code. Data which is not believed to be representative of the discharge was not included in reasonable potential calculations. The table below differentiates between tests used and not used when making WET determinations. Significant changes were made to WET test methods in 2004 and these changes were assumed to be fully implemented by certified labs by no later than June 2005. Data collected before July 1, 2005 is excluded in this evaluation.

WET Data History

Date Test Initiated	Acute Results LC ₅₀ %				Chronic Results IC ₂₅ %				Footnotes or Comments
	<i>C. dubia</i>	Fathead minnow	Pass or Fail?	Used in RP?	<i>C. dubia</i>	Fathead Minnow	Pass or Fail?	Use in RP?	
08/22/2006	>100	>100	Pass	Yes	44.07	34.15	Pass	Yes	
10/25/2007	>100	>100	Pass	Yes	>100	>100	Pass	Yes	
08/12/2008	>100	>100	Pass	No	>100	>100		No	1

Attachment #1

Date Test Initiated	Acute Results LC ₅₀ %				Chronic Results IC ₂₅ %				Footnotes or Comments
	<i>C. dubia</i>	Fathead minnow	Pass or Fail?	Used in RP?	<i>C. dubia</i>	Fathead Minnow	Pass or Fail?	Use in RP?	
11/10/2009	>100	>100	Pass	No	>100	>100		No	1
08/10/2010	>100	>100	Pass	No	>100	>100		No	1
05/12/2011	>100	>100	Pass	No	>100	>100	Pass	No	2
10/22/2013	>100	>100	Pass	Yes					
11/05/2013					72	>100	Pass	Yes	
10/20/2015	>100	>100	Pass	Yes	>100	>100	Pass	Yes	
08/09/2016	>100	>100	Pass	Yes	74.1	>100	Pass	Yes	
04/18/2017	>100	>100	Pass	Yes	61.2	>100	Pass	Yes	
03/06/2018	>100	>100	Pass	Yes	75.9	>100	Pass	Yes	
11/05/2019	>100	>100	Pass	Yes	82.3	>100	Pass	Yes	
12/01/2020	>100	>100	Pass	Yes	55.2	>100	Pass	No	2
05/04/2021	>100	>100	Pass	Yes	47.3	>100	Pass	Yes	
09/20/2022	>100	>100	Pass	Yes	>100	>100	Pass	Yes	
03/07/2023	>100	>100	Pass	Yes	54.2	>100	Pass	Yes	
12/10/2024	>100	>100	Pass	Yes	46.1	>100	Pass	Yes	

Footnotes:

1. *Tests done by S-F Analytical, July 2008 – March 2011.* The DNR has reason to believe that WET tests completed by SF Analytical Labs from July 2008 through March 31, 2011 were not performed using proper test methods. Therefore, WET data from this lab during this period has been disqualified and was not included in the analysis.
 2. *Qualified or Inconclusive Data.* Data quality concerns were noted during testing which calls into question the reliability of the test results.
- According to s. NR 106.08, Wis. Adm. Code, WET reasonable potential is determined by multiplying the highest toxicity value that has been measured in the effluent by a safety factor, to predict the likelihood (95% probability) of toxicity occurring in the effluent above the applicable WET limit. The safety factor used in the equation changes based on the number of toxicity detects in the dataset. The fewer detects present, the higher the safety factor, because there is more uncertainty surrounding the predicted value. **WET limits must be given, according to s. NR 106.08(6), Wis. Adm. Code, whenever the applicable Reasonable Potential equation results in a value greater than 1.0.**

$$\text{Acute Reasonable Potential} = [(TU_a \text{ effluent}) (B)(AMZ)]$$

$$\text{Chronic Reasonable Potential} = [(TU_c \text{ effluent}) (B)(IWC)]$$

According to s. NR 106.08(6)(d), Wis. Adm. Code, TU_a and TU_c effluent values are equal to zero whenever toxicity is not detected (i.e. when the LC₅₀, IC₂₅ or IC₅₀ ≥ 100%).

Acute Reasonable Potential = 0 < 1.0, reasonable potential is not shown, and a limit is not required.

$$\text{Chronic Reasonable Potential} = [(TU_c \text{ effluent}) (B)(IWC)]$$

Chronic WET Limit Parameters

TU_c (maximum) 100/IC ₂₅	B (multiplication factor from s. NR 106.08(6)(c), Wis. Adm. Code, Table 4)	IWC
100/34.15 = 2.9	1.8 Based on 9 detects	29%

$$[(TU_c \text{ effluent}) (B)(IWC)] = 1.53 > 1.0$$

Therefore, reasonable potential is shown for chronic WET limits using the procedures in s. NR 106.08(6), Wis. Adm. Code, and representative data from 08/22/2006 – 12/10/2024.

Expression of WET limits

Chronic WET limit = $[100/IWC]$ TU_c = 3.4 TU_c expressed as a monthly average

This is equivalent to the current chronic WET limit.

The WET checklist was developed to help DNR staff make recommendations regarding WET limits, monitoring, and other related permit conditions. The checklist indicates whether acute and chronic WET limits are needed, based on requirements specified in s. NR 106.08, Wis. Adm. Code. The checklist steps the user through a series of questions, assesses points based on the potential for effluent toxicity, and suggests monitoring frequencies based on points accumulated during the checklist analysis. As toxicity potential increases, more points accumulate, and more monitoring is recommended to ensure that toxicity is not occurring. A summary of the WET checklist analysis completed for this permittee is shown in the table below. Staff recommendations based on best professional judgment are provided below the summary table. For guidance related to reasonable potential and the WET checklist, see Chapter 1.3 of the WET Guidance Document: <https://dnr.wisconsin.gov/topic/Wastewater/WET.html>.

WET Checklist Summary


	Acute	Chronic
AMZ/IWC	Not Applicable. 0 Points	IWC = 29%. 0 Points
Historical Data	13 tests used to calculate RP. No tests failed. 0 Points	12 tests used to calculate RP. No tests failed. 0 Points
Effluent Variability	Little variability, no violations or upsets, consistent WWTF operations. 0 Points	Same as Acute. 0 Points
Receiving Water Classification	WWSF 5 Points	Same as Acute. 5 Points
Chemical-Specific Data	No reasonable potential for limits based on ATC; Ammonia nitrogen limit carried over from the current permit. detected. Additional Compounds of Concern: None. 3 Points	No reasonable potential for limits based on CTC; Ammonia nitrogen limit carried over from the current permit. detected. Additional Compounds of Concern: None. 3 Points

Attachment #1

	Acute	Chronic
Additives	1 Water Quality Conditioner added. Permittee has proper P chemical SOPs in place. 1 Point	Additive is used more than once per 4 days. 1 Point
Discharge Category	2 Industrial Contributors. 6 Points	Same as Acute. 6 Points
Wastewater Treatment	Secondary or Better. 0 Points	Same as Acute. 0 Points
Downstream Impacts	No impacts known 0 Points	Same as Acute. 0 Points
Total Checklist Points:	15 Points	15 Points
Recommended Monitoring Frequency (from Checklist):	1x yearly	1x yearly
Limit Required?	No	Yes Limit = 3.4 TU _c
TRE Recommended? (from Checklist)	No	No

- After consideration of the guidance provided in the Department's *WET Program Guidance Document* (2022) and other information described above, 1x annual acute and chronic WET tests are recommended in the reissued permit. Sampling WET concurrently with any chemical-specific toxic substances is recommended. Tests should be done in rotating quarters, to collect seasonal information about this discharge. Testing should continue after the permit expiration date (until the permit is reissued).
- According to the requirements specified in s. NR 106.08, Wis. Adm. Code, a chronic WET limit is required. The chronic WET limit shall be expressed as 3.4 TU_c as a monthly average in the effluent limits table of the permit.
- A minimum of annual chronic monitoring is required because a chronic WET limit is required. Federal regulations in 40 CFR Part 122.44(i) require that monitoring occur at least once per year when a limit is present.
- A minimum of annual acute and chronic monitoring is recommended because Saukville is a major municipal discharger with a design flow greater than 1.0 MGD. Federal regulations at 40 CFR Part 122.21(j) require at least 4 acute and chronic WET tests with each permit application on samples collected since the previous reissuance. Therefore, annual monitoring is recommended in the permit term, so that data will be available for the next permit application.

Saukville WWTF Discharge Location



Attachment #3
2020 Ammonia Calculations

Weekly Average & Monthly Average Limits based on Chronic Toxicity Criteria (CTC)

Weekly and monthly average limits based on chronic toxicity criteria for ammonia are also calculated to determine the weekly and monthly average limits to meet the requirements of s. NR 106.07(3), Wis. Adm. Code.

Weekly average and monthly average limits for ammonia nitrogen are based on chronic toxicity criteria in ch. NR 105, Wis. Adm. Code.

The 30-day chronic toxicity criterion (CTC) for ammonia in waters classified as a Warm Water Sport Fish Community is calculated by the following equation, according to subchapter IV of NR 106, Wis. Adm. Code.

$$CTC = E \times \{ [0.0676 \div (1 + 10^{(7.688 - pH)})] + [2.912 \div (1 + 10^{(pH - 7.688)})] \} \times C$$

Where:

pH = the pH (s.u.) of the receiving water,

E = 0.854,

C = the minimum of 2.85 or $1.45 \times 10^{(0.028 \times (25 - T))}$ – (Early Life Stages Present), or

C = $1.45 \times 10^{(0.028 \times (25 - T))}$ – (Early Life Stages Absent), and

T = the temperature (°C) of the receiving water – (Early Life Stages Present), or

T = the maximum of the actual temperature (°C) and 7 – (Early Life Stages Absent)

The 4-day criterion is equal to the 30-day criterion multiplied by 2.5. The 4-day criteria are used in a mass-balance equation with the 7-Q₁₀ (4-Q₃, if available) to derive weekly average limitations. And the 30-day criteria are used with the 30-Q₅ (estimated as 85% of the 7-Q₂ if the 30-Q₅ is not available) to derive monthly average limitations. The stream flow value is further adjusted to temperature; 100% of the flow is used if the Temperature ≥ 16 °C, 25% of the flow is used if the Temperature < 11 °C, and 50% of the flow is used if the Temperature ≥ 11 °C but < 16 °C.

Section NR 106.32 (3), Wis. Adm. Code, provides a mechanism for less stringent weekly average and monthly average effluent limitations when early life stages (ELS) of critical organisms are absent from the receiving water. This applies only when the water temperature is less than 14.5 °C, during the winter and spring months. Burbot, an early spawning species, are not believed to be present in the Milwaukee River, based on conversations with local fisheries biologists. So “ELS Absent” criteria apply from October through March, and “ELS Present” criteria will apply from April through September for a warm water sport fish classification.

Since minimal ambient data is available, the “default” basin assumed values are used for Temperature, pH and background ammonia concentrations, shown in the table below, with the resulting criteria and effluent limitations.

		Spring	Summer	Winter
		April & May	June – Sept.	Oct. - March
Effluent Flow	Q _e (MGD)	1.61	1.61	1.61
Background Information	7-Q (cfs)	24	24	24
	7-Q (cfs)	52	52	52
	Ammonia (mg/L)	0.04	0.03	0.08

Attachment #3

		Spring	Summer	Winter
		April & May	June – Sept.	Oct. - March
	Average Temperature (°C)	12	19	4
	Max Temperature (°C)	12	19	4
	pH (s.u.)	8.31	8.22	8.58
	% of Flow used	25	25	25
	Reference Weekly Flow (cfs)	12	24	6
	Reference Monthly Flow (cfs)	22	44	11
Criteria mg/L	4-day Chronic			
	Early Life Stages Present	3.75	2.93	
	Early Life Stages Absent			3.16
	30-day Chronic			
	Early Life Stages Present	1.50	1.17	
	Early Life Stages Absent			1.26
Effluent Limitations mg/L	Weekly Average			
	Early Life Stages Present	21.6	30.9	
	Early Life Stages Absent			10.6
	Monthly Average			
	Early Life Stages Present	14.4	21.4	
	Early Life Stages Absent			6.51

Effluent Data

The following table evaluates the statistics based upon ammonia data reported from 07/01/2015 to 11/30/2019, with those results being compared to the calculated limits to determine the need to include ammonia limits in the Saukville permit for the respective month ranges. That need is determined by calculating 99th upper percentile (or P₉₉) values for ammonia during each of the month ranges and comparing the daily maximum values to the daily maximum limit. Based on this comparison, no limits are required.

Ammonia Nitrogen mg/L	April - May	June - September	October - March
1-day P ₉₉	0.1	0.3	0.1
4-day P ₉₉	0.1	0.1	0.1
30-day P ₉₉	0.03	0.07	0.04
Mean*	0.02	0.04	0.02
Std	0.02	0.05	0.03
Sample size	71	168	224
Range	<0.025 – 0.1	<0.025 – 0.367	<0.025 – 0.41

*Values lower than the level of detection were substituted with a zero

Where there are existing ammonia nitrogen limits in the permit, the limits must be retained regardless of reasonable potential, consistent with s. NR 106.33(1)(b), Wis. Adm. Code:

- (b) If a permittee is subject to an ammonia limitation in an existing permit, the limitation shall be included in any reissued permit. Ammonia limitations shall be included in the permit if the permitted facility will be providing treatment for ammonia discharges.

Temperature limits for receiving waters with unidirectional flow

(calculation using default ambient temperature data)

Facility:	Saukville Village Sewer Utility		7-Q₁₀:	24 cfs	Temp Dates	01/01/19	01/01/20
Outfall(s):	001		Dilution:	25%	Start:	01/01/19	01/01/20
Date Prepared:	3/12/2025		f:	0	End:	12/31/19	02/28/25
Design Flow (Qe):	1.61	MGD	Stream type:	Small warm water sport or forage fish co			
Storm Sewer Dist.	0	ft	Qs:Qe ratio:	2.4 :1			
			Calculation Needed?	YES			

Month	Water Quality Criteria			Receiving Water Flow Rate (Qs)	Representative Highest Effluent Flow Rate (Qe)		f	Representative Highest Effluent Temperature		Calculated Effluent Limit	
	Ta (default)	Sub-Lethal WQC	Acute WQC	7-day Rolling Average (Qesl)	Daily Maximum Flow Rate (Qea)	Weekly Average		Daily Maximum	Weekly Average Effluent Limitation	Daily Maximum Effluent Limitation	
											(°F)
JAN	33	49	76	24.00	1.411	1.680	0	52	52	93	120
FEB	34	50	76	24.00	1.527	2.229	0	52	52	91	120
MAR	38	52	77	24.00	1.785	2.635	0	50	51	82	120
APR	48	55	79	24.00	2.357	3.031	0	53	53	67	119
MAY	58	65	82	24.00	2.623	3.351	0	55	56	75	110
JUN	66	76	84	24.00	1.960	2.268	0	62	63	96	115
JUL	69	81	85	24.00	1.472	1.756	0	65	67	113	120
AUG	67	81	84	24.00	1.175	1.303	0	67	67	NA	120
SEP	60	73	82	24.00	1.163	1.238	0	66	66	116	120
OCT	50	61	80	24.00	1.079	1.140	0	62	65	101	120
NOV	40	49	77	24.00	1.127	1.869	0	58	58	80	120
DEC	35	49	76	24.00	1.114	1.225	0	53	53	98	120