



WPDES PERMIT

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
**PERMIT TO DISCHARGE UNDER THE WISCONSIN POLLUTANT DISCHARGE
ELIMINATION SYSTEM**

Wisconsin Power and Light Company

is permitted, under the authority of Chapter 283, Wisconsin Statutes, to discharge from a facility
located at
1401 W B-R Townline Rd, Beloit, WI 53511
to
**the Rock River (Bass Creek Watershed in the Lower Rock Basin)
in Rock County**

in accordance with the effluent limitations, monitoring requirements and other conditions set
forth in this permit.

The permittee shall not discharge after the date of expiration. If the permittee wishes to continue to discharge after this expiration date an application shall be filed for reissuance of this permit, according to Chapter NR 200, Wis. Adm. Code, at least 180 days prior to the expiration date given below.

State of Wisconsin Department of Natural Resources
For the Secretary

By _____
Jason Knutson
Wastewater Section Chief

Date Permit Signed/Issued

PERMIT TERM: EFFECTIVE DATE - October 01, 2024

EXPIRATION DATE - September 30, 2028

TABLE OF CONTENTS

1 INFLUENT REQUIREMENTS	1
1.1 SAMPLING POINT(S)	1
1.2 MONITORING REQUIREMENTS	1
1.2.1 <i>Sampling Point 701 - Intake Water</i>	1
2 IN-PLANT REQUIREMENTS	2
2.1 SAMPLING POINT(S)	2
2.2 MONITORING REQUIREMENTS AND LIMITATIONS	2
2.2.1 <i>Sampling Point 199 - Field Blank for Mercury Sample</i>	2
2.2.2 <i>Sampling Point 101 – Riverside Low Volume Wastewater (LVW)</i>	3
2.2.3 <i>Sampling Point 102 – Riverside Cooling Tower Blowdown & LVW</i>	4
2.2.4 <i>Sampling Point 103 - Riverside LVW and Cooling Tower Blowdown</i>	5
2.2.5 <i>Sampling Point 111 - West Riverside: LVW</i>	5
2.2.6 <i>Sampling Point 112 - West Riverside: Cooling Tower</i>	6
2.2.7 <i>Sampling Point 113 - West Riverside: Post Treatment</i>	6
3 SURFACE WATER REQUIREMENTS	8
3.1 SAMPLING POINT(S)	8
3.2 MONITORING REQUIREMENTS AND EFFLUENT LIMITATIONS	8
3.2.1 <i>Sampling Point (Outfall) 001 - Combined WW to the Rock River</i>	8
4 SCHEDULES	14
4.1 ANNUAL WATER QUALITY TRADING (WQT) REPORT	14
4.2 ELG REQUIREMENTS FOR COOLING TOWER BLOWDOWN	14
5 STANDARD REQUIREMENTS	16
5.1 REPORTING AND MONITORING REQUIREMENTS	16
5.1.1 <i>Monitoring Results</i>	16
5.1.2 <i>Sampling and Testing Procedures</i>	16
5.1.3 <i>Recording of Results</i>	16
5.1.4 <i>Reporting of Monitoring Results</i>	17
5.1.5 <i>Records Retention</i>	17
5.1.6 <i>Other Information</i>	17
5.1.7 <i>Reporting Requirements – Alterations or Additions</i>	17
5.2 SYSTEM OPERATING REQUIREMENTS	17
5.2.1 <i>Noncompliance Reporting</i>	18
5.2.2 <i>Bypass</i>	18
5.2.3 <i>Scheduled Bypass</i>	18
5.2.4 <i>Controlled Diversions</i>	19
5.2.5 <i>Proper Operation and Maintenance</i>	19
5.2.6 <i>Operator Certification</i>	19
5.2.7 <i>Spill Reporting</i>	19
5.2.8 <i>Planned Changes</i>	19
5.2.9 <i>Duty to Halt or Reduce Activity</i>	20
5.3 SURFACE WATER REQUIREMENTS	20
5.3.1 <i>Permittee-Determined Limit of Quantitation Incorporated into this Permit</i>	20
5.3.2 <i>Appropriate Formulas for Effluent Calculations</i>	20
5.3.3 <i>Effluent Temperature Requirements</i>	20
5.3.4 <i>Energy Emergency Events</i>	21
5.3.5 <i>Visible Foam or Floating Solids</i>	21
5.3.6 <i>Surface Water Uses and Criteria</i>	21
5.3.7 <i>Total Residual Chlorine Requirements</i>	21
5.3.8 <i>Compliance with Phosphorus Limitation</i>	22

<i>5.3.9 Additives</i>	23
<i>5.3.10 Whole Effluent Toxicity (WET) Monitoring Requirements</i>	23
<i>5.3.11 Whole Effluent Toxicity (WET) Identification and Reduction</i>	23
6 SUMMARY OF REPORTS DUE	25

1 Influent Requirements

1.1 Sampling Point(s)

Sampling Point Designation	
Sampling Point Number	Sampling Point Location, Waste Type/Sample Contents and Treatment Description (as applicable)
701	INTAKE: Combination of groundwater from a radial horizontal collector well and water from the Rock River. Four flow meters are used: three for the West Riverside plant and one at the Riverside plant. There is no surface water intake. Any river water in the well is from the surrounding soil.

1.2 Monitoring Requirements

The permittee shall comply with the following monitoring requirements.

1.2.1 Sampling Point 701 - Intake Water

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Daily	Continuous	
Mercury, Total Recoverable		ng/L	Quarterly	Grab	

1.2.1.1 Mercury Monitoring

The permittee shall collect and analyze all mercury samples according to the data quality requirements of ss. NR 106.145(9) and (10), Wisconsin Administrative Code. The limit of quantitation (LOQ) used for the effluent and field blank shall be less than 1.3 ng/L, unless the samples are quantified at levels above 1.3 ng/L. The permittee shall collect at least one mercury field blank for each set of mercury samples (a set of samples may include combinations of intake, influent, effluent or other samples all collected on the same day). The permittee shall report results of samples and field blanks to the Department on Discharge Monitoring Reports.

2 In-Plant Requirements

2.1 Sampling Point(s)

Sampling Point Designation	
Sampling Point Number	Sampling Point Location, Waste Type/Sample Contents and Treatment Description (as applicable)
199	FIELD BLANK: Collect total recoverable mercury field blanks using standard sample handling procedures.
101	IN-PLANT: Riverside Low Volume Wastewater (LVW) consisting of Multimedia Filter backwash and RO concentrate. 24-hr flow proportional composite and grab samples shall be taken within the building housing the filters and RO system prior to discharge to the wastewater sump pit or discharged for reuse in the cooling tower.
102	IN-PLANT: Riverside Wastewater consisting of cooling tower blowdown, raw water, condenser effluent, aux cooling effluent, and various flows from sump pumps around the plant. Low Volume Wastewater (LVW) from in-plant sampling point 101 is also reused within the cooling tower. 24-hr flow proportional composite samples shall be taken from within the chemical building prior to discharge to the wastewater sump pit.
103	IN-PLANT: Wastewater consisting of cooling tower blowdown and low-volume wastewater from Riverside after it has mixed. Combined discharge of in-plant sampling points 101 (LVW) and 102 (blowdown) after it has mixed. 24-hr flow proportional and grab samples shall be taken from the pipe downstream of the mixing of the two Riverside streams prior to discharging out of Outfall 001
111	IN-PLANT: Wastewater consisting of low volume wastewater (LVW) from West Riverside sampled prior to commingling with in-plant sample point 112 and going through the treatment system.
112	IN-PLANT: Wastewater consisting of cooling tower blowdown from West Riverside sampled prior to commingling with in-plant sample point 111 and going through the treatment system.
113	IN-PLANT: Wastewater consisting of cooling tower blowdown and low-volume wastewater from West Riverside after it has mixed and gone through the treatment system. Combined discharge of in-plant sampling points 111 (LVW) and 112 (blowdown) after going through treatment system. 24-hr flow proportional and grab samples shall be taken from the pipe downstream of the treatment processes prior to mixing with wastewater from the "Riverside Facility."

2.2 Monitoring Requirements and Limitations

The permittee shall comply with the following monitoring requirements and limitations.

2.2.1 Sampling Point 199 - Field Blank for Mercury Sample

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Mercury, Total Recoverable		ng/L	Quarterly	Grab	

2.2.1.1 Mercury Monitoring

The permittee shall collect and analyze all mercury samples according to the data quality requirements of ss. NR 106.145(9) and (10), Wisconsin Administrative Code. The limit of quantitation (LOQ) used for the effluent and field blank shall be less than 1.3 ng/L, unless the samples are quantified at levels above 1.3 ng/L. The permittee shall

collect at least one mercury field blank for each set of mercury samples (a set of samples may include combinations of intake, influent, effluent or other samples all collected on the same day). The permittee shall report results of samples and field blanks to the Department on Discharge Monitoring Reports.

2.2.2 Sampling Point 101 – Riverside Low Volume Wastewater (LVW)

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Daily	Continuous	
Suspended Solids, Total	Daily Max	100 mg/L	Weekly	24-Hr Flow Prop Comp	
Suspended Solids, Total	Monthly Avg	30 mg/L	Weekly	24-Hr Flow Prop Comp	
Oil & Grease (Hexane)	Daily Max	20 mg/L	Weekly	Grab	
Oil & Grease (Hexane)	Monthly Avg	15 mg/L	Weekly	Grab	
pH (Maximum)	Daily Max	11.0 su	Continuous	Continuous	pH monitoring and limits do not apply if LVW is reused in the cooling tower.
pH (Minimum)	Daily Min	4.0 su	Continuous	Continuous	pH monitoring and limits do not apply if LVW is reused in the cooling tower.
pH Total Exceedance Time Minutes	Monthly Total	446 minutes	Monthly	Calculated	pH monitoring and limits do not apply if LVW is reused in the cooling tower.
pH Exceedances Greater Than 60 Minutes	Daily Max	0 Number	Daily	Calculated	pH monitoring and limits do not apply if LVW is reused in the cooling tower.

2.2.2.1 Continuous pH Monitoring

The permittee shall maintain the pH of the discharge within the range of 6.0 to 9.0 standard units (s.u.) except excursions are permitted subject to the following conditions:

- The pH is monitored continuously;
- The total time during which the pH is outside the range of 6.0 to 9.0 s.u. shall not exceed 446 minutes in any calendar month;
- No individual pH excursion outside the range of 6.0 to 9.0 s.u. shall exceed 60 minutes in duration;
- No individual pH excursion shall be outside the range of 4.0 to 11.0 s.u.; and
- On a daily basis, the permittee shall report the minimum and maximum pH, the total time that the pH is outside the range of 6.0 to 9.0 s.u. and the number of pH excursions outside the range of 6.0 to 9.0 that exceed 60 minutes in duration.

2.2.3 Sampling Point 102 – Riverside Cooling Tower Blowdown & LVW

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Daily	Continuous	
Zinc, Total Recoverable	Daily Max	1.0 mg/L	Quarterly	24-Hr Flow Prop Comp	
Zinc, Total Recoverable	Monthly Avg	1.0 mg/L	Quarterly	24-Hr Flow Prop Comp	
Chromium, Total Recoverable	Daily Max	0.2 mg/L	Quarterly	24-Hr Flow Prop Comp	
Chromium, Total Recoverable	Monthly Avg	0.2 mg/L	Quarterly	24-Hr Flow Prop Comp	
pH (Maximum)	Daily Max	11.0 su	Continuous	Continuous	
pH (Minimum)	Daily Min	4.0 su	Continuous	Continuous	
pH Total Exceedance Time Minutes	Monthly Total	446 minutes	Monthly	Calculated	
pH Exceedances Greater Than 60 Minutes	Daily Max	0 Number	Daily	Calculated	

2.2.3.1 Metals Analyses

Unless specified otherwise in the table above, metals analyses shall measure metals as total recoverable. Measurements of total metals and total recoverable metals shall be considered as equivalent.

2.2.3.2 Continuous pH Monitoring

The permittee shall maintain the pH of the discharge within the range of 6.0 to 9.0 standard units (s.u.) except excursions are permitted subject to the following conditions:

- The pH is monitored continuously;
- The total time during which the pH is outside the range of 6.0 to 9.0 s.u. shall not exceed 446 minutes in any calendar month;
- No individual pH excursion outside the range of 6.0 to 9.0 s.u. shall exceed 60 minutes in duration;
- No individual pH excursion shall be outside the range of 4.0 to 11.0 s.u.; and
- On a daily basis, the permittee shall report the minimum and maximum pH, the total time that the pH is outside the range of 6.0 to 9.0 s.u. and the number of pH excursions outside the range of 6.0 to 9.0 that exceed 60 minutes in duration.

2.2.3.3 Cooling Tower Maintenance Chemicals

Discharge of cooling tower blowdown shall be limited to no detectable amount of the 126 priority pollutants contained in chemicals added for cooling tower maintenance.

2.2.4 Sampling Point 103 - Riverside LVW and Cooling Tower Blowdown

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Daily	Continuous	
Suspended Solids, Total		mg/L	Weekly	24-Hr Flow Prop Comp	
Chlorine, Total Residual		µg/L	Daily	Grab	
Zinc, Total Recoverable		µg/L	Quarterly	24-Hr Flow Prop Comp	
Mercury, Total Recoverable		ng/L	Quarterly	Grab	
Phosphorus, Total		mg/L	Weekly	24-Hr Flow Prop Comp	

2.2.4.1 Sampling and Reporting

Sampling and reporting of all parameters, except for Flow Rate, is only required when discharge occurs via Outfall 001 (Combined WW to Rock River).

2.2.4.2 Metals Analyses

Unless specified otherwise in the table above, metals analyses shall measure metals as total recoverable. Measurements of total metals and total recoverable metals shall be considered as equivalent.

2.2.4.3 Mercury Monitoring

The permittee shall collect and analyze all mercury samples according to the data quality requirements of ss. NR 106.145(9) and (10), Wisconsin Administrative Code. The limit of quantitation (LOQ) used for the effluent and field blank shall be less than 1.3 ng/L, unless the samples are quantified at levels above 1.3 ng/L. The permittee shall collect at least one mercury field blank for each set of mercury samples (a set of samples may include combinations of intake, influent, effluent or other samples all collected on the same day). The permittee shall report results of samples and field blanks to the Department on Discharge Monitoring Reports.

2.2.5 Sampling Point 111 - West Riverside: LVW

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Daily	Calculated	
Suspended Solids, Total	Daily Max	100 mg/L	Weekly	Grab	
Suspended Solids, Total	Monthly Avg	30 mg/L	Weekly	Grab	
Suspended Solids, Total		lbs/day	Weekly	Calculated	
Oil & Grease (Hexane)	Daily Max	20 mg/L	Weekly	Grab	
Oil & Grease (Hexane)	Monthly Avg	15 mg/L	Weekly	Grab	

Oil & Grease (Hexane)		lbs/day	Weekly	Calculated	
--------------------------	--	---------	--------	------------	--

2.2.6 Sampling Point 112 - West Riverside: Cooling Tower

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Daily	Continuous	

2.2.6.1 Cooling Tower Maintenance Chemicals

Discharge of cooling tower blowdown shall be limited to no detectable amount of the 126 priority pollutants contained in chemicals added for cooling tower maintenance.

2.2.7 Sampling Point 113 - West Riverside: Post Treatment

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Daily	Continuous	
Chromium, Total Recoverable		mg/L	Quarterly	24-Hr Flow Prop Comp	
Chromium, Total Recoverable	Daily Max	0.94 lbs/day	Quarterly	Calculated	
Chromium, Total Recoverable	Monthly Avg	0.94 lbs/day	Quarterly	Calculated	
Suspended Solids, Total		mg/L	Weekly	24-Hr Flow Prop Comp	
Zinc, Total Recoverable		mg/L	Quarterly	24-Hr Flow Prop Comp	
Zinc, Total Recoverable	Daily Max	4.7 lbs/day	Quarterly	Calculated	
Zinc, Total Recoverable	Monthly Avg	4.7 lbs/day	Quarterly	Calculated	
pH (Minimum)	Daily Min	4.0 su	Daily	Continuous	
pH (Maximum)	Daily Max	11.0 su	Daily	Continuous	
pH Total Exceedance Time Minutes	Monthly Total	446 minutes	Monthly	Calculated	
pH Exceedances Greater Than 60 Minutes	Daily Max	0 Number	Daily	Calculated	
Chlorine, Total Residual		µg/L	Daily	Grab	
Mercury, Total Recoverable		ng/L	Quarterly	Grab	
Phosphorus, Total		mg/L	Weekly	24-Hr Flow	

				Prop Comp	
--	--	--	--	-----------	--

2.2.7.1 Sampling and Reporting

Sampling and reporting of all parameters, except for Flow Rate, is only required when discharge occurs via Outfall 001 (Combined WW to Rock River).

2.2.7.2 Metals Analyses

Unless specified otherwise in the table above, metals analyses shall measure metals as total recoverable. Measurements of total metals and total recoverable metals shall be considered as equivalent.

2.2.7.3 Mercury Monitoring

The permittee shall collect and analyze all mercury samples according to the data quality requirements of ss. NR 106.145(9) and (10), Wisconsin Administrative Code. The limit of quantitation (LOQ) used for the effluent and field blank shall be less than 1.3 ng/L, unless the samples are quantified at levels above 1.3 ng/L. The permittee shall collect at least one mercury field blank for each set of mercury samples (a set of samples may include combinations of intake, influent, effluent or other samples all collected on the same day). The permittee shall report results of samples and field blanks to the Department on Discharge Monitoring Reports.

2.2.7.4 Continuous pH Monitoring

The permittee shall maintain the pH of the discharge within the range of 6.0 to 9.0 standard units (s.u.) except excursions are permitted subject to the following conditions:

- The pH is monitored continuously;
- The total time during which the pH is outside the range of 6.0 to 9.0 s.u. shall not exceed 446 minutes in any calendar month;
- No individual pH excursion outside the range of 6.0 to 9.0 s.u. shall exceed 60 minutes in duration;
- No individual pH excursion shall be outside the range of 4.0 to 11.0 s.u.; and
- On a daily basis, the permittee shall report the minimum and maximum pH, the total time that the pH is outside the range of 6.0 to 9.0 s.u. and the number of pH excursions outside the range of 6.0 to 9.0 that exceed 60 minutes in duration.

3 Surface Water Requirements

3.1 Sampling Point(s)

The discharge(s) shall be limited to the waste type(s) designated for the listed sampling point(s).

Sampling Point Designation	
Sampling Point Number	Sampling Point Location, Waste Type/Sample Contents and Treatment Description (as applicable)
001	EFFLUENT: Combined discharge of comingled in-plant sample points 103 and 113. 24-hr flow proportional composite and grab samples shall be taken from each power plant prior to discharge to the Rock River and a flow weighted average shall be applied to the waste streams to determine a calculated discharge.

3.2 Monitoring Requirements and Effluent Limitations

The permittee shall comply with the following monitoring requirements and limitations.

3.2.1 Sampling Point (Outfall) 001 - Combined WW to the Rock River

Monitoring Requirements and Effluent Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Daily	Continuous	
Suspended Solids, Total	Monthly Avg	12 mg/L	Weekly	Calculated	
Chlorine, Total Residual	Daily Max	38 µg/L	Daily	Calculated	
Chlorine, Total Residual	Monthly Avg	38 µg/L	Daily	Calculated	
Zinc, Total Recoverable	Daily Max	650 µg/L	Quarterly	Calculated	
Zinc, Total Recoverable	Monthly Avg	650 µg/L	Quarterly	Calculated	
Zinc, Total Recoverable	Daily Max	12.5 lbs/day	Quarterly	Calculated	
Mercury, Total Recoverable		ng/L	Quarterly	Calculated	
Temperature Maximum		deg F	Daily	Continuous	See Temperature Monitoring section below
Nitrogen, Total		mg/L	Quarterly	Grab	See Nitrogen Monitoring section below
Chloride		mg/L	See Listed Qtr(s)	Grab	See Chloride Monitoring section below
Acute WET		TU _a	See Listed Qtr(s)	24-Hr Comp	See Whole Effluent Toxicity (WET) Testing section below

Monitoring Requirements and Effluent Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Phosphorus, Total	Rolling 12 Month Avg	1.0 mg/L	Weekly	Calculated	Limit effective throughout the permit term, as it represents a minimum control level. See "Water Quality Trading (WQT)" sections for more information.
Phosphorus, Total		lbs/day	Weekly	Calculated	Report daily mass discharged using Equation 1a. in the "Water Quality Trading (WQT)" section.
WQT Credits Used (TP)		lbs/month	Monthly	Calculated	Report WQT TP Credits used per month using Equation 2b. in the "Water Quality Trading (WQT)" section. Available TP Credits are specified in Table 2 and in the approved Water Quality Trading Plan.
WQT Computed Compliance (TP)	Monthly Avg	0.65 lbs/day	Monthly	Calculated	Report the WQT TP Computed Compliance value using Equation 3a. in the "Water Quality Trading (WQT)" section. Value entered on the last day of the month.

3.2.1.1 Temperature Monitoring

For monitoring temperature continuously, collect measurements in accordance with s. NR 218.04(13). This means that discrete measurements shall be recorded at intervals of not more than 15 minutes during the 24-hour period. In either case, report the maximum temperature.

measured during the day on the DMR.

3.2.1.2 Mercury Monitoring

The permittee shall collect and analyze all mercury samples according to the data quality requirements of ss. NR 106.145(9) and (10), Wisconsin Administrative Code. The limit of quantitation (LOQ) used for the effluent and field blank shall be less than 1.3 ng/L, unless the samples are quantified at levels above 1.3 ng/L. The permittee shall collect at least one mercury field blank for each set of mercury samples (a set of samples may include combinations of intake, influent, effluent or other samples all collected on the same day). The permittee shall report results of samples and field blanks to the Department on Discharge Monitoring Reports.

3.2.1.3 Phosphorus Water Quality Trading (WQT)

The permittee may use water quality trading to demonstrate compliance with WQBELs for total phosphorus (TP) of 0.65 lbs/day monthly average. Pollutant reduction credits for total phosphorus are available as specified in Water Quality Trading Plan **WQT-2024-0002** or approved amendments thereof.

Table 1. Available Phosphorus Credits per WQT-2024-0002

Year	Available TP Credits (lbs/yr) – Long Term
2024	108.8
2025	106.6
2026	106.6
2027	134.4
2028	138.2
2029	138.2

Only those pollutant reduction credits established by a water quality trading plan approved by the Department may be used by the permittee to demonstrate compliance with the WQBELs identified in this subsection. If the permittee wishes to use pollutant reduction credits not identified in an approved water quality trading plan, the permittee must amend the plan or develop a new plan and obtain Department approval of the amended or new plan prior to use of the new pollutant reduction credits. Prior to Department approval, the amended or new water quality trading plan will be subject to notice and opportunity for public comment. Any change in the number of available credits requires a permit modification.

In the event pollutant reduction credits as defined in the approved water quality trading plan are no longer generated, the permittee shall comply with the WQBELs for TP contained in this subsection. The sum of available interim and long-term credits shown in Table 1 may be used to demonstrate compliance for a given year. Interim credits are subject to duration limits and may not be used past the duration defined in Water Quality Trading Plan **WQT-2024-0002**.

3.2.1.4 Demonstrating Compliance with TP WQBELs Using Water Quality Trading

Use the following methods to demonstrate compliance with the TP WQBELs contained in the Water Quality Trading subsection above.

TOTAL POLLUTANT DISCHARGED (TP)

Use the following equations to calculate the amount of pollutant discharged for Monthly Avg TP [lbs/day].

$\text{TP Discharged [lbs/day]} = \text{TP Discharged [mg/L]} \times \text{Daily Flow [MGD]} \times 8.34$	<i>(Eq. 1a.)</i>
---	------------------

Monthly or Weekly Avg = Σ daily results \div # of results *(Eq. 1b.)*

WQT CREDITS USED (TOTAL PHOSPHORUS)

Use the following method to calculate the credits to be used expressed as a mass in lbs/month:

$$\text{WQT TP Credits Needed [lbs/day]} = \text{Monthly Avg TP [lbs/day]} - 0.65 \text{ lbs/day} \quad (\text{Eq. 2a.})$$

Note: When the TP discharge is less than 0.65 lbs/day as a monthly avg, report 0 (zero) as the “WQT Credits Used (TP)”.

$\text{WQT TP Credits Used [lbs/month]} = \text{WQT TP Credits Needed [lbs/day]} \times \# \text{ of days of discharge/month} \quad (\text{Eq. 2b.})$

WQT COMPUTED COMPLIANCE (TOTAL PHOSPHORUS)

Use the following method to demonstrate compliance with TP WQBELs expressed as a mass in lbs/day:

$\text{WQT TP Computed Compliance [lbs/day]} = \text{Monthly Avg TP [lbs/day]} - [\text{WQT TP Credits Needed [lbs/day]}] \quad (\text{Eq. 3a.})$

3.2.1.5 Additional Water Quality Trading Requirements

When using water quality trading to demonstrate compliance with WQBELs for TP, the permittee shall comply with the following:

- Failure to implement any of the terms or conditions of the approved water quality trading plan is a violation of this permit.
- Each month the permittee shall certify that the nonpoint source management practices installed to generate pollutant reduction credits are operated and maintained in a manner consistent with that specified in the approved water quality trading plan. Such a certification may be made by including the following statement as a comment on the monthly discharge monitoring report:

I certify that management practices identified in the approved water quality trading plan as the source of pollutant reduction credits are installed, established and properly maintained.

- At least once a year the permittee or the permittee’s agent shall inspect each nonpoint source management practice that generates pollutant reduction credits to confirm the implementation of the management practice and their appropriate operation and adequate maintenance.
- The permittee shall notify WDNR by telephone within 24 hours or next business day of becoming aware that pollutant reduction credits used or intended for use by the permittee are not being implemented or generated as defined in the approved trading plan. A written notification shall be submitted to the Department within 5 days regarding the status of the permittee’s pollutant reduction credits.
- The permittee shall provide WDNR written notice within 7 days of the trade agreement upon which the approved water quality trading plan is based being amended, modified, or revoked. This notification shall include the details of any amendment or modification in addition to the justification for the changes.
- The permittee shall not use pollutant reduction credits for the demonstration of compliance when pollutant reduction credits are not being generated.

3.2.1.6 Water Quality Trading Reopener Clause

Under any of the following conditions as provided by s. 283.53(2), Wis. Stats. and Wis. Code NR 203.135 and 203.136, the Department may modify or revoke and reissue this permit to modify or eliminate permit terms and conditions related to water quality trading:

- The permittee fails to implement the water quality trading plan as approved;
- The permittee fails to comply with permit terms and conditions related to water quality trading;
- New information becomes available that would change the number of credits available for the water quality trade or would change the Department's determinations that water quality trading is an acceptable option.

3.2.1.7 Submittal of Permit Application for Next Reissuance and Pollutant Trading Plan

The permittee shall submit the permit application for the next reissuance at least 6 months prior to expiration of this permit.

The permittee has submitted a Water Quality Trading Plan that was approved by WDNR on January 12, 2024. If the permittee intends to pursue pollutant trading to achieve compliance in a future permit term, an updated water quality trading plan is due with the application for the next reissuance. If system upgrades will be used in combination with pollutant trading the permittee shall submit plans for any system upgrade.

3.2.1.8 Nitrogen Series Monitoring

Monitoring for Total Nitrogen shall be conducted once each quarter in order to collect seasonal information about the discharge.

Nitrogen monitoring shall continue after the permit expiration date (until the permit is reissued) in accordance with the monitoring requirements specified in the last full calendar year of this permit.

Testing: Monitoring shall be performed during normal operating conditions. Permittees are not allowed to turn off or otherwise modify treatment systems, production processes, or change other operating or treatment conditions during testing.

3.2.1.9 Chloride Monitoring

Chloride monitoring is required in the following quarters: April 1st – June 30th 2025, and July 1st – September 30th 2025, January 1st – March 31st 2026, April 1st – June 30th 2026, October 1st – December 31st 2026, January 1st – March 31st 2027, July 1st – September 30th 2027, October 1st – December 31st 2027, April 1st – June 30th 2028, July 1st – September 30th 2028, January 1st – March 31st 2029

3.2.1.10 Polychlorinated Biphenyls

There shall be no discharge of polychlorinated biphenyl compounds such as those commonly used for transformer fluid.

3.2.1.11 Additives

The permittee shall maintain a record of the dosage rate of all additives used on a monthly basis. The additives may be changed during the term of the permit following procedures in the 'Additives' subsection of the Standard Requirements.

3.2.1.12 Whole Effluent Toxicity (WET) Testing

Primary Control Water: Lab water

Dilution series: At least five effluent concentrations and dual controls must be included in each test.

- **Acute:** 100, 50, 25, 12.5, 6.25% and any additional selected by the permittee.

WET Testing Frequency:

Acute tests are required during the following quarters:

- **Acute:** April 1st – June 30th 2025, October 1st – December 31st 2026, July 1st – September 30th 2027, January 1st – March 31st 2028, April 1st – June 30th 2029

Acute WET testing shall continue after the permit expiration date (until the permit is reissued) in accordance with the WET requirements specified for the last full calendar year of this permit. For example, the next test would be required in October 1st – December 31st 2030.

Testing: WET testing shall be performed during normal operating conditions. Permittees are not allowed to turn off or otherwise modify treatment systems, production processes, or change other operating or treatment conditions during WET tests.

Reporting: The permittee shall report test results on the Discharge Monitoring Report form, and also complete the "Whole Effluent Toxicity Test Report Form" (Section 6, "*State of Wisconsin Aquatic Life Toxicity Testing Methods Manual, 2nd Edition*"), for each test. The original, complete, signed version of the Whole Effluent Toxicity Test Report Form shall be sent to the Biomonitoring Coordinator, Bureau of Water Quality, 101 S. Webster St., P.O. Box 7921, Madison, WI 53707-7921, within 45 days of test completion. The Discharge Monitoring Report (DMR) form shall be submitted electronically by the required deadline.

Determination of Positive Results: An acute toxicity test shall be considered positive if the Toxic Unit - Acute (TU_a) is greater than 1.0 for either species. The TU_a shall be calculated as follows: $TU_a = 100 \div LC_{50}$.

Additional Testing Requirements: Within 90 days of a test which showed positive results, the permittee shall submit the results of at least 2 retests to the Biomonitoring Coordinator on "Whole Effluent Toxicity Test Report Forms". The 90-day reporting period shall begin the day after the test which showed a positive result. The retests shall be completed using the same species and test methods specified for the original test (see the Standard Requirements section herein).

4 Schedules

4.1 Annual Water Quality Trading (WQT) Report

Required Action	Due Date
<p>Annual WQT Report: Submit an annual WQT report that shall cover the first year of the permit term. The WQT Report shall include:</p> <p>The number of pollutant reduction credits (lbs/month) used each month of the previous year to demonstrate compliance;</p> <p>The source of each month’s pollutant reduction credits by identifying the approved water quality trading plan that details the source;</p> <p>A summary of the annual inspection of each nonpoint source management practice that generated any of the pollutant reduction credits used during the previous year; and</p> <p>Identification of noncompliance or failure to implement any terms or conditions of this permit with respect to water quality trading that have not been reported in discharge monitoring reports.</p>	01/31/2025
<p>Annual WQT Report #2: Submit an annual WQT report that shall cover the previous year.</p>	01/31/2026
<p>Annual WQT Report #3: Submit an annual WQT report that shall cover the previous year.</p>	01/31/2027
<p>Annual WQT Report #4: Submit the 4th annual WQT report. If the permittee wishes to continue to comply with phosphorus limits through WQT in subsequent permit terms, the permittee shall submit a revised WQT plan including a demonstration of credit need, compliance record of the existing WQT, and any additional practices needed to maintain compliance over time.</p>	01/31/2028
<p>Annual WQT Report Required After Permit Expiration: In the event that this permit is not reissued by the expiration date, the permittee shall continue to submit annual WQT reports by January 31 each year covering the total number of pollutant credits used, the source of the pollution reduction credits, a summary of annual inspection reports performed, and identification of noncompliance or failure to implement any terms or conditions of the approved water quality trading plan for the previous calendar year.</p>	

4.2 ELG Requirements for Cooling Tower Blowdown

Annually review the quality and source of cooling tower additives to ensure that the additives are not contributing any of the 126 priority pollutants to cooling tower blowdown.

Required Action	Due Date
<p>Annual Report: Submit annual report based on the previous calendar year according to details listed above.</p>	01/31/2025
<p>Annual Report #2: Submit annual report based on the previous calendar year according to details</p>	01/31/2026

listed above.	
Annual Report #3: Submit annual report based on the previous calendar year according to details listed above.	01/31/2027
Annual Report #4: Submit annual report based on the previous calendar year according to details listed above.	01/31/2028

5 Standard Requirements

Chapter NR 205, Wisconsin Administrative Code (Conditions for Industrial Dischargers): The conditions in ss. NR 205.07(1) and NR 205.07(3), Wis. Adm. Code, are included by reference in this permit. The permittee shall comply with all of these requirements. Some of these requirements are outlined in the Standard Requirements section of this permit. Requirements not specifically outlined in the Standard Requirement section of this permit can be found in ss. NR 205.07(1) and NR 205.07(3), Wis. Adm. Code.

5.1 Reporting and Monitoring Requirements

5.1.1 Monitoring Results

Monitoring results obtained during the previous month shall be summarized and reported on a Department Wastewater Discharge Monitoring Report. The report may require reporting of any or all of the information specified below under 'Recording of Results'. This report is to be returned to the Department no later than the date indicated on the form. A copy of the Wastewater Discharge Monitoring Report Form or an electronic file of the report shall be retained by the permittee.

Monitoring results shall be reported on an electronic discharge monitoring report (eDMR). The eDMR shall be certified electronically by a responsible executive or officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The 'eReport Certify' page certifies that the electronic report form is true, accurate and complete.

If the permittee monitors any pollutant more frequently than required by this permit, the results of such monitoring shall be included on the Wastewater Discharge Monitoring Report.

The permittee shall comply with all limits for each parameter regardless of monitoring frequency. For example, monthly, weekly, and/or daily limits shall be met even with monthly monitoring. The permittee may monitor more frequently than required for any parameter.

5.1.2 Sampling and Testing Procedures

Sampling and laboratory testing procedures shall be performed in accordance with Chapters NR 218 and NR 219, Wis. Adm. Code, and completed by a laboratory certified or registered in accordance with the requirements of ch. NR 149, Wis. Adm. Code. Groundwater sampling shall be performed in accordance with procedures contained in s. NR 140.16, Wis. Adm. Code, and the WDNR publications, Groundwater Sampling Desk Reference (PUBL-DG-037-96) and Groundwater Sampling Field Manual (PUBL-DG-038-96). The analytical methodologies used shall enable the laboratory to quantitate all substances for which monitoring is required at levels below the effluent limitation and/or groundwater standard. If the required level cannot be met by any of the methods available in ch. NR 219, Wis. Adm. Code, then the method with the lowest limit of detection shall be selected. Additional test procedures may be specified in this permit.

5.1.3 Recording of Results

The permittee shall maintain records which provide the following information for each effluent measurement or sample taken:

- the date, exact place, method and time of sampling or measurements;
- the individual who performed the sampling or measurements;
- the date the analysis was performed;
- the individual who performed the analysis;
- the analytical techniques or methods used; and
- the results of the analysis.

5.1.4 Reporting of Monitoring Results

The permittee shall use the following conventions when reporting effluent monitoring results:

- Pollutant concentrations less than the limit of detection shall be reported as < (less than) the value of the limit of detection. For example, if a substance is not detected at a detection limit of 0.1 mg/L, report the pollutant concentration as < 0.1 mg/L.
- Pollutant concentrations equal to or greater than the limit of detection, but less than the limit of quantitation, shall be reported and the limit of quantitation shall be specified.
- For purposes of calculating fees under ch. NR 101, Wis. Adm. Code, a reporting limit of 2.0 mg/L for BOD₅ and 2.5 mg/L Total Suspended Solids shall be considered to be limits of quantitation.
- For the purposes of reporting a calculated result, average or a mass discharge value, the permittee may substitute a “0” (zero) for any pollutant concentration that is less than the limit of detection. However, if the effluent limitation is less than the limit of detection, the department may substitute a value other than zero for results less than the limit of detection, after considering the number of monitoring results that are greater than the limit of detection and if warranted when applying appropriate statistical techniques.
- If no discharge occurs through an outfall, flow related parameters (e.g. flow rate, hydraulic application rate, volume, etc.) should be reported as “0” (zero) at the required sample frequency specified for the outfall. For example: if the sample frequency is daily, “0” would be reported for any day during the month that no discharge occurred.

5.1.5 Records Retention

The permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings or electronic data records for continuous monitoring instrumentation, copies of all reports required by the permit, and records of all data used to complete the application for the permit for a period of at least 3 years from the date of the sample, measurement, report or application, except for sludge management forms and records, which shall be kept for a period of at least 5 years.

5.1.6 Other Information

Where the permittee becomes aware that it failed to submit any relevant facts in a permit application or submitted incorrect information in a permit application or in any report to the Department, it shall promptly submit such facts or correct information to the Department.

5.1.7 Reporting Requirements – Alterations or Additions

The permittee shall give notice to the Department as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is only required when:

- The alteration or addition to the permitted facility may meet one of the criteria for determining whether a facility is a new source.
- The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification requirement applies to pollutants which are not subject to effluent limitations in the existing permit.
- The alteration or addition results in a significant change in the permittee’s sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use of disposal sites not reported during the permit application process nor reported pursuant to an approved land application plan. Additional sites may not be used for the land application of sludge until department approval is received.

5.2 System Operating Requirements

5.2.1 Noncompliance Reporting

The permittee shall report the following types of noncompliance by a telephone call to the Department's regional office within 24 hours after becoming aware of the noncompliance:

- any noncompliance which may endanger health or the environment;
- any violation of an effluent limitation resulting from a bypass;
- any violation of an effluent limitation resulting from an upset; and
- any violation of a maximum discharge limitation for any of the pollutants listed by the Department in the permit, either for effluent or sludge.

A written report describing the noncompliance shall also be submitted to the Department as directed at the end of this permit within 5 days after the permittee becomes aware of the noncompliance. On a case-by-case basis, the Department may waive the requirement for submittal of a written report within 5 days and instruct the permittee to submit the written report with the next regularly scheduled monitoring report. In either case, the written report shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times; the steps taken or planned to reduce, eliminate and prevent reoccurrence of the noncompliance; and if the noncompliance has not been corrected, the length of time it is expected to continue.

A scheduled bypass approved by the Department under the 'Scheduled Bypass' section of this permit shall not be subject to the reporting required under this section.

NOTE: Section 292.11(2)(a), Wisconsin Statutes, requires any person who possesses or controls a hazardous substance or who causes the discharge of a hazardous substance to notify the Department of Natural Resources **immediately** of any discharge not authorized by the permit. **The discharge of a hazardous substance that is not authorized by this permit or that violates this permit may be a hazardous substance spill. To report a hazardous substance spill, call DNR's 24-hour HOTLINE at 1-800-943-0003.**

5.2.2 Bypass

Except for a controlled diversion as provided in the 'Controlled Diversions' section of this permit, any bypass is prohibited and the Department may take enforcement action against a permittee for such occurrences under s. 283.89, Wis. Stats. The Department may approve a bypass if the permittee demonstrates all the following conditions apply:

- The bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
- There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities or adequate back-up equipment, retention of untreated wastes, reduction of inflow and infiltration, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance. When evaluating feasibility of alternatives, the department may consider factors such as technical achievability, costs and affordability of implementation and risks to public health, the environment and, where the permittee is a municipality, the welfare of the community served; and
- The bypass was reported in accordance with the 'Noncompliance Reporting' section of this permit.

5.2.3 Scheduled Bypass

Whenever the permittee anticipates the need to bypass for purposes of efficient operations and maintenance and the permittee may not meet the conditions for controlled diversions in the 'Controlled Diversions' section of this permit, the permittee shall obtain prior written approval from the Department for the scheduled bypass. A permittee's written request for Department approval of a scheduled bypass shall demonstrate that the conditions for unscheduled bypassing are met and include the proposed date and reason for the bypass, estimated volume and duration of the bypass, alternatives to bypassing and measures to mitigate environmental harm caused by the bypass. The department may require the permittee to provide public notification for a scheduled bypass if it is determined there is significant public interest in the proposed action and may recommend mitigation measures to minimize the impact of such bypass.

5.2.4 Controlled Diversions

Controlled diversions are allowed only when necessary for essential maintenance to assure efficient operation provided the following requirements are met:

- Effluent from the wastewater treatment facility shall meet the effluent limitations established in the permit. Wastewater that is diverted around a treatment unit or treatment process during a controlled diversion shall be recombined with wastewater that is not diverted prior to the effluent sampling location and prior to effluent discharge;
- A controlled diversion may not occur during periods of excessive flow or other abnormal wastewater characteristics;
- A controlled diversion may not result in a wastewater treatment facility overflow; and
- All instances of controlled diversions shall be documented in wastewater treatment facility records and such records shall be available to the department on request.

5.2.5 Proper Operation and Maintenance

The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance includes effective performance, adequate funding, adequate operator staffing and training as required in ch. NR 114, Wis. Adm. Code, and adequate laboratory and process controls, including appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems only when necessary to achieve compliance with the conditions of the permit.

5.2.6 Operator Certification

The wastewater treatment facility shall be under the direct supervision of a state certified operator. In accordance with s. NR 114.53, Wis. Adm. Code, every WPDES permitted treatment plant shall have a designated operator-in-charge holding a current and valid certificate. The designated operator-in-charge shall be certified at the level and in all subclasses of the treatment plant, except laboratory. Treatment plant owners shall notify the department of any changes in the operator-in-charge within 30 days. Note that s. NR 114.52(22), Wis. Adm. Code, lists types of facilities that are excluded from operator certification requirements (i.e. private sewage systems, pretreatment facilities discharging to public sewers, industrial wastewater treatment that consists solely of land disposal, agricultural digesters and concentrated aquatic production facilities with no biological treatment).

5.2.7 Spill Reporting

The permittee shall notify the Department in accordance with ch. NR 706 (formerly NR 158), Wis. Adm. Code, in the event that a spill or accidental release of any material or substance results in the discharge of pollutants to the waters of the state at a rate or concentration greater than the effluent limitations established in this permit, or the spill or accidental release of the material is unregulated in this permit, unless the spill or release of pollutants has been reported to the Department in accordance with s. NR 205.07 (1)(s), Wis. Adm. Code.

5.2.8 Planned Changes

In accordance with ss. 283.31(4)(b) and 283.59, Stats., the permittee shall report to the Department any facility expansion, production increase or process modifications which will result in new, different or increased discharges of pollutants. The report shall either be a new permit application, or if the new discharge will not violate the effluent limitations of this permit, a written notice of the new, different or increased discharge. The notice shall contain a description of the new activities, an estimate of the new, different or increased discharge of pollutants and a description of the effect of the new or increased discharge on existing waste treatment facilities. Following receipt of this report, the Department may modify this permit to specify and limit any pollutants not previously regulated in the permit.

5.2.9 Duty to Halt or Reduce Activity

Upon failure or impairment of treatment facility operation, the permittee shall, to the extent necessary to maintain compliance with its permit, curtail production or wastewater discharges or both until the treatment facility operations are restored or an alternative method of treatment is provided.

5.3 Surface Water Requirements

5.3.1 Permittee-Determined Limit of Quantitation Incorporated into this Permit

For pollutants with water quality-based effluent limits below the Limit of Quantitation (LOQ) in this permit, the LOQ calculated by the permittee and reported on the Discharge Monitoring Reports (DMRs) is incorporated by reference into this permit. The LOQ shall be reported on the DMRs, shall be the lowest quantifiable level practicable, and shall be no greater than the minimum level (ML) specified in or approved under 40 CFR Part 136 for the pollutant at the time this permit was issued, unless this permit specifies a higher LOQ.

5.3.2 Appropriate Formulas for Effluent Calculations

The permittee shall use the following formulas for calculating effluent results to determine compliance with average concentration limits and mass limits and total load limits:

Weekly/Monthly/Six-Month/Annual Average Concentration = the sum of all daily results for that week/month/six-month/year, divided by the number of results during that time period. [Note: When a six-month average effluent limit is specified for Total Phosphorus the applicable periods are May through October and November through April, except in cases of Water Quality Trading, wherein the applicable periods are January through June and July through December.]

Weekly Average Mass Discharge (lbs/day): Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the week.

Monthly Average Mass Discharge (lbs/day): Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the month.

Six-Month Average Mass Discharge (lbs/day): Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the six-month period. [Note: When a six-month average effluent limit is specified for Total Phosphorus the applicable periods are May through October and November through April.]

Annual Average Mass Discharge (lbs/day): Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the entire year.

Total Monthly Discharge: = monthly average concentration (mg/L) x total flow for the month (MG/month) x 8.34.

Total Annual Discharge: = sum of total monthly discharges for the calendar year.

12-Month Rolling Sum of Total Monthly Discharge: = the sum of the most recent 12 consecutive months of Total Monthly Discharges.

5.3.3 Effluent Temperature Requirements

Weekly Average Temperature – If temperature limits are included in this permit, Weekly Average Temperature shall be calculated as the sum of all daily maximum results for that week divided by the number of daily maximum results during that time period.

Cold Shock Standard – Water temperatures of the discharge shall be controlled in a manner as to protect fish and aquatic life uses from the deleterious effects of cold shock pursuant to Wis. Adm. Code, s. NR 102.28. ‘Cold Shock’ means exposure of aquatic organisms to a rapid decrease in temperature and a sustained exposure to low temperature that induces abnormal behavior or physiological performance and may lead to death.

Rate of Temperature Change Standard – Temperature of a water of the state or discharge to a water of the state may not be artificially raised or lowered at such a rate that it causes detrimental health or reproductive effects to fish or aquatic life of the water of the state pursuant to Wis. Adm. Code, s. NR 102.29.

5.3.4 Energy Emergency Events

The Department will use enforcement discretion whenever there are exceedances of effluent temperature limitations for the electric generating facility during an energy emergency warning or when an energy emergency event has been declared under a Federal Energy Regulatory Commission order (Standard EOP-002, North American Electric Reliability Corporation).

5.3.5 Visible Foam or Floating Solids

There shall be no discharge of floating solids or visible foam in other than trace amounts.

5.3.6 Surface Water Uses and Criteria

In accordance with NR 102.04, Wis. Adm. Code, surface water uses and criteria are established to govern water management decisions. Practices attributable to municipal, industrial, commercial, domestic, agricultural, land development or other activities shall be controlled so that all surface waters including the mixing zone meet the following conditions at all times and under all flow and water level conditions:

- a) Substances that will cause objectionable deposits on the shore or in the bed of a body of water, shall not be present in such amounts as to interfere with public rights in waters of the state.
- b) Floating or submerged debris, oil, scum or other material shall not be present in such amounts as to interfere with public rights in waters of the state.
- c) Materials producing color, odor, taste or unsightliness shall not be present in such amounts as to interfere with public rights in waters of the state.
- d) Substances in concentrations or in combinations which are toxic or harmful to humans shall not be present in amounts found to be of public health significance, nor shall substances be present in amounts which are acutely harmful to animal, plant or aquatic life.

5.3.7 Total Residual Chlorine Requirements

When total residual chlorine (TRC) limit(s) or monitoring are included in a permit, the permittee shall comply with the following conditions:

- a) The permittee shall perform TRC monitoring required in this permit using an approved method from ch. NR 219, Wis. Adm. Code, which produces a detection limit that is less than or equal to the permitted limit or produces the lowest economically feasible detection limit if the approved methods cannot meet the permit limit. If the facility cannot achieve a detection limit less than or equal to the permit limit using the approved methods, contact the laboratory accreditation program for guidance.
- b) The permittee shall determine the limit of detection (LOD) as specified in s. NR 149.48 (2)(b), Wis. Adm. Code, or the permittee shall contact the laboratory accreditation program for information on how to determine a verified detection limit allowed just for TRC. If the verified detection limit is determined using the special procedure, then the LOD and limit of quantitation (LOQ) shall be set to be equal to the verified detection limit determined from this special procedure.
- c) The permittee shall determine compliance with the TRC limit(s) as follows:

1. If the facility determines a statistical LOD as specified in s. NR 149.48 (2)(b), Wis. Adm. Code, and the measured TRC levels are less than the LOD, the permittee shall report the results as less than the LOD (<LOD). For this situation the LOQ shall be established at 3.33 times the LOD or at the concentration of the lowest standard in the calibration curve. TRC levels that are < LOD are in compliance with the TRC limit.
2. If the facility determines the verified detection limit using the laboratory accreditation program special procedure, this verified detection limit shall be reported as the LOD and LOQ. If the measured TRC levels are less than the LOD, the permittee shall report the results as < LOD. TRC levels that are < LOD are in compliance with the TRC limit.
3. If the facility determines the statistical LOD as specified in s. NR 149.48 (2)(b), Wis. Adm. Code, and the measured TRC levels are greater than the statistical LOD but less than the LOQ, TRC levels are in compliance with the TRC limit - except when the measured levels are consistently reported between the LOD and LOQ. When the measured TRC levels are consistently reported between the LOD and LOQ, the facility shall take action to determine the reliability of detected results (such as resampling and/or re-calculating dosages) and shall adjust the chemical feed system if necessary to reduce the chances of detecting levels between the statistical LOD and LOQ.
4. If the facility determines the statistical LOQ as specified in s. NR 149.48 (2)(b), Wis. Adm. Code, or determines the verified detection limit using the laboratory accreditation program special procedure, TRC measured levels that are greater than the statistical LOQ and the TRC limit, are not in compliance with the TRC limit. The permittee shall report the level as a limit exceedance.
5. If the facility determines the statistical LOD as specified in s. NR 149.48 (2)(b), Wis. Adm. Code, and the measured level is < LOD, then a "0" (zero) value may be substituted for any test result less than the statistical LOD when calculating the average or mass discharge values. Calculated values shall then be compared directly to the average or mass limits to determine compliance.
6. If the facility determines the verified detection limit using the laboratory accreditation program special procedure and the measured level is < LOD (set equal to the verified detection limit), then a "0" (zero) value may be substituted for any test result less than the LOD when calculating the average or mass discharge values. Calculated values shall then be compared directly to the average or mass limits to determine compliance.

5.3.8 Compliance with Phosphorus Limitation

Compliance with the concentration limitation for phosphorus shall be determined as a rolling twelve-month average and shall be calculated as follows:

First, determine the pounds of phosphorus for an individual month by multiplying the average of all the concentration values for phosphorus (in mg/L) for that month by the total flow for the month in Million Gallons times the conversion factor of 8.34.

Then, the monthly pounds of phosphorus determined in this manner shall be summed for the most recent 12 months and inserted into the numerator of the following equation.

$$\text{Average concentration of P in mg/L} = \frac{\text{Total lbs of P discharged (most recent 12 months)}}{\text{Total flow in MG (most recent 12 months)} \times 8.34}$$

The compliance calculation shall be performed each month with a reported discharge volume after substituting data from the most recent month(s) for the oldest month(s). A calculated value in excess of the concentration limitation will be considered equivalent to a violation of a monthly average.

5.3.9 Additives

In the event that the permittee wishes to commence use of a water treatment additive, or increase the usage of the additives greater than indicated in the permit application, the permittee must get a written approval from the Department prior to initiating such changes. This written approval shall provide authority to utilize the additives at the specific rates until the permit can be either reissued or modified in accordance with s. 283.53, Stats. Restrictions on the use of the additives may be included in the authorization letter.

5.3.10 Whole Effluent Toxicity (WET) Monitoring Requirements

In order to determine the potential impact of the discharge on aquatic organisms, static-renewal toxicity tests shall be performed on the effluent in accordance with the procedures specified in the "*State of Wisconsin Aquatic Life Toxicity Testing Methods Manual, 2nd Edition*" (PUB-WT-797, November 2004) as required by NR 219.04, Table A, Wis. Adm. Code). All of the WET tests required in this permit, including any required retests, shall be conducted on the *Ceriodaphnia dubia* and fathead minnow species. Receiving water samples shall not be collected from any point in contact with the permittee's mixing zone and every attempt shall be made to avoid contact with any other discharge's mixing zone.

5.3.11 Whole Effluent Toxicity (WET) Identification and Reduction

Within 60 days of a retest which showed positive results, the permittee shall submit a written report to the Biomonitoring Coordinator, Bureau of Water Quality, 101 S. Webster St., PO Box 7921, Madison, WI 53707-7921, which details the following:

- A description of actions the permittee has taken or will take to remove toxicity and to prevent the recurrence of toxicity;
- A description of toxicity reduction evaluation (TRE) investigations that have been or will be done to identify potential sources of toxicity, including the following actions:
 - a) Evaluate the performance of the treatment system to identify deficiencies contributing to effluent toxicity (e.g., operational problems, chemical additives, incomplete treatment)
 - b) Identify the compound(s) causing toxicity. Conduct toxicity screening tests on the effluent at a minimum of once per month for six months to determine if toxicity recurs. Screening tests are WET tests using fewer effluent concentrations conducted on the most sensitive species. If any of the screening tests contain toxicity, conduct a toxicity identification evaluation (TIE) to determine the cause. TIE methods are available from USEPA "Methods for Aquatic Toxicity Identification Evaluations: Phase I Toxicity Characterization Procedures (EPA/600/6-91/003) and "Toxicity Identification Evaluation: Characterization of Chronically Toxic Effluents, Phase I" (EPA/600/6-91/005F).
 - c) Trace the compound(s) causing toxicity to their sources (e.g., industrial, commercial, domestic)
 - d) Evaluate, select, and implement methods or technologies to control effluent toxicity (e.g., in-plant or pretreatment controls, source reduction or removal)
- Where corrective actions including a TRE have not been completed, an expeditious schedule under which corrective actions will be implemented;
- If no actions have been taken, the reason for not taking action.

The permittee may also request approval from the Department to postpone additional retests in order to investigate the source(s) of toxicity. Postponed retests must be completed after toxicity is believed to have been removed.

6 Summary of Reports Due

FOR INFORMATIONAL PURPOSES ONLY

Description	Date	Page
Annual Water Quality Trading (WQT) Report -Annual WQT Report	January 31, 2025	14
Annual Water Quality Trading (WQT) Report -Annual WQT Report #2	January 31, 2026	14
Annual Water Quality Trading (WQT) Report -Annual WQT Report #3	January 31, 2027	14
Annual Water Quality Trading (WQT) Report -Annual WQT Report #4	January 31, 2028	14
Annual Water Quality Trading (WQT) Report -Annual WQT Report Required After Permit Expiration	See Permit	14
ELG Requirements for Cooling Tower Blowdown -Annual Report	January 31, 2025	14
ELG Requirements for Cooling Tower Blowdown -Annual Report #2	January 31, 2026	15
ELG Requirements for Cooling Tower Blowdown -Annual Report #3	January 31, 2027	15
ELG Requirements for Cooling Tower Blowdown -Annual Report #4	January 31, 2028	15
Wastewater Discharge Monitoring Report	no later than the date indicated on the form	16

Report forms shall be submitted electronically in accordance with the reporting requirements herein. Any facility plans or plans and specifications for municipal, industrial, industrial pretreatment and non industrial wastewater systems shall be submitted to the Bureau of Water Quality, P.O. Box 7921, Madison, WI 53707-7921. All other submittals required by this permit shall be submitted to:

Central Office, 101 S Webster St, P.O. Box 7921, Madison, WI 53707-7921