



WPDES PERMIT

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
**PERMIT TO DISCHARGE UNDER THE WISCONSIN POLLUTANT DISCHARGE
ELIMINATION SYSTEM**

VILLAGE OF WYOCENA

is permitted, under the authority of Chapter 283, Wisconsin Statutes, to discharge from a facility
located at
EASEMENT ROAD, NEQ, SWQ, & NWQ, SEQ, SEC 16, T12N, R10E, WYOCENA TWP, WYOCENA,
WISCONSIN
to
**GROUNDWATERS OF THE DUCK CREEK/ROCKY RUN WATERSHED (LW20) IN THE LOWER
WISCONSIN RIVER BASIN IN COLUMBIA COUNTY**

in accordance with the effluent limitations, monitoring requirements and other conditions set
forth in this permit.

The permittee shall not discharge after the date of expiration. If the permittee wishes to continue to discharge after this expiration date an application shall be filed for reissuance of this permit, according to Chapter NR 200, Wis. Adm. Code, at least 180 days prior to the expiration date given below.

State of Wisconsin Department of Natural Resources
For the Secretary

By _____
Lisa Creegan
Wastewater Field Supervisor

Date Permit Signed/Issued

PERMIT TERM: EFFECTIVE DATE - October 01, 2026

EXPIRATION DATE - September 30, 2031

TABLE OF CONTENTS

1 INFLUENT REQUIREMENTS	1
1.1 SAMPLING POINT(S)	1
1.2 MONITORING REQUIREMENTS	1
1.2.1 <i>Sampling Point 701 - INFLUENT</i>	1
2 LAND TREATMENT REQUIREMENTS	2
2.1 SAMPLING POINT(S)	2
2.2 MONITORING REQUIREMENTS AND LIMITATIONS	2
2.2.1 <i>Sampling Point (Outfall) 001 - EFFLUENT, Absorption Pond (Seepage Cell)</i>	2
3 GROUNDWATER REQUIREMENTS	4
3.1 MONITORING REQUIREMENTS AND LIMITATIONS	4
3.1.1 <i>Groundwater Monitoring System for Seepage Cells</i>	4
4 LAND APPLICATION REQUIREMENTS	5
4.1 SAMPLING POINT(S)	5
4.2 MONITORING REQUIREMENTS AND LIMITATIONS	5
4.2.1 <i>Sampling Point (Outfall) 002 - LAGOON SLUDGE</i>	5
5 SCHEDULES	12
5.1 CHLORIDE SOURCE REDUCTION MEASURES (SRMs) FOR GROUNDWATER DISCHARGES	12
5.2 SLUDGE MANAGEMENT PLAN	12
5.3 LAND TREATMENT MANAGEMENT PLAN	12
6 STANDARD REQUIREMENTS	14
6.1 REPORTING AND MONITORING REQUIREMENTS	14
6.1.1 <i>Monitoring Results</i>	14
6.1.2 <i>Sampling and Testing Procedures</i>	14
6.1.3 <i>Sample Types</i>	14
6.1.4 <i>Recording of Results</i>	15
6.1.5 <i>Reporting of Monitoring Results</i>	15
6.1.6 <i>Compliance Maintenance Annual Reports</i>	16
6.1.7 <i>Records Retention</i>	16
6.1.8 <i>Other Information</i>	16
6.1.9 <i>Reporting Requirements – Alterations or Additions</i>	16
6.2 SYSTEM OPERATING REQUIREMENTS	17
6.2.1 <i>Noncompliance Reporting</i>	17
6.2.2 <i>Flow Meters</i>	17
6.2.3 <i>Raw Grit and Screenings</i>	17
6.2.4 <i>Sludge Management</i>	17
6.2.5 <i>Prohibited Wastes</i>	17
6.2.6 <i>Bypass</i>	18
6.2.7 <i>Scheduled Bypass</i>	18
6.2.8 <i>Controlled Diversions</i>	18
6.2.9 <i>Proper Operation and Maintenance</i>	19
6.2.10 <i>Operator Certification</i>	19
6.3 SEWAGE COLLECTION SYSTEMS	19
6.3.1 <i>Sanitary Sewage Overflows and Sewage Treatment Facility Overflows</i>	19
6.3.2 <i>Capacity, Management, Operation and Maintenance (CMOM) Program</i>	21
6.3.3 <i>Sewer Cleaning Debris and Materials</i>	21
7 SUMMARY OF REPORTS DUE	22

1 Influent Requirements

1.1 Sampling Point(s)

Sampling Point Designation	
Sampling Point Number	Sampling Point Location, Waste Type/Sample Contents and Treatment Description (as applicable)
701	Representative influent grab samples shall be collected from the influent manhole prior to entering Lagoon #1. Flow meter located at the lift station near Lovers Lane.

1.2 Monitoring Requirements

The permittee shall comply with the following monitoring requirements.

1.2.1 Sampling Point 701 - INFLUENT

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Daily	Continuous	
BOD ₅ , Total		mg/L	Weekly	Grab	
Suspended Solids, Total		mg/L	Weekly	Grab	
Nitrogen, Total Kjeldahl		mg/L	Monthly	Grab	
Nitrogen, Ammonia (NH ₃ -N) Total		mg/L	Monthly	Grab	
Nitrogen, Organic Total		mg/L	Monthly	Calculated	

2 Land Treatment Requirements

2.1 Sampling Point(s)

Sampling Point Designation	
Sampling Point Number	Sampling Point Location, Waste Description/Sample Contents and Treatment Description (as applicable)
001	Representative effluent samples shall be collected at the wet well.

2.2 Monitoring Requirements and Limitations

The permittee shall comply with the following monitoring requirements and limitations.

2.2.1 Sampling Point (Outfall) 001 - EFFLUENT, Absorption Pond (Seepage Cell)

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Daily	Total Daily	
BOD ₅ , Total	Monthly Avg	50 mg/L	Weekly	Grab	
Suspended Solids, Total		mg/L	Weekly	Grab	
pH Field		su	Weekly	Grab	
Nitrogen, Total Kjeldahl		mg/L	Monthly	Grab	
Nitrogen, Ammonia (NH ₃ -N) Total		mg/L	Monthly	Grab	
Nitrogen, Organic Total		mg/L	Monthly	Calculated	
Nitrogen, Nitrite + Nitrate Total		mg/L	Monthly	Grab	
Nitrogen, Total		mg/L	Monthly	Calculated	
Solids, Total Dissolved		mg/L	Monthly	Grab	
Chloride		mg/L	Monthly	Grab	
Phosphorus, Total		mg/L	Monthly	Grab	

Daily Log – Monitoring Requirements and Limitations

All discharge and monitoring activity shall be documented on log sheets. Originals of the log sheets shall be kept by the permittee as described under “Records Retention” in the Standard Requirements section, and if requested, made available to the Department.

Parameters	Limit	Units	Sample Frequency	Sample Type
Cell(s) Being Loaded	-	Cell Number	Daily	Log
Volume per Cell		Gallons	Daily	Log
Start to End Time	-	Date, Hour	Daily	Log

3 Groundwater Requirements

3.1 Monitoring Requirements and Limitations

3.1.1 Groundwater Monitoring System for Seepage Cells

Location of Monitoring System: NEQ, SWQ & NWQ, SEQ, SEC 16, T12N, R10E, WYOCENA TWP

Groundwater Monitoring Well(s) to be Sampled: MW-5 (805), MW-6 (806), PW-6 (807), MW-7 (808), MW-8 (809)

Groundwater Monitoring Well(s) Used to Evaluate Background Groundwater Quality: MW-8 (809)

Preventive Action Limits (PAL) and Enforcement Standards (ES) listed in the table below are from ss. NR 140.10 and NR.140.12, Wis. Adm. Code. PALs for s. NR 140.20 Wis. Adm. Code Indicator Parameters and s. NR 140.28 Wis. Adm. Code Exemptions with Alternative Concentration Limits listed in the table below have been calculated based on background groundwater quality data from this/these designated well(s). Groundwater contaminant concentrations shall be minimized and PALs met in groundwater monitoring wells to the extent it is technically and economically feasible.

Groundwater Monitoring Well(s) Used for Point of Standards Application: None

“Point of standards application” refers to any point of present groundwater use (i.e., potable well) or a specific groundwater monitoring well that is located beyond the design management zone or the property boundary, whichever is closer to the land treatment/disposal system at which the concentration of a substance in groundwater is measured for purposes of determining whether a PAL or an ES has been attained or exceeded. See the Standard Requirements section of this permit for additional conditions related to exceedance of groundwater standards.

Required Monitoring: Grab samples shall be collected from each monitoring well and analyzed for the parameters per the frequency shown in the table below.

PARAMETER	UNITS	PREVENTIVE ACTION LIMIT	ENFORCEMENT STANDARD	FREQUENCY
Depth To Groundwater	feet	N/A	N/A	Quarterly
Groundwater Elevation	feet MSL	N/A	N/A	Quarterly
Nitrogen, Nitrite + Nitrate (as N) Dissolved	mg/L	23.5	23.5	Quarterly
Nitrogen, Ammonia Dissolved	mg/L	0.97	9.7	Quarterly
Nitrogen, Organic Dissolved	mg/L	2.2	N/A	Quarterly
Chloride Dissolved	mg/L	125	250	Quarterly
Phosphorus, Total Dissolved	mg/L	N/A	N/A	Quarterly
pH Field	su	8.8	N/A	Quarterly
Solids, Total Dissolved	mg/L	830	N/A	Quarterly
COD, Filtered	mg/L	N/A	N/A	Quarterly

4 Land Application Requirements

4.1 Sampling Point(s)

The discharge(s) shall be limited to land application of the waste type(s) designated for the listed sampling point(s) on Department approved land spreading sites or by hauling to another facility.

Sampling Point Designation	
Sampling Point Number	Sampling Point Location, Waste Type/Sample Contents and Treatment Description (as applicable)
002	Representative sludge samples shall be collected from lagoon #1 in 2028 and monitored for List 1, PFAS and PCBs.

4.2 Monitoring Requirements and Limitations

The permittee shall comply with the following monitoring requirements and limitations.

4.2.1 Sampling Point (Outfall) 002 - LAGOON SLUDGE

Sludge Management: The permittee shall contact the Department prior to recycling/disposing of any sludge. The permittee shall monitor for the following parameters during the second full year of the permit, (2028). Analysis shall be submitted by **January 31, 2029**.

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Solids, Total		Percent	Once	Composite	
Arsenic Dry Wt	Ceiling	75 mg/kg	Once	Composite	
Arsenic Dry Wt	High Quality	41 mg/kg	Once	Composite	
Cadmium Dry Wt	Ceiling	85 mg/kg	Once	Composite	
Cadmium Dry Wt	High Quality	39 mg/kg	Once	Composite	
Copper Dry Wt	Ceiling	4,300 mg/kg	Once	Composite	
Copper Dry Wt	High Quality	1,500 mg/kg	Once	Composite	
Lead Dry Wt	Ceiling	840 mg/kg	Once	Composite	
Lead Dry Wt	High Quality	300 mg/kg	Once	Composite	
Mercury Dry Wt	Ceiling	57 mg/kg	Once	Composite	
Mercury Dry Wt	High Quality	17 mg/kg	Once	Composite	
Molybdenum Dry Wt	Ceiling	75 mg/kg	Once	Composite	
Nickel Dry Wt	Ceiling	420 mg/kg	Once	Composite	
Nickel Dry Wt	High Quality	420 mg/kg	Once	Composite	

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Selenium Dry Wt	Ceiling	100 mg/kg	Once	Composite	
Selenium Dry Wt	High Quality	100 mg/kg	Once	Composite	
Zinc Dry Wt	Ceiling	7,500 mg/kg	Once	Composite	
Zinc Dry Wt	High Quality	2,800 mg/kg	Once	Composite	
Nitrogen, Total Kjeldahl		Percent	Per Application	Composite	
Nitrogen, Ammonium (NH ₄ -N) Total		Percent	Per Application	Composite	
Phosphorus, Total		Percent	Per Application	Composite	
Phosphorus, Water Extractable		% of Tot P	Per Application	Composite	
Potassium, Total Recoverable		Percent	Per Application	Composite	
PFOA + PFOS		µg/kg	Once	Calculated	Report the sum of PFOA and PFOS. See PFAS Permit Sections for more information.
PCB Total Dry Wt	Ceiling	50 mg/kg	Once	Composite	
PCB Total Dry Wt	High Quality	10 mg/kg	Once	Composite	
PFAS Dry Wt			Once	Grab	Perfluoroalkyl and Polyfluoroalkyl Substances based on updated DNR PFAS List. See PFAS Permit Sections for more information.

Other Sludge Requirements	
Sludge Requirements	Sample Frequency
List 3 Requirements – Pathogen Control: The requirements in List 3 shall be met prior to land application of sludge.	Required only when sludge is land applied
List 4 Requirements – Vector Attraction Reduction: The vector attraction reduction shall be satisfied prior to, or at the time of land application as specified in List 4.	Required only when sludge is land applied

4.2.1.1 Requirements for Potential and/or Unscheduled Land Application of Sludge

Monitoring for List 1, PCBs, and PFAS (if listed in monitoring requirements table above) shall occur in year two of permit term (2028) unless a sludge removal date has been established which would occur within the permit term, but in a different year. Monitoring for List 2 is highly recommended during the same sampling event to determine acreage needs for land application of sludge should it be necessary at a future date.

If a sludge removal date has been established other than in year two (2028), monitoring for Lists 1, 2, 3 & 4, PCBs and PFAS (if listed) shall occur in the year of, but prior to, land application of the removed sludge. Monitoring must be done, and compliance assured, prior to land application, in addition to all other requirements specified herein and in ch. NR 204, Wis. Adm. Code. The permittee shall notify the Department prior to such land application. If sludge removal and land application are necessary after the monitoring for List 1, PCBs and PFAS (if listed) in year two of the permit, monitoring for Lists 2, 3 & 4 shall be done in the year of and prior to land application.

4.2.1.2 Changes in Feed Sludge Characteristics

If a change in feed sludge characteristics, treatment process, or operational procedures occurs which may result in a significant shift in sludge characteristics, the permittee shall reanalyze the sludge for List 1, 2, 3 and 4 parameters each time such change occurs.

4.2.1.3 Multiple Sludge Sample Points (Outfalls)

If there are multiple sludge sample points (outfalls), but the sludges are not subject to different sludge treatment processes, then a separate List 2 analysis shall be conducted for each sludge type which is land applied, just prior to land application, and the application rate shall be calculated for each sludge type. In this case, List 1, 3, and 4 and PCBs need only be analyzed on a single sludge type, at the specified frequency. If there are multiple sludge sample points (outfalls), due to multiple treatment processes, List 1, 2, 3 and 4 and PCBs shall be analyzed for each sludge type at the specified frequency.

4.2.1.4 Sludge Which Exceeds the High Quality Limit

Cumulative pollutant loading records shall be kept for all bulk land application of sludge which does not meet the high quality limit for any parameter. This requirement applies for the entire calendar year in which any exceedance of Table 3 of s. NR 204.07(5)(c), Wis. Adm. Code, is experienced. Such loading records shall be kept for all List 1 parameters for each site land applied in that calendar year. The formula to be used for calculating cumulative loading is as follows:

$$[(\text{Pollutant concentration (mg/kg)} \times \text{dry tons applied/ac}) \div 500] + \text{previous loading (lbs/acre)} = \text{cumulative lbs pollutant per acre}$$

When a site reaches 90% of the allowable cumulative loading for any metal established in Table 2 of s. NR 204.07(5)(b), Wis. Adm. Code, the Department shall be so notified through letter or in the comment section of the annual land application report (3400-55).

4.2.1.5 Sludge Analysis for PCBs

The permittee shall analyze the sludge for Total PCBs one time during 2028. The results shall be reported as "PCB Total Dry Wt". Either congener-specific analysis or Aroclor analysis shall be used to determine the PCB concentration. The permittee may determine whether Aroclor or congener specific analysis is performed. Analyses shall be performed in accordance with Table EM in s. NR 219.04, Wis. Adm. Code and the conditions specified in Standard Requirements of this permit. PCB results shall be submitted by January 31, following the specified year of analysis.

4.2.1.6 Lists 1, 2, 3, and 4

List 1 TOTAL SOLIDS AND METALS See the Monitoring Requirements and Limitations table above for monitoring frequency and limitations for the List 1 parameters	
Solids, Total (percent)	
Arsenic, mg/kg (dry weight)	
Cadmium, mg/kg (dry weight)	
Copper, mg/kg (dry weight)	
Lead, mg/kg (dry weight)	
Mercury, mg/kg (dry weight)	
Molybdenum, mg/kg (dry weight)	
Nickel, mg/kg (dry weight)	
Selenium, mg/kg (dry weight)	
Zinc, mg/kg (dry weight)	

List 2 NUTRIENTS See the Monitoring Requirements and Limitations table above for monitoring frequency for the List 2 parameters	
Solids, Total (percent)	
Nitrogen Total Kjeldahl (percent)	
Nitrogen Ammonium (NH ₄ -N) Total (percent)	
Phosphorus Total as P (percent)	
Phosphorus, Water Extractable (as percent of Total P)	
Potassium Total Recoverable (percent)	

List 3		
PATHOGEN CONTROL FOR CLASS B SLUDGE		
The permittee shall implement pathogen control as listed in List 3. The Department shall be notified of the pathogen control utilized and shall be notified when the permittee decides to utilize alternative pathogen control.		
The following requirements shall be met prior to land application of sludge.		
Parameter	Unit	Limit
Fecal Coliform*	MPN/gTS or CFU/gTS	2,000,000
OR, ONE OF THE FOLLOWING PROCESS OPTIONS		
Aerobic Digestion	Air Drying	
Anaerobic Digestion	Composting	
Alkaline Stabilization	PSRP Equivalent Process	
* The Fecal Coliform limit shall be reported as the geometric mean of 7 discrete samples on a dry weight basis.		

List 4
VECTOR ATTRACTION REDUCTION

The permittee shall implement any one of the vector attraction reduction options specified in List 4. The Department shall be notified of the option utilized and shall be notified when the permittee decides to utilize an alternative option.

One of the following shall be satisfied prior to, or at the time of land application as specified in List 4.

Option	Limit	Where/When it Shall be Met
Volatile Solids Reduction	≥38%	Across the process
Specific Oxygen Uptake Rate	≤1.5 mg O ₂ /hr/g TS	On aerobic stabilized sludge
Anaerobic bench-scale test	<17 % VS reduction	On anaerobic digested sludge
Aerobic bench-scale test	<15 % VS reduction	On aerobic digested sludge
Aerobic Process	>14 days, Temp >40°C and Avg. Temp > 45°C	On composted sludge
pH adjustment	>12 S.U. (for 2 hours) and >11.5 (for an additional 22 hours)	During the process
Drying without primary solids	>75 % TS	When applied or bagged
Drying with primary solids	>90 % TS	When applied or bagged
Equivalent Process	Approved by the Department	Varies with process
Injection	-	When applied
Incorporation	-	Within 6 hours of application

4.2.1.7 Daily Land Application Log

Daily Land Application Log		
Discharge Monitoring Requirements and Limitations		
The permittee shall maintain a daily land application log for biosolids land applied each day when land application occurs. The following minimum records must be kept, in addition to all analytical results for the biosolids land applied. The log book records shall form the basis for the annual land application report requirements.		
Parameters	Units	Sample Frequency
DNR Site Number(s)	Number	Daily as used
Outfall number applied	Number	Daily as used
Acres applied	Acres	Daily as used
Amount applied	As appropriate * /day	Daily as used
Application rate per acre	unit */acre	Daily as used
Nitrogen applied per acre	lb/acre	Daily as used
Method of Application	Injection, Incorporation, or surface applied	Daily as used

*gallons, cubic yards, dry US Tons or dry Metric Tons

4.2.1.8 Sludge Monitoring for PFAS

Sampling shall occur for perfluoroalkyl and polyfluoroalkyl compounds (PFAS) listed in the table below and as indicated in sampling point sections above. Monitoring shall occur at each sample point when sludge is generated regardless of the end use (i.e. land applied, hauled to another facility, landfilled).

PERFLUOROALKYLCARBOXYLIC Acids (PFCAs)	
PFBA	Perfluorobutanoic acid
PFPeA	Perfluoropentanoic acid
PFHxA	Perfluorohexanoic acid
PFHpA	Perfluoroheptanoic acid
PFOA	Perfluorooctanoic acid
PFNA	Perfluorononanoic acid
PFDA	Perfluorodecanoic acid
PFUnA	Perfluoroundecanoic acid
PFDoA	Perfluorododecanoic acid
PFTTrDA	Perfluorotridecanoic acid
PFTeDA	Perfluorotetradecanoic acid
PERFLUOROALKYLSULFONIC Acids (PFSA's)	
PFBS	Perfluorobutane sulfonic acid
PFPeS	Perfluoropentane sulfonic acid
PFHxS	Perfluorohexane sulfonic acid
PFHpS	Perfluoroheptane sulfonic acid
PFOS	Perfluorooctane sulfonic acid
PFNS	Perfluorononane sulfonic acid
PFDS	Perfluorodecane sulfonic acid
PFDoS	Perfluorododecane sulfonic acid
TELOMER SULFONIC Acids	
4:2FTSA	1H,1H,2H,2H-Perfluorohexane sulfonic acid
6:2FTSA	1H,1H,2H,2H-Perfluorooctane sulfonic acid
8:2FTSA	1H,1H,2H,2H-Perfluorodecane sulfonic acid
PERFLUOROOCTANCESULFONAMIDES (FOSA's)	
PFOSA	Perfluorooctane sulfonamide
NMeFOSA	N-Methyl perfluorooctane sulfonamide
NEtFOSA	N-Ethyl perfluorooctane sulfonamide
PERFLUOROOCTANCESULFONAMIDOACETIC Acids	
NMeFOSAA	N-Methyl perfluorooctane sulfonamidoacetic acid
NEtFOSAA	N-Ethyl perfluorooctane sulfonamidoacetic acid
NATIVE PERFLUOROOCTANCESULFONAMIDOETHANOLS (FOSE's)	
NMeFOSE	N-Methyl perfluorooctane sulfonamidoethanol
NEtFOSE	N-Ethyl perfluorooctane sulfonamidoethanol
PERFLUOROALKYLETHERCARBOXYLIC Acids (PFECA's)	
HFPO-DA	Hexafluoropropylene oxide dimer acid

ADONA	4,8-dioxa-3 <i>H</i> -perfluorononanoic acid
PFMPA	Perfluoro-3-methoxypropanoic acid
PFMBA	Perfluoro-4-methoxybutanoic acid
NFDHA	Nonafluoro-3,6-dioxaheptaioic acid
CHLORO-PERFLUOROALKYLSULFONATE	
9Cl-PF3ONS	9-chlorohexadecafluoro-3-oxanone-1-sulfonic acid
11Cl-PF3OUdS	11-chloroelcosafluoro-3-oxaundecane-1-sulfonic acid
PFEESA	Perfluoro(2-ethoxyethane)sulfonic acid
TELOMER SULFONIC Acids	
3:3FTCA	3-Perfluoropropyl propanoic acid
5:3FTCA	2 <i>H</i> ,2 <i>H</i> ,3 <i>H</i> ,3 <i>H</i> -Perfluorooctanoic acid
7:3FTCA	3-Perfluoroheptyl propanoic acid

Note: If WDNR Lab Certification removes a particular compound from the reporting list above and upon receiving written communication from the department, reporting for that compound is no longer required.

4.2.1.9 Sampling and Reporting Sludge Samples for PFAS

Representative sludge samples shall be collected at each sample point as listed. At minimum, liquid sludge storage/digesters should be thoroughly mixed prior to sampling. Cake sludge samples should consist of seven equal size discrete samples and be collected from different areas and depths then composited into one sample for laboratory analysis.

Note: If additional equipment is used for collecting sludge samples (i.e., shovels, compositing buckets, bottles, etc.), then a one-time equipment blank is recommended to be collected with the first sample. An equipment blank sample is collected by passing laboratory verified PFAS-free water over or through field sampling equipment before the collection of a representative sludge sample. The equipment blank result shall be reported on the annual Sludge Characteristics Form (3400-049) in the comment section when reporting PFAS concentrations in the sludge.

The permittee shall report each of the PFAS sludge monitoring results on the annual Sludge Characteristics and Monitoring Form (3400-049) as provided by the department. The permittee shall also report the summation of PFOS and PFOA on this same form. All results shall be reported in dry weight. The annual Sludge Characteristics and Monitoring Form (3400-049) are due January 31, of the year following the collection of the sludge samples.

The laboratory performing the analysis on any samples shall be certified for the applicable PFAS compounds in the solids matrix by the Wisconsin Laboratory Certification Program established under s. 299.11, Wis. Stats., and in accordance with s. NR 149.41, Wis. Adm. Code. The department may reject any sample results if results are produced by a laboratory that is not in compliance with certification requirements under ch. NR 149, Wis. Adm. Code.

4.2.1.10 PFAS Land Application Requirements

The department recommends the landspreading and/or land application of sludge be done in a manner consistent with the most recent version of the [“Interim Strategy for Land Application of Biosolids and Industrial Sludges containing PFAS”](#).

5 Schedules

5.1 Chloride Source Reduction Measures (SRMs) for Groundwater Discharges

Required Action	Due Date
Chloride Reduction Plan: The permittee shall complete and submit for Department review and approval a chloride reduction plan (CRP). The CRP is an initial step toward controlling chloride and ensuring compliance with chloride limits based on applicable groundwater standards. The CRP shall evaluate all applicable source reduction measures (SRMs) and establish appropriate implementation activities for the SRMs. The CRP shall include a schedule for implementing the selected SRMs.	01/31/2027
Annual Progress Report: Once the chloride reduction plan (CRP) is approved by the Department, the permittee shall submit an annual progress report, under the authority of s. NR 205.07(1)(h), Wis. Adm. Code. If a SRM implementation date of an approved CRP is not met, this may constitute a violation of the permit. Submittal of the first annual progress report is required by the Date Due.	01/31/2028
Second Annual Progress Report: Submit progress report in implementing the chloride reduction plan (CRP).	01/31/2029
Third Annual Progress Report: Submit progress report in implementing the chloride reduction plan (CRP).	01/31/2030
Fourth Annual Progress Report: Submit progress report in implementing the chloride reduction plan (CRP).	01/31/2031

5.2 Sludge Management Plan

A management plan is required for sludge removal.

Required Action	Due Date
Sludge Management Plan Submittal: The permittee shall submit a management plan for approval if removal of sludge will occur during this permit term. The plan shall demonstrate compliance with ch. NR 204 Wis. Adm. Code and at minimum address 1) How and where is sludge sampled; 2) Available sludge storage details and location(s); 3) How will the sludge be removed with details on volume, characterization and how the treatment plant will continue to function during the drawdown; 4) Describe the type of transportation and spreading vehicles and loading and unloading practices; 5) Identify approved land application sites, apply for needed sites, site limitations, total acres needed and vegetative cover management; 6) Specify record keeping procedures including site loading; 7) Address contingency plans for adverse weather and odor/nuisance abatement; and 8) Include any other pertinent information such as other disposal options that may be used or specifications of any pretreatment processes. Once approved, all sludge management activities shall be conducted in accordance with the plan. Any changes to the plan must be approved by the Department prior to implementing the changes. No desludging may occur unless approval from the Department is obtained. Daily logs shall be kept that record where the sludge has been disposed. The plan is due at least 60 days prior to desludging.	

5.3 Land Treatment Management Plan

A management plan is required for the land treatment system.

Required Action	Due Date
Land Treatment Management Plan Submittal: Submit a management plan to optimize the land treatment system performance and demonstrate compliance with ch. NR 206, Wis. Adm. Code. The land treatment system shall be operated in accordance with the approved management plan.	10/01/2027

6 Standard Requirements

Chapter NR 205, Wisconsin Administrative Code: The conditions in ss. NR 205.07(1) and NR 205.07(2), Wis. Adm. Code, are included by reference in this permit. The permittee shall comply with all of these requirements. Some of these requirements are outlined in the Standard Requirements section of this permit. Requirements not specifically outlined in the Standard Requirement section of this permit can be found in ss. NR 205.07(1) and NR 205.07(2), Wis. Adm. Code.

6.1 Reporting and Monitoring Requirements

6.1.1 Monitoring Results

Monitoring results obtained during the previous month shall be summarized and reported on a Department Wastewater Discharge Monitoring Report. The report may require reporting of any or all of the information specified below under 'Recording of Results'. This report is to be returned to the Department no later than the date indicated on the form. A copy of the Wastewater Discharge Monitoring Report Form or an electronic file of the report shall be retained by the permittee.

Monitoring results shall be reported on an electronic discharge monitoring report (eDMR). The eDMR shall be certified electronically by a responsible executive or municipal officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The 'eReport Certify' page certifies that the electronic report form is true, accurate and complete.

If the permittee monitors any pollutant more frequently than required by this permit, the results of such monitoring shall be included on the Wastewater Discharge Monitoring Report pursuant s. NR 205.07(1)(r)2., Wis. Adm. Code.

For the purpose of meeting sampling frequency requirements, a week is defined as a calendar week, which begins on Sunday and ends on Saturday. The calendar week shall be used as the basis for reporting monitoring data on discharge monitoring reports.

The permittee shall comply with all limits for each parameter regardless of monitoring frequency. For example, monthly, weekly, and/or daily limits shall be met even with monthly monitoring. The permittee may monitor more frequently than required for any parameter.

6.1.2 Sampling and Testing Procedures

Sampling and laboratory testing procedures shall be performed in accordance with Chapters NR 218 and NR 219, Wis. Adm. Code, and completed by a laboratory certified or registered in accordance with the requirements of ch. NR 149, Wis. Adm. Code. Groundwater sampling shall be performed in accordance with procedures contained in s. NR 140.16, Wis. Adm. Code, and the WDNR publications, Groundwater Sampling Desk Reference (PUBL-DG-037-96) and Groundwater Sampling Field Manual (PUBL-DG-038-96). The analytical methodologies used shall enable the laboratory to quantitate all substances for which monitoring is required at levels below the effluent limitation and/or groundwater standard. If the required level cannot be met by any of the methods available in ch. NR 219, Wis. Adm. Code, then the method with the lowest limit of detection shall be selected. Additional test procedures may be specified in this permit.

6.1.3 Sample Types

The permittee shall use the following definitions from s. NR 218.04, Wis. Adm. Code as prescribed in the WPDES permit for the appropriate method and manner of obtaining samples:

24-hour Composite Sample: A combination of individual samples taken at intervals of not more than one hour such that the volumes of each of the individual samples and of the combination are proportional to the volumes of flow during each interval and during the 24-hour period respectively.

- **24-hour Flow Proportional Composite Sample:** A combination of individual grab samples taken over a 24-hr period, where the individual grab samples are of equal volume and taken at intervals after a specified volume of discharge has occurred.
- **24-hour Time Proportional Composite Sample:** A combination of individual grab samples taken over a 24-hr period, where the individual grab samples are of equal volume and taken at consistent intervals not exceeding 15 minutes.

Composite Sample: A combination of individual samples of equal volume taken at approximately equal intervals not exceeding one hour over a specified period of time.

- **3-hr Composite Sample:** A combination of three (3) individual grab samples of equal volume taken at one-hour intervals.

Continuous Sample: A composite of successive individual samples of equal volume taken automatically at equal intervals not exceeding 15 minutes. Where the term is used in connection with monitoring temperature or pH it means continuous in-line recording or monitoring at intervals of not more than 15 minutes.

Continuous sample is synonymous with in-line measurements and may apply to flow, temperature, pH, and dissolved oxygen measurements only. The in-line instrument takes automatic readings at intervals of not more than 15 minutes during a 24-hour period.

Grab Sample: A single sample taken at one moment of time or a combination of several smaller samples of equal volume taken in less than a 2-minute period. Where the term is used in connection with monitoring temperature or pH it means a single measurement.

6.1.4 Recording of Results

The permittee shall maintain records which provide the following information for each effluent measurement or sample taken:

- The date, exact place, method and time of sampling or measurements;
- The individual who performed the sampling or measurements;
- The date the analysis was performed;
- The individual who performed the analysis;
- The analytical techniques or methods used; and
- The results of the analysis.

6.1.5 Reporting of Monitoring Results

The permittee shall use the following conventions when reporting effluent monitoring results:

- Pollutant concentrations less than the limit of detection shall be reported as < (less than) the value of the limit of detection. For example, if a substance is not detected at a detection limit of 0.1 mg/L, report the pollutant concentration as < 0.1 mg/L.
- Pollutant concentrations equal to or greater than the limit of detection, but less than the limit of quantitation, shall be reported and the limit of quantitation shall be specified.
- For purposes of calculating fees under ch. NR 101, Wis. Adm. Code, a reporting limit of 2.0 mg/L for BOD₅ and 2.5 mg/L Total Suspended Solids shall be considered to be limits of quantitation.
- For the purposes of reporting a calculated result, average or a mass discharge value, the permittee may substitute a "0" (zero) for any pollutant concentration that is less than the limit of detection. However, if the effluent limitation is less than the limit of detection, the department may substitute a value other than zero for

results less than the limit of detection, after considering the number of monitoring results that are greater than the limit of detection and if warranted when applying appropriate statistical techniques.

- If no discharge occurs through an outfall, flow related parameters (e.g. flow rate, hydraulic application rate, volume, etc.) should be reported as “0” (zero) at the required sample frequency specified for the outfall. For example: if the sample frequency is daily, “0” would be reported for any day during the month that no discharge occurred.

6.1.6 Compliance Maintenance Annual Reports

Compliance Maintenance Annual Reports (CMAR) shall be completed using information obtained over each calendar year regarding the wastewater conveyance and treatment system. The CMAR shall be submitted and certified by the permittee in accordance with ch. NR 208, Wis. Adm. Code, by June 30, each year on an electronic report form provided by the Department.

In the case of a publicly owned treatment works, a resolution shall be passed by the governing body and submitted as part of the CMAR, verifying its review of the report and providing responses as required. Private owners of wastewater treatment works are not required to pass a resolution; but they must provide an Owner Statement and responses as required, as part of the CMAR submittal.

The CMAR shall be certified electronically by a responsible executive or municipal officer, manager, partner or proprietor as specified in s. 283.37(3), Wis. Stats., or a duly authorized representative of the officer, manager, partner or proprietor that has been delegated signature authority pursuant to s. NR 205.07(1)(g)2, Wis. Adm. Code. The certification verifies that the electronic report is true, accurate and complete.

6.1.7 Records Retention

The permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings or electronic data records for continuous monitoring instrumentation, copies of all reports required by the permit, and records of all data used to complete the application for the permit for a period of at least 3 years from the date of the sample, measurement, report or application. All pertinent sludge information, including permit application information and other documents specified in this permit or s. NR 204.06(9), Wis. Adm. Code shall be retained for a minimum of 5 years.

6.1.8 Other Information

Where the permittee becomes aware that it failed to submit any relevant facts in a permit application or submitted incorrect information in a permit application or in any report to the Department, it shall promptly submit such facts or correct information to the Department.

6.1.9 Reporting Requirements – Alterations or Additions

The permittee shall give notice to the Department as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is only required when:

- The alteration or addition to the permitted facility may meet one of the criteria for determining whether a facility is a new source.
- The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification requirement applies to pollutants which are not subject to effluent limitations in the existing permit.
- The alteration or addition results in a significant change in the permittee’s sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use of disposal sites not reported during the permit application process nor reported pursuant to an approved land application plan. Additional sites may not be used for the land application of sludge until department approval is received.

6.2 System Operating Requirements

6.2.1 Noncompliance Reporting

Sanitary sewer overflows and sewage treatment facility overflows shall be reported according to the 'Sanitary Sewer Overflows and Sewage Treatment Facility Overflows' section of this permit.

The permittee shall report the following types of noncompliance by a telephone call to the Department's regional office within 24 hours after becoming aware of the noncompliance:

- Any noncompliance which may endanger health or the environment;
- Any violation of an effluent limitation resulting from a bypass;
- Any violation of an effluent limitation resulting from an upset; and
- Any violation of a maximum discharge limitation for any of the pollutants listed by the Department in the permit, either for effluent or sludge.

A written report describing the noncompliance shall also be submitted to the Department's regional office within 5 days after the permittee becomes aware of the noncompliance. On a case-by-case basis, the Department may waive the requirement for submittal of a written report within 5 days and instruct the permittee to submit the written report with the next regularly scheduled monitoring report. In either case, the written report shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times; the steps taken or planned to reduce, eliminate and prevent reoccurrence of the noncompliance; and if the noncompliance has not been corrected, the length of time it is expected to continue.

A scheduled bypass approved by the Department under the 'Scheduled Bypass' section of this permit shall not be subject to the reporting required under this section.

NOTE: Section 292.11(2)(a), Wisconsin Statutes, requires any person who possesses or controls a hazardous substance or who causes the discharge of a hazardous substance to notify the Department of Natural Resources **immediately** of any discharge not authorized by the permit. **The discharge of a hazardous substance that is not authorized by this permit or that violates this permit may be a hazardous substance spill. To report a hazardous substance spill, call DNR's 24-hour HOTLINE at 1-800-943-0003.**

6.2.2 Flow Meters

Flow meters shall be calibrated annually, as per s. NR 218.06, Wis. Adm. Code.

6.2.3 Raw Grit and Screenings

All raw grit and screenings shall be disposed of at a properly licensed solid waste facility or picked up by a licensed waste hauler. If the facility or hauler are located in Wisconsin, then they shall be licensed under chs. NR 500-555, Wis. Adm. Code.

6.2.4 Sludge Management

All sludge management activities shall be conducted in compliance with ch. NR 204 "Domestic Sewage Sludge Management", Wis. Adm. Code.

6.2.5 Prohibited Wastes

Under no circumstances may the introduction of wastes prohibited by s. NR 211.10, Wis. Adm. Code, be allowed into the waste treatment system. Prohibited wastes include those:

- Which create a fire or explosion hazard in the treatment work;
- Which will cause corrosive structural damage to the treatment work;

- Solid or viscous substances in amounts which cause obstructions to the flow in sewers or interference with the proper operation of the treatment work;
- Wastewaters at a flow rate or pollutant loading which are excessive over relatively short time periods so as to cause a loss of treatment efficiency; and
- Changes in discharge volume or composition from contributing industries which overload the treatment works or cause a loss of treatment efficiency.

6.2.6 Bypass

This condition applies only to bypassing at a sewage treatment facility that is not a scheduled bypass, approved blending as a specific condition of this permit, a sewage treatment facility overflow or a controlled diversion as provided in the sections titled 'Scheduled Bypass', 'Blending' (if approved), 'SSO's and Sewage Treatment Facility Overflows' and 'Controlled Diversions' of this permit. Any other bypass at the sewage treatment facility is prohibited and the Department may take enforcement action against a permittee for such occurrences under s. 283.89, Wis. Stats. The Department may approve a bypass if the permittee demonstrates all the following conditions apply:

- The bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
- There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities or adequate back-up equipment, retention of untreated wastes, reduction of inflow and infiltration, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventative maintenance. When evaluating feasibility of alternatives, the department may consider factors such as technical achievability, costs and affordability of implementation and risks to public health, the environment and, where the permittee is a municipality, the welfare of the community served; and
- The bypass was reported in accordance with the Noncompliance Reporting section of this permit.

6.2.7 Scheduled Bypass

Whenever the permittee anticipates the need to bypass for purposes of efficient operations and maintenance and the permittee may not meet the conditions for controlled diversions in the 'Controlled Diversions' section of this permit, the permittee shall obtain prior written approval from the Department for the scheduled bypass. A permittee's written request for Department approval of a scheduled bypass shall demonstrate that the conditions for bypassing specified in the above section titled 'Bypass' are met and include the proposed date and reason for the bypass, estimated volume and duration of the bypass, alternatives to bypassing and measures to mitigate environmental harm caused by the bypass. The department may require the permittee to provide public notification for a scheduled bypass if it is determined there is significant public interest in the proposed action and may recommend mitigation measures to minimize the impact of such bypass.

6.2.8 Controlled Diversions

Controlled diversions are allowed only when necessary for essential maintenance to assure efficient operation. Sewage treatment facilities that have multiple treatment units to treat variable or seasonal loading conditions may shut down redundant treatment units when necessary for efficient operation. The following requirements shall be met during controlled diversions:

- Effluent from the sewage treatment facility shall meet the effluent limitations established in the permit. Wastewater that is diverted around a treatment unit or treatment process during a controlled diversion shall be recombined with wastewater that is not diverted prior to the effluent sampling location and prior to effluent discharge;

- A controlled diversion does not include blending as defined in s. NR 210.03(2e), Wis. Adm. Code, and as may only be approved under s. NR 210.12. A controlled diversion may not occur during periods of excessive flow or other abnormal wastewater characteristics;
- A controlled diversion may not result in a wastewater treatment facility overflow; and
- All instances of controlled diversions shall be documented in sewage treatment facility records and such records shall be available to the department on request.

6.2.9 Proper Operation and Maintenance

The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance includes effective performance, adequate funding, adequate operator staffing and training as required in ch. NR 114, Wis. Adm. Code, and adequate laboratory and process controls, including appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems only when necessary to achieve compliance with the conditions of the permit.

6.2.10 Operator Certification

The wastewater treatment facility shall be under the direct supervision of a state certified operator. In accordance with s. NR 114.53, Wis. Adm. Code, every WPDES permitted treatment plant shall have a designated operator-in-charge holding a current and valid certificate. The designated operator-in-charge shall be certified at the level and in all subclasses of the treatment plant, except laboratory. Treatment plant owners shall notify the department of any changes in the operator-in-charge within 30 days. Note that s. NR 114.52(22), Wis. Adm. Code, lists types of facilities that are excluded from operator certification requirements (i.e. private sewage systems, pretreatment facilities discharging to public sewers, industrial wastewater treatment that consists solely of land disposal, agricultural digesters and concentrated aquatic production facilities with no biological treatment).

6.3 Sewage Collection Systems

6.3.1 Sanitary Sewage Overflows and Sewage Treatment Facility Overflows

6.3.1.1 Overflows Prohibited

Any overflow or discharge of wastewater from the sewage collection system or at the sewage treatment facility, other than from permitted outfalls, is prohibited. The permittee shall provide information on whether any of the following conditions existed when an overflow occurred:

- The sanitary sewer overflow or sewage treatment facility overflow was unavoidable to prevent loss of life, personal injury or severe property damage;
- There were no feasible alternatives to the sanitary sewer overflow or sewage treatment facility overflow such as the use of auxiliary treatment facilities or adequate back-up equipment, retention of untreated wastes, reduction of inflow and infiltration, or preventive maintenance activities;
- The sanitary sewer overflow or the sewage treatment facility overflow was caused by unusual or severe weather-related conditions such as large or successive precipitation events, snowmelt, saturated soil conditions, or severe weather occurring in the area served by the sewage collection system or sewage treatment facility; and
- The sanitary sewer overflow or the sewage treatment facility overflow was unintentional, temporary, and caused by an accident or other factors beyond the reasonable control of the permittee.

6.3.1.2 Permittee Response to Overflows

Whenever a sanitary sewer overflow or sewage treatment facility overflow occurs, the permittee shall take all feasible steps to control or limit the volume of untreated or partially treated wastewater discharged, and terminate the discharge as soon as practicable. Remedial actions, including those in s. NR 210.21 (3), Wis. Adm. Code, shall be implemented consistent with an emergency response plan developed under the CMOM program.

6.3.1.3 Permittee Reporting

Permittees shall report all sanitary sewer overflows and sewage treatment overflows as follows:

- The permittee shall notify the department by telephone, fax or email as soon as practicable, but no later than 24 hours from the time the permittee becomes aware of the overflow;
- The permittee shall, no later than five days from the time the permittee becomes aware of the overflow, provide to the department the information identified in this paragraph using department form number 3400-184. If an overflow lasts for more than five days, an initial report shall be submitted within 5 days as required in this paragraph and an updated report submitted following cessation of the overflow. At a minimum, the following information shall be included in the report:
 - a) The date and location of the overflow;
 - b) The surface water to which the discharge occurred, if any;
 - c) The duration of the overflow and an estimate of the volume of the overflow;
 - d) A description of the sewer system or treatment facility component from which the discharge occurred such as manhole, lift station, constructed overflow pipe, or crack or other opening in a pipe;
 - e) The estimated date and time when the overflow began and stopped or will be stopped;
 - f) The cause or suspected cause of the overflow including, if appropriate, precipitation, runoff conditions, areas of flooding, soil moisture and other relevant information;
 - g) Steps taken or planned to reduce, eliminate and prevent reoccurrence of the overflow and a schedule of major milestones for those steps;
 - h) A description of the actual or potential for human exposure and contact with the wastewater from the overflow;
 - i) Steps taken or planned to mitigate the impacts of the overflow and a schedule of major milestones for those steps;
 - j) To the extent known at the time of reporting, the number and location of building backups caused by excessive flow or other hydraulic constraints in the sewage collection system that occurred concurrently with the sanitary sewer overflow and that were within the same area of the sewage collection system as the sanitary sewer overflow; and
 - k) The reason the overflow occurred or explanation of other contributing circumstances that resulted in the overflow event. This includes any information available including whether the overflow was unavoidable to prevent loss of life, personal injury, or severe property damage and whether there were feasible alternatives to the overflow.

NOTE: A copy of form 3400-184 for reporting sanitary sewer overflows and sewage treatment facility overflows may be obtained from the department or accessed on the department's web site at <http://dnr.wi.gov/topic/wastewater/SSOreport.html>. As indicated on the form, additional information may be submitted to supplement the information required by the form.

- The permittee shall identify each specific location and each day on which a sanitary sewer overflow or sewage treatment facility overflow occurs as a discrete sanitary sewer overflow or sewage treatment facility overflow occurrence. An occurrence may be more than one day if the circumstances causing the sanitary sewer overflow or sewage treatment facility overflow results in a discharge duration of greater than 24 hours.

If there is a stop and restart of the overflow at the same location within 24 hours and the overflow is caused by the same circumstance, it may be reported as one occurrence. Sanitary sewer overflow occurrences at a specific location that are separated by more than 24 hours shall be reported as separate occurrences; and

- A permittee that is required to submit wastewater discharge monitoring reports under s. NR 205.07 (1) (r), Wis. Adm. Code, shall also report all sanitary sewer overflows and sewage treatment facility overflows on that report.

6.3.1.4 Public Notification

The permittee shall notify the public of any sanitary sewer and sewage treatment facility overflows consistent with its emergency response plan required under the CMOM (Capacity, Management, Operation and Maintenance) section of this permit and s. NR 210.23 (4) (f), Wis. Adm. Code. Such public notification shall occur promptly following any overflow event using the most effective and efficient communications available in the community. At minimum, a daily newspaper of general circulation in the county(s) and municipality whose waters may be affected by the overflow shall be notified by written or electronic communication.

6.3.2 Capacity, Management, Operation and Maintenance (CMOM) Program

- The permittee shall have written documentation of the Capacity, Management, Operation and Maintenance (CMOM) program components in accordance with s. NR 210.23(4), Wis. Adm. Code. Such documentation shall be available for Department review upon request. The Department may request that the permittee provide this documentation or prepare a summary of the permittee's CMOM program at the time of application for reissuance of the WPDES permit.
- The permittee shall implement a CMOM program in accordance with s. NR 210.23, Wis. Adm. Code.
- The permittee shall at least annually conduct a self-audit of activities conducted under the permittee's CMOM program to ensure CMOM components are being implemented as necessary to meet the general standards of s. NR 210.23(3), Wis. Adm. Code.

6.3.3 Sewer Cleaning Debris and Materials

All debris and material removed from cleaning sanitary sewers shall be managed to prevent nuisances, run-off, ground infiltration or prohibited discharges.

- Debris and solid waste shall be dewatered, dried and then disposed of at a licensed solid waste facility.
- Liquid waste from the cleaning and dewatering operations shall be collected and disposed of at a permitted wastewater treatment facility.
- Combination waste including liquid waste along with debris and solid waste may be disposed of at a licensed solid waste facility or wastewater treatment facility willing to accept the waste.

7 Summary of Reports Due

FOR INFORMATIONAL PURPOSES ONLY

Description	Date	Page
Chloride Source Reduction Measures (SRMs) for Groundwater Discharges - Chloride Reduction Plan	January 31, 2027	12
Chloride Source Reduction Measures (SRMs) for Groundwater Discharges - Annual Progress Report	January 31, 2028	12
Chloride Source Reduction Measures (SRMs) for Groundwater Discharges - Second Annual Progress Report	January 31, 2029	12
Chloride Source Reduction Measures (SRMs) for Groundwater Discharges - Third Annual Progress Report	January 31, 2030	12
Chloride Source Reduction Measures (SRMs) for Groundwater Discharges - Fourth Annual Progress Report	January 31, 2031	12
Sludge Management Plan -Sludge Management Plan Submittal	See Permit	12
Land Treatment Management Plan -Land Treatment Management Plan Submittal	October 1, 2027	13
Compliance Maintenance Annual Reports (CMAR)	by June 30, each year	16
Wastewater Discharge Monitoring Report	no later than the date indicated on the form	14

Report forms shall be submitted electronically in accordance with the reporting requirements herein. Any facility plans or plans and specifications for municipal, industrial, industrial pretreatment and non industrial wastewater systems shall be submitted to the Bureau of Water Quality, P.O. Box 7921, Madison, WI 53707-7921. All other submittals required by this permit shall be submitted to: Central Office, 101 S Webster St, P.O. Box 7921, Madison, WI 53707-7921.