



November 03, 2014

THE HONORABLE DAVID AMENT
MAYORS' OFFICE
3805 SOUTH CASPER DRIVE
NEW BERLIN WI 53151-0921

Subject: 2014 Documentation of Reporting Requirements for the City of New Berlin Water Supply Service Area Plan

Dear Mayor Ament:

On February 21st, 2014 the department received the City of New Berlin's Annual Report of Water Use in the Approved Service Area and Return Flow for the City of New Berlin, Wisconsin (Report) for calendar year 2013.

The Water Supply Service Area Plan and Diversion Approval (Approval) issued by the department on May 21, 2009 requires the City of New Berlin (City) to submit annual reporting information to the department by March 1st of the following year. Specifically, section VI of the Approval requires the City to report the following information for the prior year (2013) to the department:

1. The total amount of water purchased from Milwaukee.
2. The amount of water sold to each category and subcategory of customer on a quarterly basis within the approved City limits.
3. The amount of water sold to each category and subcategory of customer on a quarterly basis within the approved diversion area.
4. The amount of water diverted to the approved diversion area on a monthly basis (to be estimated by the City).
5. The amount of water pumped from each municipal well within the City limits on a quarterly basis, noting the basin in which each well is located.
6. Average residential per capita water use.
7. A description of efforts made by the City to improve water conservation and efficiency and minimize infiltration and inflow within the city.
8. Estimates of the total monthly sewerage flow within the City.
9. Estimates of the monthly sewerage return flow within the approved water supply service area and the approved diversion area.

The following paragraphs briefly summarize the department's review.

1. *The total amount of water purchased from Milwaukee.* The total amount of water purchased from the City of Milwaukee in 2013 is reported in Table 1-1 of the Report as 902,230,120 gallons (or 2.472 million gallons per day).
2. *The amount of water sold to each category and subcategory of customer on a quarterly basis within the approved City limits.* This information is presented in the Report Table 2-1.

3. *The amount of water sold to each category and subcategory of customer on a quarterly basis within the approved diversion area.* This information is presented in the Report Table 3-1.
4. *The amount of water diverted to the approved diversion area on a monthly basis (to be estimated by the City).* The City diverted 516,977,866 gallons in 2013, an average of 1.416 million gallons per day. New Berlin is authorized to divert an average of 2.142 million gallons per day. The information is presented in the Report Table 4-1.
5. *The amount of water pumped from each municipal well within the City limits on a quarterly basis, noting the basin in which each well is located.* This reporting element is no longer applicable as all of the City's wells have been taken out of service and abandoned as required by the Approval.
6. *Average residential per capita water use.* The per capita water use calculation is described in Table 6-1 of the Report. The residential per capita water use in the service area is reported as 59.58 gallons per capita per day (gpcd). The City's goal is to have per capita residential water use reduced by at least 10% from the 2007 base year by 2020. Meeting that goal reflects a residential per capita water use of 61 gpcd or less. In 2013, the City met its goal for per capita residential water use.
7. *A description of efforts made by the City to improve water conservation and efficiency and minimize the infiltration and inflow within the City.* Section 7 of the Report details the City's efforts to improve water conservation and efficiency. Efforts to minimize Inflow and Infiltration (I/I) are described in Table 7-1 and in Appendix B. The City spent \$498,456 on reducing I/I in 2013. The Report indicated that the estimated I/I for the sewer system was 3.129 MGD in 2013.
8. *Estimates of the total monthly sewerage flow within the City.* This information is presented in the Report Table 9-1.
9. *Estimates of the monthly sewerage return flow within the approved water supply service area and the approved diversion area.* This information is presented in Table 9-1 of the Report. The average monthly sewerage flow estimate for 2013 is 197,580,000 gallons.

2013 Summary Data		
Type of Water	Average Amount of Water (million gallons per day)	Data Source
Purchased water	2.472	Table 1-1
Sold within city limits	2.352	Table 2-1
Diversion amount	1.416	Table 4-1
Citywide Inflow/Infiltration	3.129	Page 7 of the Report
Diversion area sewerage returned	3.129	Table 9-1
Total sewerage returned	6.586	Table 9-1

In addition to the reporting requirements above, the City has also submitted documentation demonstrating compliance with Tier 3 water conservation as required by section V of the Approval and ch. NR 852, Wis. Adm. Code. The information provided in the Report meets the annual reporting requirements.

The City's 2014 Annual Report is to be submitted to the department by March 1st, 2015.

Please contact Chris Fuchsteiner (christopher.fuchsteiner@wisconsin.gov, (608) 266-9264 with any additional questions regarding reporting.

Sincerely,

A handwritten signature in cursive script that reads "Eric K. Ebersberger".

Eric K Ebersberger
Chief, Water Use Section

- cc. Greg Kessler, Director of Community Development, City of New Berlin (email only)
- Jim Hart, Water Utility Manager, City of New Berlin (email only)
- Sue Hanley, Administrative Supervisor, City of New Berlin (email only)
- Denise Schmidt, Water Conservation Coordinator, PSC (email only)
- Jill Jonas, Bureau Director, Bureau of Drinking Water and Groundwater, DNR (email only)